

## **PERMIT ATTACHMENT L CORRECTIVE ACTION UNITS**

### **Introduction**

There are two (2) Corrective Action Management Units or Areas of Concern (AOCs) at the Rinchem Company, Inc. Container Storage Facility (CSF). These include the Truck Loading Dock, and the Spill Drain and Collection Tank System, both of which are described in the following paragraphs. Figure L-1 (Page 2 of this Attachment) shows the location of the subject Areas of Concern.

### **Truck Loading Dock**

The Truck Loading Dock is located in the southeast area of the CSF. The dock is constructed of concrete with a metal roof. The floor has an epoxy seal and the joints are caulked to prevent ground contamination if a spill should occur. The floor is sloped to the center to contain a spill and there is a concrete secondary containment system around the lower elevation to capture leakage involving a vehicle. There has been no release of hazardous materials or wastes to report.

### **Spill Drain System**

The Spill Drain System manages any spills which may occur in Rooms B and C. The system consists of concrete construction, a cast-iron grate covering, and a six-inch cast-iron pipe that shall carry any spills to the Spill Collection Tank. The Spill Drain Collection Tank System is active and has been in operation since January 1, 1987.

### **Spill Collection Tank**

Any spills that occur in Rooms B & D are drained to the Spill Collection Tank located below the west dock. This dock is located on the west end of room D and is approximately 60 feet long and 30 feet wide. The in-ground tanks are constructed of concrete and consist of a 500 gallon tank located inside of a 3790 gallon vault. A six-inch cast-iron pipe shall carry any spill to the 500 gallon tank. If the spill is greater than 500 gallons it will overflow into the 3790 gallon vault. There has been no chemical cleanup in this area to report since operations began at the CSF.

If a release of hazardous waste or hazardous constituents occurs from the active permitted operational unit areas into the environment, Rinchem shall submit to the New Mexico Environment Department all available information pertaining to the release. Rinchem shall also report any spills or contamination within the drainage areas.