


41-B-856 HEPA Bank and Waste Hoist Tower Differential Pressure




Prior to 2/5/2014 (2/3 @ 0200-0215)

856 Mod	0.47
856 High	0.75
856 HEPA	1.54
856 HEPA	1.45

*** Fire Event Waste Tower dp Details**
 During the Fire Event positive dp was seen on 2/5 and 2/6. Overall the dp was negative for the daily average.
 2/5 Postive dp (Avg) + 0.308 (Duration 13 hrs)
 2/6 Postive dp (AVg) + 0.200 (Duration 14 hrs)

- HEPA
- HEPA
- Hi Particulate
- Mod Filter
- WH Tower

41-B-857 HEPA Bank and Waste Hoist Tower Differential Pressure



Prior to 2/5/2014 (2/3 @ 0200-0215)

857	Mod	0.45
857	High	0.75
857	HEPA	1.52
857	HEPA	1.45

*** Fire Event Waste Tower dp Details**
 During the Fire Event positive dp was seen on 2/5 and 2/6. Overall the dp was negative for the daily average.
 2/5 Positive dp (Avg) + 0.308 (Duration 13 hrs)
 2/6 Positive dp (AVg) + 0.200 (Duration 14 hrs)

- HEPA
- HEPA
- Hi Particulate
- Mod Filter
- WH Tower