

June 29, 2016 Daily Update provided by Fred Whistle, AV Water

1. Boil Water Advisory still in effect
2. Still no water outages. System is functioning. A temporary pump and generator are scheduled to be hooked up late tomorrow to push Farmington water in our upper system. We will continue to pump from the plant and hope to fill all our tanks in a few days. Then we will shut the plant down and see if the temporary pump is sufficient to maintain tank levels.
3. Deficiency Study is about 66% finished. To date we have found 1 valve and three fire hydrants that are deficient. No evidence of any water leaks.
4. City of Farmington inter connect. See below previous emails. The pump station is under construction. Footings are dug and underground piping is being laid . Concrete will be poured Friday and Monday. Building still scheduled for July 5 start. Finish date of pump station remains July 15 or sooner.
5. Temporary pump. See above. Also the City of Farmington will allow us to use a temporary pump without a tank.
6. A site visit was made by Chris Cudia of NMED this morning.
7. Still no evidence of outside water use again hopefully conservation measures are working.
8. Completion date. Still July 15 or sooner

Respectfully,
Fred Whistle