



NEW MEXICO
ENVIRONMENT DEPARTMENT



SUSANA MARTINEZ
Governor
JOHN A. SANCHEZ
Lieutenant Governor

P.O. Box 5469
Santa Fe, NM 87502-5469
Phone (505) 476-8620 Fax (505) 476-8656
www.nmenv.state.nm.us

RYAN FLYNN
Cabinet Secretary
BUTCH TONGATE
Deputy Secretary

CERTIFIED RETURN RECEIPT REQUESTED
7005 1820 0001 5772 3057

March 9, 2015

John Arango
Algodones WUA
PO Box 618
Algodones, NM 87001

**RE: Administrative Compliance Order, No. 2011-CO-017 Algodones WUA, PWS#
NM3535123
Request for Extension**

Mr. Arango:

The New Mexico Environment Department (NMED) Drinking Water Bureau received your request for extension dated March 2, 2015. The NMED has reviewed your request and agrees to modify Paragraphs 19 and 20 of Administrative Compliance Order No. 2011-CO-017. Paragraph 19 shall be modified to read "By September 30, 2016, be in compliance with Section 20.7.10.100 NMAC, incorporating 40 C.F.R. § 141.62(b)(16), and provide drinking water with concentrations of Arsenic below 0.010 mg/L". Paragraph 20 shall be modified to read "By September 30, 2017, be in compliance with Section 20.7.10.100 NMAC, incorporating 40 C.F.R. § 141.23(i)(1) and have a RAA for Arsenic below the MCL of 0.010 mg/L".

If you have any questions or need assistance, please contact Maria J. Medina, Enforcement Coordinator, at 505-476-8629 or via email at maria.medina@state.nm.us.

Sincerely,

Trais Kliphuis
Division Director
Water Protection Division

cc. Glenn Deguzman, Compliance Officer
Jenna Manheimer, Region 6, EPA (Electronic)
P:\-ENFORCEMENT\Individual PWS Enforcement Info
Central File

CERTIFICATE OF SERVICE

I hereby certify that a copy of the foregoing letter was sent via certified return receipt requested on the following party of record on 3/10, 2015.

John Arango
Algodones WUA
PO Box 618
Algodones, NM 87001



Maria J. Medina