



NEW MEXICO
ENVIRONMENT DEPARTMENT



SUSANA MARTINEZ
Governor
JOHN A. SANCHEZ
Lieutenant Governor

P.O. Box 5469
Santa Fe, NM 87502-5469
Phone (505) 476-8620 Fax (505) 476-8656
www.env.nm.gov

RYAN FLYNN
Cabinet Secretary
BUTCH TONGATE
Deputy Secretary

CERTIFIED RETURN RECEIPT REQUESTED
7005 1820 0001 5772 3330

July 17, 2015

Mindy Cahill
Cimarron Water System
PO Box 654
Cimarron, NM 87714

RE: Settlement Agreement and Stipulated Final Order, No. 2012-ACO-006 Cimarron Water System, PWS# NM3526204 Request for Extension

Ms. Cahill:

The New Mexico Environment Department (NMED) Drinking Water Bureau received your request for extension letter dated June 3, 2015. The NMED has reviewed your request and agrees to modify Paragraph 10 of Settlement Agreement and Stipulated Final Order No. 2012-ACO-006. Paragraph 10 shall be modified to read "By July 12, 2016, Respondent shall comply with Section 20.7.10.100 NMAC, incorporating 40 C.F.R. § 141.135(b)(2) TOC percent removal requirements calculated according to Section 20.7.10.100 NMAC, incorporating 40 C.F.R. § 141.135(c)(1)(v), and provide drinking water with TOC removal ratios greater than 1.00, or install an alternative surface water treatment technology which does not require monitoring of TOC removal."

If you have any questions or need assistance, please contact Maria J. Medina, Enforcement Coordinator, at 505-476-8629 or via at email at maria.medina@state.nm.us.

Sincerely,

Trais Kliphuis
Division Director
Water Protection Division

cc. Jan Dyc, Compliance Officer (Electronic)
Jenna Manheimer, Region 6, EPA (Electronic)
P:\~ENFORCEMENT\Individual PWS Enforcement Info
Central File

CERTIFICATE OF SERVICE

I hereby certify that a copy of the foregoing letter was sent via certified return receipt requested on the following party of record on 7/17, 2015.

Mindy Cahill
Cimarron Water System
PO Box 654
Cimarron, NM 87714



Maria J. Medina