



NEW MEXICO
ENVIRONMENT DEPARTMENT



SUSANA MARTINEZ
Governor
JOHN A. SANCHEZ
Lieutenant Governor

P.O. Box 5469
Santa Fe, NM 87502-5469
Phone (505) 476-8620 Fax (505) 476-8656
www.nmenv.state.nm.us

RYAN FLYNN
Cabinet Secretary
BUTCH TONGATE
Deputy Secretary

CERTIFIED RETURN RECEIPT REQUESTED
7005 1820 0001 5772 3309

June 19, 2015

Adam Trubow
Juniper Hills Mobile Home Park
1115 Central Ave NE
Albuquerque, NM 87102

RE: Administrative Compliance Order, No. 2011-CO-026 Juniper Hills Mobile Home Park, PWS# NM3571026 Request for Extension

Mr. Trubow:

The New Mexico Environment Department (NMED) Drinking Water Bureau received your request for extension letter dated June 9, 2015. The NMED has reviewed your request and agrees to modify Paragraphs 21 and 22 of Administrative Compliance Order No. 2011-CO-026. Paragraph 21 shall be modified to read "By December 31, 2016, be in compliance with Section 20.7.10.100 NMAC, incorporating 40 C.F.R. § 141.62(b)(16), and provide water with concentrations of Arsenic below 0.010 mg/L." Paragraph 22 shall be modified to read "By December 31, 2017, be in compliance with Section 20.7.10.100 NMAC, incorporating 40 C.F.R. § 141.23(i)(1) and have a RAA for Arsenic below the MCL of 0.010 mg/L."

If you have any questions or need assistance, please contact Maria J. Medina, Enforcement Coordinator, at 505-476-8629 or via at email at maria.medina@state.nm.us.

Sincerely,

Trais Kliphuis
Division Director
Water Protection Division

cc. Jeff Pompeo, Compliance Officer
Jenna Manheimer, Region 6, EPA (Electronic)
P:\-ENFORCEMENT\Individual PWS Enforcement Info
Central File

CERTIFICATE OF SERVICE

I hereby certify that a copy of the foregoing letter was sent via certified return receipt requested on the following party of record on 6/19, 2015.

Adam Trubow
Juniper Hills Mobile Home Park
1115 Central Ave NE
Albuquerque, NM 87102



Maria J. Medina