



NEW MEXICO
ENVIRONMENT DEPARTMENT



SUSANA MARTINEZ
Governor
JOHN A. SANCHEZ
Lieutenant Governor

P.O. Box 5469
Santa Fe, NM 87502-5469
Phone (505) 476-8620 Fax (505) 476-8656
www.nmenv.state.nm.us

RYAN FLYNN
Cabinet Secretary
BUTCH TONGATE
Deputy Secretary

CERTIFIED RETURN RECEIPT REQUESTED
7005 1820 0001 5772 3040

March 9, 2015

Mike E. Vigil
Miami Water Users Association
P.O. Box 295
Springer, NM 87747

**RE: Administrative Compliance Order, NO. 2009-CO-007 Miami Water Users Association, PWS# NM3526504
Request for Extension**

Mr. Vigil:

The New Mexico Environment Department (NMED) Drinking Water Bureau received your request for extension letter dated February 24, 2015. The NMED has reviewed your request and agrees to modify Paragraph 9 of Administrative Compliance Order NO. 2009-CO-007. Paragraph 9 shall be modified to read "No later than December 31, 2015, have a RAA for TTHM below 0.080 mg/L and be in compliance with Section 20.7.10.100 NMAC, incorporating 40 C.F.R. § 141.64(b), MCL for disinfection byproducts, TTHM."

If you have any questions or need assistance, please contact Maria J. Medina, Enforcement Coordinator, at 505-476-8629 or via email at maria.medina@state.nm.us.

Sincerely,

Trais Kliphuis
Division Director
Water Protection Division

cc. Jan Dye, Compliance Officer
Jenna Manheimer, Region 6, EPA (Electronic)
P:\-ENFORCEMENT\Individual PWS Enforcement Info
Central File

CERTIFICATE OF SERVICE

I hereby certify that a copy of the foregoing letter was sent via certified return receipt requested on the following party of record on 3/10, 2015.

Mike E. Vigil
Miami Water Users Association
P.O. Box 295
Springer, NM 87747



Maria J. Medina