

**New Mexico Public Water Systems Responding to Current Lead and/or Copper Action Level Exceedances - Updated 11/02/2016**

Public Water System Number	System Name	System Type	Population Served	Contaminant Exceeding Action Level	90th Percentile Level (mg/L)*	Action Level (mg/L)	Date of Exceedance	Does Post-Exceedance Monitoring Show Analytical Results to be Below Action Levels?	Current Status	System currently in compliance with LCR monitoring requirements?
NM3503926	Agua Fria Water Association	C	650	Lead	0.019	0.015	August 2014	Yes August 2015 April 2016	Active Scheduled to conduct lead/copper monitoring in July to December 2016	Yes
NM3535123	Algodones WUA	C	675	Lead	0.018	0.015	August 2014	Yes August to September 2015	Active Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	No System did not monitor for lead and copper January to June 2016
NM3530414	Alto Mountain Village	C	172	Copper	1.6	1.3	August 2015	Yes February 2016	Active Scheduled to conduct lead/copper monitoring in July to December 2016	Yes
NM3501029	Arroyos del Norte Elementary School	NTNC	350	Lead	0.016	0.015	September 2012	Yes April 2016 September 2016	Resolved System to monitor lead/copper every 3 years Next samples due June to September 2019	Yes
NM3500321	Barranco MDWCA	C	51	Lead	0.02	0.015	September 2015	Yes May 2016	Active Scheduled to conduct lead/copper monitoring in July to December 2016	Yes
NM3500101	Bearcat Homeowners Association	C	60	Lead	0.028	0.015	August 2015	No	Active Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	No System did not monitor for lead and copper January to June 2016
NM3510333	Bluewater Acres WUA	C	371	Lead	0.018	0.015	September 2011	Yes September 2014 June 2016 September 2016	Resolved System to monitor lead/copper every 3 years Next samples due June to September 2019	Yes
NM3510026	Canoncito at Apache Canyon	C	250	Lead	0.114	0.015	August 2014	Yes September 2015 May 2016	Resolved System to monitor annually Next lead/copper samples due June to September 2017	Yes

NM3593121	Chimayo Elementary School	NTNC	250	Lead	0.16	0.015	September 2013	Yes September 2014 September 2015 May 2016	Active Scheduled to conduct lead/copper monitoring in July to December 2016	Yes
NM3566026	Chupadero MDWCA	C	160	Copper	2.0	1.3	June 2015	Yes December 2015 June 2016	Resolved System to monitor annually Next lead/copper samples due June to September 2017	Yes
NM3513519	Cloudcroft Water System	C	1475	Lead	0.016	0.015	June 2011	Yes July 2011 July 2014 June 2016	Active Scheduled to conduct lead/copper monitoring in July to December 2016	Yes
NM3574429	Cuchilla del Llano MDWCA	C	400	Lead	0.019	0.015	August 2011	Yes September 2012 September 2013	Active Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	No System did not conduct monitoring for lead and copper in 2014, 2015 or January to June 2016
NM3500302	Datil Elementary Schools	NTNC	30	Lead	0.28	0.015	June 2014	Yes September 2015 June 2016	Resolved System to monitor annually Next lead/copper samples due June to September 2017	Yes
NM3556913	DCP Midstream Eunice Plant	NTNC	100	Lead	0.016	0.015	September 2008	Yes September 2014 August 2016	Active Completed lead and copper monitoring in July to December 2016. Scheduled to conduct lead/copper monitoring in January to June 2017.	No System monitored for lead and copper January to June 2016 (results below action levels), but did not properly submit results to NM Drinking Water Bureau
				Copper	1.6	1.3	September 2011			
NM3511021	Delancey Street Foundation	C	80	Copper	1.5	1.3	May 2011	Yes June 2012 May 2016	Active Scheduled to conduct lead/copper monitoring in January to June 2017 and July to December 2017	Yes
					2.3	1.3	August 2016	No		
NM3504021	El Rito Regional W&WWA	C	1200	Copper	1.8	1.3	May 2012	Yes October 2012 June 2016	Active Completed lead and copper monitoring in January to June 2016. Scheduled to conduct lead/copper monitoring in July to December 2016	No System has not monitored for lead and copper during two consecutive 6 month monitoring periods from January 2013 till present
					1.8	1.3	June 2011	Yes December 2012	Active Completed lead and copper	No System has not monitored for lead and

NM3591021	Escalante High School	NTNC	275	Copper	1.5	1.3	June 2012	December 2013 June 2015 May 2016	monitoring in January to June 2016. Scheduled to conduct lead/copper monitoring in July to December 2016	copper during two consecutive 6 month monitoring periods from July 2011 till present
NM3502426	Greater Chimayo MDWCA	C	474	Copper	1.4	1.3	September 2015	Yes June 2016	Active Scheduled to conduct lead/copper monitoring in July to December 2016	Yes
NM3514127	Hillsboro MDWCA	C	167	Lead	0.026	0.015	August 2015	Yes June 2016	Active Scheduled to conduct lead/copper monitoring in July to December 2016	Yes
NM3566221	La Association de Agua de los Brazos	C	32	Copper	1.4	1.3	June 2013	No	Active Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	Yes
				Copper	7.2	1.3	July 2016			
				Lead	0.064	0.015	July 2016	No		
NM3501129	La Lama MDWCA	C	45	Lead	0.02	0.015	July 2015	Yes May 2016	Active Scheduled to conduct lead/copper monitoring in July to December 2016	Yes
NM3502121	La Madera MDWCA	C	150	Copper	1.5	1.3	August 2015	Yes July 2016	Active Scheduled to conduct lead/copper monitoring in January to June 2017	Yes
				Copper	1.5	2.4	June 2016			
NM3500224	La Vida Mission CWS	C	42	Copper	1.8	1.3	September 2013	Yes June 2016	Active Scheduled to conduct lead/copper monitoring in July to December 2016	Yes
NM3511101	Lost Horizon Co-op Association	C	80	Lead	0.032	0.015	June 2011	Yes August 2015 June 2016	Resolved System to monitor annually Next lead/copper samples due June to September 2017	Yes
NM3560617	Manuelito Navajo Childrens Home	C	65	Lead	0.0165	0.015	July 2016	No	Active Scheduled to conduct lead/copper monitoring in January to June 2017 and July to December 2017	Yes
NM3590621	Mesa Vista High School	NTNC	400	Copper	2.6	1.3	June 2016	No	Active Completed lead and copper monitoring in January to June 2016. Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	No System has not monitored for lead and copper during two consecutive 6 month monitoring periods from July 2009 till present

NM3506621	Ojo Caliente MDWCA	C	415	Copper	1.8	1.3	June to September 2011	No	Active Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	Yes
NM3547125	Pendaries MDWCA	C	500	Lead	0.019	0.015	June 2015	Yes June 2016	Active Scheduled to conduct lead/copper monitoring in July to December 2016	Yes
NM3510607	Picacho Hills Utility Company	C	2183	Lead	0.032	0.015	August 2015	No	Active Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	Yes
NM3596029	Rio Valley Enterprises	NTNC	65	Lead	0.016	0.015	September 2012	No	Active Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	No System did not conduct monitoring for lead and copper in 2015
NM3507329	Rodarte MDWCA	C	75	Copper	2.7	1.3	July 2016	No	Active Completed lead and copper monitoring in July to December 2016. Scheduled to conduct lead/copper monitoring in January to June 2017 and July to December 2017	No System has not monitored for lead and copper during two consecutive 6 month monitoring periods from January 2010 till present
NM3552803	Roswell Correction Center	C	340	Lead	0.068	0.015	August 2014	Yes April 2015 March 2016 August 2016	Resolved System to monitor lead/copper every 3 years Next samples due June to September 2019	Yes
NM3502221	Rutheron Mutual WA	C	90	Copper	2.8	1.3	September 2015	No	Active Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	Yes
NM3590109	San Lorenzo Elementary School	NTNC	77	Lead	0.021	0.015	June 2016	No	Active Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	Yes

NM3509723	San Ysidro Water Supply System	C	198	Copper	2.1	1.3	September 2013	Yes September 2014 September 2015	Active Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	Yes
NM3501826	Southwestern College	NTNC	117	Lead	0.021	0.015	June 2008	Yes September 2008 September 2009	Active Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	No System has not monitored for lead and copper during two consecutive 6 month monitoring periods from January 2010 till present
NM3596033	St. Josephs School	NTNC	100	Lead	0.04	0.015	June 2015	Yes August 2016	Active Completed lead and copper monitoring in July to December 2016. Scheduled to conduct lead/copper monitoring in January to June 2017	No System monitored for lead and copper January to June 2016 (results below action levels), but did not collect correct number of samples from valid locations
NM3580026	St. Vincent Regional Medical Center	NTNC	1200	Lead	0.016 to 0.59	0.015	2011 to 2015	Yes April to May 2016 September 2016	Resolved System to monitor lead/copper every 3 years Next samples due June to September 2019	Yes
NM3590628	Stallion Range Center	NTNC	50	Lead	0.054	0.015	July 2016	No	Active Scheduled to conduct lead/copper monitoring in January to June 2017 and July to December 2017	Yes
NM3501204	UU Bar	NTNC	50	Copper	1.85	1.3	September 2015	Yes April 2016 July 2016	Resolved System to monitor lead/copper every 3 years Next samples due June to September 2019	Yes
NM3550504	Vermejo Park - Headquarters	C	140	Copper	1.4	1.3	June 2010	Yes November 2010 August 2012	Active Scheduled to conduct lead/copper monitoring in July to December 2016 and January to June 2017	No System did not monitor for lead and copper in 2015
NM3501529	West Rim MDWUA	C	113	Lead	0.28	0.015	September 2012	Yes May/June 2016	Active Scheduled to conduct lead/copper monitoring in July to December 2016	Yes

\* mg/L = milligrams per liter