GROUND WATER DISCHARGE PERMIT
Broken Arrow Bible Ranch, DP-1693

I. INTRODUCTION

The New Mexico Environment Department (NMED) issues this Discharge Permit (Discharge Permit), DP-1693, to United Indian Mission International (permittee) pursuant to the New Mexico Water Quality Act (WQA), NMSA 1978 §§74-6-1 through 74-6-17, and the New Mexico Water Quality Control Commission (WQCC) Regulations, 20.6.2 NMAC.

NMED's purpose in issuing this Discharge Permit, and in imposing the requirements and conditions specified herein, is to control the discharge of water contaminants from the Broken Arrow Bible Ranch (facility) into ground and surface water, so as to protect ground and surface water for present and potential future use as domestic and agricultural water supply and other uses and protect public health. In issuing this Discharge Permit, NMED has determined that the requirements of Subsection C of 20.6.2.3109 NMAC have been met.

The activities which produce the discharge, the location of the discharge, and the quantity, quality and flow characteristics of the discharge are briefly described as follows:

Up to 7,000 gallons per day of domestic wastewater is treated by an Orenco Systems, Inc. fixed media, attached growth wastewater treatment system and by existing septic tank/leachfield systems. Treated wastewater is then discharged to a 20,000 square foot field via a subsurface low pressure dose irrigation system. Recreational Vehicle waste is disposed to a holding tank until pumped and hauled off-site by a licensed hauler for disposal. The discharge contains water contaminants or toxic pollutants which may be elevated above the standards of Section 20.6.2.3103 NMAC. The facility is located at Vanderwagen, in Section 17, T12N, R18W, McKinley County. Ground water most likely to be affected is at a depth of approximately 44 feet and has a total dissolved solids concentration of approximately 320 milligrams per liter.

The permittee's application consists of the materials submitted by Cripin Kinney, P.E, on behalf of the permittee dated July 3, 2008. The discharge shall be managed in accordance with all conditions and requirements of this Discharge Permit.

Pursuant to Section 20.6.2.3109 NMAC, NMED reserves the right to require a Discharge Permit Modification in the event NMED determines that the requirements of 20.6.2 NMAC are being or may be violated or the standards of Section 20.6.2.3103 NMAC are being or may be violated. This may include a determination that structural controls and/or management practices approved under this Discharge Permit are not protective of ground water quality, and that more stringent requirements to protect and/or remediate ground water quality may be required by NMED. These requirements may include: expanding the land application area; changing waste management practices; expanding monitoring requirements; and/or implementing abatement of water pollution.

Issuance of this Discharge Permit does not relieve the permittee of the responsibility to comply with the WQA, WQCC Regulations, and any other applicable federal, state and/or local laws and

draft

regulations, such as zoning requirements and nuisance ordinances. The following abbreviations may be used in this Discharge Permit:

Abbreviation	Explanation		Abbreviation	Explanation
BOD_5	biochemical oxygen demand (5-day)		NTU	nephelometric turbidity units
CFR	Code of Federal Regulations		Org	organisms
Cl	chloride		TDS	total dissolved solids
LADS	land application data sheet(s)		TKN	total Kjeldahl nitrogen
mg/L	milligrams per liter		total nitrogen	$TKN+NO_3$-N
mL	milliliters		TRC	Total Residual Chlorine
NMAC	New Mexico Administrative Code		TSS	total suspended solids
NMED	New Mexico Environment Department		WQA	New Mexico Water Quality Act
NMSA	New Mexico Statutes Annotated		WQCC	Water Quality Control Commission
NO_3-N	nitrate-nitrogen			

II. FINDINGS

In issuing this Discharge Permit, NMED finds:

1. The permittee is discharging effluent or leachate from the facility so that such effluent or leachate may move directly or indirectly into ground water within the meaning of Section 20.6.2.3104 NMAC.

2. The permittee is discharging effluent or leachate from the facility so that such effluent or leachate may move into ground water of the State of New Mexico which has an existing concentration of 10,000 milligrams per liter or less of total dissolved solids within the meaning of Subsection A of 20.6.2.3101 NMAC.

3. The discharge from the facility is not subject to any of the exemptions of Section 20.6.2.3105 NMAC.

III. CONDITIONS

The following conditions shall be complied with by the permittee and are enforceable by NMED. The permittee is authorized to discharge water contaminants subject to the following conditions:

OPERATIONAL PLAN

#	Terms and Conditions
1.	The permittee shall implement the following operational plan to ensure compliance with Title 20, Chapter 6, Parts 1 and 2 NMAC. [20.6.2.3106.C NMAC, 20.6.2.3107 NMAC]

draft

2.	The permittee shall operate in a manner such that standards and requirements of Sections 20.6.2.3101 and 20.6.2.3103 NMAC are not violated. [20.6.2.3101 NMAC, 20.6.2.3103 NMAC]
3.	Prior to discharging to the facility, the permittee shall give written notification to NMED stating the date discharge is to commence. [20.6.2.3109.H NMAC]
4.	The permittee is authorized to discharge up to 7,000 gallons per day of domestic wastewater to an Orenco Systems, Inc. fixed media, attached growth wastewater treatment system. Treated wastewater is then discharged to a 20,000 square foot field via a subsurface low pressure dose irrigation system. Existing septic tank/leachfield systems are used to dispose of small quantities of domestic wastewater from assorted buildings at the facility. Recreational Vehicle waste is stored in a holding tank until pumped and hauled off-site by a licensed hauler for disposal. [20.6.2.3104 NMAC, 20.6.2.3106 NMAC]
5.	Within 180 days of the effective date of this Discharge Permit (**by Date**), the permittee shall construct the proposed wastewater treatment system according to the final construction plans and specifications submitted to NMED on July 3, 2008. The permittee shall notify NMED at the commencement of construction to allow NMED personnel to be onsite for inspection during the construction phase. Record drawings of the finished wastewater treatment facility shall be submitted to NMED within 30 days of completion. A licensed New Mexico professional engineer shall certify all construction plans and specifications, supporting design calculations, and record drawings of the wastewater treatment system. [20.6.2.3109 NMAC]
6.	Treated wastewater discharged from the irrigation dosing tank to the 20,000 square foot low pressure dose disposal field shall not exceed the following limitation: **Total Nitrogen: 20 mg/L**. [20.6.2.3109 NMAC]
7.	Within 180 days of the effective date of this Discharge Permit (**by date**), the permittee shall submit to NMED written verification and photographic documentation that the existing septic tank/leachfield system servicing the dining hall has been properly closed out, as follows: a) Remove or plug all lines conveying wastewater to the septic tank/leachfield system so that a discharge can no longer occur. b) Pump the grease interceptor and septic tank by a licensed hauler and dispose of pumpings in accordance with all local, state, and federal regulations. c) Backfill the tank with clean fill or sand or remove it from the site. [20.7.3.307 NMAC]
8.	Prior to discharging from the facility, the permittee shall install mechanisms at the wastewater treatment facility to control public access. The mechanisms shall be constructed in a manner which prevents access by the general public and animals such as dogs (e.g., chain link, field fencing or locking lids) and shall be maintained throughout the term of this Discharge Permit. [20.6.2.3109 NMAC]
9.	Prior to discharging from the facility, the permittee shall post signs at the facility entrance and other areas where public contact is possible indicating that the water distributed to the

draft

	subsurface low pressure dose irrigation system is not potable. All signs shall remain visible and legible for the term of this Discharge Permit. [20.6.2.3109 NMAC]
10.	Within 30 days of completion, the permittee shall submit updated record drawings of the wastewater collection system to NMED as residences, offices or new ranch dwellings that contribute wastewater to the wastewater treatment system are added. A licensed New Mexico professional engineer shall certify all supporting design calculations and record drawings of the wastewater treatment and collection systems. [20.6.2.3109 NMAC]
11.	The permittee shall remove solids from the treatment system when they exceed ¼ of the liquid depth of either the septic tank or dosing tank, based upon quarterly sludge blanket depth determinations. The solids shall be contained, transported, and disposed of in accordance with all local, state, and federal (40 CFR Part 503) regulations. Records of solids disposal shall be submitted to NMED in the quarterly monitoring reports. [20.6.2.3109 NMAC]
12.	The permittee shall utilize operators, certified by the State of New Mexico at the appropriate level, to operate the wastewater treatment and disposal systems. All operations and maintenance of all or any part of the wastewater system shall be performed by, or under the direct supervision of, a certified operator. [20.7.4 NMAC]

MONITORING, REPORTING, AND OTHER REQUIREMENTS

#	**Terms and Conditions**
13.	The permittee shall conduct the following monitoring, reporting, and other requirements listed below. [20.6.2.3107 NMAC]
14.	METHODOLOGY - Unless otherwise approved in writing by NMED, the permittee shall conduct sampling and analysis in accordance with the most recent edition of the following documents: a) American Public Health Association, Standard Methods for the Examination of Water and Wastewater (18th, 19th or current); b) U.S. Environmental Protection Agency, Methods for Chemical Analysis of Water and Waste; c) U.S. Geological Survey, Techniques for Water Resources Investigations of the U.S. Geological Survey; d) American Society for Testing and Materials, Annual Book of ASTM Standards, Part 31.Water; e) U.S. Geological Survey, et al., National Handbook of Recommended Methods for Water Data Acquisition; or f) Methods of Soil Analysis: Part 1. Physical and Mineralogical Methods and Part 2. Chemical and Microbiological Properties, American Society of Agronomy. [20.6.2.3107.B NMAC]
15.	The permittee shall submit quarterly monitoring reports to NMED by the 1st of February, May, August and November each year.

draft

	Quarterly monitoring shall be performed during the following periods: • January 1st through March 31st (first quarter) – **due by May 1st**; • April 1st through June 30th (second quarter) – **due by August 1st**; • July 1st through September 30th (third quarter) – **due by November 1st**; and • October 1st through December 31st (fourth quarter) – **due by February 1st**. Monitoring requirements detailed in this Discharge Permit are summarized on the sheet titled *Summary of Required Actions, Monitoring and Reporting*. [20.6.2.3107 NMAC]
16.	Prior to discharging from the facility, the permittee shall install a totalizing flow meter on the discharge line between the wastewater treatment system's irrigation dosing tank and the subsurface disposal field to measure the volume of treated wastewater discharged. Confirmation of meter installation, type, calibration and locations shall be submitted to NMED prior to discharging from the facility. [20.6.2.3109 NMAC]
17.	The permittee shall estimate the volume of wastewater discharged monthly to the wastewater treatment system by recording the monthly meter readings for the facility's water supply and calculating the monthly water usage. The permittee shall make note of any significant uses of the water during each month, such as irrigation or evaporative cooling, that do not contribute to the wastewater treatment system. The monthly meter readings, calculated water usage, notes and estimated volume of wastewater discharged shall be submitted to NMED in the quarterly reports. The water supply meter shall be kept operational at all times. [20.6.2.3107.A(1) NMAC, 20.6.2.3109.H(1) NMAC]
18.	The permittee shall measure the monthly volume of treated wastewater discharged from the treatment system to the disposal field using a totalizing flow meter. The monthly meter readings and monthly discharge volumes shall be submitted to NMED in the quarterly monitoring reports. The flow meter shall be calibrated to within +/- 10% of actual flow and kept operational at all times. [20.6.2.3107 NMAC, 20.6.2.3109 NMAC]
19.	Within 90 days of the effective date of this Discharge Permit (**by date**), the permittee shall install three new monitoring wells. The permittee shall install: • One monitoring well (MW-1) hydrologically upgradient of the facility, • One monitoring well (MW-2) located 20 to 50 feet hydrologically downgradient of the subsurface irrigated disposal field, and • One monitoring well (MW-3) located at an alternate location from MW-2 and 20 to 50 feet hydrologically downgradient of the subsurface irrigated disposal field. All monitoring well locations shall be approved by NMED prior to installation. The wells shall be completed in accordance with the attachment titled *Ground Water Discharge Permit Monitoring Well Construction and Abandonment Conditions*, Revision 1.0, July 2008. Construction and lithologic logs shall be submitted to NMED within 30 days of well completion. [20.6.2.3107 NMAC]

draft

20.	Following well development and no more than five days after installation of the new monitoring wells required by this Discharge Permit, the permittee shall sample ground water in the new wells and analyze the samples for NO_3-N, TKN, Cl, and TDS. The permittee shall sample: • MW-1, intended to be located hydrologically upgradient of the facility; • MW-2, intended to be located hydrologically downgradient of the subsurface irrigated disposal field; and • MW-3, intended to be located at an alternate location from MW-2 and hydrologically downgradient of the subsurface irrigated disposal field. Ground water sample collection, preservation, transport and analysis shall be performed according to the following procedure: a) measure the depth-to-ground water from the top of well casing to the nearest hundredth of a foot; b) purge three well volumes of water from the well prior to sample collection; c) obtain samples from the well for analysis; d) properly prepare, preserve and transport samples; and e) analyze samples in accordance with the methods authorized in this Discharge Permit. Depth-to-water measurements, analytical results, including the laboratory QA/QC summary report, and a facility layout map showing the location and number of each well shall be submitted to NMED within 45 days of the installation of the monitoring wells. [20.6.2.3107 NMAC]
21.	Within 120 days of the effective date of this Discharge Permit (**by date**), the permittee shall survey all wells approved by NMED for Discharge Permit monitoring purposes to a U.S. Geological Survey (USGS) or other permanent benchmark. Survey data shall include northing, easting and elevation to the nearest hundredth of a foot or in accordance with the "Minimum Standards for Surveying in New Mexico" (12.8.2 NMAC). A survey elevation shall be established at the top-of-casing, with a permanent marking indicating the point of survey. The survey shall be completed and certified by a licensed New Mexico professional surveyor. Depth-to-water shall be measured to the nearest hundredth of a foot in all surveyed wells, and the data shall be used to develop a map showing the location of all monitoring wells and the direction and gradient of ground water flow at the facility. The data and map of ground water flow direction at the facility shall be submitted to NMED within 30 days of survey completion. [20.6.2.3107 NMAC]
22.	The permittee shall perform quarterly ground water sampling in three monitoring wells and analyze the samples for NO_3-N, TKN, Cl, and TDS. The permittee shall sample: • MW-1, intended to be located hydrologically upgradient of the facility; • MW-2, intended to be located hydrologically downgradient and within 20-50 feet of the subsurface irrigated disposal field; and • MW-3, intended to be located at an alternate location from MW-2 and hydrologically downgradient and within 20-50 feet of the subsurface irrigated disposal field. Ground water sample collection, preservation, transport and analysis shall be performed

draft

	according to the following procedure: a) measure the depth-to-ground water from the top of well casing to the nearest hundredth of a foot; b) purge three well volumes of water from the well prior to sample collection; c) obtain samples from the well for analysis; d) properly prepare, preserve and transport samples; and e) analyze samples in accordance with the methods authorized in this Discharge Permit. Depth-to-water measurements, analytical results, including the laboratory QA/QC summary report, and a facility layout map showing the location and number of each well shall be submitted to NMED in the quarterly monitoring reports. [20.6.2.3107 NMAC]
23.	The permittee shall sample treated wastewater from the irrigation dosing tank on a quarterly basis and analyze the samples for TKN, NO_3-N, TDS and Cl. Analytical results shall be submitted to NMED in the quarterly monitoring reports. [20.6.2.3107 NMAC]
24.	Until all septic tanks are hooked up to the wastewater treatment facility, the permittee shall sample wastewater on an annual basis from the septic tanks and analyze the samples for TKN, TDS and Cl. Wastewater samples shall be collected from three septic tanks each year, rotating among all the residential, office, and ranch dwelling tanks. Analytical results shall be submitted to NMED in the quarterly monitoring report due by August 1st each year. [20.6.2.3107 NMAC]
25.	The permittee shall inspect the grease interceptor on a quarterly basis and pump it as needed. Inspection records shall be kept on-site. Pumping invoices shall be submitted to NMED in the quarterly monitoring reports. [20.6.2.3109 NMAC]
26.	The permittee shall visually inspect the area above the low pressure dose irrigated disposal field and leachfields semi-annually to ensure proper maintenance. Any conditions that indicate damage to the low pressure dose disposal field or leachfields shall be corrected. Such conditions include, but are not limited to erosion damage, animal activity/damage, or evidence of seepage. The permittee shall keep a log of the inspection findings and repairs made. [20.6.2.3107 NMAC]
27.	The permittee shall inspect all septic tanks semi-annually for the accumulation of scum and solids. In the event that the scum layer exceeds three inches or the settled solids exceed 50% of the depth of the liquid in the tank, the contents of the tanks shall be pumped by a licensed hauler. The inspection and pumping records shall be submitted to NMED in the quarterly monitoring reports. [20.6.2.3107 NMAC]
28.	The permittee shall inspect the RV waste holding tank on a regular basis during periods of frequent usage to ensure that the tank does not overflow. The contents of the tank shall be pumped as needed by a licensed hauler. The inspection and pumping records shall be submitted to NMED in the quarterly monitoring reports. [20.6.2.3107 NMAC]

draft

CONTINGENCY PLAN

#	Terms and Conditions
29.	In the event that monitoring indicates ground water standards are violated during the term of this Discharge Permit, upon closure of the facility or during post-closure monitoring, the permittee shall collect a confirmatory sample from the monitoring well within 15 days to confirm the initial sampling results. Within 15 days of confirmation of ground water contamination, the permittee shall submit to NMED a corrective action plan that proposes measures to mitigate damage from the discharge including, at a minimum, source control measures and an implementation schedule. The permittee may be required to abate water pollution pursuant to Sections 20.6.2.4000 though 20.6.2.4115 NMAC, if the corrective action plan will not result in compliance with the standards and requirements set forth in Section 20.6.2.4103 NMAC within 180 days of confirmation of ground water contamination. [20.6.2.1203 NMAC, 20.6.2.4105.A(8) NMAC]
30.	In the event of a spill or release that is not authorized under this Discharge Permit, the permittee shall initiate the notifications and corrective actions as required in Section 20.6.2.1203 NMAC. The permittee shall take immediate corrective action to contain and remove or mitigate the damage caused by the discharge. Within 24 hours after discovery of the discharge, the permittee shall verbally notify NMED and provide the information required by Paragraph (1) of Subsection A of 20.6.2.1203 NMAC. Within 7 days of discovering the discharge, the permittee shall submit a written report to NMED verifying the oral notification and providing any additional information or changes. The permittee shall submit a corrective action report within 15 days after discovery of the discharge. [20.6.2.1203 NMAC]
31.	In the event NMED or the permittee identifies any other failures of the Discharge Permit or system not specifically noted herein, NMED may require the permittee to develop for NMED approval contingency plans and schedules to cope with the failures. [20.6.2.3107.A(10) NMAC]
32.	In the event that analytical results of a quarterly treated wastewater sample exceed the total nitrogen limitation set by Condition 6 of this Discharge Permit, the permittee shall analyze another sample within 15 days to confirm the initial results. Upon confirmation that the limitation is being exceeded, the permittee shall enact the following contingency plan: a) NMED shall be notified immediately that the contingency plan is being enacted. b) Wastewater sampling and analysis shall be done on a monthly basis. c) The permittee shall examine the operation and maintenance log, required under the Record Keeping section of this permit, for improper operational procedures. The permittee shall also conduct a physical inspection of the treatment system to detect abnormalities. Any abnormalities discovered shall be corrected. d) If analytical results from wastewater sampling continue to exceed the limitation, the permittee shall submit a corrective action plan for NMED approval to modify operational procedures and/or upgrade the treatment process to achieve the effluent limit. The plan shall be submitted within 90 days of the original confirmation of exceedance of the effluent limitation. The corrective action plan shall be implemented immediately upon NMED approval.

draft

	When analytical results from three consecutive months of wastewater sampling do not exceed the limitation, the permittee shall return to quarterly monitoring. [20.6.2.3107.A(10) NMAC]
33.	In the event that an inspection of the low pressure dose disposal field or leachfields reveals failure, the permittee shall enact the following contingency plan: a) Within 24 hours of the discovered failure, the permittee shall notify NMED of the failure and public access to the area shall be restricted. b) The permittee shall conduct a physical inspection of the treatment and disposal system to identify additional failures. c) The permittee shall submit a corrective action plan for NMED approval to address the failure and propose methods of correction. The corrective action plan shall be submitted within 30 days of the discovered failure and shall be implemented immediately upon NMED approval. [20.6.2.3107 NMAC, 20.6.2.3109 NMAC]

CLOSURE PLAN

#	Terms and Conditions
34.	Within 30 days of closure of each residence, office or ranch dwelling septic tank and connection to the wastewater treatment facility, the permittee shall submit written verification to NMED that the following closure measures were performed: a) Remove or plug all lines conveying wastewater to each septic tank/leachfield system so that a discharge can no longer occur. b) Pump each septic tank and dispose of pumpings in accordance with all local, state, and federal regulations. c) Backfill each tank with clean fill or sand, or remove from the site. [20.7.3.307 NMAC]
35.	Upon closure of the facility, the permittee shall perform the following closure measures: d) Complete the installation of all monitoring wells as required by this Discharge Permit. e) Remove or plug all lines leading to the treatment system and disposal area so that a discharge can no longer occur. f) Drain and/or evaporate all liquids from all treatment units and dispose of all sludge in accordance with all local, state, and federal (40 CFR Part 503) regulations. g) Remove or demolish all tanks and re-grade area with clean fill to blend with surface topography and prevent ponding. h) Continue ground water monitoring as required by this Discharge Permit for two years after closure to confirm the absence of ground water contamination. If monitoring results show that the ground water standards in Section 20.6.2.3103 NMAC are being violated, the permittee shall implement the contingency plan required by this Discharge Permit. i) Following notification from NMED that post-closure monitoring may cease, the permittee shall plug and abandon the monitoring wells in accordance with the attachment titled *Ground Water Discharge Permit Monitoring Well Construction and Abandonment Conditions*, Revision 1.0, July 2008. When all post-closure requirements have been met, the permittee may request to terminate

draft

	the Discharge Permit. [20.6.2.3107.A(11) NMAC]

GENERAL TERMS AND CONDITIONS

#	Terms and Conditions
36.	RECORD KEEPING - The permittee shall maintain at its facility a written record of all data and information related to field measurements, sampling, and analysis conducted pursuant to this Discharge Permit. The following information shall be recorded and shall be made available to NMED upon request: a) The dates, exact place and times of sampling or field measurements; b) The name and job title of the individuals who performed each sample collection or field measurement; c) The date of the analysis of each sample; d) The name and address of the laboratory and the name and job title of the person that performed the analysis of each sample; e) The analytical technique or method used to analyze each sample or take each field measurement; f) The results of each analysis or field measurement, including raw data; g) The results of any split sampling, spikes or repeat sampling; and h) A description of the quality assurance and quality control procedures used. [20.6.2.3107.A NMAC]
37.	RECORD KEEPING - The permittee shall maintain a written record of any spills, seeps, and/or leaks of effluent, and of leachate and/or process fluids not authorized by this Discharge Permit. [20.6.2.3107.A NMAC]
38.	RECORD KEEPING - The permittee shall maintain a written record of the operation, maintenance, and repair of all facilities/equipment used to treat, store or dispose of wastewater; to measure flow rates, to monitor water quality, or to collect other data required by this Discharge Permit. This record shall include repair, replacement or calibration of any monitoring equipment and repair or replacement of any equipment used in the permittee's waste or wastewater treatment and disposal system. [20.6.2.3107.A NMAC]
39.	RECORD KEEPING - The permittee shall maintain a written record of the amount of wastewater, effluent, leachate or other wastes discharged pursuant to this Discharge Permit. [20.6.2.3107.A NMAC]
40.	RECORD KEEPING - The permittee shall retain records of all monitoring information, including all calibration and maintenance records, copies of all reports required by this Discharge Permit, and records of all data used to complete the application for this Discharge Permit for a period of at least five years from the date of the sample collection, measurement, report or application. This period may be extended by request of the Secretary at any time. [20.6.2.3107.A NMAC]
41.	INSPECTION and ENTRY - The permittee shall allow the Secretary or an authorized representative, upon the presentation of credentials, to:

draft

	a) Enter at regular business hours or at other reasonable times upon the permittee's premises or other location where records must be kept under the conditions of this Discharge Permit, or under any federal or WQCC regulation. b) Inspect and copy, during regular business hours or at other reasonable times, any records required to be kept under the conditions of this Discharge Permit, or under any federal or WQCC regulation. c) Inspect, at regular business hours or at other reasonable times, any facility, equipment (including monitoring and control equipment or treatment works), practices or operations regulated or required under this Discharge Permit, or under any federal or WQCC regulation. d) Sample or monitor, at reasonable times for the purpose of assuring compliance with this Discharge Permit or as otherwise authorized by the WQA, any effluent, water contaminant, or receiving water at any location before or after discharge. [20.6.2.3107.D NMAC, 74-6-9(B) & (E) WQA]
42.	INSPECTION and ENTRY - Nothing in this Discharge Permit shall be construed as limiting in any way the inspection and entry authority of NMED under the WQA, the WQCC Regulations, or any other applicable law or regulation. [20.6.2.3107 NMAC, 74-6-9(B) & (E) WQA]
43.	DUTY to PROVIDE INFORMATION - The permittee shall furnish to NMED, within a reasonable time, any documents or other information which it may request to determine whether cause exists for modifying, terminating and/or renewing this Discharge Permit or to determine compliance with this Discharge Permit. The permittee shall also furnish to NMED, upon request, copies of documents required to be kept by this Discharge Permit. [20.6.2.3107.D NMAC, 74-6-9(B) & (E) WQA]
44.	SPILLS, LEAKS, and OTHER UNAUTHORIZED DISCHARGES - This Discharge Permit authorizes only those discharges specified herein. Any unauthorized discharges violate Section 20.6.2.3104 NMAC and must be reported to NMED and remediated as required by Section 20.6.2.1203 NMAC. [20.6.2.1203 NMAC]
45.	MODIFICATIONS and/or AMENDMENTS - The permittee shall notify NMED of any changes to the permittee's wastewater treatment and disposal system, including any changes in the wastewater flow rate or the volume of wastewater storage, or of any other changes to operations or processes that would result in any significant change in the discharge of water contaminants. The permittee shall obtain NMED's approval, as a modification to this Discharge Permit pursuant to Subsections E, F, or G of 20.6.2.3109 NMAC, prior to any increase in the quantity discharged, or any increase in the concentration of water contaminants discharged, above those levels approved in this Discharge Permit. [20.6.2.3107.C NMAC]
46.	PLANS and SPECIFICATIONS - The permittee shall file plans and specifications with NMED for the construction of a wastewater system and for proposed changes that will change substantially the quantity or quality of the discharge from the system. The permittee shall file plans and specifications prior to the commencement of construction. Changes to the wastewater system having a minor effect on the character of the discharge shall be reported as of January 1 and June 30 of each year to NMED. [20.6.2.1202 NMAC]

draft

47.	CIVIL PENALTIES - Any violation of the requirements and conditions of this Discharge Permit, including any failure to allow NMED staff to enter and inspect records or facilities, or any refusal or failure to provide NMED with records or information, may subject the permittee to a civil enforcement action. Pursuant to WQA 74-6-10(A) and (B), such action may include a compliance order requiring compliance immediately or in a specified time, assessing a civil penalty, modifying or terminating the Discharge Permit, or any combination of the foregoing; or an action in district court seeking injunctive relief, civil penalties, or both. Pursuant to WQA 74-6-10(C) and 74-6-10.1, civil penalties of up to $15,000 per day of noncompliance may be assessed for each violation of the WQA 74-6-5, the WQCC Regulations, or this Discharge Permit, and civil penalties of up to $10,000 per day of noncompliance may be assessed for each violation of any other provision of the WQA, or any regulation, standard, or order adopted pursuant to such other provision. In any action to enforce this Discharge Permit, the permittee waives any objection to the admissibility as evidence of any data generated pursuant to this Discharge Permit. [74-6-10 WQA, 74-6-10.1 WQA]
48.	CRIMINAL PENALTIES – Any person who knowingly violates or knowingly causes or allows another person to: 1) make any false material statement, representation, certification or omission of material fact in an application, record, report, plan or other document filed, submitted or required to be maintained under the WQA; 2) falsify, tamper with or render inaccurate any monitoring device, method or record required to be maintained under the WQA; or 3) fail to monitor, sample or report as required by a permit issued pursuant to a state or federal law or regulation, is subject to felony charges and shall be sentenced in accordance with the provisions of Section 31-18-15 NMSA 1978. [74-6-10.2(A-F) WQA]
49.	COMPLIANCE WITH OTHER LAWS - Nothing in this Discharge Permit shall be construed in any way as relieving the permittee of the obligation to comply with all applicable federal, state, and local laws, regulations, permits or orders. [20.6.2 NMAC]
50.	RIGHT to APPEAL - The permittee may file a petition for review before the WQCC on this Discharge Permit. Such petition shall be in writing to the WQCC within thirty (30) days of the receipt of this Discharge Permit. Unless a timely petition for review is made, the decision of NMED shall be final and not subject to judicial review. [74-6-5(O) WQA]
51.	TRANSFER of DISCHARGE PERMIT - Prior to the transfer of any ownership, control, or possession of this permitted facility or any portion thereof, the permittee shall notify the proposed transferee in writing of the existence of this Discharge Permit and include a copy of this Discharge Permit with the notice. The permittee shall deliver or send by certified mail to NMED a copy of the notification and proof that such notification has been received by the proposed transferee. [20.6.2.3111 NMAC]
52.	TERM - Pursuant to WQA 74-6-5(I) and Subsection H of 20.6.2.3109 NMAC, the term of this Discharge Permit is five years from its effective date. To renew this Discharge Permit, the permittee must submit an application for renewal at least 180 days before the termination

draft

	date. [20.6.2.3109.H NMAC, 74-6-5(I) WQA]
53.	Payment of permit fees is due at the time of Discharge Permit approval. Permit fees shall be paid in a single payment or shall be paid in equal installments on a yearly basis over the term of the Discharge Permit. Single payments shall be remitted to NMED no later than 30 days after the Discharge Permit effective date. Initial installment payments shall be remitted to NMED no later than 30 days after the Discharge Permit effective date; subsequent installment payments shall be remitted to NMED no later than the anniversary of the Discharge Permit effective date. An approved Discharge Permit shall be suspended or terminated if the facility fails to remit an installment payment by its due date. [20.6.2.3114.F NMAC, 74-6-5(K) WQA]

EFFECTIVE DATE: **effective date**
EXPIRATION DATE: **expiration date**

WILLIAM C. OLSON
Chief, Ground Water Quality Bureau
New Mexico Environment Department

draft