



Notice is hereby given pursuant to 20.6.2.3108 NMAC, the following proposed Ground Water Discharge Permit applications have been submitted to the New Mexico Environment Department (NMED) for review.

DP #	Facility/Applicant	Closest City	County	Notice	NMED Permit Contact
68	Reeves Generating Station Richard Threet, Plant Manager Reeves Generating Station Public Service Co. NM Alvarado Square-ER16 Albuquerque, NM 87109	Albuquerque	Bernalillo	Reeves Generating Station, Richard Threet, Plant Manager, proposes to renew the Discharge Permit for the discharge of up to 9,500 gallons per day of industrial wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 4400 Paseo Del Norte NE, Albuquerque, in Section 23, T11N, R03E, Bernalillo County. Ground water beneath the site is at a depth of approximately 137 feet and has a total dissolved solids concentration of approximately 585 milligrams per liter.	John Hall
228	New Horizon Dairy Bradley Bouma, Operator New Horizon Dairy Gerrit DeGraff Family Partnership LTD 3730 Whitehead Rd. Roswell, NM 88203	Roswell	Chaves	New Horizon Dairy, Bradley Bouma, Operator, proposes to renew and modify the Discharge Permit for the discharge of up to 120,000 gallons per day of agricultural wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 1673 Corrales Road, Roswell, in Sections 35 and 36, T11S, R24E, and Section 36, T11S, R25E Chaves County. Ground water beneath the site is at a depth of approximately 40.60 feet and has a total dissolved solids concentration of approximately 1,940 milligrams per liter.	Kimberly Kirby
109	Bluewater Water and Sanitation District Van Spencer, Chairman Bluewater Water & Sanitation District PO Box 68 Bluewater, NM 87005	Bluewater	Cibola	Bluewater Water and Sanitation District, Van Spencer, Chairman, proposes to renew the Discharge Permit for the discharge of up to 65,000 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 0.25 miles east of Main and Sunrise Loop, Bluewater, in Sections 23 and 26, T12N, R11W, Cibola County. Ground water beneath the site is at a depth of approximately 178 feet and has a total dissolved solids concentration of approximately 949 milligrams per liter.	Steven Pedro
1213	Village of Eagle Nest- Wastewater Treatment	Eagle Nest	Colfax	Village of Eagle Nest-Wastewater Treatment Plant, Billie Odum, Mayor, proposes to renew and modify the Discharge	John Rebar, Jr.



	Plant Billie Odum, Mayor Village of Eagle Nest- WWTP PO Box 168 Eagle Nest, NM 87718			Permit for the discharge of up to 91,000 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at Highway 38 and Willow Creek Drive, Eagle Nest, in Sections 17, 20, 29, and 30, T27N, R16E, Colfax County. Ground water beneath the site is at a depth of approximately 53 feet and has a total dissolved solids concentration of approximately 150 milligrams per liter.	
878	Rajen Dairy #2 Randy Vander Dussen Owner Rajen Dairy #2 948 Curry Road O Clovis, NM 88101	Clovis	Curry	Rajen Dairy #2, Randy Vander Dussen, Owner, proposes to renew and modify the Discharge Permit for the discharge of up to 72,000 gallons per day of agricultural wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 1157 Curry Rd 7, Clovis, in Sections 34, 35, and 36, T02N, R35E, Curry County. Ground water beneath the site is at a depth of approximately 308.5 feet and has a total dissolved solids concentration of approximately 320 milligrams per liter.	Kimberly Kirby
1136	Heritage Dairy Eric Daale, Owner Heritage Dairy 650 Curry Rd. F Clovis, NM 88101	Clovis	Curry	Heritage Dairy, Eric Daale, Owner, proposes to renew and modify the Discharge Permit for the discharge of up to 150,000 gallons per day of agricultural wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 650 Curry Road F, Clovis, in Section 35, T02N, R36E, and in Section 3, T01N, R36E, Curry County. Ground water beneath the site is at a depth of approximately 315 feet and has a total dissolved solids concentration of approximately 368 milligrams per liter.	Kimberly Kirby
203	Tellbrook Subdivision Wastewater System Bobbie Suggs, Office Manager Tellbrook Subdivision Wastewater System Johnny's Septic Tank Co. 2155 Dona Ana Rd. Las Cruces, NM 88007	Las Cruces	Doña Ana	Tellbrook Subdivision Wastewater System, Bobbie Suggs, Office Manager, proposes to renew the Discharge Permit for the discharge of discharge up to 4,650 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at Maxim Court, Las Cruces, in Section 34, T23S, R02E, Doña Ana County. Ground water beneath the site is at a depth of approximately 180 feet and has a total dissolved solids concentration of approximately 350 milligrams per liter.	John Rebar, Jr.



1431	<p>NM Army National Guard-Las Cruces Organizational Maintenance Shop</p> <p>Wilford Griego Environmental Program Manager NM Army National Guard Las Cruces Organizational Maintenance Shop 47 Bataan Blvd. Santa Fe, NM 87508</p>	Las Cruces	Doña Ana	<p>NM Army National Guard-Las Cruces Organizational Maintenance Shop, Wilford Griego, Environmental Program Manager, proposes to renew the Discharge Permit for the discharge of up to 3,054 gallons per day of domestic wastewater to a treatment and disposal system and 11,440 gallons per year of vehicle wash rack wastewater. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 249 Armory Road, Las Cruces, in Section 27, T23S, R01W, Doña Ana County. Ground water beneath the site is at a depth of approximately 310 feet and has a total dissolved solids concentration of approximately 1,000 milligrams per liter.</p>	John Hall
1718	<p>Sapphire Energy-NM R&D Facility</p> <p>Bryn Davis NM Operations Manager Sapphire Energy NM R&D Facility 9035 Advancement Ave. Las Cruces, NM 88007</p>	Las Cruces	Doña Ana	<p>Sapphire Energy-NM R&D Facility, Bryn Davis, NM Operations Manager, proposes to discharge up to 170,000 gallons per day of agricultural wastewater from an algae production facility to a disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 9035 Advancement Ave, Las Cruces, in Section 34, T23S, R01W, Dona Ana County. Ground water beneath the site is at a depth of approximately 331 feet and has a total dissolved solids concentration of approximately 664 milligrams per liter.</p>	Rebecca Cook
1474	<p>Lordsburg Generating Station</p> <p>Greg Nugent, Plant Manager Lordsburg Generating Station 10100 W. Afton Rd. No5 La Mesa, NM 88044</p>	Lordsburg	Hidalgo	<p>Lordsburg Generating Station, Greg Nugent, Plant Manager, proposes to renew the Discharge Permit for the discharge of up to 2,500 gallons per day of industrial wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 2 Power Plant Road, Lordsburg, in Section 33, T22S, R18W, Hidalgo County. Ground water beneath the site is at a depth of approximately 90.96 feet and has a total dissolved solids concentration of approximately 1,200 milligrams per liter.</p>	Naomi Davidson
313	<p>Rancho Ruidoso Valley Estates Wastewater Treatment Plant</p>	Alto	Lincoln	<p>Rancho Ruidoso Valley Estates Wastewater Treatment Plant, Jerry Satterfield, President, proposes to renew the Discharge Permit for the discharge of up to 40,000 gallons per day of domestic wastewater to a treatment and disposal</p>	Rebecca Cook



	Jerry Satterfield, President Rancho Ruidoso Valley Estates Wastewater Treatment Plant Property Owners Committee PO Box 1231 Alto, NM 88312			system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at Intersection of Custers Last Stand Rd and Little Creek Rd, Alto, in Section 21, T10S, R14E, Lincoln County. Ground water beneath the site is at a depth of approximately 125 feet and has a total dissolved solids concentration of approximately 700 milligrams per liter.	
907	County of Los Alamos- White Rock Wastewater Treatment Plant Pete Padilla Environmental Manager County of Los Alamos White Rock-WWTP Los Alamos County Public Utilities PO Drawer 1030 Los Alamos, NM 87544	White Rock	Los Alamos	County of Los Alamos-White Rock Wastewater Treatment Plant, Pete Padilla, Environmental Compliance Specialist, proposes to renew the Discharge Permit for the discharge of up to 820,000 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located on Overlook Road, White Rock, in Section 9, T18N, R07E, Los Alamos County. Ground water beneath the site is at a depth of approximately 563 feet and has a total dissolved solids concentration of approximately 133 milligrams per liter.	Gerald Knutson
1119	Amigo's Mexican Foods Arnulfo Orquiz, Owner Amigo's Mexican Foods 1202 East Poplar St. Deming, NM 88030	Deming	Luna	Amigo's Mexican Foods, Arnulfo Orquiz, Owner, proposes to renew the Discharge Permit for the discharge of up to 1,800 gallons per day of industrial wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 1202 East Poplar St, Deming, in Section 20, T24S, R09W, Luna County. Ground water beneath the site is at a depth of approximately 110 feet and has a total dissolved solids concentration of approximately 250 milligrams per liter.	John Rebar
206	Escalante Generating Station Barbara Walz Environmental Vice President Escalante Generating Station	Prewitt	McKinley	Escalante Generating Station, Barbara Walz, Environmental Vice President, proposes to renew and modify the Discharge Permit for the discharge of up to 1 457 550 gallons per day of domestic and industrial wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds and metals. The facility is located at County Road 19, Prewitt, in Sections 25, 26, and 27, T14N, R12W, McKinley County. Ground water	Jennifer Fullam



	Tri-State Generation & Transmission Association Inc. PO Box 33695 Denver, CO 80233-0695			beneath the site is at a depth of approximately 38-205 feet and has a total dissolved solids concentration of approximately 500 milligrams per liter.	
1479	Holloman Air Force Base T-38 Petroleum Contaminated Soil Land Farm Colonel Jeffrey Harrigian 49 th Fighter Wing Commander Holloman Air Force Base PO Box 2000 Holloman AFB, NM 88330	Holloman Air Force Base	Otero	Holloman Air Force Base T-38 Petroleum Contaminated Soil Land Farm, Colonel Jeffrey Harrigian, 49 th Fighter Wing Commander, proposes to renew and modify the Discharge Permit for the discharge of up to 310,000 cubic yards of petroleum contaminated soil to a treatment and disposal system. Potential contaminants from this type of discharge include organic compounds. The facility is located at Holloman Air Force Base, in Section 14, T17S, R08E, Otero County. Ground water beneath the site is at a depth of approximately 15-18 feet and has a total dissolved solids concentration of approximately 15,600 milligrams per liter.	Jennifer Fullam
1732	Rosa Mora Colin Cannon, Owner Rosa Mora PO Box 1910 Alto, NM 88312	Three Rivers	Otero	Rosa Mora, Colin Cannon, Owner, proposes to discharge up to 20,000 gallons per day of domestic septage, wastewater treatment plant sludge, and grease trap waste to a land disposal site. Potential contaminants from this type of discharge include nitrogen compounds and organics. The facility is located approximately 1 mile west of US Hwy 54 on Otero CR B028, near Three Rivers, in Section 33, T11S, R09E, Otero County. Ground water beneath the site is at a depth of approximately 240 feet and has a total dissolved solids concentration of approximately 1,796 milligrams per liter.	John Hall
1454	Rancho de Chimayo Florence Jaramillo, Owner Rancho de Chimayo 300 Rio Arriba CR 98 Chimayo, NM 87522	Chimayo	Rio Arriba	Rancho de Chimayo, Florence Jaramillo, Owner, proposes to renew the Discharge Permit for the discharge of 4,290 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 300 Rio Arriba CR 98, Chimayo, in Section 1, T20N, R09E, Rio Arriba County. Ground water beneath the site is at a depth of approximately 27 feet and has a total dissolved solids concentration of approximately 300 milligrams per liter.	Jennifer Fullam



1251	Crosswinds Dairy Doug Idsinga, Owner Crosswinds Dairy 795 NM 202 Portales, NM 88130	Portales	Roosevelt	Crosswinds Dairy, Doug Idsinga, Owner, proposes to renew the Discharge Permit for the discharge of up to 50,000 gallons per day of agricultural wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 795 NM 202, Portales, in Sections 1 and 12, T01S, R36E, Roosevelt County. Ground water beneath the site is at a depth of approximately 175 feet and has a total dissolved solids concentration of approximately 400 milligrams per liter.	Kimberly Kirby
872	Pendaries Park at Rociada Michael Gregory President Rociada Properties Inc. PO Box 2742 Las Vegas, NM 87701	Rociada	San Miguel	Pendaries Park at Rociada, Michael Gregory, President, proposes to renew and modify the Discharge Permit for the discharge of up to 11,760 gallons per day of domestic wastewater from an RV park to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at mile marker 3 on Hwy 105, two miles northeast of Rociada, in Sections 19 and 30, T19N, R15E (projected), San Miguel County. Ground water most likely to be affected is at a depth of approximately 60 feet and has a total dissolved solids concentration of approximately 187 milligrams per liter.	Kathie Deal
76	El Dorado Community School Jim Romero Chief Operations Officer El Dorado Community School Santa Fe Public Schools 610 Alta Vista Santa Fe, NM 87505	Santa Fe	Santa Fe	El Dorado Community School, Jim Romero, Chief Operations Officer, proposes to renew and modify the Discharge Permit for the discharge of up to 7,950 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at #2 Avenida Torreon, Santa Fe, in Section 8, T15N, R10E, Santa Fe County. Ground water beneath the site is at a depth of approximately 206 - 300 feet and has a total dissolved solids concentration of approximately 500 milligrams per liter.	Steven Pedro
1164	Ranchland Utility-Rancho Viejo Waste Water Reclamation Plant Isaac Pino, Vice President Rancho Viejo Waste Water Reclamation Plant	Santa Fe	Santa Fe	Ranchland Utility-Rancho Viejo Waste Water Reclamation Plant, Isaac Pino, Vice President, proposes to renew and modify the Discharge Permit for the discharge of up to 400,000 gallons per day of domestic wastewater to a treatment, reuse, and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at A-van-nu-po Rd and Avenida Del Sur, approximately 2 miles south of Santa Fe, in Sections 16, 19, 20, 21, 28, 29, and 30, T16N, R09E, Santa	John Hall



	Ranchland Utility Corp. 55 Canada del Rancho Santa Fe, NM 87508			Fe County. Ground water beneath the site is at a depth of approximately 200 feet and has a total dissolved solids concentration of approximately 150 milligrams per liter.	
1408	Downs Trailer Park Raymond & Gloria Gallegos, Owners Downs Trailer Park PO Box 334 Española, NM 87532	Santa Fe	Santa Fe	Downs Trailer Park, Raymond and Gloria Gallegos, Owners, propose to renew the Discharge Permit for the discharge of up to 4,500 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at O Josephine St, Carlson Subdivision E across Santa Fe Downs, Santa Fe, in Section 34, T16N, R08E, Santa Fe County. Ground water beneath the site is at a depth of approximately 70 feet and has a total dissolved solids concentration of approximately 335 milligrams per liter.	Rebecca Cook
429	Las Colonias Mobile Home Park Elbert Martinez, Owner Las Colonias MHP 6404 Milpa Alta Rd. NE Rio Rancho, NM 87144	El Prado	Taos	Las Colonias Mobile Home Park, Elbert Martinez, Owner, proposes to renew the Discharge Permit for the discharge of up to 7,200 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 25003 US Hwy 64 W, El Prado, in Section 30, T26N, R13E, Taos County. Ground water beneath the site is at a depth of approximately 60 feet and has a total dissolved solids concentration of approximately 300 milligrams per liter.	Steven Pedro
748	Rio Lucio Septic Service Jerry Sanchez, Owner Rio Lucio Septic Service 1238 Hwy 75 Peñasco, NM 87553	Peñasco	Taos	Rio Lucio Septic Service, Jerry Sanchez, Owner, proposes to renew and modify the Discharge Permit for the discharge of up to 2,001 gallons per day of domestic septage to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 1238 Hwy 75, Peñasco, in Sections 17 and 21, T23N, R11E, Taos County. Ground water beneath the site is at a depth of approximately 400 feet and has an unknown total dissolved solids concentration.	Steven Pedro
1180	Arroyos Del Norte Elementary School Quinton Wood Facilities & Grounds Supervisor	Taos	Taos	Arroyos Del Norte Elementary School, Quinton Wood, Facilities and Grounds Supervisor, proposes to renew the Discharge Permit for the discharge of up to 5,000 gallons per day of domestic wastewater to a treatment and disposal system. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 405	Steven Pedro



	Arroyos Del Norte Elementary School Taos Municipal Schools 213 Paseo del Canon E Taos, NM 87571			Hondo Seco Road, Taos, in the Antonio Martinez or Godoi Grant, at latitude 36 degrees, 31 minutes, 51.4 seconds north and longitude 105 degrees, 35 minutes, 40.2 seconds west (projected), Taos County. Ground water beneath the site is at a depth of approximately 155 feet and has a total dissolved solids concentration of approximately 190 milligrams per liter.	
746	NM Army National Guard-Belen Armory Wilford Griego Environmental Program Manager NM Army National Guard Belen Armory 47 Bataan Blvd. Santa Fe, NM 87508	Belen	Valencia	NM Army National Guard-Belen Armory, Wilford Griego, Environmental Program Manager, proposes to renew the Discharge Permit for the discharge of up to 2,000 gallons per day of domestic wastewater to a treatment and disposal system and up to 5,180 gallons per year of wash rack wastewater. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located at 21 General Baca Road, Belen, in Section 1, T04N, R01E, Valencia County. Ground water beneath the site is at a depth of approximately 40 feet and has a total dissolved solids concentration of approximately 1,400 milligrams per liter.	John Hall

Provided the applicant has met applicable requirements, the New Mexico Environment Department (NMED) will propose for approval a Discharge Permit containing limitations, monitoring requirements, and other conditions intended to protect ground water quality for present and potential future use. Information in this public notice was provided by the applicants and will be verified by NMED during the permit application review process. NMED will accept comments and statements of interest regarding applications and will create facility-specific mailing lists for persons who wish to receive future notices. Questions, comments or statements of interest should be directed to the NMED permit contact at (505) 827-2900 or at the following address: Ground Water Quality Bureau, PO Box 5469, Santa Fe, NM 87502-5469.

To view this and other public notices issued by the Ground Water Quality Bureau on-line, go to:
<http://www.nmenv.state.nm.us/gwb/NMED-GWQB-PublicNotice.htm>