



Notice is hereby given pursuant to 20.6.2.3108.H NMAC, the following Ground Water Discharge Permit applications have been proposed for approval. To request additional information or to obtain a copy of a draft permit, contact the Ground Water Quality Bureau in Santa Fe at (505) 827-2900. Draft permits may also be viewed on-line at <http://www.nmenv.state.nm.us/gwb/NMED-GWQB-PublicNotice.htm>

NOTE – If viewing by WEB - Click on facility name to review a copy of the draft permit.

DP #	Facility/Applicant	Closest City	County	Notice	NMED Permit Contact
812	Doña Ana County Liquid Waste Disposal Facility M. Sue Padilla Assist. County Manager Utilities Dept. Doña Ana County 845 N. Motel Blvd. Las Cruces, NM 88007	Mesquite	Dona Ana	Doña Ana County Liquid Waste Disposal Facility, M. Sue Padilla, Assistant County Manager, proposes to renew the Discharge Permit for the discharge of up to 30,000 gallons per day of domestic septage, domestic wastewater treatment plant sludge, grease trap waste, car wash grit trap waste, agricultural waste and food processing waste to two synthetically lined evaporation lagoons. Potential contaminants associated with this type of discharge include nitrogen compounds, metals and organic compounds. The facility is located at 725 CR B-59, approximately 3.5 miles northeast of Mesquite, in Section 21, T24S, R03E, Doña Ana County. Ground water beneath the site is at a depth of approximately 250 feet and has a total dissolved solids concentration of approximately 553 milligrams per liter.	Gerald Knutson
1036	Mesquite Wastewater Treatment System Martin G. Lopez, General Manager Mesquite Mutual Domestic Water Consumers & Mutual Sewage Works Assoc. P.O. Box 349 215 Bryant St. Mesquite, NM 88048	Mesquite	Dona Ana	Mesquite Wastewater Treatment System, Martin Lopez, General Manager, proposes to renew the Discharge Permit for the discharge of up to 88,000 gallons per day of domestic wastewater from the Town of Mesquite. Wastewater is treated by a constructed wetland system and discharged to four infiltration basins. The facility will be closed in the near future and the discharge directed to Doña Ana County's sanitary sewer. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located west of Santo Tomas Road, in Mesquite, in Section 2, T25S, R02E, Doña Ana County. Ground water beneath the site is at a depth of approximately 7 feet and has a total dissolved solids concentration of approximately 590 milligrams per liter.	Gerald Knutson
166	Freeport-McMoRan Tyrone Inc.,	Silver City	Grant	Freeport-McMoRan Tyrone Inc., Richard N. Mohr, General Manager, proposes to modify the Discharge Permit to allow	Keith Ehlert



	Richard N. Mohr General Manager Freeport-McMoRan Tyrone, Inc. P.O. Drawer 571 Tyrone, NM 88065			for the deepening of the Copper Mountain Pit. Leach solution and pit water management facilities will be changed as a result of the project. The facility is located approximately 12 miles south of Silver City, New Mexico, in Sections 21, 22, 27 and 28, T19S, R15W, Grant County, New Mexico. Depth to ground water in the area of the permitted discharge ranges from approximately 1 to 325 feet and has a total dissolved solids concentration of approximately 200-400 milligrams per liter.	
907	Los Alamos County-White Rock Wastewater Treatment Facility G. Pete Padilla Environmental Compliance Specialist Dept.of Public Utilities Los Alamos County 901 Trinity Drive P.O. Drawer 1030 Los Alamos, NM 87544	White Rock	Los Alamos	Los Alamos County-White Rock Wastewater Treatment Facility, G. Pete Padilla, Environmental Compliance Specialist, proposes to renew the Discharge Permit for the discharge of up to 820,000 gallons per day of domestic wastewater from the Community of White Rock to a municipal wastewater treatment facility. Treated wastewater is discharged to Canada del Buey pursuant to a NPDES permit and/or is reused to irrigate approximately 28.81 acres of landscape at Overlook Park. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility and landscape areas are located on Overlook Road in White Rock, in Section 9, T18N, R07E, Los Alamos County. Ground water beneath the site is at a depth of approximately 563 feet and has a total dissolved solids concentration of approximately 133 milligrams per liter.	Gerald Knutson
1698	Enchanted Mesa Mobile Home Park Robert R. Amador Owner 313 State Road #399, Space 51 Española, NM 87532	Española	Rio Arriba	Enchanted Mesa Mobile Home Park, Robert Amador, Owner, proposes to discharge up to 16,900 gallons per day of domestic wastewater from a mobile home park. Wastewater is treated in a mechanical treatment plant and then is discharged to a low pressure dose drip irrigation and/or disposal fields. Primary contaminants associated with this type of discharge include nitrogen compounds. The mobile home park is located in La Mesilla at 313 State Road 399, approximately 4 miles south of Española, Rio Arriba County. Ground water beneath the site is at a depth of approximately 40 feet and has a total dissolved solids concentration of approximately 538 milligrams per liter.	Brad Reid
1099	Corrales Elementary School, Board of	Corrales	Sandoval	Corrales Elementary School, Board of Education, Albuquerque Public Schools, proposes to renew and modify	Melanie Sanchez



	Education, Albuquerque Public Schools Van K. Lewis, Manager Environmental Management Dept. Albuquerque Public Schools P.O. Box 25704 Albuquerque, NM 87125			the Discharge Permit for the discharge of up to 13,300 gallons per day of domestic wastewater to a treatment and disposal system. The modification consists of including a synthetically lined lagoon for storing wastewater. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at 200 Target Road, in Corrales, in Section 34, T12N, R3E, Sandoval County. Ground water beneath the site is at a depth of approximately 10 feet and has a total dissolved solids concentration of approximately 500 milligrams per liter.	
1422	Praxair Inc.-Kirtland Facility Elizabeth Casciani Corporate Vice President Praxair Inc. P.O. Box 44 Tonawanda, NY 14151	Kirtland	San Juan	Praxair Inc.-Kirtland Facility, Elizabeth Casciani, Corporate Vice President, proposes to renew the Discharge Permit for the discharge of up to 15,200 gallons per day of industrial wastewater including cooling tower blowdown, compressor foundation stormwater, and air compressor condensate. Potential contaminants associated with this type of discharge include metals and total dissolved solids. The facility is located at 101 County Road 6500, approximately 1.75 miles north of Kirtland, in Section 1, T29N, R15W, San Juan County. Ground water beneath the site is at a depth of approximately 15-20 feet and has a total dissolved solids concentration of approximately 8,600-14,000 milligrams per liter.	Gerald Knutson
289	City of Santa Fe Bryan Romero, Acting Director Wastewater Management Division 73 Paseo Real Santa Fe, NM 87507	City of Santa Fe	Santa Fe	City of Santa Fe, Bryan Romero, Acting Wastewater Management Division Director, proposes to renew the discharge permit for the discharge of treated and reclaimed wastewater from the Santa Fe Wastewater Treatment Facility. The treatment facility is located approximately 7 miles southwest of downtown Santa Fe in Section 10, T16N, R08E, Santa Fe County. Up to 13,000,000 gallons per day of treated wastewater is discharged into the Santa Fe River (also subject to NPDES Permit No. NM0022292), or reclaimed wastewater is used for irrigation and various purposes within the City and its vicinity located in Sections 21, 22, 26, 27 and 35, T17N, R8E. Reclaimed wastewater is also transferred for other uses covered by separate Discharge Permits. Ground water below the sites ranges in depths from approximately 120 to 300 feet and has a total dissolved solids concentration of approximately 250 milligrams per liter.	Brad Reid



1583	The Village at Galisteo Basin Preserve Ted Harrison, President Commonweal Conservancy 117 North Guadalupe St., Suite C Santa Fe, New Mexico 87501	El Dorado	Santa Fe	The Village at Galisteo Basin Preserve, Ted Harrison, President, proposes to discharge up to 30,000 gallons per day of domestic wastewater to a treatment, disposal and reuse system. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located off U.S. Highway 285, approximately five miles south of El Dorado, in Sections 6 and 31, Township 14 and 15 North, Range 10 East, Santa Fe County. Ground water beneath the site is at a depth of approximately 82 feet and has a total dissolved solids concentration of approximately 190 milligrams per liter.	Steve Pedro
1747	Santa Fe County Judicial Complex Construction Site Joseph Gutierrez Director SF County Community Services Dept. P.O. Box 276 Santa Fe, NM 87501	Santa Fe	Santa Fe	Santa Fe County Judicial Complex Construction Site, Joseph Gutierrez, Santa Fe County Community Services Department Director, proposes to discharge up to 90,000 gallons per day of treated ground water from a remediation system to either an onsite infiltration gallery pursuant to this Discharge Permit or the Santa Fe River pursuant to National Pollutant Discharge Elimination System (NPDES) Permit No. NM0031046. Potential contaminants associated with this type of discharge include nitrogen and organic compounds. The facility is located at 327 Sandoval Street, Santa Fe, in Section 24, T17N, R09E, Santa Fe County. Ground water beneath the site is at a depth of approximately 3.5 feet and has a total dissolved solids concentration of approximately 224-812 milligrams per liter.	John Rebar, Jr.
232	Town of Taos Amos Torres, Public Utilities Director Town of Taos 1030 Dea Lane Taos, NM 87571	Taos	Taos	Town of Taos, Amos Torres, Public Utilities Director, proposes to renew the discharge permit for the discharge of treated and reclaimed wastewater from the Taos Wastewater Treatment Facility. The treatment facility is located approximately 6 miles southwest of Taos in Section 27, T25N, R12E, Taos County. Up to 2,000,000 gallons per day of treated wastewater is discharged into the Rio Pueblo de Taos (also subject to NPDES Permit No. NM0024066), or reclaimed wastewater is used for irrigation and various purposes within Taos and its vicinity. Reclaimed wastewater is also transferred from the facility for other uses covered by separate Discharge Permits. Ground water below the site ranges in depths from approximately	Brad Reid



				16 to 56 feet and has a total dissolved solids concentration of approximately 500 milligrams per liter.	
1383	Village of Taos Ski Valley Sludge Disposal Site Bruce Kelly, Village Administrator Village of Taos Ski Valley P.O. Box 100 Taos Ski Valley, NM 87525	Taos	Taos	Village of Taos Ski Valley Sludge Disposal Site, Bruce Kelly, Village Administrator, proposes to renew the Discharge Permit for the discharge of up to 3,700 gallons per day, not to exceed 80,000 gallons per year, of treated domestic wastewater sludge. Raw domestic wastewater is treated by extended aeration, filtration and disinfection at the Village of Taos Ski Valley Wastewater Treatment Plant and resultant wastewater sludge is then dewatered through a belt press, transported to the 5-acre land application site and disked into the soil. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located on the west side of State Highway 64, approximately 1.5 miles northwest of the Rio Grande Gorge Bridge, in Section 15, Township 26N, Range 11E, Taos County. Ground water beneath the site is at a depth of approximately 370-588 feet and has a total dissolved solids concentration of approximately 209 milligrams per liter.	Rebecca Cook

Prior to ruling on any proposed Discharge Permit or its modification, the New Mexico Environment Department (NMED) will allow thirty days after the date of publication of this notice to receive written comments and during which time a public hearing may be requested by any interested person, including the applicant. Requests for public hearing shall be in writing and shall set forth the reasons why a hearing should be held. A hearing will be held if NMED determines that there is substantial public interest. Comments or requests for hearing should be submitted to the Ground Water Quality Bureau at PO Box 5469, Santa Fe, NM 87502-5469.

To view this and other public notices issued by the Ground Water Quality Bureau on-line, go to:
<http://www.nmenv.state.nm.us/gwb/NMED-GWQB-PublicNotice.htm>