



Notice is hereby given pursuant to 20.6.2.3108.H NMAC, the following Ground Water Discharge Permit applications have been proposed for approval. To request additional information or to obtain a copy of a draft permit, contact the Ground Water Quality Bureau in Santa Fe at (505) 827-2900. Draft permits may also be viewed on-line at <http://www.nmenv.state.nm.us/gwb/NMED-GWQB-PublicNotice.htm>

**NOTE – If viewing by WEB - Click on facility name to review a copy of the draft permit.**

DP #	Facility/Applicant	Closest City	County	Notice	NMED Permit Contact
363	<a href="#">Freeport-McMoRan Tyrone Mines Company-1A and 1B Leach Stockpiles</a>  Richard N. Mohr President Freeport-McMoRan Tyrone Mines Co. P.O. Drawer 574 Tyrone, NM 88065	Silver City	Grant	<p>Freeport-McMoRan Tyrone Mines Company-1A and 1B Leach Stockpiles, Richard N. Mohr, President, proposes to renew and modify the Discharge Permit for the 1A Leach Stockpile, the 1B Leach Stockpile and associated facilities. The combined maximum permitted discharge rate of acid leaching solution (raffinate) to the 1A Leach Stockpile and/or adjacent 1B Leach Stockpile is 16,488,000 gallons per day (gpd). Facilities presently covered under DP-363 include the 1A Leach Stockpile, 1A PLS Collection Tank, 1A PLS Overflow Pond, the 1A Storm Water Pond, and the East Side Seepage Collection System consisting of interceptor wells and interceptor trenches. The proposed modification of DP-363 will incorporate facilities presently covered under DP-383, including the 1B Leach Stockpile, surface and sub-surface infiltration gallery collection systems at the toe of the 1B Leach Stockpile, the 1B PLS Collection Tank and the 1B PLS Overflow Pond.</p> <p>The No. 1A and 1B Leach Stockpiles and the East Side Seepage Collection System are located approximately 12 miles south of Silver City in Sections 23, 24 and 25, T19S, R15W; and Sections 19, 28, 29, 30, 33 &amp; 34, T19S, R14W, Grant County, New Mexico.</p> <p>The facilities covered by this Discharge Permit are located adjacent to an actively dewatered area of the Tyrone Mine. Depth to ground water ranges from approximately 10 to 30 feet in the alluvial aquifer and 200 to 500 feet in the regional aquifer. The total dissolved solids concentration in the regional aquifer is approximately 280 milligrams per liter.</p>	Keith Ehlert



244	<a href="#">Hondo Valley Public Schools</a>  Andrea M. Nieto Superintendent Hondo Valley Public School District P.O. Box 55 Hondo, NM 88336	Hondo	Lincoln	Hondo Valley Public Schools, Andrea M. Nieto, Superintendent, proposes to renew the Discharge Permit for the discharge of up to 6,000 gallons per day of domestic wastewater to a package treatment plant. Treated wastewater is discharged to a leachfield. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at 111 Don Pablo Lane, in Hondo, in Section 3, T10S, R17E, Lincoln County. Ground water beneath the site is at a depth of approximately 39 feet and has a total dissolved solids concentration of approximately 1,144 milligrams per liter.	Melanie Sanchez
1037	<a href="#">Agora Shopping Center</a>  Gary Grable, Manager Agora Shopping Center LLC c/o Security Bank of Kansas City 1000 Minnesota Ave. Kansas City, KS 66101	Santa Fe	Santa Fe	Agora Shopping Center, Gary Grable, Manager and President of Agora Shopping Center LLC, proposes to renew and modify the Discharge Permit for the discharge of up to 6,000 gallons per day (gpd) of domestic wastewater from a package treatment plant. Treated wastewater is discharged to a 4,200 square-foot subsurface disposal field and to a 1,000 square-foot subsurface irrigation system. The modification consists of increasing the maximum daily discharge volume from 5,802 gpd to 6,000 gpd and the addition of 1,000 square-feet of subsurface irrigation. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at 7 Avenida Vista Grande, approximately 13 miles southeast of Santa Fe, in Section 9, Township 15N, Range 10E, Santa Fe County. Ground water beneath the site is at a depth of approximately 61.5 feet and has a total dissolved solids concentration of approximately 500 milligrams per liter.	Jennifer Fullam

Prior to ruling on any proposed Discharge Permit or its modification, the New Mexico Environment Department (NMED) will allow thirty days after the date of publication of this notice to receive written comments and during which time a public hearing may be requested by any interested person, including the applicant. Requests for public hearing shall be in writing and shall set forth the reasons why a hearing should be held. A hearing will be held if NMED determines that there is substantial public interest. Comments or requests for hearing should be submitted to the Ground Water Quality Bureau at PO Box 5469, Santa Fe, NM 87502-5469.

To view this and other public notices issued by the Ground Water Quality Bureau on-line, go to:  
<http://www.nmenv.state.nm.us/gwb/NMED-GWQB-PublicNotice.htm>