



Notice is hereby given pursuant to 20.6.2.3108.H NMAC, the following Ground Water Discharge Permit applications have been proposed for approval. To request additional information or to obtain a copy of a draft permit, contact the Ground Water Quality Bureau in Santa Fe at (505) 827-2900. Draft permits may also be viewed on-line at <http://www.nmenv.state.nm.us/gwb/NMED-GWQB-PublicNotice.htm>

NOTE – If viewing by WEB - Click on facility name to review a copy of the draft permit.

DP #	Facility/Applicant	Closest City	County	Notice	NMED Permit Contact
254	City of Raton Wastewater Treatment Facility Dan Campbell, General Manager Raton Water Works P.O. Box 99 Raton, NM 87740	Raton	Colfax	City of Raton Wastewater Treatment Facility, Dan Campbell, General Manager of Raton Water Works proposes to renew and modify the Discharge Permit for the discharge of up to 620,000 gallons per day (gpd) of reclaimed domestic wastewater for irrigation of 250 acres of athletic fields, a cemetery and a golf course, up to 100,000 gpd of domestic wastewater treatment facility sludge to a 60-acre surface disposal site and up to 1,500 gpd of grease trap/interceptor waste. The modification consists of authorizing the disposal of grease trap/interceptor waste for up to 1 year and then allowing dewatering of grease trap/interceptor waste at the WWTF site. Potential contaminants associated with these types of discharges include nitrogen compounds, metals, and organic compounds. The facility is located at 420 Hereford Ave, Raton, in Section 6, Township 30 N, Range 24 E (projected), Colfax County. Reclaimed wastewater irrigation areas are located in Section 1, Township 30 N, Range 23 E and Sections 25, 26 and 27, Township 31 N, Range 23 E (projected), Colfax County. Ground water is reported to be present at depths ranging from three to 28 feet in the vicinity of the WWTF site. Ground water in the area is reported to contain TDS concentrations ranging from 3,660 to 4,600 mg/L.	Robert George
1284	Carlsbad KOA Scott and Susan Bacher, Owners Carlsbad KOA 2 Manthei Rd. Hwy 285 Carlsbad, NM 88220	Carlsbad	Eddy	Carlsbad KOA, Scott and Susan Bacher, Owners, propose to renew the Discharge Permit for the discharge of up to 9,999 gallons per day (gpd) of domestic wastewater to a synthetically lined impoundment for disposal by evaporation. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at 2 Manthei Road, approximately 1.4 miles	Robert George



				northwest of Carlsbad, in Section 8, T20S, R26E, Eddy County. Ground water beneath the site is at a depth of approximately 30 feet and has a total dissolved solids concentration of approximately 1,550 milligrams per liter.	
1758	Aspendale Baptist Encampment, Inc. Jay Hammond, Manager Aspendale Baptist Encampment, Inc. PO Box 287 Cloudcroft, NM 88317	Cloudcroft	Otero	Aspendale Baptist Encampment, Inc., Jay Hammond, Camp Manager, proposes to discharge up to 10,600 gallons per day of domestic wastewater to 19 septic tank/leachfield systems. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at 163 Pierce Canyon Road, Cloudcroft, in Sections 7 and 18, T16S, R12E, Otero County. Ground water beneath the site is at a depth of approximately 20 feet and has a total dissolved solids concentration of approximately 363 milligrams per liter.	Bill Pearson
1743	Stone House Lodge LLC Carolyn Bogdan, Registered Agent Stone House Lodge LLC 8000 Harwood Ave., NE Albuquerque, NM 87110	Rutheron	Rio Arriba	Stone House Lodge LLC, Carolyn Bogdan, Registered Agent, proposes to discharge up to 3,310 gallons per day of domestic wastewater to a treatment system and then to a ½ acre subsurface irrigation system. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at 1409 Heron Lake Road, Highway 95, approximately 10 miles southwest of Rutheron, in projected Section 20, Township 28N, Range 2E of the Tierra Amarilla Land Grant, Rio Arriba County. Ground water beneath the site is at a depth of approximately 600 feet and has a total dissolved solids concentration of approximately 1,560-5,160 milligrams per liter.	Jennifer Fullam
1492	New Mexico Christian Children's Home Charles Anderson, Executive Director NM Christian Children's Home 1356 NM HWY 236 Portales, NM 88130	Portales	Roosevelt	New Mexico Christian Children's Home, Charles Anderson, Executive Director, proposes to renew the Discharge Permit for the discharge of up to 9,750 gallons per day of domestic wastewater to 35 septic tank/leachfield systems. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at 1356 NM Highway 236, approximately 7 miles northwest of Portales in Section 13, T1S, R33E, Roosevelt County. Ground water beneath the site is at a depth of approximately 80 feet and has a total dissolved solids concentration of approximately 1085 milligrams per liter.	Russell Isaac



1073	<p>Dam Site Mobile Home and RV Park</p> <p>Harry Dalton, Partner Dam Site Properties P.O. Box 5220 Farmington, NM 87499</p>	Navajo Dam	San Juan	<p>Dam Site Mobile Home and RV Park, Dam Site Partnership, proposes to renew the Discharge Permit for the discharge of up to 3,333 gallons per day (gpd) of domestic wastewater. Wastewater is discharged from up to 46 mobile home and RV lots into a synthetically lined lagoon for disposal by evaporation. Changes from the previous discharge permit include decreasing the discharge volume from 5,175 to 3,333 gpd and replacing the two clay-lined lagoons with a single synthetically lined lagoon. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at 6 County Road 4228, Navajo Dam, in Section 20, T30N, R8W, San Juan County. Ground water beneath the site is at a depth of approximately 80 feet and has a total dissolved solids concentration of approximately 500 milligrams per liter.</p>	Kimberly Kirby
132	<p>Chevron Mining Inc.- Questa Mine</p> <p>Phillip Howard, General Mine Manager Chevron Mining Inc. P.O. Box 469 Questa, NM 87556</p>	Questa	Taos	<p>Chevron Mining Inc.-Questa Mine, Phillip Howard, General Mine Manager, proposes to renew and modify the Discharge Permit for the discharge of up to 7,045 gallons per day of domestic wastewater from the Questa Mine and Tailings Sites. Domestic wastewater is discharged to a package treatment plant and disposed of in four leachfields or to eight remote septic tank/leachfield disposal systems. The modification includes upgrading the Goathill Wastewater Treatment System from an aerated lagoon system followed by three leachfields to an activated sludge process (package plant) followed by four leachfields and the inclusion of eight existing septic tank/leachfield systems. Potential contaminants associated with this type of discharge include nitrogen and inorganic compounds. The facilities at the Mine Site are located at 354 State Road 38 (Goathill Complex) and 710 State Road 38 (Mill Site), approximately 3.5 miles east of Questa, in Section 2, T28N, R13E, and in Sections 6 & 31, T28N, R14E, Taos County. The Tailings Site is located at 32 Abra Road, approximately 0.5 miles west of Questa, in Sections 2 & 36, T29N, R12E, Taos County. Ground water beneath the site is at a depth of approximately 96 feet and has a total dissolved solids concentration of approximately 2,200 milligrams per liter.</p>	Gerald Knutson



191	<p>Village of Questa Wastewater Treatment Facility</p> <p>Brent Jaramillo, Administrator Village of Questa P.O. Box 260 Questa, NM 87556</p>	Questa	Taos	<p>Village of Questa Wastewater Treatment Facility, Brent Jaramillo, Administrator, proposes to renew and modify the Discharge Permit for the treatment and discharge of up to 175,000 gallons per day (gpd) of domestic wastewater from the Village of Questa. The modification consists of the construction of a new treatment system and increasing the discharge volume from 120,00 gpd to 175,000 gpd. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at 2500 Old Highway 3, approximately 1.5 miles south of Questa, in Section 1, Township 28N, Range 12E, Taos County. Ground water beneath the site is at a depth of approximately 32 feet and has a total dissolved solids concentration of approximately 258 milligrams per liter.</p>	Jennifer Fullam
748	<p>Rio Lucio Septic Service</p> <p>Jerry Sanchez, Owner Rio Lucio Septic Service 1238 NM Highway 75 Penasco, NM 87553</p>	Penasco	Taos	<p>Rio Lucio Septic Service, Jerry Sanchez, Owner, proposes to renew and modify the Discharge Permit for up to 2,001 gallons per day of domestic septage to be disposed in three clay-lined lagoons for evaporation. Dried septage may be land applied to 65 acres of rangeland or disposed of at a licensed disposal facility in accordance with all local, state, and federal regulations. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located off NM Highway 75, approximately six miles west of Penasco, in Section 21, Township 23 North, Range 11 East, Taos County. Ground water beneath the site is greater than 400 feet and has an unknown total dissolved solids concentration.</p>	Steve Pedro
1244	<p>Village of Bosque Farms Sludge Disposal Facility</p> <p>The Honorable Wayne Ake, Mayor Village of Bosque Farms 1455 W. Bosque Loop Bosque Farms, NM 87106</p>	Los Lunas	Valencia	<p>Village of Bosque Farms Sludge Disposal Facility, The Honorable Wayne Ake, Mayor, proposes to renew the Discharge Permit for the discharge of up to 17,500 gallons per day of biosolids (sludge) from the Village of Bosque Farms Wastewater Treatment Plant to a disposal facility. Potential contaminants associated with this type of discharge include nitrogen compounds and metals. The facility is located approximately 4.75 miles southwest of the intersection of NM-6 and Dalies Road, approximately 9 miles southwest of Los Lunas in the Nicolas de Chavez Grant, in Section 17 (projected), T06N, R01E, Valencia County. Ground water beneath the site is at a depth of approximately 400 feet and has a total dissolved solids</p>	John Rebar



				concentration of approximately 150 milligrams per liter.	
--	--	--	--	--	--

Prior to ruling on any proposed Discharge Permit or its modification, the New Mexico Environment Department (NMED) will allow thirty days after the date of publication of this notice to receive written comments and during which time a public hearing may be requested by any interested person, including the applicant. Requests for public hearing shall be in writing and shall set forth the reasons why a hearing should be held. A hearing will be held if NMED determines that there is substantial public interest. Comments or requests for hearing should be submitted to the Ground Water Quality Bureau at PO Box 5469, Santa Fe, NM 87502-5469.

To view this and other public notices issued by the Ground Water Quality Bureau on-line, go to:
<http://www.nmenv.state.nm.us/gwb/NMED-GWQB-PublicNotice.htm>