



Notice is hereby given pursuant to 20.6.2.3108.H NMAC, the following Ground Water Discharge Permit applications have been proposed for approval. To request additional information or to obtain a copy of a draft permit, contact the Ground Water Quality Bureau in Santa Fe at (505) 827-2900. Draft permits may also be viewed on-line at <http://www.nmenv.state.nm.us/gwb/NMED-GWQB-PublicNotice.htm>

NOTE – If viewing by WEB - Click on facility name to review a copy of the draft permit.

DP #	Facility/Applicant	Closest City	County	Notice	NMED Permit Contact
238	Maxwell Wastewater Treatment Facility Karla K. Pinkston, Mayor Village of Maxwell P.O. Box 356 Maxwell, NM 87728	Maxwell	Colfax	Maxwell Wastewater Treatment Facility, Karla K. Pinkston, Mayor, proposes to renew the Discharge Permit for the discharge of up to 22,000 gallons per day of domestic wastewater to two treatment impoundments for disposal by evaporation or discharge to the Canadian River. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located on Chico Road approximately 1/2 mile East of Maxwell, in Sections 31, Township 27N, Range 23E, Colfax County. Ground water most likely to be affected is at a depth of approximately 28 feet and has a total dissolved solids concentration of approximately 2,500 milligrams per liter.	Russell Isaac russell.isaac@state.nm.us
565	Camino Real Landfill Sludge Land Application Area James Norstrom, P.E, Regional Engineer Camino Real Environmental, Inc. 11803 Faunview Dr. Houston, TX 77070	Sunland Park	Doña Ana	Camino Real Landfill Sludge Land Application Area, James Norstrom, Region Engineer, proposes to renew and modify the Discharge Permit for the closure of this facility. This facility was previously permitted for the discharge of up to 25,250 gallons per day of municipal wastewater treatment facility sludge. Discharge ceased in 1997. Potential contaminants from this type of discharge include nitrogen compounds. The facility is located approximately 6,000 ft. N-NW of the intersection of Camino Real Blvd and the Santa Fe Railroad, Sunland Park, in Section 2, Township 29 South, Range 03 East, Doña Ana County. Ground water beneath the site is at a depth ranging from 147 to 228 feet and has a total dissolved solids concentration of approximately 278 milligrams per liter.	Melissa Halick melissa.halick@state.nm.us



193	<p>Burlington Northern Santa Fe Railway Company Gallup Fueling Facility</p> <p>Michael Clift, Sr. Manager Environmental Operations BNSF Railway Co. 4200 Deen Rd. Fort Worth, TX 76106</p>	Gallup	McKinley	<p>Burlington Northern Santa Fe Railway Company Gallup Fueling Facility, Michael Clift, Sr. Manager Environmental Operations, proposes to renew the Discharge Permit for the discharge of up to 325 gallons per day daily average on an annual basis of industrial wastewater consisting of spilled grease, diesel fuel, wash water, oil, and stormwater wastewater from the fueling facility. The wastewater is discharged to an oil-water separator. Separated oil is pumped out of the oil-water separator to an aboveground used oil storage tank and transported off site for refining. Separated water is discharged into two synthetically lined lagoons for disposal by evaporation. Potential contaminants associated with this type of discharge include volatile and semi-volatile organic compounds and total dissolved solids. The facility is located at 811 Roundhouse Road in Gallup, in Section 16, Township 15N, Range 18W, McKinley County. Ground water beneath the site is at a depth ranging from approximately 1.2 to 18 feet below ground surface and has a total dissolved solids concentration ranging from approximately 457 to 2,130 milligrams per liter.</p>	<p>Bart Faris bart.faris@state.nm.us</p>
505	<p>Kirtland Elementary School</p> <p>Dennis Fieldsted Maintenance & Construction Coordinator Central Consolidated School District No. 22 P.O. Box 1199 Shiprock, NM 87420</p>	Kirtland	San Juan	<p>Kirtland Elementary School, Dennis Fieldsted, Maintenance and Construction Coordinator, proposes to renew the Discharge Permit in order to complete closure of the synthetically lined domestic wastewater total evaporation impoundment and site restoration at the school. The facility is located at #30 County Road 6446, in Kirtland, in Section 6, T29N, R14W, San Juan County. Ground water beneath the site is at a depth of approximately 70 feet and has a total dissolved solids concentration of approximately 1,190 milligrams per liter.</p>	<p>Gerald Knutson gerald.knutson@state.nm.us</p>
168	<p>Lifeway Glorieta Conference Center</p>	Glorieta	Santa Fe	<p>Lifeway Glorieta Conference Center, John Hoogendoorn, Facility Manager, proposes to renew the Discharge Permit for the discharge of up to 400,000 gallons per day of domestic wastewater which is received and treated using a mechanical treatment plant. Treated wastewater is discharged to Glorieta Creek under a NPDES permit</p>	<p>Gerald Knutson gerald.knutson@state.nm.us</p>



	<p>John Hoogendoorn, Facility Manager Lifeway Christian Resources P.O. Box 8 Glorieta, NM 87535</p>			<p>and/or reused to irrigate approximately two acres of landscape at the treatment plant. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at the terminus of Cottonwood within the Center, approximately 0.3 miles northwest of the Community of Glorieta, in Section 27, T16N, R11E, Santa Fe County. Ground water beneath the site is at a depth of approximately 15 feet and has a total dissolved solids concentration of approximately 568 milligrams per liter.</p>	
835	<p>Elephant Butte Lake State Park–North Kay Dunlap Park Superintendent Elephant Butte Lake State Park P.O. Box 13 Elephant Butte, NM 87935</p>	Truth or Consequences	Sierra	<p>Elephant Butte Lake State Park–North, Kay Dunlap, Park Superintendent, proposes to renew the Discharge Permit for the combined discharge of up to 5,375 gallons per day of domestic wastewater, domestic septage & sludge and RV & marine dump station waste to a synthetically lined wetland treatment system; domestic wastewater to three septic tank/leachfield systems; and vault toilet waste and domestic septage to two concrete line evaporative impoundments. Potential contaminants associated with this type of discharge include nitrogen compounds. The disposal systems are located at the northern terminus of an access road off of Rock Canyon Road prior to Island Road and within the South Monticello Campground, approximately 6.5 and 12 miles northeast of Truth or Consequences, in Section 35, T12S, R04W and Section 6, T12S, R03W, Sierra County. Ground water most likely to be affected is at a depth of approximately 100 to 150 feet and has a total dissolved solids concentration of approximately 500 milligrams per liter.</p>	<p>Gerald Knutson gerald.knutson@state.nm.us</p>
975	<p>Town of Estancia Wastewater Treatment Plant Theodore Barela, Mayor Town of Estancia PO Box 166 Estancia, NM 87016</p>	Estancia	Torrance	<p>Town of Estancia Wastewater Treatment Plant, Theodore Barela, Mayor, proposes to renew the Discharge Permit for the discharge of up to 115,000 gallons per day (gpd) of domestic wastewater. Wastewater is received and treated using a synthetically-lined impoundment system consisting of two synthetically-lined aeration lagoons followed by three synthetically-lined holding lagoons. Following treatment, reclaimed wastewater is discharged by flood irrigation to 13.5-acre and 35-acre re-use areas of native grassland. A 20-acre sludge disposal area, located 1.5 miles southeast of the wastewater treatment plant has</p>	<p>Melissa Halick melissa.halick@state.nm.us</p>



				<p>ceased receiving sludge from the impoundment system. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located approximately 0.7 miles east of Estancia on County Road A047, in Section 12, Township 06 North, Range 09 East, Torrance County. Ground water most likely to be affected is at a depth of approximately 25 feet and has a total dissolved solids concentration of approximately 1,500 milligrams per liter.</p>	
--	--	--	--	--	--

Prior to ruling on any proposed Discharge Permit or its modification, the New Mexico Environment Department (NMED) will allow thirty days after the date of publication of this notice to receive written comments and during which time a public hearing may be requested by any interested person, including the applicant. Requests for public hearing shall be in writing and shall set forth the reasons why a hearing should be held. A hearing will be held if NMED determines that there is substantial public interest. Comments or requests for hearing should be submitted to the Ground Water Quality Bureau at PO Box 5469, Santa Fe, NM 87502-5469.

To view this and other public notices issued by the Ground Water Quality Bureau on-line, go to:
<http://www.nmenv.state.nm.us/gwb/NMED-GWQB-PublicNotice.htm>