GROUND WATER DISCHARGE PERMIT
Ski Apache, DP-1768

I. INTRODUCTION

The New Mexico Environment Department (NMED) issues this Discharge Permit (Discharge Permit), DP-1768, to the Mescalero Apache Tribe (permittee) pursuant to the New Mexico Water Quality Act (WQA), NMSA 1978 §§74-6-1 through 74-6-17, and the New Mexico Water Quality Control Commission (WQCC) Regulations, 20.6.2 NMAC.

NMED's purpose in issuing this Discharge Permit, and in imposing the requirements and conditions specified herein, is to control the discharge of water contaminants from Ski Apache (facility) into ground and surface water, so as to protect ground and surface water for present and potential future use as domestic and agricultural water supply and other uses and protect public health. In issuing this Discharge Permit, NMED has determined that the requirements of Subsection C of 20.6.2.3109 NMAC have been or will be met.

The activities which produce the discharge, the location of the discharge, and the quantity, quality and flow characteristics of the discharge are briefly described as follows:

Up to 30,000 gallons per day (gpd) of domestic wastewater is discharged to two 50,000 gallon holding tanks for temporary storage until being removed for offsite disposal at a appropriate facility. Domestic wastewater will also be discharged to four Clivus composting toilets located throughout the ski resort.

The discharge may contain water contaminants which exceed the standards of Section 20.6.2.3103 NMAC and/or may contain toxic pollutants as defined in Subsection WW of 20.6.2.7 NMAC. This Discharge Permit contains requirements intended to prevent the discharge from causing standards to be exceeded in ground water and/or the presence of toxic pollutants in ground water.

The facility is located at 1286 Ski Run Road, Alto, in Section 34, Township 10 South, Range 11 East (projected), Lincoln County. Ground water most likely to be affected is at a depth of approximately 15 feet and has a total dissolved solids concentration of approximately 488 milligrams per liter.

The application consists of the materials submitted by Justin Rowland, Director of Operations-Ski Apache on behalf of the Mescalero Apache Tribe dated September 20, 2010 and updated materials submitted by Allen Bolinger, P.E., Smith Engineering on October 1, 2012. The discharge plan consists of the application and materials contained in the administrative record prior to issuance of this Discharge Permit. The discharge as described in the discharge plan shall be managed in accordance with all conditions and requirements of this Discharge Permit.

Pursuant to Section 20.6.2.3109 NMAC, NMED reserves the right to require a Discharge Permit Modification in the event NMED determines that the requirements of 20.6.2 NMAC are being or may be violated or the standards of Section 20.6.2.3103 NMAC are being or may be violated. This may include a determination that structural controls and/or management practices approved under this Discharge Permit are not protective of ground water quality, and that more stringent

draft

requirements to protect ground water quality may be required by NMED. The permittee may be required to implement abatement of water pollution and remediate ground water quality.
Issuance of this Discharge Permit does not relieve the permittee of the responsibility to comply with the WQA, WQCC Regulations, and any other applicable federal, state and/or local laws and regulations, such as zoning requirements and nuisance ordinances.

The following acronyms and abbreviations may be used in this Discharge Permit:

Abbreviation	Explanation		Abbreviation	Explanation
CFR	Code of Federal Regulations		NMED	New Mexico Environment Department
EPA	United States Environmental Protection Agency		NMSA	New Mexico Statutes Annotated
gpd	gallons per day		TDS	total dissolved solids
mg/L	milligrams per liter		UPC	Uniform Plumbing Code
mL	milliliters		WQA	New Mexico Water Quality Act
NMAC	New Mexico Administrative Code		WQCC	Water Quality Control Commission

II. FINDINGS

In issuing this Discharge Permit, NMED finds:

1. The permittee is discharging effluent or leachate from the facility so that such effluent or leachate may move directly or indirectly into ground water within the meaning of Section 20.6.2.3104 NMAC.

2. The permittee is discharging effluent or leachate from the facility so that such effluent or leachate may move into ground water of the State of New Mexico which has an existing concentration of 10,000 mg/L or less of TDS within the meaning of Subsection A of 20.6.2.3101 NMAC.

3. The discharge from the facility is not subject to any of the exemptions of Section 20.6.2.3105 NMAC.

III. AUTHORIZATION TO DISCHARGE

The permittee is authorized to discharge up to 30,000 gpd of domestic wastewater to two 50,000 gallons holding tanks for temporary storage until pumped and disposed offsite at a licensed facility. The permittee is also authorized to discharge domestic wastewater to four Clivus composting toilets located within the ski resort. The systems consist of the following:

System Designation	**Capacity**	**Specifications**
Two (2) Fiberglass Holding Tanks	50,000 gallon	Xerxes storage tank, 12 foot diameter; single wall. Each tank equipped with two manhole access openings and level

draft

		(float) detecting alarms positioned at 8,000 gallons, 12,000 gallons and 20,000 gallons.
Four (4) Clivus Composting Toilets	Continuous composting	Model: Clivus Multrum M54 Trailhead. Consists of a 300 gallon liquid reservoir and a 10 ft^3 solids composting chamber. Clivus composting toilets are located throughout the ski resort.

[20.6.2.3104 NMAC, Subsection C of 20.6.2.3106 NMAC, Subsection C of 20.6.2.3109 NMAC]

IV. CONDITIONS

The conditions of this Discharge Permit shall be complied with by the permittee and are enforceable by NMED.

The permittee is authorized to discharge water contaminants subject to the following conditions:

A. OPERATIONAL PLAN

#	Terms and Conditions
1.	The permittee shall implement the following operational plan to ensure compliance with Title 20, Chapter 6, Parts 1 and 2 NMAC. [Subsection C of 20.6.2.3109 NMAC]
2.	The permittee shall operate in a manner such that standards and requirements of Sections 20.6.2.3101 and 20.6.2.3103 NMAC are not violated. [20.6.2.3101 NMAC, 20.6.2.3103 NMAC, Subsection C of 20.6.2.3109 NMAC]
3.	Within 30 days following the effective date of this Discharge Permit (**by DATE**), the permittee shall submit record drawings that bear the seal and signature of a licensed New Mexico professional engineer (pursuant to the New Mexico Engineering and Surveying Practice Act and the rules promulgated under that authority) for the constructed domestic wastewater storage system to NMED. [Subsections A and C 20.6.2.1202 NMAC, Subsection C of 20.6.2.3109 NMAC, NMSA 1978, §§ 61-23-1 through 61-23-32]
4.	The permittee shall maintain locking lids for each holding tank to control access by the general public and animals. Access controls shall be maintained throughout the term of this Discharge Permit. [Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]

draft

B. MONITORING AND REPORTING

#	Terms and Conditions
5.	The permittee shall conduct the following monitoring, reporting, and other requirements listed below in accordance with the monitoring requirements of this Discharge Permit. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
6.	METHODOLOGY – Unless otherwise approved in writing by NMED, the permittee shall conduct sampling and analysis in accordance with the most recent edition of the following documents: a) American Public Health Association, Standard Methods for the Examination of Water and Wastewater (18th, 19th or current) b) U.S. Environmental Protection Agency, Methods for Chemical Analysis of Water and Waste c) U.S. Geological Survey, Techniques for Water Resources Investigations of the U.S. Geological Survey d) American Society for Testing and Materials, Annual Book of ASTM Standards, Part 31. Water e) U.S. Geological Survey, et al., National Handbook of Recommended Methods for Water Data Acquisition f) Federal Register, latest methods published for monitoring pursuant to Resource Conservation and Recovery Act regulations g) Methods of Soil Analysis: Part 1. Physical and Mineralogical Methods; Part 2. Microbiological and Biochemical Properties; Part 3. Chemical Methods, American Society of Agronomy [Subsection B of 20.6.2.3107 NMAC]
7.	The permittee shall submit semi-annual monitoring reports to NMED for the most recently completed semi-annual period by the 1st of May and November each year. Semi-annual monitoring shall be performed during the following periods and submitted as follows: • October 1st through March 31st (first half) – **due by May 1st** • April 1st through September 30th (second half) – **due by November 1st** Monitoring requirements detailed in this Discharge Permit are summarized on the sheet titled *Cover Page for Discharge Permit Monitoring Reports*. The permittee shall complete and attach a copy of the enclosed *Cover Page for Discharge Permit Monitoring Reports* to each monitoring report submitted. NMED recommends that the permittee use the monitoring report form provided to compile and submit the monitoring data. The permittee shall provide copies of all laboratory reports with the monitoring reports. [Subsection A of 20.6.2.3107 NMAC]

draft

#	**Terms and Conditions**
8.	The permittee shall measure the totalized volume of wastewater discharged to the holding tanks each month using the Parshall flume equipped with an ultrasonic head sensing flow meter located on the influent line prior to the holding tanks. The totalized monthly discharge volumes for each month shall be submitted to NMED in the semi-annual monitoring reports. [Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]
9.	The permittee shall inspect the grease interceptor on a weekly basis during peak ski season operations and remove accumulated grease and settled solids to prevent them from exiting the unit. When not in ski season, the permittee shall inspect the grease interceptor on a quarterly basis. The permittee shall maintain a record of grease/solids removal and disposal, including date, volume of grease/solids removed, and method of disposal (e.g, contents removed/disposed by professional grease interceptor cleaner). The records of grease removal and disposal (e.g., cleaning invoices) shall be submitted to NMED in the semi-annual monitoring reports. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
10.	The permittee shall inspect the holding tanks on a weekly basis during peak ski season peak operations to ensure that the tanks do not overflow. When not in ski season, the permittee shall inspect the holding tanks on a quarterly basis. The contents of the tanks shall be pumped as needed by a licensed hauler. The permittee shall maintain a record of wastewater removal, including date and volume of wastewater removed. The records of wastewater removal (e.g., pumping invoices) shall be submitted to NMED in the semi-annual monitoring reports. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
11.	The permittee shall inspect each Clivus composting toilet on a monthly basis during ski season peak operations in accordance with the Clivus Multrum, Inc. maintenance specifications. When not in ski season, the permittee shall inspect each Clivus composting toilet on a quarterly basis. The permittee shall maintain a record of solids removal and disposal, including date, volume of solids removed, and method of disposal. The records of solids removal and disposal (e.g., pumping invoices) shall be submitted to NMED in the semi-annual monitoring reports. [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
12.	The permittee shall test each set of alarm floats equipped in each holding tank on a weekly basis during peak ski season operations to ensure that the alarms are functional and the tanks do not overflow. When not in ski season, the permittee shall test each set of alarm floats on a quarterly basis. The highest alarm float shall be positioned at 75% of full tank capacity. The permittee shall maintain a log and record all weekly alarm testings and maintain the log on site.

draft

#	Terms and Conditions
	[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]

C. CONTINGENCY PLAN

#	Terms and Conditions
13.	In the event that a ground water quality standard identified in Section 20.6.2.3103 NMAC is exceeded; the total nitrogen concentration in ground water is greater than 10 mg/L; or a toxic pollutant (defined in Subsection WW of 20.6.2.7 NMAC) is present in ground water during the term of this Discharge Permit, upon closure of the facility or during the implementation of post-closure requirements, the permittee shall propose measures to mitigate damage from the discharge including, at a minimum, source control measures and a completion schedule by submitting a corrective action plan to NMED for approval. The permittee may be required to abate water pollution pursuant to Sections 20.6.2.4000 through 20.6.2.4115 NMAC, should the corrective action plan not result in compliance with the standards and requirements set forth in Section 20.6.2.4103 NMAC within 180 days of confirmation of ground water contamination. [Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]
14.	In the event that a release (commonly known as a "spill") occurs that is not authorized under this Discharge Permit, the permittee shall take measures to mitigate damage from the unauthorized discharge and initiate the notifications and corrective actions required in Section 20.6.2.1203 NMAC and summarized below. Within <u>24 hours</u> following discovery of the unauthorized discharge, the permittee shall verbally notify NMED and provide the following information: a) The name, address, and telephone number of the person or persons in charge of the facility, as well as of the owner and/or operator of the facility. b) The name and address of the facility. c) The date, time, location, and duration of the unauthorized discharge. d) The source and cause of unauthorized discharge. e) A description of the unauthorized discharge, including its estimated chemical composition. f) The estimated volume of the unauthorized discharge. g) Any actions taken to mitigate immediate damage from the unauthorized discharge. These actions may include, as appropriate: • restriction of public access to the area; • immediate actions to stop/reduce the unauthorized discharge or impacts from it; • disinfection of contaminated soil and other materials; and • physical inspection of the treatment and disposal system(s) to identify additional failures. Within <u>one week</u> following discovery of the unauthorized discharge, the permittee shall

draft

#	Terms and Conditions
	submit written notification to NMED with the information listed above and any pertinent updates. Within 15 days following discovery of the unauthorized discharge, the permittee shall submit a corrective action report/plan to NMED describing any corrective actions taken and/or to be taken relative to the unauthorized discharge that includes the following: a) A description of proposed actions to mitigate damage from the unauthorized discharge. b) A description of proposed actions to prevent future unauthorized discharges of this nature. c) A schedule for completion of proposed actions. Nothing in this condition shall be construed as relieving the permittee of the obligation to comply with all requirements of Section 20.6.2.1203 NMAC. [20.6.2.1203 NMAC, Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]
15.	In the event that NMED or the permittee identifies any failures of the discharge plan or this Discharge Permit not specifically noted herein, NMED may require the permittee to submit a corrective action plan and a schedule for completion of corrective actions to address the failure(s). Additionally, NMED may require a Discharge Permit modification to achieve compliance with 20.6.2 NMAC. [Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]

D. CLOSURE PLAN

#	Terms and Conditions
16.	Within one year of the effective date of this Discharge Permit (**by date**), the permittee shall complete the following closure measures on the existing septic tank leachfield system at the facility: a) Remove all lines leading to and from the closed system(s) or permanently plug them and abandon them in place. b) Pump any remaining wastewater and solids from all closed septic tanks and dispose of the contents in accordance with all federal, state and local laws, rules and ordinances. c) Remove or demolish all closed septic tanks, grease trap/interceptors, lift stations, dosing chambers, distribution boxes or other system(s) components (with the exception of leachfields) and re-grade the area with suitable fill to blend with surface topography to promote positive drainage and prevent ponding. The permittee shall submit to NMED a Closure Plan report along with photographic documentation of closure measures performed within 30 days of completion.

draft

#	Terms and Conditions
	[Subsection A of 20.6.2.3107 NMAC, 40 CFR Part 503]
17.	In the event the facility, or a component of the facility, is proposed to be permanently closed, upon ceasing discharge, the permittee shall perform closure measures. Within 90 days of ceasing discharge to the wastewater holding tanks and Clivus composting toilets, the permittee shall complete the following closure measures: a) Plug all lines leading to each holding tank so that a discharge can no longer occur. b) Wastewater, septage, and grease interceptor waste shall be pumped from the system components (e.g., holding tanks, grease trap/interceptors, Clivus liquid reservoir and composting chamber) and it shall be contained, transported, and disposed of in accordance with all local, state, and federal regulations, including 40 CFR Part 503. The permittee shall maintain a record of all wastes transported for off-site disposal. Within 180 days of ceasing discharge to the wastewater holding tanks and Clivus composting toilets, the permittee shall complete the following closure measures: d) Remove all lines leading to and from the closed system(s) or permanently plug them and abandon them in place. e) Remove each Clivus composting toilet from the site(s) and re-grade the area with suitable fill to blend with surface topography to promote positive drainage and prevent ponding. f) Remove or demolish each holding tank and grease trap/interceptor and re-grade the area with suitable fill to blend with surface topography to promote positive drainage and prevent ponding. When all closure and post-closure requirements have been met, the permittee may submit a written request for termination of the Discharge Permit to NMED. [Subsection A of 20.6.2.3107 NMAC, 40 CFR Part 503]

E. GENERAL TERMS AND CONDITIONS

#	Terms and Conditions
18.	RECORD KEEPING – The permittee shall maintain a written record of the following information: a) Information and data used to complete the application for this Discharge Permit. b) Records of any releases (commonly known as "spills") not authorized under this Discharge Permit and reports submitted pursuant to 20.6.2.1203 NMAC. c) Records of the operation, maintenance, and repair of all facilities/equipment used to treat, store or dispose of wastewater. d) Facility record drawings (plans and specifications) showing the actual construction of the facility and bear the seal and signature of a licensed New Mexico professional engineer.

draft

#	Terms and Conditions
	e) Copies of monitoring reports completed and/or submitted to NMED pursuant to this Discharge Permit. f) The volume of wastewater or other wastes discharged pursuant to this Discharge Permit. g) Ground water quality and wastewater quality data collected pursuant to this Discharge Permit. h) Copies of construction records (well log) for all ground water monitoring wells required to be sampled pursuant to this Discharge Permit. i) Records of the maintenance, repair, replacement or calibration of any monitoring equipment or flow measurement devices required by this Discharge Permit. j) Data and information related to field measurements, sampling, and analysis conducted pursuant to this Discharge Permit. The following information shall be recorded and shall be made available to NMED upon request: i) The dates, location and times of sampling or field measurements; ii) The name and job title of the individuals who performed each sample collection or field measurement; iii) The sample analysis date of each sample; iv) The name and address of the laboratory, and the name of the signatory authority for the laboratory analysis; v) The analytical technique or method used to analyze each sample or collect each field measurement; vi) The results of each analysis or field measurement, including raw data; vii) The results of any split, spiked, duplicate or repeat sample; and viii) A copy of the laboratory analysis chain-of-custody as well as a description of the quality assurance and quality control procedures used. The written record shall be maintained by the permittee at a location accessible during a facility inspection by NMED for a period of at least five years from the date of application, report, collection or measurement and shall be made available to the department upon request. [Subsections A and D of 20.6.2.3107 NMAC]
19.	INSPECTION and ENTRY – The permittee shall allow inspection by NMED of the facility and its operations which are subject to this Discharge Permit and the WQCC regulations. NMED may upon presentation of proper credentials, enter at reasonable times upon or through any premises in which a water contaminant source is located or in which are located any records required to be maintained by regulations of the federal government or the WQCC. The permittee shall allow NMED to have access to and reproduce for their use any copy of the records, and to perform assessments, sampling or monitoring during an inspection for the purpose of evaluating compliance with this Discharge Permit and the WQCC regulations.

draft

#	**Terms and Conditions**
	Nothing in this Discharge Permit shall be construed as limiting in any way the inspection and entry authority of NMED under the WQA, the WQCC Regulations, or any other local, state or federal regulations. [Subsection D of 20.6.2.3107 NMAC, NMSA 1978, §§ 74-6-9.B and 74-6-9.E]
20.	DUTY to PROVIDE INFORMATION – The permittee shall, upon NMED's request, allow for NMED's inspection/duplication of records required by this Discharge Permit and/or furnish to NMED copies of such records. [Subsection D of 20.6.2.3107 NMAC]
21.	MODIFICATIONS and/or AMENDMENTS – In the event the permittee proposes a change to the facility or the facility's discharge that would result in a change in the volume discharged; the location of the discharge; or in the amount or character of water contaminants received, treated or discharged by the facility, the permittee shall notify NMED prior to implementing such changes. The permittee shall obtain approval (which may require modification of this Discharge Permit) by NMED prior to implementing such changes. [Subsection C of 20.6.2.3107 NMAC, Subsections E and G of 20.6.2.3109 NMAC]
22.	PLANS and SPECIFICATIONS – In the event the permittee is proposing to construct a wastewater system or change a process unit of an existing system such that the quantity or quality of the discharge will change substantially from that authorized by this Discharge Permit, the permittee shall submit construction plans and specifications to NMED for the proposed system or process unit prior to the commencement of construction. In the event the permittee implements changes to the wastewater system authorized by this Discharge Permit which result in only a minor effect on the character of the discharge, the permittee shall report such changes (including the submission of record drawings, where applicable) as of January 1 and June 30 of each year to NMED. [Subsections A and C of 20.6.2.1202 NMAC]
23.	CIVIL PENALTIES – Any violation of the requirements and conditions of this Discharge Permit, including any failure to allow NMED staff to enter and inspect records or facilities, or any refusal or failure to provide NMED with records or information, may subject the permittee to a civil enforcement action. Pursuant to WQA 74-6-10(A) and (B), such action may include a compliance order requiring compliance immediately or in a specified time, assessing a civil penalty, modifying or terminating the Discharge Permit, or any combination of the foregoing; or an action in district court seeking injunctive relief, civil penalties, or both. Pursuant to WQA 74-6-10(C) and 74-6-10.1, civil penalties of up to $15,000 per day of noncompliance may be assessed for each violation of the WQA 74-6-5, the WQCC Regulations, or this Discharge Permit, and civil penalties of up to $10,000 per day of noncompliance may be assessed for each violation of any other provision of the

draft

#	**Terms and Conditions**
	WQA, or any regulation, standard, or order adopted pursuant to such other provision. In any action to enforce this Discharge Permit, the permittee waives any objection to the admissibility as evidence of any data generated pursuant to this Discharge Permit. [20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10 and 74-6-10.1]
24.	CRIMINAL PENALTIES – No person shall: 1) make any false material statement, representation, certification or omission of material fact in an application, record, report, plan or other document filed, submitted or required to be maintained under the WQA; 2) falsify, tamper with or render inaccurate any monitoring device, method or record required to be maintained under the WQA; or 3) fail to monitor, sample or report as required by a permit issued pursuant to a state or federal law or regulation. Any person who knowingly violates or knowingly causes or allows another person to violate the requirements of this condition is guilty of a fourth degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who is convicted of a second or subsequent violation of the requirements of this condition is guilty of a third degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition or knowingly causes another person to violate the requirements of this condition and thereby causes a substantial adverse environmental impact is guilty of a third degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition and knows at the time of the violation that he is creating a substantial danger of death or serious bodily injury to any other person is guilty of a second degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. [20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10.2.A through 74-6-10.2.F]
25.	COMPLIANCE with OTHER LAWS – Nothing in this Discharge Permit shall be construed in any way as relieving the permittee of the obligation to comply with all applicable federal, state, and local laws, regulations, permits or orders. [NMSA 1978, § 74-6-5.L]
26.	RIGHT to APPEAL – The permittee may file a petition for review before the WQCC on this Discharge Permit. Such petition shall be in writing to the WQCC within thirty days of the receipt of postal notice of this Discharge Permit and shall include a statement of the issues to be raised and the relief sought. Unless a timely petition for review is made, the decision of NMED shall be final and not subject to judicial review. [20.6.2.3112 NMAC, NMSA 1978, § 74-6-5.O]
27.	TRANSFER of DISCHARGE PERMIT – Prior to the transfer of any ownership, control, or

draft

#	Terms and Conditions
	possession of this facility or any portion thereof, the permittee shall: 1) notify the proposed transferee in writing of the existence of this Discharge Permit; 2) include a copy of this Discharge Permit with the notice; and 3) deliver or send by certified mail to NMED a copy of the notification and proof that such notification has been received by the proposed transferee. Until both ownership and possession of the facility have been transferred to the transferee, the permittee shall continue to be responsible for any discharge from the facility. [20.6.2.3111 NMAC]
28.	PERMIT FEES – Payment of permit fees is due at the time of Discharge Permit approval. Permit fees shall be paid in a single payment or shall be paid in equal installments on a yearly basis over the term of the Discharge Permit. Single payments shall be remitted to NMED no later than 30 days after the Discharge Permit effective date. Initial installment payments shall be remitted to NMED no later than 30 days after the Discharge Permit effective date; subsequent installment payments shall be remitted to NMED no later than the anniversary of the Discharge Permit effective date. Permit fees are associated with <u>issuance</u> of this Discharge Permit. Nothing in this Discharge Permit shall be construed as relieving the permittee of the obligation to pay all permit fees assessed by NMED. A permittee that ceases discharging or does not commence discharging from the facility during the term of the Discharge Permit shall pay all permit fees assessed by NMED. An approved Discharge Permit shall be suspended or terminated if the facility fails to remit an installment payment by its due date. [Subsection F of 20.6.2.3114 NMAC, NMSA 1978, § 74-6-5.K]

V. PERMIT TERM & SIGNATURE

EFFECTIVE DATE: [effective date]

TERM ENDS: [date term ends]

[Subsection H of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.I]

draft

_____

JERRY SCHOEPPNER
Chief, Ground Water Quality Bureau
New Mexico Environment Department