



Notice is hereby given pursuant to 20.6.2.3108.H NMAC, the following Ground Water Discharge Permit applications have been proposed for approval. To request additional information or to obtain a copy of a draft permit, contact the Ground Water Quality Bureau in Santa Fe at (505) 827-2900. Draft permits may also be viewed on-line at <http://www.nmenv.state.nm.us/gwb/NMED-GWQB-PublicNotice.htm>

**NOTE – If viewing by WEB - Click on facility name to review a copy of the draft permit.**

DP #	Facility/Applicant	Closest City	County	Notice	NMED Permit Contact
819	<a href="#">County Services</a>  Garth Merrick, President County Services 101, SE 11 <sup>th</sup> Ave., Suite 200 Amarillo, TX 79101	Albuquerque	Bernalillo	County Services, Garth Merrick, President, proposes to renew the Discharge Permit for the discharge of up to 200 gallons per day of agricultural and domestic wastewater from an animal carcass processing station. Currently, County Services is discharging animal carcass processing wash-down water to a grease trap coupled with a 1,250-gallon underground holding tank. Domestic wastewater from a processing facility restroom is also discharged to the 1,250-gallon holding tank by a separate sewer line. Wastewater is pumped from the holding tank and is taken to the City of Albuquerque Southside Water Reclamation Plant by a licensed hauler for disposal. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at 4124 Broadway SE, Albuquerque, in Section 8, T9N, R3E, Bernalillo County. Ground water beneath the site is at a depth of approximately 205 feet and has a total dissolved solids concentration of approximately 192 milligrams per liter.	Sara Arthur
996	<a href="#">Sandia Peak Ski Area</a>  Benny Abruzzo President Sandia Peak Ski Co. 10 Tramway Loop, NE Albuquerque, NM 87122	Cedar Crest	Bernalillo	Sandia Peak Ski Area, Benny Abruzzo, President, proposes to renew the Discharge Permit for the discharge of up to 12,900 gallons per day of domestic wastewater to a synthetically-lined lagoon, equipped with a leak detection system, for disposal by evaporation. Domestic wastewater may also be stored temporarily in an 8,000-gallon aboveground, steel-constructed storage tank. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located in the Sandia Mountains, six and a half miles northwest of Cedar Crest on Highway 536, in Section 4, T11N, R5E, Bernalillo County. Ground water beneath the site is at a depth of	Melanie Sanchez



				approximately 380 feet and has a total dissolved solids concentration of approximately 362 milligrams per liter.	
760	<a href="#">Hagerman Wastewater Treatment Facility</a>  Cassius Mason Acting Public Works Director Town of Hagerman P.O. Box 247 Hagerman , NM 88232	Hagerman	Chaves	Hagerman Wastewater Treatment Facility, Cassius Mason, Acting Public Works Director, proposes to renew the Discharge Permit for the discharge of up to 65,000 gallons per day (gpd) of wastewater which is currently being discharged to a clay-lined lagoon system. NMED is proposing that the permittee be required to rehabilitate the existing system or construct a new wastewater treatment system <b>designed</b> to receive, treat and dispose of at least 130,000 gpd and close the existing system within three years. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at 700 Navajo Road, Hagerman, in Section 2, Township 14S, Range 26E, Chaves County. Ground water beneath the site is at a depth of approximately 19 feet and has a total dissolved solids concentration of approximately 1,000 milligrams per liter.	Jennifer Fullam
258	<a href="#">City of Artesia Wastewater Treatment Plant (WWTP)</a>  Robert E. Forrest Infrastructure Director City of Artesia 1702 N. Haldeman Rd. Artesia, NM 88210	Artesia	Eddy	City of Artesia Wastewater Treatment Plant (WWTP), Robert E. Forrest, Infrastructure Director, proposes to renew the Discharge Permit for the discharge of up to 3.0 million gallons per day (MGD) of reclaimed domestic wastewater from the City of Artesia WWTP. Treated and disinfected wastewater from the WWTP is discharged directly to the Pecos River pursuant to NPDES permit NM0022268. Reclaimed wastewater from the WWTP is used to irrigate City parks and athletic fields. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at 1702 N Haldeman Road, Artesia, in Sections 2, 7, and 8, T17S, R26E, and Sections 6 and 24, T17S, R25E, Eddy County. Ground water beneath the site is at a depth of approximately 9-11 feet and has a total dissolved solids concentration of approximately 2,000 milligrams per liter.	Naomi Davidson
1502	<a href="#">SKP Ranch RV Park</a>  Robert Jones, President SKP Co-Op Retreat of NM	Lakewood	Eddy	SKP Ranch RV Park, Robert Jones, President, proposes to renew the Discharge Permit for the discharge of up to 6,500 gallons per day of wastewater from an RV park to a synthetically lined lagoon for disposal by total evaporation. Potential contaminants associated with this type of	Naomi Davidson



	PO Box 109 Lakewood, NM 88254			discharge include nitrogen compounds. The facility is located at 30 SKP Ranch Road, Lakewood in Section 28, T19S, R26E, Eddy County. Ground water beneath the site is at a depth of approximately 36 feet and has a total dissolved solids concentration of approximately 2,700 milligrams per liter.	
455	<a href="#">Freeport-McMoRan, Tyrone Inc.</a>  Richard N. Mohr, General Manager Freeport-McMoRan Tyrone, Inc. P.O. Drawer 571 Tyrone, NM 88065	Silver City	Grant	Freeport-McMoRan, Tyrone Inc., Richard N. Mohr, General Manager, proposes to renew and modify the Discharge Permit, which presently covers the Gettysburg Pit and allows for the discharge of up to 11,088,000 gallons per day (gpd) of acid leach solution to the Nos. 6C and 7B Leach Stockpiles. The permit modification will combine these facilities with the 6B Leach Stockpile and Savannah Pit presently covered under DP-670 for a total discharge rate of 18,288,000 gpd. The facilities are located approximately 10 miles south of Silver City, New Mexico, in Sections 22, 23, 25, 26 and 27, T19S, R15W, Grant County, New Mexico. Depth to ground water in the area of the permitted discharge ranges from approximately 0 to 560 feet and has a total dissolved solids concentration of approximately 500 milligrams per liter.	Clint Marshall
206	<a href="#">Escalante Generating Station</a>  Barbara A. Walz Vice President Environmental Tri-State Generation & Transmission Association, Inc. P.O. Box 33695 Denver, CO 80233-0695	Prewitt	McKinley	Escalante Generating Station, Barbara A. Walz, Vice President Environmental, Tri-State Generation and Transmission Association, Inc., proposes to modify the Discharge Permit for the discharge of up to 1,457,550 gallons per day of domestic and industrial wastewater from a coal-combustion electric generating station into clay-lined and synthetically lined lagoons for disposal by evaporation. The facility disposes of solid coal-combustion wastes to an approximately 25 million cubic yard landfill. Potential contaminants associated with this type of discharge include nitrogen compounds, metals and organic compounds. The facility is located approximately 3 miles northwest of Prewitt, in Sections 25 and 26, Township 14N, Range 12W, McKinley County. Ground water beneath the site is at a depth of approximately 15 feet and has a total dissolved solids concentration of approximately 665 milligrams per liter.	Jennifer Fullam



1253	<a href="#">Cedar Cove Mobile Home and RV Park</a>  Steve Bell, Owner Steve Bell and Bell Brothers Revocable Trust P.O. Box 898 Elephant Butte, NM 87935	Elephant Butte	Sierra	Cedar Cove Mobile Home and RV Park, Steve Bell, Owner, proposes to renew and modify the Discharge Permit for the discharge of up to 15,050 gallons per day (gpd) of domestic wastewater from a mobile home and RV park to three septic tank/leachfield disposal systems. The modification includes increasing the wastewater discharge from 9,500 gpd to 15,050 gpd and the addition of a third septic tank/leachfield system. Potential contaminants associated with this type of discharge include nitrogen compounds. The facility is located at Highway 195 and Yapple Canyon Road, in Elephant Butte, in Section 10, T13S, R04W, Sierra County. Ground water beneath the site is at a depth of approximately 313 feet and has a total dissolved solids concentration of approximately 449 milligrams per liter.	Gerald Knutson
------	---	----------------	--------	--	----------------

Prior to ruling on any proposed Discharge Permit or its modification, the New Mexico Environment Department (NMED) will allow thirty days after the date of publication of this notice to receive written comments and during which time a public hearing may be requested by any interested person, including the applicant. Requests for public hearing shall be in writing and shall set forth the reasons why a hearing should be held. A hearing will be held if NMED determines that there is substantial public interest. Comments or requests for hearing should be submitted to the Ground Water Quality Bureau at PO Box 5469, Santa Fe, NM 87502-5469.

To view this and other public notices issued by the Ground Water Quality Bureau on-line, go to:  
<http://www.nmenv.state.nm.us/gwb/NMED-GWQB-PublicNotice.htm>