



NEW MEXICO
ENVIRONMENT DEPARTMENT

Ground Water Quality Bureau

1190 Saint Francis Drive / PO Box 5469

Santa Fe, NM 87502-5469

Phone (505) 827-2900 Fax (505) 827-2965

www.env.nm.gov



Draft: October 12, 2021

GROUND WATER QUALITY BUREAU
DISCHARGE PERMIT
Issued under 20.6.2 NMAC

Facility Name: Torrance County Detention Facility
Discharge Permit Number: DP-690
Facility Location: 209 Allen Ayers Boulevard
Estancia, NM 87016

County: Torrance

Permittee: CoreCivic of Tennessee, LLC
Mailing Address: PO Box 837
Estancia, NM 87016

Facility Contact: George Dedos Jimenez
Telephone Number/Email: 505-384-2711 / George.DedosJimenez@corecivic.com

Permitting Action: Renewal
Permit Issuance Date: DATE
Permit Expiration Date: DATE

NMED Permit Contact: Ron Sholdt, Geoscientist
Telephone Number/Email: 505-660-9662 / Ron.sholdt@state.nm.us

Justin D. Ball
Acting Chief, Ground Water Quality Bureau

TABLE OF CONTENTS

I. INTRODUCTION 1

II. FINDINGS..... 3

III. AUTHORIZATION TO DISCHARGE 3

IV. CONDITIONS 3

A. OPERATIONAL PLAN 3

 Operational Actions with Implementation Deadlines 4

 Operating Conditions 4

B. MONITORING AND REPORTING 7

 Due Dates for Monitoring Reports 8

 Monitoring Actions with Implementation Deadlines 8

 Groundwater Monitoring Conditions 8

 Facility Monitoring Conditions10

C. CONTINGENCY PLAN.....13

D. CLOSURE PLAN18

 Permanent Facility Closure Conditions18

E. GENERAL TERMS AND CONDITIONS.....20

ATTACHMENTS

- Discharge Permit Summary
- Groundwater Discharge Permit Guidance for Synthetically Lined Lagoons – Liner
Material and Site Preparation, Revision 0.0, May 2007
- Land Application Data Sheet (LADS)

I. INTRODUCTION

The New Mexico Environment Department (NMED) issues this groundwater discharge permit Renewal (Discharge Permit or DP-690) to CoreCivic of Tennessee, LLC (Permittee) pursuant to the New Mexico Water Quality Act (WQA), NMSA 1978 §§74-6-1 through 74-6-17, and the New Mexico Water Quality Control Commission (WQCC) Ground and Surface Water Protection Regulations, 20.6.2 NMAC.

NMED's purpose in issuing this Discharge Permit, and in imposing the requirements and conditions specified herein, is to control the discharge of water contaminants from Torrance County Detention Facility (Facility) in order to protect groundwater and those segments of surface water gaining from groundwater inflow for present and potential future use as domestic and agricultural water supply and other uses, and to protect public health. It is NMED's determination in issuing this Discharge Permit that the Permittee has met the requirements of Subsection C of 20.6.2.3109 NMAC. The Permittee is responsible for complying with the terms and conditions of this Discharge Permit pursuant to Section 20.6.2.3104 NMAC; failure to do so may result in enforcement action by NMED (20.6.2.1220 NMAC).

Described below are the activities that produce the discharge, the location of the discharge, and the quantity, quality and flow characteristics.

A synthetically lined facultative impoundment system receives and treats up to 150,000 gallons per day (gpd) of domestic wastewater. Treated wastewater discharges via flood irrigation to a 125-acre surface disposal area adjacent to the impoundment on an as-needed basis.

The discharge may contain water contaminants or toxic pollutants elevated above the standards of Section 20.6.2.3103 NMAC and is not subject to the exemption at Subsection 20.6.2.3105.A NMAC.

The Facility is located at 209 Allen Ayers Boulevard, approximately 1.5 miles east of Estancia, in Section 8, Township 06N, Range 09E, Torrance County. A discharge at the Facility is most likely to affect groundwater at a depth of approximately 34 feet, which had a pre-discharge total dissolved solids (TDS) concentration of approximately 1,300 milligrams per liter.

NMED issued the original Discharge Permit to the Permittee on August 25, 1990, and subsequently renewed the Permit on December 8, 1995, renewed and modified the Permit on March 5, 2001, renewed and modified the Permit on May 4, 2007, amended the Permit on February 8, 2008, and renewed and modified the Permit on August 15, 2016. The application (i.e., discharge plan) associated with this Discharge Permit consists of the materials submitted by George Dedos Jimenez on behalf of the Permittee dated March 17, 2021, and materials contained in the administrative record prior to issuance of this Discharge Permit.

The Permittee shall manage the discharge in accordance with all conditions and requirements of this Discharge Permit.

NMED reserves the right to require a Discharge Permit modification in the event NMED determines that the Permittee is or may be violating, or is likely to violate in the future, the requirements of 20.6.2 NMAC or the standards of Section 20.6.2.3103 NMAC. NMED reserves this right pursuant to Section 20.6.2.3109 NMAC. An NMED requirement to modify the Discharge Permit may result from a determination by the department that structural controls and/or management practices approved under this Discharge Permit are insufficiently protective of groundwater quality and human health. NMED reserves the right to require the Permittee implement abatement of water pollution and remediate groundwater quality.

NMED issuance of this Discharge Permit does not relieve the Permittee of the responsibility to comply with the WQA, WQCC Regulations, and any other applicable federal, state and/or local laws and regulations, such as zoning requirements and nuisance ordinances.

This Discharge Permit may use the following acronyms and abbreviations.

| Abbreviation | Explanation | Abbreviation | Explanation |
|------------------|---|--------------------|-----------------------------------|
| BOD ₅ | biochemical oxygen demand (5-day) | NMED | New Mexico Environment Department |
| CAP | Corrective Action Plan | NMSA | New Mexico Statutes Annotated |
| CFR | Code of Federal Regulations | NO ₃ -N | nitrate-nitrogen |
| CFU | colony forming unit | NTU | nephelometric turbidity units |
| Cl | chloride | QA/QC | Quality Assurance/Quality Control |
| EPA | United States Environmental Protection Agency | TDS | total dissolved solids |
| gpd | gallons per day | TKN | total Kjeldahl nitrogen |
| LAA | land application area | total nitrogen | = TKN + NO ₃ -N |
| LADS | Land Application Data Sheet(s) | TRC | total residual chlorine |
| mg/L | milligrams per liter | TSS | total suspended solids |
| mL | milliliters | WQA | New Mexico Water Quality Act |
| MPN | most probable number | WQCC | Water Quality Control Commission |
| NMAC | New Mexico Administrative Code | WWTF | Wastewater Treatment Facility |

II. FINDINGS

In issuing this Discharge Permit, NMED finds the following.

1. The Permittee is discharging effluent or leachate from the Facility so that such effluent or leachate may move into groundwater of the State of New Mexico that has an existing concentration of 10,000 mg/L or less of TDS, within the meaning of Subsection A of 20.6.2.3101 NMAC, without exceeding standards of 20.6.2.3103 NMAC for any water contaminant.
2. The Permittee is discharging effluent or leachate from the Facility directly or indirectly into groundwater pursuant to this Discharge Permit and Sections 20.6.2.3000 through 20.6.2.3114 NMAC.
3. The discharge from the Facility is not subject to any of the exemptions of Section 20.6.2.3105 NMAC.

III. AUTHORIZATION TO DISCHARGE

The Permittee is responsible for ensuring that discharges authorized by this Discharge Permit are consistent with the terms and conditions herein pursuant to 20.6.2.3104 NMAC.

This Discharge Permit authorizes the Permittee to receive and treat up to 150,000 gpd of domestic wastewater using a synthetically lined facultative impoundment. This Discharge Permit authorizes the Permittee to discharge treated wastewater to a 125-acre land application area on an as-needed basis.

[20.6.2.3104 NMAC, Subsection C of 20.6.2.3106 NMAC, Subsection D of 20.6.2.3109 NMAC]

IV. CONDITIONS

NMED issues this Discharge Permit for the discharge of water contaminants subject to the following conditions.

A. OPERATIONAL PLAN

| # | Terms and Conditions |
|----|---|
| 1. | The Permittee shall implement the following operational plan to ensure compliance with Title 20, Chapter 6, Parts 2 and 4 NMAC. [Subsection C of 20.6.2.3109 NMAC] |

| # | Terms and Conditions |
|----|---|
| 2. | <p>The Permittee shall operate in a manner that does not violate standards and requirements of Sections 20.6.2.3101 and 20.6.2.3103 NMAC.</p> <p>[20.6.2.3101 NMAC, 20.6.2.3103 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |

Operational Actions with Implementation Deadlines

| # | Terms and Conditions |
|----|---|
| 3. | <p>Within 60 days following the issuance date of this Discharge Permit (by DATE), the Permittee shall measure the thickness of the settled solids in the northwest quarter of the synthetically lined impoundment, which was constructed with a base 7 feet lower than the larger impoundment. The Permittee shall report the results of the solids thickness measurements to NMED in the next required periodic monitoring report.</p> <p>The Permittee shall measure the thickness of settled solids in accordance with the following procedure.</p> <ul style="list-style-type: none"> a) The division of the total surface area of the treatment impoundment into nine equal sub-areas. b) One measurement (to the nearest half foot) using a settled solids measurement device (e.g., core sampler) per sub-area. c) Calculation of the average of the nine measurements. <p>In the event that the measured settled solids exceed one-third of the maximum liquid depth in the impoundment, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |

Operating Conditions

| # | Terms and Conditions | | | | |
|----------------|---|------|---------|----------------|------------------|
| 4. | <p>The Permittee shall ensure that any wastewater discharged from the synthetically lined impoundment does not exceed the following discharge limits.</p> <table border="1" style="margin-left: 40px;"> <thead> <tr> <th>Test</th> <th>Maximum</th> </tr> </thead> <tbody> <tr> <td>Fecal coliform</td> <td>5,000 CFU/100 mL</td> </tr> </tbody> </table> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p> | Test | Maximum | Fecal coliform | 5,000 CFU/100 mL |
| Test | Maximum | | | | |
| Fecal coliform | 5,000 CFU/100 mL | | | | |

| # | Terms and Conditions |
|----|---|
| 5. | <p>The Permittee shall discharge treated wastewater to the surface disposal area such that the amount of total nitrogen discharged does not exceed 200 pounds per acre in any 12-month period. The Permittee shall not adjust nitrogen content to account for volatilization or mineralization processes. The Permittee shall distribute wastewater evenly throughout the entire disposal area.</p> <p>[Subsection C of 20.6.2.3109 NMAC]</p> |
| 6. | <p>The Permittee shall maintain 18 to 24-inch berms around the surface disposal area to prevent surface water run-on and run-off. The Permittee shall inspect the berms on a monthly basis and after any major precipitation event and repaired as necessary.</p> <p>The Permittee shall keep a log of the inspections that includes a date of the inspection, any findings and repairs, and the name of the person responsible for the inspection. The Permittee shall make the log available to NMED upon request.</p> <p>[Subsection C of 20.6.2.3109 NMAC]</p> |
| 7. | <p>The Permittee shall maintain fences around the Facility and disposal area to restrict access by the general public and animals. The fences shall consist of a minimum of six-foot chain link or field fencing and locking gates. The Permittee shall maintain the fences to serve the stated purpose throughout the term of this Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p> |
| 8. | <p>The Permittee shall install and maintain signs indicating that the wastewater at the Facility and disposal area is not potable. The Permittee shall post signs at the Facility entrance and other areas where there is potential for public contact with wastewater. The Permittee shall print signs in English and Spanish and shall ensure the signs remain visible and legible for the term of this Discharge Permit.</p> <p>[Subsections B and C of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p> |
| 9. | <p>The Permittee shall maintain the impoundment liner to avoid conditions that could affect the structural integrity of the liner or the impoundment. Characterization of such conditions may include the following:</p> <ul style="list-style-type: none">• erosion damage;• animal burrows or other damage;• the presence of vegetation including aquatic plants, weeds, woody shrubs or trees growing within five feet of the top inside edge of a sub-grade impoundment, within five feet of the toe of the outside berm of an above-grade impoundment, or within the impoundment itself; |

| # | Terms and Conditions |
|-----|--|
| | <ul style="list-style-type: none">• the presence of large debris or large quantities of debris in the impoundment;• evidence of seepage; or• evidence of berm subsidence. <p>The Permittee shall routinely control vegetation growing around the impoundment by mechanical removal that is protective of the impoundment liner.</p> <p>The Permittee shall visually inspect the impoundment and surrounding berms on a monthly basis to ensure proper maintenance. In the event that inspection reveals any evidence of damage that threatens the structural integrity of an impoundment berm or liner, or that may result in an unauthorized discharge, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p> <p>The Permittee shall create and maintain a log of all impoundment inspections which describes the date of the inspection, any findings and repairs and the name of the person responsible for the inspection. The Permittee shall make the log available to NMED upon request.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |
| 10. | <p>The Permittee shall preserve a minimum of two feet of freeboard, i.e., the liquid level in the impoundment and the elevation of the lowest-most top of the impoundment liner.</p> <p>In the event that the Permittee determines that it cannot preserve two feet of freeboard in the impoundment, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |
| 11. | <p>The Permittee shall visually inspect the surface disposal area semi-annually to ensure proper maintenance. The Permittee shall correct any conditions that indicate damage to the disposal system. The Permittee shall ensure conditions corrected include erosion damage, animal activity/damage, evidence of seepage, or any other condition indicating damage.</p> <p>The Permittee shall keep a log of the inspections that includes a date of the inspection, any findings and repairs, and the name of the inspector. The Permittee shall make the log available to NMED upon request.</p> <p>In the event of a failure of the disposal system, the Permittee shall implement the Contingency Plan set forth in this Discharge Permit.</p> |

| # | Terms and Conditions |
|-----|--|
| | [Subsections A and D of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC] |
| 12. | <p>The Permittee shall inspect the grease interceptor on a monthly basis and remove accumulated grease and settled solids as needed to prevent them from exiting the unit.</p> <p>The Permittee shall create and maintain a log of all grease interceptor inspections which describes all findings, repairs, removals, the date of the inspection, and the name of the person responsible for the inspection. The Permittee shall make the log available to NMED upon request.</p> <p>The Permittee shall maintain a record of grease/solids removal and disposal, including date, volume of grease/solids removed, disposal method and disposal location.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |
| 13. | <p>The Permittee shall inspect and clean the lift station(s) as needed to prevent pump failure.</p> <p>The Permittee shall maintain a record of lift station inspections, repairs, and cleanings. The Permittee shall make the record available to NMED upon request.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |
| 14. | <p>The Permittee shall utilize operators, certified by the State of New Mexico at the appropriate level pursuant to 20.7.4 NMAC, to operate the wastewater collection, treatment and disposal systems. A certified operator or a direct supervisee of a certified operator shall perform the operations and maintenance of all or any part of the wastewater system.</p> <p>The Permittee shall notify the NMED within 24 hours if at any time the Permittee no longer has a certified operator maintaining the system.</p> <p>[Subsection C of 20.6.2.3109 NMAC, 20.7.4 NMAC]</p> |

B. MONITORING AND REPORTING

| # | Terms and Conditions |
|-----|---|
| 15. | The Permittee shall conduct the monitoring, reporting, and other requirements listed below in accordance with the monitoring requirements of this Discharge Permit. |

| # | Terms and Conditions |
|-----|--|
| | [Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC] |
| 16. | METHODOLOGY – Unless otherwise specified by this Discharge Permit, or approved in writing by NMED, the Permittee shall use sampling and analytical techniques that conform with the references listed in Subsection B of 20.6.2.3107 NMAC. [Subsection B of 20.6.2.3107 NMAC] |

Due Dates for Monitoring Reports

| | |
|-----|---|
| 17. | <p>Quarterly monitoring - The Permittee shall perform monitoring and other Permit required actions during the following periods and shall submit quarterly reports to NMED by the following due dates:</p> <ul style="list-style-type: none"> • January 1st through March 31st – due by May 1st; • April 1st through June 30th – due by August 1st; • July 1st through September 30th – due by November 1st; and • October 1st through December 31st – due by February 1st. <p>[Subsection A of 20.6.2.3107 NMAC]</p> |
|-----|---|

Monitoring Actions with Implementation Deadlines

| # | Terms and Conditions |
|-----|---|
| 18. | <p>Prior to any discharge from the synthetically lined impoundment to the surface disposal area, the Permittee shall install the following flow meter.</p> <p>a) One hours recorder installed between the Facility’s impoundment and surface disposal area to estimate the volume of treated wastewater discharged.</p> <p>The Permittee shall submit confirmation of meter installation, type, calibration, and location prior to discharging from the Facility.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |

Groundwater Monitoring Conditions

| # | Terms and Conditions |
|-----|---|
| 19. | The Permittee shall perform quarterly groundwater sampling in the following groundwater monitoring wells and analyze the samples for TKN, NO ₃ -N, TDS and Cl. |

| # | Terms and Conditions |
|-----|--|
| | <p>a) MW-1A, located hydrologically downgradient of decommissioned Lagoon #1. b) MW-2A, located hydrologically downgradient of Lagoon #2. c) MW-3A, located hydrologically upgradient of Lagoon #2. d) MW-5, located hydrologically upgradient of Lagoon #2 and the surface disposal area. e) MW-6, located hydrologically cross-gradient to downgradient of the surface disposal area.</p> <p>The Permittee shall perform groundwater sample collection, preservation, transport and analysis according to the following procedures.</p> <p>a) Measure the depth-to-most-shallow groundwater from the top of the well casing to the nearest one-hundredth of a foot. b) Purge three well volumes of water from the well prior to sample collection. c) Obtain samples from the well for analysis. d) Properly prepare, preserve, and transport samples. e) Analyze samples in accordance with the methods authorized in this Discharge Permit.</p> <p>The Permittee shall submit the depth-to-most-shallow groundwater measurements and the laboratory analytical data results including the laboratory QA/QC summary report for each well, and a Facility layout map showing the location and number of each well to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p> |
| 20. | <p>The Permittee shall develop a groundwater elevation contour map, i.e., potentiometric surface map, on a quarterly basis using the top of casing elevation data from the monitoring well survey and the most recent depth-to-most-shallow groundwater measurements, referenced to mean sea level, obtained during the groundwater sampling required by this Discharge Permit.</p> <p>The groundwater elevation contour map shall depict the groundwater flow direction based on the groundwater elevation contours. The Permittee shall estimate groundwater elevations between monitoring well locations using common interpolation methods. The Permittee shall use a contour interval appropriate to the data but shall not be greater than two feet. Groundwater elevation contour maps shall use arrows to depict the groundwater flow direction based on the orientation of the groundwater elevation contours and shall locate and identify each monitoring well and contaminant source.</p> <p>The Permittee shall submit to NMED a groundwater elevation contour map in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p> |

| # | Terms and Conditions |
|-----|---|
| 21. | <p>NMED shall have the option to perform downhole inspections of all groundwater monitoring wells identified in this Discharge Permit. NMED shall establish the inspection date and provide at least a 60-day notice to the Permittee by certified mail. The Permittee shall remove any existing dedicated pumps at least 48 hours prior to NMED inspection to allow adequate settling time of sediment agitated from pump removal.</p> <p>Should the Permittee decide to install a pump in a monitoring well without a dedicated pump, the Permittee shall notify NMED at least 90 days prior to pump installation so that NMED can schedule a downhole well inspection(s) prior to pump placement.</p> <p>[Subsections A and D of 20.6.2.3107 NMAC]</p> |

Facility Monitoring Conditions

| # | Terms and Conditions |
|-----|---|
| 22. | <p>During any month that the discharge of wastewater occurs to the surface disposal area, the Permittee shall perform the following analyses on the wastewater samples collected at the point of discharge using the following sampling method and frequency:</p> <ul style="list-style-type: none"> • Fecal coliform or E. coli bacteria: grab sample at peak daily flow once per month; • Total Nitrogen (TKN + NO₃-N): grab sample at peak daily flow once per month. <p>The Permittee shall ensure the samples are properly prepared, preserved, transported, and analyzed in accordance with the methods authorized in this Discharge Permit. The Permittee shall submit the laboratory analytical data results, including the QA/QC summary and Chain of Custody to NMED in the subsequent quarterly monitoring report.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections B, C and H of 20.6.2.3109 NMAC, NMSA 1978, § 74-6-5.D]</p> |
| 23. | <p>The Permittee shall measure the total monthly volume, calculate the daily average volume, and record the daily peak volume of wastewater received by the treatment facility each month using the totalizing flow meters located at the east and west lift stations. The Permittee shall submit the totalized influent volumes for each month to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p> |
| 24. | <p>The Permittee shall, on a monthly basis, measure the volume of wastewater discharged from the synthetically lined impoundment to the surface disposal area.</p> |

| # | Terms and Conditions |
|-----|--|
| | <p>To determine the discharge volume, the Permittee shall obtain readings from a totalizing flow meter located between the impoundment and surface disposal area and calculate the monthly and average daily discharge volume. The Permittee shall use the monthly volume discharged on the LADS (copy enclosed) to calculate nitrogen loading.</p> <p>The Permittee shall submit the monthly meter readings, calculated monthly discharge volumes, and average daily discharge volumes to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p> |
| 25. | <p>All flow meters shall be capable of having their accuracy verified under working (i.e., real-time in-the-field) conditions. The Permittee shall develop a field verification method for each flow meter and shall utilize that method to check the accuracy of each respective meter. The Permittee shall perform field calibrations, at a minimum, on an annual basis. The Permittee shall also perform field calibrations upon repair or replacement of a flow measurement device.</p> <p>The Permittee shall calibrate each flow meter to its manufacturer's recommended specification which shall be no less accurate than plus or minus 10 percent of actual flow, as measured under field conditions. An individual knowledgeable in flow measurement shall perform field calibration and the installation/operation of the device in use. The Permittee shall prepare a flow meter calibration report for each flow measurement device calibration event. The flow meter calibration report shall include the following information.</p> <ol style="list-style-type: none">a) The location and meter identification.b) The method of flow meter field calibration employed.c) The measured accuracy of each flow meter prior to adjustment indicating the positive or negative offset as a percentage of actual flow as determined by an in-field calibration check.d) The measured accuracy of each flow meter following adjustment, if necessary, indicating the positive or negative offset as a percentage of actual flow of the meter.e) Any flow meter repairs made during the previous year or during field calibration.f) The name of the individual performing the calibration and the date of the calibration. <p>The Permittee shall maintain records of flow meter calibration(s) at a location accessible for review by NMED during Facility inspections.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p> |

| # | Terms and Conditions |
|-----|--|
| 26. | <p>The Permittee shall visually inspect flow meters on a monthly basis for evidence of malfunction. The Permittee shall maintain a log of the inspections that includes a date of the inspection, findings and repairs, and the name of the inspector. The Permittee shall make the log available to NMED upon request.</p> <p>If a visual inspection indicates a flow meter is not functioning as required by this Discharge Permit, the Permittee shall repair or replace the meter within 30 days of discovery. For <i>repaired</i> meters, the Permittee shall submit a report to NMED with the next monitoring report following the repair that includes a description of the malfunction; a statement verifying the repair; and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit. For <i>replacement</i> meters, the Permittee shall submit a report to NMED with the next monitoring report following the replacement that includes a design schematic for the device and a flow meter field calibration report completed in accordance with the requirements of this Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |
| 27. | <p>The Permittee shall collect samples of wastewater from synthetically lined impoundment on a quarterly basis and analyze the samples for:</p> <ul style="list-style-type: none">• TKN;• NO₃-N;• TDS; and• Cl. <p>The Permittee shall ensure the samples are properly prepared, preserved, transported and analyzed in accordance with the methods authorized in this Discharge Permit. The Permittee shall submit the laboratory analytical data results, including the QA/QC summary and Chain of Custody, to NMED in the subsequent quarterly monitoring report.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsections C and H of 20.6.2.3109 NMAC]</p> |
| 28. | <p>The Permittee shall complete the LADS (copy enclosed) on a monthly basis to document the amount of nitrogen applied to the surface disposal area during the most recent 12 months. The LADS shall reflect the total nitrogen concentration from the most recent wastewater analysis and the estimated discharge volumes to the surface disposal area for each month. The Permittee shall complete the LADS with the information above or include a statement that application of wastewater did not occur. The Permittee shall submit the LADS to NMED in the subsequent quarterly monitoring report.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |

| # | Terms and Conditions |
|-----|--|
| 29. | <p>The Permittee shall submit all records of solids and grease removal and disposal to NMED in the quarterly monitoring reports.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p> |

C. CONTINGENCY PLAN

| # | Terms and Conditions |
|-----|--|
| 30. | <p>In the event that groundwater monitoring indicates that groundwater exceeds a standard identified in Section 20.6.2.3103 NMAC in a monitoring well with no previous exceedances of the chemical constituent at the date of issuance of this Discharge Permit, the Permittee shall collect a confirmatory sample from the monitoring well within 15 days of receipt of the initial sampling results to confirm the initial sampling results.</p> <p>Within 60 days of confirmation of groundwater contamination, the Permittee shall submit to NMED a Corrective Action Plan (CAP) that proposes, at a minimum, contaminant source control measures and an implementation schedule. The Permittee shall implement the CAP as approved by NMED.</p> <p>Once this groundwater exceedance response condition is invoked whether during the term of this Discharge Permit or after the term of this Discharge Permit and prior to the completion of the Discharge Permit closure plan requirements, this condition shall apply until the Permittee has fulfilled the requirements of this condition and groundwater monitoring confirms for a minimum of eight (8) consecutive quarterly samples that groundwater does not exceed the standards of Section 20.6.2.3103 NMAC.</p> <p>Violation of the groundwater standard beyond 180 days after the confirmation of groundwater contamination may cause NMED to require the Permittee to abate water pollution consistent with the requirements and provisions of Section 20.6.2.4101, Section 20.6.2.4103, Subsections C and E of 20.6.2.4106, Section 20.6.2.4107, Section 20.6.2.4108 and Section 20.6.2.4112 NMAC.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]</p> |
| 31. | <p>In the event that information available to NMED indicates that a well is not constructed in a manner consistent with the attached Monitoring Well Guidance; contains insufficient water to effectively monitor groundwater quality; or is otherwise not completed in a manner that is protective of groundwater quality, the Permittee shall install a replacement well(s) within 120 days following notification from NMED.</p> |

| # | Terms and Conditions |
|-----|---|
| | <p>The Permittee shall install replacement wells at locations approved by NMED prior to installation and shall complete replacement wells in accordance with the Monitoring Well Guidance. The Permittee shall survey the replacement monitoring well(s) within 30 days following well completion. The Permittee shall submit well construction and lithologic logs along with survey data and a groundwater elevation contour map to NMED within 60 days following well completion.</p> <p>The Permittee shall properly plug and abandon a monitoring well requiring replacement upon completion of the replacement monitoring well. The Permittee shall complete the well plugging and abandonment, and shall document the abandonment procedures, in accordance with the Monitoring Well Guidance and all applicable local, state, and federal regulations. The Permittee shall submit a copy of the well abandonment documentation to NMED within 60 days following the replacement well completion.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p> |
| 32. | <p>In the event that groundwater flow information obtained pursuant to this Discharge Permit indicates that a monitoring well is not appropriately located, e.g., hydrologically downgradient of the discharge location it is intended to monitor, the Permittee shall install a replacement well within 120 days following notification from NMED. The Permittee shall survey the replacement monitoring well within 30 days following well completion.</p> <p>The Permittee shall install replacement wells at locations approved by NMED prior to installation and shall complete replacement wells in accordance with the attached Monitoring Well Guidance. The Permittee shall submit construction and lithologic logs, survey data and a groundwater elevation contour map within 60 days following well completion.</p> <p>The Permittee shall properly plug and abandon a monitoring well requiring replacement upon completion of the replacement monitoring well. The Permittee shall complete the well plugging and abandonment, and shall document the abandonment procedures, in accordance with the Monitoring Well Guidance and all applicable local, state, and federal regulations. The Permittee shall submit a copy of the well abandonment documentation to NMED within 60 days following the replacement well completion.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p> |
| 33. | <p>In the event that analytical results of a wastewater discharge sample indicate an exceedance of the maximum discharge limit for fecal coliform as set by this Discharge Permit, the Permittee shall collect and submit for analysis a second sample within 24</p> |

| # | Terms and Conditions |
|-----|---|
| | <p>hours after becoming aware of the exceedance. In the event the second sample results confirm the exceedance of the maximum discharge limits, the Permittee shall implement the Contingency Plan below.</p> <p><u>Contingency Plan</u></p> <ul style="list-style-type: none">a) Within 48 hours of becoming aware of a confirmed exceedance (as identified above), the Permittee shall:<ul style="list-style-type: none">i) notify NMED that the Permittee is implementing the Contingency Plan; andii) submit copies of the recent analytical results indicating an exceedance to NMED.b) The Permittee shall examine the operation and maintenance log, required by the Record Keeping conditions of this Discharge Permit, for improper operational procedures.c) The Permittee shall conduct a physical inspection of the treatment system to detect abnormalities. The Permittee shall correct any abnormalities discovered. The Permittee shall submit a report detailing the corrections made to NMED within 30 days following correction. <p>If a Facility is required to implement the Contingency Plan more than two times in a 12-month period, the Permittee shall propose to modify operational procedures and/or upgrade the treatment process to achieve consistent compliance with the maximum and 30-day average discharge limits by submitting a Corrective Action Plan (CAP) for NMED approval. The CAP shall include a schedule for completion of corrective actions and submitted within 60 days following receipt of the analytical results confirming the exceedance. The Permittee shall initiate implementation of the CAP following approval by NMED. NMED may require, prior to recommencing discharge to the reuse area, additional sampling of any stored reclaimed domestic wastewater in response to the submitted CAP.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |
| 34. | <p>In the event that the LADS (copy enclosed) show that the amount of nitrogen in wastewater applied in any 12-month period exceeds 200 pounds per acre, the Permittee shall propose the reduction of nitrogen loading to the surface disposal area by submitting a Corrective Action Plan (CAP) to NMED for approval. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions and submit the CAP within 90 days following the end of the monitoring period in which the exceedance occurred. The Permittee shall implement the CAP following approval by NMED.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |

| # | Terms and Conditions |
|-----|---|
| 35. | <p>In the event that an inspection reveals significant damage has occurred or is likely to affect the structural integrity of an impoundment or liner or their ability to contain contaminants, the Permittee shall propose the repair or replacement by submitting a CAP to NMED for approval. The Permittee shall submit the CAP to NMED within 30 days after discovery of the damage or following notification from NMED that significant damage is evident. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall initiate implementation of the CAP following approval by NMED.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |
| 36. | <p>In the event that an impoundment cannot preserve a minimum of two feet of freeboard, the Permittee shall take actions to restore the required freeboard as authorized by this Discharge Permit and all applicable local, state, and federal regulations.</p> <p>In the event that two feet of freeboard cannot be restored within a period of 72 hours following discovery, the Permittee shall propose actions to restore two feet of freeboard by submitting a short-term Corrective Action Plan (CAP) to NMED for approval. Examples of short-term corrective actions include the pumping and hauling of excess wastewater from the impoundment or reducing the volume of wastewater discharged to the impoundment. The Permittee shall ensure the CAP includes a schedule for completion of corrective actions. The Permittee shall submit the CAP within 15 days following the date the Permittee or the NMED discover the exceedance. The Permittee shall implement the CAP following NMED approval.</p> <p>In the event that the short-term corrective actions fail to restore two feet of freeboard, the Permittee shall submit to NMED a proposal for permanent corrective actions in a long-term CAP. The Permittee shall submit the long-term CAP within 90 days following failure of the short-term CAP. Examples corrective actions include the installation of an additional storage impoundment or a significant and permanent reduction in the volume of wastewater discharged to the impoundment. The Permittee shall ensure the long-term CAP includes a schedule for completion of corrective actions. The Permittee shall implement the CAP following NMED approval.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p> |
| 37. | <p>In the event the average solids accumulation exceeds one-third of the maximum liquid depth in the impoundments, the Permittee shall propose a plan for the removal and disposal of the solids. The Permittee shall submit the solids removal and disposal plan to NMED for approval within 120 days following discovery and includes the following information.</p> |

| # | Terms and Conditions |
|-----|---|
| | <p>a) A method for removal of the solids to a depth of less than six inches throughout the treatment impoundment in a manner that is protective of the impoundment liner.</p> <p>b) A description of how the Permittee will contain, transport, and dispose of the solids in accordance with all local, state, and federal regulations, including 40 CFR Part 503.</p> <p>c) A schedule for completion of the solids removal and disposal project.</p> <p>The Permittee shall initiate implementation of the plan following approval by NMED.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection C of 20.6.2.3109 NMAC]</p> |
| 38. | <p>In the event that a release occurs that is not authorized under this Discharge Permit (commonly known as a “spill”), the Permittee shall take measures to mitigate damage from the unauthorized discharge and initiate the notifications and corrective actions required in Section 20.6.2.1203 NMAC and summarized below.</p> <p>Within <u>24 hours</u> following discovery of the unauthorized discharge, the Permittee shall verbally notify NMED and provide the following information.</p> <p>a) The name, address, and telephone number of the person or persons in charge of the Facility, as well as of the owner and/or operator of the Facility.</p> <p>b) The name and address of the Facility.</p> <p>c) The date, time, location, and duration of the unauthorized discharge.</p> <p>d) The source and cause of unauthorized discharge.</p> <p>e) A description of the unauthorized discharge, including its estimated chemical composition.</p> <p>f) The estimated volume of the unauthorized discharge.</p> <p>g) Any actions taken to mitigate immediate damage from the unauthorized discharge.</p> <p>Within <u>one week</u> following discovery of the unauthorized discharge, the Permittee shall submit written notification to NMED providing the information listed above and any pertinent updates.</p> <p>Within <u>15 days</u> following discovery of the unauthorized discharge, the Permittee shall submit a Corrective Action Plan (CAP) to NMED describing any corrective actions previously taken and corrective actions to be taken relative to the unauthorized discharge. The CAP shall include the following information.</p> <p>a) A description of proposed actions to mitigate damage from the unauthorized discharge.</p> <p>b) A description of proposed actions to prevent future unauthorized discharges of this nature.</p> <p>c) A schedule for completion of proposed actions.</p> |

| # | Terms and Conditions |
|-----|--|
| | <p>In the event that the unauthorized discharge causes or may with reasonable probability cause water pollution in excess of the standards and requirements of Section 20.6.2.4103 NMAC, and the water pollution will not be abated within 180 days after notice is required to be given pursuant to Paragraph (1) of Subsection A of 20.6.2.1203 NMAC, NMED may require the Permittee to abate water pollution pursuant to Sections 20.6.2.4000 through 20.6.2.4115 NMAC.</p> <p>The Permittee shall not construe anything in this condition as relieving them of the obligation to comply with all requirements of Section 20.6.2.1203 NMAC.</p> <p>[20.6.2.1203 NMAC]</p> |
| 39. | <p>In the event that NMED or the Permittee identifies any failures of the discharge plan, i.e., the application, or this Discharge Permit not specifically noted herein, NMED may require the Permittee to submit a Corrective Action Plan and a schedule for completion of corrective actions to address the failure(s). Additionally, NMED may require a discharge permit modification to achieve compliance with 20.6.2 NMAC.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection E of 20.6.2.3109 NMAC]</p> |

D. CLOSURE PLAN

Permanent Facility Closure Conditions

| # | Terms and Conditions |
|-----|---|
| 40. | <p>The Permittee shall perform the following closure measures in the event the Facility, or a component thereof, is proposed to be permanently closed.</p> <p>Within <u>60 days</u> of ceasing to discharge to the impoundment(s), the Permittee shall plug the impoundment influent lines so that a discharge can no longer occur.</p> <p>Within <u>60 days</u> of ceasing to discharge to the impoundment(s), the Permittee shall evaporate or drain all wastewater from the impoundment and any other wastewater system component and disposed of it in accordance with all local, state, and federal regulations. The permittee may discharge wastewater from the impoundment and any other wastewater system component to the surface disposal area providing none of the limits set by this permit are exceeded. The Permittee shall not discharge accumulated solids (sludge) from the impoundment to the surface disposal area.</p> |

| # | Terms and Conditions |
|---|--|
| | <p>Within <u>90 days</u> of ceasing to discharge to the impoundment(s), the Permittee shall submit a sludge removal and disposal plan to NMED for approval. The Permittee shall implement the plan within 30 days following approval by NMED. The sludge removal and disposal plan shall include the following information.</p> <ul style="list-style-type: none">a) The estimated volume and dry weight of sludge planned for removal and disposal, including measurements and calculations.b) Analytical results for samples of the sludge taken from the impoundment for TKN, NO₃-N, percent total solids, and any other parameters tested (reported in mg/kg, dry weight basis).c) The method of sludge <i>removal</i> from the impoundment(s).d) The method of <i>disposal</i> for all the sludge (and its contents) removed from the impoundment(s). The method shall comply with all local, state and federal regulations, including 40 CFR Part 503. <i>Note: A proposal that includes the surface disposal of sludge may be subject to Groundwater Discharge Permitting requirements pursuant to 20.6.2.3104 NMAC that are separate from the requirements of this Discharge Permit.</i>e) A schedule for completion of sludge removal and disposal not to exceed two years from the date discharge to the impoundment(s) ceased. <p>Within <u>one year</u> following completion of the sludge removal and disposal, the Permittee shall complete the following closure measures.</p> <ul style="list-style-type: none">a) Remove all lines leading to and from the impoundment(s), or permanently plug and abandon the lines in place.b) Remove or demolish any other wastewater system components and re-grade area with suitable fill to blend with surface topography, promote positive drainage and prevent ponding.c) Characterize, remove and dispose of all solids from the impoundments in accordance with local, state, and federal regulations, and maintain a record of solids transported for off-site disposal, including the volume of solids transported and the disposal location.d) Remove and dispose of the impoundment liners at a solid waste facility. If there is evidence of contaminated soil below the liners, assess the impact, report that assessment to NMED, and mitigate the impacts following NMED approval.e) Fill the impoundment(s) with suitable fill.f) Re-grade the impoundment site and the locations of ancillary equipment, e.g., influent piping, to blend with surface topography, promote positive drainage and prevent ponding. <p>The Permittee shall continue groundwater monitoring until the Permittee meets the requirements of this condition met and groundwater monitoring confirms for a minimum</p> |

| # | Terms and Conditions |
|---|--|
| | <p>of eight consecutive quarterly groundwater sampling events that groundwater does not exceed the standards of Section 20.6.2.3103 NMAC. This period is referred to as “post-closure.”</p> <p>If at any time monitoring results show an exceedance of a groundwater quality standard in Section 20.6.2.3103 NMAC, the Permittee shall implement the Contingency Plan required by this Discharge Permit.</p> <p>Following notification from NMED that the Permittee may cease post-closure monitoring, the Permittee shall plug and abandon the monitoring well(s) in accordance with the attached Monitoring Well Guidance.</p> <p>When the Permittee has met all closure and post-closure requirements and verified appropriate actions with date stamped photographic evidence or an associated NMED inspection, the Permittee may submit to NMED a written request, including photographic evidence, for termination of the Discharge Permit.</p> <p>[Subsection A of 20.6.2.3107 NMAC, Subsection D of 20.6.2.4103 NMAC, 40 CFR Part 503]</p> |

E. GENERAL TERMS AND CONDITIONS

| # | Terms and Conditions |
|-----|---|
| 41. | <p>RECORD KEEPING - The Permittee shall maintain a written record of the following:</p> <ul style="list-style-type: none"> • Information and data used to complete the application for this Discharge Permit; • Information, data, and documents demonstrating completion of closure activities; • Any releases (commonly known as “spills”) not authorized under this Discharge Permit and reports submitted pursuant to 20.6.2.1203 NMAC; • The operation, maintenance, and repair of all facilities/equipment used to treat, store or dispose of wastewater; • Facility record drawings (plans and specifications) showing the actual construction of the Facility and bear the seal and signature of a licensed New Mexico professional engineer; • Copies of logs, inspection reports, and monitoring reports completed and/or submitted to NMED pursuant to this Discharge Permit; • The volume of wastewater or other wastes discharged pursuant to this Discharge Permit; • Groundwater quality and wastewater quality data collected pursuant to this Discharge Permit; |

| # | Terms and Conditions |
|-----|---|
| | <ul style="list-style-type: none"> • Copies of construction records (well log) for all sampled groundwater monitoring wells pursuant to this Discharge Permit; • The maintenance, repair, replacement or calibration of any monitoring equipment or flow measurement devices required by this Discharge Permit; and • Data and information related to field measurements, sampling, and analysis conducted pursuant to this Discharge Permit, including: <ul style="list-style-type: none"> ○ the dates, location and times of sampling or field measurements; ○ the name and job title of the individuals who performed each sample collection or field measurement; ○ the sample analysis date of each sample ○ the name and address of the laboratory, and the name of the signatory authority for the laboratory analysis; ○ the analytical technique or method used to analyze each sample or collect each field measurement; ○ the results of each analysis or field measurement, including raw data; ○ the results of any split, spiked, duplicate or repeat sample; and ○ a copy of the laboratory analysis chain-of-custody as well as a description of the quality assurance and quality control procedures used. <p>The Permittee shall maintain the written record at a location accessible to NMED during a Facility inspection for the lifetime of the Discharge Permit. The Permittee shall make the record available to the department upon request.</p> <p>[Subsections A and D of 20.6.2.3107 NMAC]</p> |
| 42. | <p>SUBMITTALS – The Permittee shall submit both a paper copy and an electronic copy of all notification and reporting documents required by this Discharge Permit, e.g., monitoring reports. The Permittee shall submit paper and electronic documents to the NMED Permit Contact identified on the Permit cover page.</p> <p>[Subsection A of 20.6.2.3107 NMAC]</p> |
| 43. | <p>INSPECTION and ENTRY – The Permittee shall allow NMED to inspect the Facility and its operations that are subject to this Discharge Permit and the WQCC regulations. NMED may upon presentation of proper credentials, enter at reasonable times upon or through any premises in which a water contaminant source is located or in which any maintained records required by this Discharge Permit, the regulations of the federal government, or the WQCC are located.</p> <p>The Permittee shall allow NMED to have access to and reproduce for their use any copy of the records, and to perform assessments, sampling or monitoring during an inspection</p> |

| # | Terms and Conditions |
|-----|--|
| | <p>for the purpose of evaluating compliance with this Discharge Permit and the WQCC regulations.</p> <p>No person shall construe anything in this Discharge Permit as limiting in any way the inspection and entry authority of NMED under the WQA, the WQCC Regulations, or any other local, state or federal regulations.</p> <p>[Subsection D of 20.6.2.3107 NMAC, NMSA 1978, §§ 74-6-9.B and 74-6-9.E]</p> |
| 44. | <p>DUTY to PROVIDE INFORMATION - The Permittee shall, upon NMED's request, allow for NMED's inspection/duplication of records required by this Discharge Permit and/or furnish to NMED copies of such records.</p> <p>[Subsection D of 20.6.2.3107 NMAC]</p> |
| 45. | <p>MODIFICATIONS and/or AMENDMENTS – In the event the Permittee proposes a change to the Facility or the Facility's discharge that would result in a change in the volume discharged; the location of the discharge; or in the amount or character of water contaminants received, treated or discharged by the Facility, the Permittee shall notify NMED prior to implementing such changes. The Permittee shall obtain NMED's approval (which may require modification of this Discharge Permit) prior to implementing such changes.</p> <p>[Subsection C of 20.6.2.3107 NMAC, Subsections E and G of 20.6.2.3109 NMAC]</p> |
| 46. | <p>PLANS and SPECIFICATIONS – In the event the Permittee proposes to construct a wastewater system or change a process unit of an existing system such that the quantity or quality of the discharge will change substantially from that authorized by this Discharge Permit, the Permittee shall submit construction plans and specifications of the proposed system or process unit to NMED for approval prior to the commencement of construction.</p> <p>In the event the Permittee implements changes to the wastewater system authorized by this Discharge Permit that result in only a minor effect on the character of the discharge, the Permittee shall report such changes (including the submission of record drawings where applicable) to NMED prior to implementation.</p> <p>[Subsections A and C of 20.6.2.1202 NMAC, NMSA 1978, §§ 61-23-1 through 61-23-32]</p> |
| 47. | <p>CIVIL PENALTIES - Any violation of the requirements and conditions of this Discharge Permit, including any failure to allow NMED staff to enter and inspect records or facilities, or any refusal or failure to provide NMED with records or information, may subject the</p> |

| # | Terms and Conditions |
|-----|---|
| | <p>Permittee to a civil enforcement action. Pursuant to WQA 74-6-10(A) and (B), such action may include a compliance order requiring compliance immediately or in a specified time, assessing a civil penalty, modifying or terminating the Discharge Permit, or any combination of the foregoing; or an action in district court seeking injunctive relief, civil penalties, or both. Pursuant to WQA 74-6-10(C) and 74-6-10.1, civil penalties of up to \$15,000 per day of noncompliance may be assessed for each violation of the WQA 74-6-5, the WQCC Regulations, or this Discharge Permit, and civil penalties of up to \$10,000 per day of noncompliance may be assessed for each violation of any other provision of the WQA, or any regulation, standard, or order adopted pursuant to such other provision. In any action to enforce this Discharge Permit, the Permittee waives any objection to the admissibility as evidence of any data generated pursuant to this Discharge Permit.</p> <p>[20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10 and 74-6-10.1]</p> |
| 48. | <p>CRIMINAL PENALTIES – No person shall:</p> <ul style="list-style-type: none"> • Make any false material statement, representation, certification or omission of material fact in an application, record, report, plan or other document filed, submitted or maintained under the WQA; • Falsify, tamper with or render inaccurate any monitoring device, method or record maintained under the WQA; or • Fail to monitor, sample or report as required by a permit issued pursuant to a state or federal law or regulation. <p>Any person who knowingly violates or knowingly causes or allows another person to violate the requirements of this condition is guilty of a fourth-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who is convicted of a second or subsequent violation of the requirements of this condition is guilty of a third-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition or knowingly causes another person to violate the requirements of this condition and thereby causes a substantial adverse environmental impact is guilty of a third-degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15. Any person who knowingly violates the requirements of this condition and knows at the time of the violation that he is creating a substantial danger of death or serious bodily injury to any other person is guilty of a second degree felony and shall be sentenced in accordance with the provisions of NMSA 1978, § 31-18-15.</p> <p>[20.6.2.1220 NMAC, NMSA 1978, §§ 74-6-10.2.A through 74-6-10.2.F]</p> |
| 49. | <p>COMPLIANCE with OTHER LAWS - Nothing in this Discharge Permit shall be construed in any way as relieving the Permittee of the obligation to comply with any other applicable</p> |

| # | Terms and Conditions |
|-----|--|
| | <p>federal, state, and/or local laws, regulations, zoning requirements, nuisance ordinances, permits or orders.</p> <p>[NMSA 1978, § 74-6-5.L]</p> |
| 50. | <p>RIGHT to APPEAL - The Permittee may file a petition for review before the WQCC on this Discharge Permit. Such petition shall be in writing to the WQCC within thirty days of the receipt of postal notice of this Discharge Permit and shall include a statement of the issues raised and the relief sought. Unless the Permittee files a timely petition for review, the decision of NMED shall be final and not subject to judicial review.</p> <p>[20.6.2.3112 NMAC, NMSA 1978, § 74-6-5.O]</p> |
| 51. | <p>TRANSFER of DISCHARGE PERMIT - Prior to the transfer of any ownership, control, or possession of this Facility or any portion thereof, the Permittee shall:</p> <ul style="list-style-type: none">• Notify the proposed transferee in writing of the existence of this Discharge Permit;• Include a copy of this Discharge Permit with the notice; and• Deliver or send by certified mail to NMED a copy of the notification and proof that the proposed transferee has received such notification. <p>The Permittee shall continue to be responsible for any discharge from the Facility, until both ownership and possession of the Facility have been transferred to the transferee.</p> <p>[20.6.2.3111 NMAC]</p> |
| 52. | <p>PERMIT FEES – The Permittee shall be aware that the payment of permit fees is due at the time of Discharge Permit approval. The Permittee may pay the permit fees in a single payment or they may pay the fee in equal installments on a yearly basis over the term of the Discharge Permit. The Permittee shall remit single payments to NMED no later than 30 days after the Discharge Permit issuance date. The Permittee shall remit initial installment payments to NMED no later than 30 days after the Discharge Permit issuance date; with subsequent installment payments remitted to NMED no later than the anniversary of the Discharge Permit issuance date.</p> <p>Permit fees are associated with <u>issuance</u> of this Discharge Permit. No person shall construe anything in this Discharge Permit as relieving the Permittee of the obligation to pay all permit fees assessed by NMED. A Permittee that ceases discharging or does not commence discharging from the Facility during the term of the Discharge Permit shall pay all permit fees assessed by NMED. NMED shall suspend or terminate an approved Discharge Permit if the Permittee fails to remit an installment payment by its due date.</p> <p>[Subsection F of 20.6.2.3114 NMAC, NMSA 1978, § 74-6-5.K]</p> |

draft