



SUSANA MARTINEZ  
Governor

JOHN A. SANCHEZ  
Lieutenant Governor

NEW MEXICO  
ENVIRONMENT DEPARTMENT

*Surface Water Quality Bureau*

Harold Runnels Building, N2050  
1190 South St. Francis Drive (87505)  
P.O. Box 5469, Santa Fe, NM 87502-5469  
Phone (505) 827-0187 Fax (505) 827-0160  
[www.nmenv.state.nm.us](http://www.nmenv.state.nm.us)



RYAN FLYNN  
Cabinet Secretary-Designate

BUTCH TONGATE  
Deputy Secretary

ERIKA SCHWENDER  
Director  
Resource Protection Division

**Certified Mail - Return Receipt Requested**

June 29, 2016

Mr. Mike Sloane, Chief-Fisheries Division  
State of New Mexico Department of Game and Fish  
PO Box 25112  
Santa Fe, NM 87504

**Re: New Mexico Department of Game and Fish, Lisboa Springs Hatchery; Major; Individual Permit; SIC 0921; NPDES Compliance Evaluation Inspection; NM0030121; June 27, 2016**

Dear Mr. Sloane:

Enclosed please find a copy of the report and check list for the referenced inspection that the New Mexico Environment Department (NMED) conducted at your facility on behalf of the U.S. Environmental Protection Agency (USEPA). This inspection report will be sent to the USEPA in Dallas for their review. These inspections are used by USEPA to determine compliance with the National Pollutant Discharge Elimination System (NPDES) permitting program in accordance with requirements of the federal Clean Water Act.

Introduction, treatment scheme, and problems noted during this inspection are discussed in the "Further Explanations" section of the inspection report.

You are encouraged to review the inspection report, required to correct any problems noted during the inspection, and advised to modify your operational and/or administrative procedures, as appropriate. If you have comments on or concerns with the basis for the findings in the NMED inspection report, please contact us (see the address below) in writing within 30 days from the date of this letter. Further, you are encouraged to notify in writing both the USEPA and NMED regarding modifications and compliance schedules at the addresses below:

Racquel Douglas  
US Environmental Protection Agency, Region VI  
Enforcement Branch (6EN-WM)  
1445 Ross Avenue  
Dallas, Texas 75202-2733

Bruce Yurdin  
New Mexico Environment Department  
Surface Water Quality Bureau  
Point Source Regulation Section  
P.O. Box 5469  
Santa Fe, New Mexico 87502

If you have any questions about this inspection report, please contact Sarah Holcomb at 505-827-2798 or at [sarah.holcomb@state.nm.us](mailto:sarah.holcomb@state.nm.us).

NMDGF Lisboa Springs State Trout Hatchery

June 29, 2016

Page 2

Sincerely,

Bruce J. Yurdin  
Program Manager  
Point Source Regulation Section  
Surface Water Quality Bureau

cc: Carol Peters-Wagnon, USEPA (6EN-WM) by e-mail  
Gladys Gooden-Jackson, USEPA (6EN-WC) by e-mail  
Brent Larsen, USEPA (6WQ-PP) by e-mail  
Racquel Douglas, USEPA (6EN-WM) by e-mail  
NMED District 2, Bob Italiano by e-mail



Form Approved  
OMB No. 2040-0003  
Approval Expires 7-31-85

### NPDES Compliance Inspection Report

#### Section A: National Data System Coding

Transaction Code	NPDES	yr/mo/day	Inspec. Type	Inspector	Fac Type
1 N 2 5 3 N M 0 0 3 0 1 2 1 11 12 1 6 0 6 2 7 17 18 C 19 S 20 2					
Remarks					
S T A T E F I S H H A T C H E R Y					
Inspection Work Days	Facility Evaluation Rating	BI	QA	-----Reserved-----	
67 69	70 4	71 N	72 N 73	74 75	80

#### Section B: Facility Data

<b>Name and Location of Facility Inspected</b> <i>(For industrial users discharging to POTW, also include POTW name and NPDES permit number)</i> NM Department of Game and Fish, Lisboa Springs Hatchery, San Miguel County: From I-25 exit onto the Glorieta exit 299. Turn left to cross the bridge and travel east on Hwy 50 for approximately 5.5 miles until you reach the intersection of Hwy 50 and Hwy 63. Travel north on Hwy 63 for approximately 2.5 miles (just past mile marker 8 and the monastery) to the hatchery.	Entry Time /Date 0920 hours / 6-27-2016	Permit Effective Date 10-1-2013
	Exit Time/Date 1100 hours / 6-27-2016	Permit Expiration Date 9-30-2018
<b>Name(s) of On-Site Representative(s)/Title(s)/Phone and Fax Number(s)</b> Ms. Francina Martinez, Asst. Manager (505) 757-6360	Other Facility Data	
<b>Name, Address of Responsible Official/Title/Phone and Fax Number</b> Mr. Michael Sloane, Fisheries Chief, NM Department of Game and Fish PO Box 25112, Santa Fe, NM 87504 (505) 476-8055	Contacted Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> *	Outfall 002: N 35° 36' 30.2" W -105° 40' 36.9" Outfall 003: N 35° 36' 29.7" W. -105° 40' 35.9" Outfall 004: N. 35° 36' 33.7" W. -105° 40' 37.4" SIC 0921

#### Section C: Areas Evaluated During Inspection

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

S	Permit	S	Flow Measurement	S	Operations & Maintenance	N	CSO/SSO
S	Records/Reports	S	Self-Monitoring Program	S	Sludge Handling/Disposal	N	Pollution Prevention
S	Facility Site Review	N	Compliance Schedules	N	Pretreatment	N	Multimedia
S	Effluent/Receiving Waters	S	Laboratory	N	Storm Water	N	Other:

#### Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

1. Please see further explanations for more information.

<b>Name(s) and Signature(s) of Inspector(s)</b> Sarah Holcomb /s/ Sarah Holcomb	<b>Agency/Office/Telephone/Fax</b> 505-827-2798	<b>Date</b> 6-29-16
<b>Signature of Management QA Reviewer</b> Bruce Yurdin /s/ Bruce Yurdin	<b>Agency/Office/Phone and Fax Numbers</b> 505-827-2795	<b>Date</b> 6-29-16

SECTION A - PERMIT VERIFICATION

PERMIT SATISFACTORILY ADDRESSES OBSERVATIONS DETAILS:  S  M  U  NA (FURTHER EXPLANATION ATTACHED NO)

- 1. CORRECT NAME AND MAILING ADDRESS OF PERMITTEE  Y  N  NA
- 2. NOTIFICATION GIVEN TO EPA/STATE OF NEW DIFFERENT OR INCREASED DISCHARGES  Y  N  NA
- 3. NUMBER AND LOCATION OF DISCHARGE POINTS AS DESCRIBED IN PERMIT  Y  N  NA
- 4. ALL DISCHARGES ARE PERMITTED  Y  N  NA

SECTION B - RECORDKEEPING AND REPORTING EVALUATION

RECORDS AND REPORTS MAINTAINED AS REQUIRED BY PERMIT. DETAILS:  S  M  U  NA (FURTHER EXPLANATION ATTACHED NO)

- 1. ANALYTICAL RESULTS CONSISTENT WITH DATA REPORTED ON DMRs.  Y  N  NA
- 2. SAMPLING AND ANALYSES DATA ADEQUATE AND INCLUDE.  S  M  U  NA
  - a) DATES, TIME(S) AND LOCATION(S) OF SAMPLING  Y  N  NA
  - b) NAME OF INDIVIDUAL PERFORMING SAMPLING  Y  N  NA
  - c) ANALYTICAL METHODS AND TECHNIQUES.  Y  N  NA
  - d) RESULTS OF ANALYSES AND CALIBRATIONS.  Y  N  NA
  - e) DATES AND TIMES OF ANALYSES.  Y  N  NA
  - f) NAME OF PERSON(S) PERFORMING ANALYSES.  Y  N  NA
- 3. LABORATORY EQUIPMENT CALIBRATION AND MAINTENANCE RECORDS ADEQUATE.  S  M  U  NA
- 4. PLANT RECORDS INCLUDE SCHEDULES, DATES OF EQUIPMENT MAINTENANCE AND REPAIR.  S  M  U  NA
- 5. EFFLUENT LOADINGS CALCULATED USING DAILY EFFLUENT FLOW AND DAILY ANALYTICAL DATA.  Y  N  NA

SECTION C - OPERATIONS AND MAINTENANCE

TREATMENT FACILITY PROPERLY OPERATED AND MAINTAINED. DETAILS:  S  M  U  NA (FURTHER EXPLANATION ATTACHED YES)

- 1. TREATMENT UNITS PROPERLY OPERATED.  S  M  U  NA
- 2. TREATMENT UNITS PROPERLY MAINTAINED.  S  M  U  NA
- 3. STANDBY POWER OR OTHER EQUIVALENT PROVIDED.  S  M  U  NA
- 4. ADEQUATE ALARM SYSTEM FOR POWER OR EQUIPMENT FAILURES AVAILABLE.  S  M  U  NA
- 5. ALL NEEDED TREATMENT UNITS IN SERVICE  S  M  U  NA
- 6. ADEQUATE NUMBER OF QUALIFIED OPERATORS PROVIDED.  S  M  U  NA
- 7. SPARE PARTS AND SUPPLIES INVENTORY MAINTAINED.  S  M  U  NA
- 8. OPERATION AND MAINTENANCE MANUAL AVAILABLE.  Y  N  NA
- STANDARD OPERATING PROCEDURES AND SCHEDULES ESTABLISHED.  Y  N  NA
- PROCEDURES FOR EMERGENCY TREATMENT CONTROL ESTABLISHED.  Y  N  NA

## SECTION C - OPERATIONS AND MAINTENANCE (CONT'D)

9. HAVE BYPASSES/OVERFLOWS OCCURRED AT THE PLANT OR IN THE COLLECTION SYSTEM IN THE LAST YEAR?  Y  N  NA  
 IF SO, HAS THE REGULATORY AGENCY BEEN NOTIFIED?  Y  N  NA  
 HAS CORRECTIVE ACTION BEEN TAKEN TO PREVENT ADDITIONAL BYPASSES/OVERFLOWS?  Y  N  NA

10. HAVE ANY HYDRAULIC OVERLOADS OCCURRED AT THE TREATMENT PLANT?  Y  N  NA  
 IF SO, DID PERMIT VIOLATIONS OCCUR AS A RESULT?  Y  N  NA

## SECTION D - SELF-MONITORING

PERMITTEE SELF-MONITORING MEETS PERMIT REQUIREMENTS.  S  M  U  NA (FURTHER EXPLANATION ATTACHED NO).  
 DETAILS:

1. SAMPLES TAKEN AT SITE(S) SPECIFIED IN PERMIT.  Y  N  NA

2. LOCATIONS ADEQUATE FOR REPRESENTATIVE SAMPLES.  Y  N  NA

3. FLOW PROPORTIONED SAMPLES OBTAINED WHEN REQUIRED BY PERMIT.  Y  N  NA

4. SAMPLING AND ANALYSES COMPLETED ON PARAMETERS SPECIFIED IN PERMIT.  Y  N  NA

5. SAMPLING AND ANALYSES PERFORMED AT FREQUENCY SPECIFIED IN PERMIT.  Y  N  NA

6. SAMPLE COLLECTION PROCEDURES ADEQUATE  Y  N  NA

a) SAMPLES REFRIGERATED DURING COMPOSITING.  Y  N  NA

b) PROPER PRESERVATION TECHNIQUES USED.  Y  N  NA

c) CONTAINERS AND SAMPLE HOLDING TIMES CONFORM TO 40 CFR 136.3.  Y  N  NA

7. IF MONITORING AND ANALYSES ARE PERFORMED MORE OFTEN THAN REQUIRED BY PERMIT, ARE THE RESULTS REPORTED IN PERMITTEE'S SELF-MONITORING REPORT?  Y  N  NA

## SECTION E - FLOW MEASUREMENT

PERMITTEE FLOW MEASUREMENT MEETS PERMIT REQUIREMENTS.  S  M  U  NA (FURTHER EXPLANATION ATTACHED NO).  
 DETAILS:

1. PRIMARY FLOW MEASUREMENT DEVICE PROPERLY INSTALLED AND MAINTAINED.  Y  N  NA  
 TYPE OF DEVICE 4" Weir

2. FLOW MEASURED AT EACH OUTFALL AS REQUIRED.  Y  N  NA

3. SECONDARY INSTRUMENTS (TOTALIZERS, RECORDERS, ETC.) PROPERLY OPERATED AND MAINTAINED.  Y  N  NA

4. CALIBRATION FREQUENCY ADEQUATE.  Y  N  NA  
 RECORDS MAINTAINED OF CALIBRATION PROCEDURES.  Y  N  NA  
 CALIBRATION CHECKS DONE TO ASSURE CONTINUED COMPLIANCE.  Y  N  NA

5. FLOW ENTERING DEVICE WELL DISTRIBUTED ACROSS THE CHANNEL AND FREE OF TURBULENCE.  Y  N  NA

6. HEAD MEASURED AT PROPER LOCATION.  Y  N  NA

7. FLOW MEASUREMENT EQUIPMENT ADEQUATE TO HANDLE EXPECTED RANGE OF FLOW RATES.  Y  N  NA

## SECTION F - LABORATORY

PERMITTEE LABORATORY PROCEDURES MEET PERMIT REQUIREMENTS.  S  M  U  NA (FURTHER EXPLANATION ATTACHED NO).  
 DETAILS: Permittee obtained permission from David Stockton, EPA Region 6, to use the Oakton pH pen.

1. EPA APPROVED ANALYTICAL PROCEDURES USED (40 CFR 136.3 FOR LIQUIDS, 503.8(b) FOR SLUDGES)  Y  N  NA



**NMDGF Lisboa Springs State Trout Hatchery  
Compliance Evaluation Inspection  
NPDES Permit No. NM0030121  
June 27, 2016**

**Further Explanations**

**Introduction**

On June 27, 2016, Sarah Holcomb of the New Mexico Environment Department (NMED), Surface Water Quality Bureau (SWQB) conducted a Compliance Evaluation Inspection (CEI) at the NM Department of Game and Fish, Lisboa Springs State Trout Hatchery on Hwy 63 near Pecos, NM in San Miguel County. The Lisboa State Trout Hatchery has a design flow rate of 0.913 MGD and is classified as a minor industrial discharger under the federal Clean Water Act, Section 402, of the National Pollutant Discharge Elimination System (NPDES) permit program. It is assigned NPDES permit number NM0030121.

The Lisboa Hatchery discharges into the Pecos River in Segment 20.6.4.217 NMAC of the Pecos River Basin (*State of New Mexico Standards for Interstate and Intrastate Surface Waters*). Designated uses of Segment 20.6.4.217 NMAC are domestic water supply, fish culture, high quality coldwater aquatic life, irrigation, livestock watering, wildlife habitat, and primary contact. Part of this segment, from Alamitos Canyon to Willow Creek, did not support the high quality coldwater aquatic life use and turbidity was listed as the cause of impairment. (See *2012-2014 State of New Mexico 303(d) List for Assessed River/Stream Reaches Requiring Total Maximum Daily Loads.*) A TMDL for turbidity was prepared for this segment in 2005. The permit's daily maximum limitation of 15 mg/L TSS is in accordance with the Waste Load Allocation of the TMDL. The 2014-2016 303(d)/305(b) list no longer lists the segment as impaired, but the TMDL is still in place.

The NMED performs a certain number of CEIs each year for the U.S. Environmental Protection Agency (USEPA), Region VI. The purpose of this inspection is to provide the USEPA with information to evaluate the Permittee's compliance with the NPDES permit. This inspection report is based on information provided by the Permittee's representatives, observations made by the NMED inspector, and records and reports kept by the Permittee and/or NMED.

An entrance interview was conducted with Ms. Francina Martinez, Assistant Manager at approximately 0930 hours on June 27, 2016. The inspector made introductions, presented her credentials and discussed the purpose of the inspection. The inspector toured the facility with Ms. Martinez. An exit interview to discuss the preliminary findings of the inspection was conducted with Ms. Martinez at approximately 1050 hours on June 27, 2016, and then followed up with Ms. Heather Timmons – Environmental Compliance Specialist via phone after the inspection.

**Treatment Scheme**

The Lisboa Hatchery is a production facility for rainbow trout with an estimated annual rate of production of 65,000 pounds per year. The water source for the hatchery is natural springs and a ground water well. The spring source stays at a constant flow year round.

The facility has been converted into a semi-recirculation system. The water enters the facility via three spring boxes. Spring box #1 supplies water to the hatchery and eight fry raceways. After the spring water exits the fry raceways, it is supplemented with additional water as needed from the groundwater well. It then proceeds to a drum and disc filtration system along with UV sterilization (added to the facility during a shutdown period in 1999 due to the presence of whirling disease. The facility then re-opened in March 2003). This system treats the water before it is delivered to the sixteen available north side/spring-side raceways, where fingerlings and catchable trout are raised. The filtration system filters out solids larger than 10 µm. The excess water from the north side is then delivered to a sump, and then proceeds through another drum and disc filtration system, along with UV sterilization, prior to entering the sixteen south side/riverside raceways. The solids collected during filtration and from cleaning of the raceways are sent to the facility's waste manifolds, and then to the kettles for settling before the wastewater is discharged from Outfall 002. Generally, flow from the raceways is sent to two recirculation tanks and is then pumped back to the disc filters and resent through the facility.

In 2014, the south side raceways were found to be contaminated with bacterial kidney disease, resulting in the destruction of the contaminated fish, and disinfection of the raceways with hydrogen peroxide. The disinfection appears to have been successful and the hatchery is in the process of putting those raceways back online.

Spring box #2 supplies domestic water for the residences on site, and spring box #3 supplies the water rack for filling trucks.

There are 32 major and 8 minor raceways, and 24 troughs in the system.

Outfall 001 was discontinued/plugged and is no longer available for discharge.

Outfall 002 is currently the primary outfall for wastewater discharge. It is located at the kettle raceway – a concrete structure originally used for trout production, but which is now used as the final settling basin. This facility change occurred in 1996 when a pipe was installed, allowing facility staff to directly discharge from the waste manifold. Discharge is measured by head height at a 4” weir.

Outfall 003 is the old earthen settling basin, which is not currently in use. It would only be used when the kettle basins are being cleaned. Flow would be measured at this outfall by a head height over a 20” weir. The earthen pond has not been in use since approximately 2011.

Outfall 004 is also no longer in use. It was used for the production pond in the past, but has been sealed off. According to past inspection documentation from USEPA, there is the possibility that this could be used in the future for hydroelectric power generation.

### **Solids/Sludge Management**

Lisboa removes solids from the system by using a vacuum tank. According to facility staff, solids are removed from the system approximately every eight months. The vacuum tank is mounted on the back of a truck and by using a hose and head attachment, solids are gently removed over the course of a few days. The solids are reportedly disposed of on a local farm’s fields and used as a nutrient source to grow grasses. The vacuum tank was not readily visible during this inspection.

## Further Explanations

Note: The sections are arranged according to the format of the enclosed EPA Inspection Checklist (Form 3560-3), rather than being ranked in order of importance.

### Section C – Operations and Maintenance Evaluation – Overall rating of “Satisfactory”

The permit states in Part III.B.3:

#### Proper Operation and Maintenance

- a. *The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by permittee as efficiently as possible and in a manner which will minimize upsets and discharges of excessive pollutants and will achieve compliance with the conditions of this permit...*

#### Findings for Operation and Maintenance:

During a pre-inspection review, the inspector noted an article that described the facility undergoing disinfection procedures due to the detection of bacterial kidney disease in the resident Rainbow Trout. Please see Attachment A for the NMDGF article on their website. The fish from the south side of the facility were destroyed to prevent the spread of the disease and the facility was disinfected with hydrogen peroxide. The permittee representative indicated that the H<sub>2</sub>O<sub>2</sub> was applied in very dilute form and any water with residual H<sub>2</sub>O<sub>2</sub> was discharged to the settling pond to dissipate the rest of the chemical. The facility was in the process of bringing the southside raceways back on line at the time of this inspection.

During the site tour of the facility, the inspector noted that the kettles just prior to discharge at Outfall 002 had accumulated a large amount of algae. From reviewing the facility's NetDMR submissions, the algae do not appear to be affecting the TSS levels at the outfall, but the inspector noted that the kettles should be cleaned to prevent elevated TSS levels in the effluent. Permittee representatives indicated that this action is planned for FY2017.

## Discharge Monitoring Report Calculation Check

The DMR calculation check was conducted for the parameter of TSS for the month of November 2013.

✓ = in agreement with calculation result submitted on facility's NetDMR.

<u>Date</u>	<u>TSS Result</u>
1-12-15	<3.0 mg/L
1-26-15	3.0 mg/L

<u>Date</u>	<u>Flow rate</u>
1-12-15	Weir measurement = 1.5 in. [4 ft x 64.93 gpm x 0.00144 = 0.374 MGD]
1-26-15	Weir measurement = 1.75 in [4 ft x 81.94 gpm x 0.00144 = 0.472 MGD]

### Loading:

January's 30-day average :

1-12-15: 3.0 mg/L x 8.34 x 0.374 mgd = 9.36 lbs/day

11-20-2013: <3.0 mg/L x 8.34 x 0.472 mgd = 11.81 lbs/day

Avg:  $(9.36 + 11.81)/2 = 10.59$  lbs/day (This was reported as 10.5925 lbs/day) ✓

January's 7-day average = 11.81 lbs/day (This was reported as 11.8174 lbs/day) ✓

### Concentration:

January's 30-day average =  $(3.0 \text{ mg/L} + <3.0 \text{ mg/L})/2 = 3.0 \text{ mg/L}$  (this was reported as 3.0 mg/L) ✓

January's 7-day average = 3.0 mg/L (This was reported as 3.0 mg/L) ✓


**NMED/SWQB**  
**Official Photograph Log**  
Photo # 1

Photographer: Sarah Holcomb	Date: 1-22-2014	Time: 1035 hours
City/County: Near Pecos, San Miguel County		
Location: NMDGF Lisboa Springs State Hatchery.		
Subject: Outfall 002 discharge to the Pecos River. Note scouring from 2013 floods in comparison to photo #2.		



**NMED/SWQB**  
**Official Photograph Log**  
Photo # 2

Photographer: Sarah Holcomb	Date: 6-27-2016	Time: 1023 hours
City/County: Near Pecos, San Miguel County		
Location: NMDGF Lisboa Springs State Hatchery.		
Subject: Outfall 002 discharge to the Pecos River.		



**NMED/SWQB**  
**Official Photograph Log**  
Photo # 3

Photographer: Sarah Holcomb	Date: 6-27-2016	Time: 1019 hours
City/County: Near Pecos, San Miguel County		
Location: NMDGF Lisboa Springs State Hatchery.		
Subject: Kettles/settling basins prior to Outfall 002. Large amounts of algae accumulation noted although it does not appear to be affecting TSS in discharge.		



## Appendix A

Need Assistance? (888) 248-6866 |

Customer Login

Contact the NMDGF

ispa@state.nm.us

Search the Website 



Home 

Hunting 

Fishing 

OHV 

Recreation 

Conservation 

Education 

Enforcement 

Commission 

## Fishing News

Fishing

[Fishing News](#)

Fishing Calendar

Weekly Fishing & Stocking  
Report

Licenses & Permits

Game Fish and Regulations

Native New Mexico Fish

Legal and Safety Advisories

Maps and Water Access

Fish Vendors

## Trout removed from Lisboa Springs Fish Hatchery

New Mexico Department of Game and Fish

Media contact: Karl Moffatt, (505) 476-8007

Public contact: (888) 248-6866

[karl.moffatt@state.nm.us](mailto:karl.moffatt@state.nm.us)

**FOR IMMEDIATE RELEASE, DATE: April 21, 2015:**

### TROUT REMOVED FROM LISBOA SPRINGS FISH HATCHERY


PECOS – More than 160,000 small rainbow trout will be removed from their raceways at [Lisboa Springs Hatchery](#) near Pecos after tests showed some of the fish had contracted a bacterial disease.

The Department of Game and Fish found bacterial kidney disease in trout being raised in one of two sections of the hatchery during regular testing in early February. All of the trout, ranging in size from three to nine inches, will be destroyed to ensure full decontamination of the section, department Fisheries Chief Mike Sloane said.

Fish Hatcheries

Fisheries Management

Fishing Glossary



“That’s why we do this testing to ensure we are raising strong, healthy fish for the public to catch and eat,” Sloane said.

The disease is naturally present in the environment and can be caught by fish due to a variety of circumstances, including living in a hatchery environment. The disease is no threat to humans. However, the department will not be distributing the diseased fish for human consumption because the department does not want to risk further spreading the disease, Sloane said.

“It’s a little like catching the common flu for them, but in some instances it can be catastrophic to a population of fish,” Sloane said.

The affected area of the hatchery will be drained, disinfected, restocked and additional testing will occur to ensure its cleanliness before it is returned to full production. This process may take up to two years to complete.

The hatchery will continue to produce trout in its second section, but overall production will be reduced by about half at the Lisboa Springs Hatchery. Waters normally stocked by the hatchery, including Monastery Lake, Cowles Ponds and the Pecos River will receive their scheduled allotments of fish, Sloane said.

The department’s [five other hatcheries](#) normally produce excess fish and those will be used to make up for the shortfall.

###

Share This Story, Choose Your Platform!



### OUR MISSION

To conserve, regulate, propagate and protect the wildlife and fish within the state of New Mexico using a flexible management system that ensures sustainable use for public food supply, recreation and safety; and to provide for off-highway motor

### E-MAIL UPDATES

Type your e-mail address & click

**Sign-Up this Address**

### CONTACT WEBMASTER

### NEW MEXICO DEPARTMENT OF GAME & FISH

1 Wildlife Way, Santa Fe, NM 87507  
Phone: (505) 476-8000 | Toll-free (888) 248-6866  
Email: [ispa@state.nm.us](mailto:ispa@state.nm.us)

vehicle recreation that recognizes cultural, historic, and resource values while ensuring public safety. (Read more...)

E-mail: [dgf-webmaster@state.nm.us](mailto:dgf-webmaster@state.nm.us)

SOCIAL MEDIA



COME WORK FOR US

Learn about **available opportunities** with NMDGF.

OPERATION GAME THIEF

Report poaching **online** or call:  
1-800-432-GAME

