



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY  
REGION 6  
1445 ROSS AVENUE, SUITE 1200  
DALLAS TX 75202-2733

AUG 28 2013

CERTIFIED MAIL: RETURN RECEIPT REQUESTED (7010 2780 0002 4353 9359)

REPLY TO: 6WQ-NP

Michael Sloane  
Chief of Fisheries  
Lisboa Springs State Fish Hatchery  
P.O. Box 25112  
Santa Fe, NM 87508


Re: Application to Discharge to Waters of the United States Permit No. NM0030121, Lisboa Springs State Fish Hatchery

Dear Mr. Sloane:

This package constitutes EPA's final permit decision for the above referenced facility. Enclosed are the responses to comments received during the public comment period and the final permit. According to EPA regulations at 40 CFR §124.19, within 30 days after a final permit decision has been issued, any person who filed comments on that draft permit or participated in the public hearing may petition the Environmental Appeals Board to review any condition of the permit decision.

Should you have any questions regarding the final permit, please feel free to contact Tung Nguyen of the NPDES Permits Branch at the above address or by telephone: (214) 665-7153, by fax: (214) 665-2191, or by E-mail: [nguyen.tung@epa.gov](mailto:nguyen.tung@epa.gov). Should you have any questions regarding compliance with the conditions of this permit, please contact the Water Enforcement Branch at the above address or by telephone: 214-665-6468.

Sincerely yours,

  
William K. Honker, P.E.  
Director  
Water Quality Protection Division

Enclosures

cc w/enclosures:  
New Mexico Environment Department

# NPDES PERMIT NO. NM0030121

## RESPONSE TO COMMENTS

RECEIVED ON THE SUBJECT DRAFT NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT IN ACCORDANCE WITH REGULATIONS LISTED AT 40 CFR §124.17

**APPLICANT:** Lisboa Springs State Fish Hatchery  
P.O. Box 25112  
Santa Fe, NM 87508

**ISSUING OFFICE:** U.S. Environmental Protection Agency  
Region 6  
1445 Ross Avenue  
Dallas, TX 75202-2733

**PREPARED BY:** Tung Nguyen  
Environmental Engineer  
NPDES Permits Branch (6WQ-PP)  
Water Quality Protection Division  
VOICE: 214-665-7153  
FAX: 214-665-2191  
EMAIL: [nguyen.tung@epa.gov](mailto:nguyen.tung@epa.gov)

**PERMIT ACTION:** Final permit decision and response to comments received on the draft reissued NPDES permit publicly noticed on May 30, 2013.

**DATE PREPARED:** August 27, 2013

Unless otherwise stated, citations to 40 CFR refer to promulgated regulations listed at Title 40, Code of Federal Regulations, revised as of July 1, 2013.

**DOCUMENT ABBREVIATIONS**

In the document that follows, various abbreviations are used. They are as follows:

4Q3	Lowest four-day average flow rate expected to occur once every three-years
BAT	Best available technology economically achievable
BCT	Best conventional pollutant control technology
BPT	Best practicable control technology currently available
BMP	Best management plan
BOD	Biochemical oxygen demand (five-day unless noted otherwise)
BPJ	Best professional judgment
CBOD	Carbonaceous biochemical oxygen demand (five-day unless noted otherwise)
CD	Critical dilution
CFR	Code of Federal Regulations
cfs	Cubic feet per second
COD	Chemical oxygen demand
COE	United States Corp of Engineers
CWA	Clean Water Act
DMR	Discharge monitoring report
ELG	Effluent limitation guidelines
EPA	United States Environmental Protection Agency
ESA	Endangered Species Act
FCB	Fecal coliform bacteria
F&WS	United States Fish and Wildlife Service
mg/l	Milligrams per liter
ug/l	Micrograms per liter
MGD	Million gallons per day
NMAC	New Mexico Administrative Code
NMED	New Mexico Environment Department
NMP	New Mexico NPDES Permit Implementation Procedures
NMWQS	New Mexico State Standards for Interstate and Intrastate Surface Waters.
NPDES	National Pollutant Discharge Elimination System
ML	Minimum quantification level
O&G	Oil and grease
POTW	Publically owned treatment works
RP	Reasonable potential
s.u.	Standard units (for parameter pH)
SWQB	Surface Water Quality Bureau
TDS	Total dissolved solids
TMDL	Total maximum daily load
TRC	Total residual chlorine
TSS	Total suspended solids
UAA	Use attainability analysis
USFWS	United States Fish & Wildlife Service
USGS	United States Geological Service
WLA	Wasteload allocation
WET	Whole effluent toxicity
WQCC	New Mexico Water Quality Control Commission
WQMP	Water Quality Management Plan

SUBSTANTIAL CHANGES FROM DRAFT PERMIT

There is no change from the draft NPDES permit publicly noticed on May 30, 2013.

STATE CERTIFICATION

Letter from James Hogan, New Mexico Environment Department (NMED) to William K. Honker, (EPA) dated July 9, 2013.

CONDITIONS OF CERTIFICATION

There are no conditions of State certification.

COMMENTS RECEIVED ON THE DRAFT PERMIT

Letter from Michael Sloane, New Mexico Department of Game and Fish to Diane Smith, EPA dated June 20, 2013.

RESPONSE TO COMMENTS

**Comment 1:** "The New Mexico Department of Game and Fish, Lisboa Springs State Fish Hatchery, requests Whole Effluent Toxicity test (WET) requirements using the 7 day chronic test method for *Ceriodaphnia dubia* and *Pimephales promelas* at a frequency of once per term remain in effect from the previous permit. Lisboa Springs State Fish Hatchery has consistently passed WET tests over previous permit terms. In addition, an increase in WET test frequency to once/6 months would be extremely burdensome causing a significant increase in work load and requisite budget. The cost incurred is estimated to be approximately four times greater than if this request is granted. If the above mentioned request for continuing the 7 day chronic test using *Ceriodaphnia dubia* and *Pimephales promelas* at a frequency of once per permit term is not granted, the New Mexico Department of Game and Fish, Lisboa Springs State Fish Hatchery requests that the proposed WET test requirements be phased in and only become fully effective during the final year of the permit to allow for operational planning and cost allocation."

**Response 1:** The WET requirements, acute (48-hr.) test using *Daphnia pulex* and *Pimephales promelas* once every six months, are based on the NMIP in consultation with the Surface Water Quality Bureau, New Mexico Environmental Department. Pursuant to 40 CFR 122.44(d) EPA believes the established WET requirements are most appropriate to insure no source will be allowed to discharge any wastewater which results in instream aquatic toxicity, or otherwise cause a violation of State water quality standard. Please note acute test significantly costs less than chronic test in the previous permit, and if all tests pass during the first year, acute test using *Pimephales promelas* will go down to once/year for remaining permit term. EPA is not able to accommodate the requests and there will be no change in the established WET requirements.

**Comment 2:** "The New Mexico Department of Game and Fish, Lisboa Springs State Fish Hatchery, has eliminated chlorine usage in a manner potentially causing the presence of residual chlorine at the facility. In addition, there is no basis for the proposed monitoring and reporting requirement for TRC as it was uncertainly detected below a concerned level at the settling pond. It is therefore requested that proposed monitoring and reporting requirements for TRC be removed."

**Response 2:** As stated in the Effluent Characteristic, TRC was detected below 0.1 mg/L (100 ug/L). TRC limit was established with a daily maximum of 19 ug/L at Outfall 01B in the previous permit. The following are basis that EPA requires the permittee to monitor and report TRC during the next permit term:

- a. The permittee inadequately demonstrated compliance with the limit requirement for TRC because the detected TRC was not always at or below the limit.
- b. According to OTIS (see attachment), during the previous permit term the permittee was in violations for not submitting TRC reports on time and one effluent violation dated on May 31, 2011.
- c. An EPA Administrative Complaint dated October 25, 2011 (CWA-06-2011-1900) shows there was a TRC exceedance of 200 ug/L released into the receiving stream that resulted in a fish kill.
- d. In the letter dated March 3, 2011 the permittee stated each analyte was not detected at or above the MQL, except boron; this statement was inaccurate since the detected TRC was not certainly below its MQL (33 ug/L).

On July 22, 2013 the permittee requested to have TRC monitored for the first year and to have TRC monitoring removed thereafter if the TRC results would be consistently non-detect. Pursuant to 40 CFR 122.44(i)(1) and (2), EPA believes TRC monitoring is appropriate to assure the permittee is not discharging TRC in harmful amounts. EPA does not concur with the permittee's latest request, and the TRC monitoring requirement remains in the final permit.

**Comment 3:** "The New Mexico Department of Game and Fish, Lisboa Springs State Fish Hatchery, asks to have the list of MQL's be attached in Appendix A of Part II as stated in the first paragraph."

**Response 3:** Appendix A was inadvertently omitted from the proposed permit and is included in the final permit.



REGION 6  
1445 ROSS AVENUE  
DALLAS, TEXAS 75202-2733

NPDES Permit No NM0030121

## AUTHORIZATION TO DISCHARGE UNDER THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Clean Water Act, as amended, (33 U.S.C. 1251 et. seq; the "Act"),

Lisboa Springs State Fish Hatchery  
P.O. Box 25112  
Santa Fe, NM 87508

is authorized to discharge from a facility located at 11 Route 2-HC 74 Box 61, City of Pecos, San Miguel County, New Mexico, to Pecos River, in Segment No. 20.6.4.217 of the Pecos River Basin.

Outfall 002 - Latitude 35° 36' 30.2" North, Longitude 105° 40' 36.9" West  
Outfall 003 - Latitude 35° 36' 29.7" North, Longitude 105° 40' 35.9" West  
Outfall 004 - Latitude 35° 36' 33.7" North, Longitude 105° 40' 37.4" West

in accordance with this cover page and the effluent limitations, monitoring requirements and other conditions set forth in Part I, Part II and Part III.


This permit supersedes and replaces NPDES Permit No. NM0030121 with an effective date of October 1<sup>st</sup>, 2006.


This permit shall become effective on October 1, 2013

This permit and the authorization to discharge shall expire at midnight, September 30, 2018

Issued on August 28, 2013

Prepared by

  
William K. Honker, P.E.  
Division Director  
Water Quality Protection Division (6WQ)

  
Tung Nguyen  
Environmental Engineer  
Permits & Technical Section (6WQ-PP)

## DOCUMENT ABBREVIATIONS

In the document that follows, various abbreviations are used. They are as follows:

4Q3	Lowest four-day average flow rate expected to occur once every three-years
BAT	Best available technology economically achievable
BCT	Best conventional pollutant control technology
BPT	Best practicable control technology currently available
BMP	Best management plan
BOD	Biochemical oxygen demand (five-day unless noted otherwise)
BPJ	Best professional judgment
CBOD	Carbonaceous biochemical oxygen demand (five-day unless noted otherwise)
CD	Critical dilution
CFR	Code of Federal Regulations
cfs	Cubic feet per second
COD	Chemical oxygen demand
COE	United States Corp of Engineers
CWA	Clean Water Act
DMR	Discharge monitoring report
ELG	Effluent limitation guidelines
EPA	United States Environmental Protection Agency
ESA	Endangered Species Act
FCB	Fecal coliform bacteria
FWS	United States Fish and Wildlife Service
mg/l	Milligrams per liter
ug/l	Micrograms per liter
lbs	Pounds
MGD	Million gallons per day
NMAC	New Mexico Administrative Code
NMED	New Mexico Environment Department
NMIP	New Mexico NPDES Permit Implementation Procedures
NMWQS	New Mexico State Standards for Interstate and Intrastate Surface Waters
NPDES	National Pollutant Discharge Elimination System
SQL	Minimum quantification level
O&G	Oil and grease
POTW	Publically owned treatment works
RP	Reasonable potential
SS	Settleable solids
SIC	Standard industrial classification
s.u.	Standard units (for parameter pH)
SWQB	Surface Water Quality Bureau
TDS	Total dissolved solids
TMDL	Total maximum daily load
TRC	Total residual chlorine
TSS	Total suspended solids
UAA	Use attainability analysis
USGS	United States Geological Service
WLA	Wasteload allocation
WET	Whole effluent toxicity
WQCC	New Mexico Water Quality Control Commission
WQMP	Water Quality Management Plan
WWTP	Wastewater treatment plant

**PART I – REQUIREMENTS FOR NPDES PERMITS****A. LIMITATIONS AND MONITORING REQUIREMENTS**

## 1. OUTFALL 002, 003 - FINAL Effluent Limits – 0.98 MGD

During the period beginning the effective date of the permit and lasting through the expiration date of the permit (unless otherwise noted), the permittee is authorized to discharge hatchery wastewater to Pecos River (Segment 20.6.4.217) from Outfall 002 and 003. Such discharges shall be limited and monitored by the permittee and reported as Outfall 002, as specified below:

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS		MONITORING REQUIREMENTS	
	MINIMUM	MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH	6.6 s.u.	8.8 s.u.	2/Month	Grab

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS					MONITORING REQUIREMENTS	
	lbs/day, unless noted		mg/l, unless noted (*1)			MEASUREMENT FREQUENCY	SAMPLE TYPE
POLLUTANT	30-DAY AVG	DAILY MAX	30-DAY AVG	7-DAY AVG	DAILY MAX		
Flow	Report MGD	Report MGD	***	***	***	Daily	Measured over weir
TSS	82	123	10	N/A	15	2/Month (*2)	Grab
SS	N/A	N/A	0.1 ml/l	N/A	0.5 ml/l	2/Month (*2)	Grab
TRC	N/A	N/A	N/A	N/A	Report	2/Month (*2,6)	Instantaneous Grab (*5)

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS		MONITORING REQUIREMENTS	
	30-DAY AVG	48-HOUR MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
WHOLE EFFLUENT TOXICITY TESTING 48-HOUR STATIC RENEWAL (*3)				
Daphnia pulex	Report	Report	Once/6 month (*4)	Grab
Pimephales promelas	Report	Report	Once/6 month (*4)	Grab

Footnotes:

- \*1 See Appendix A of Part II of the permit for minimum quantification limits.
- \*2 The first sample event of any reporting period shall be at least 10-days from the first sample event of the previous reporting period. Sampling shall be during times of cleaning of raceways, troughs or tanks if possible.
- \*3 Monitoring and reporting requirements begin on the effective date of this permit. See Part II of the permit for WET testing requirements for additional WET monitoring and reporting conditions.
- \*4 The tests shall take place between April 1 and June 30, and six months thereafter. This permit does not establish requirements to automatically increase the WET testing frequency after a test failure, or to begin a toxicity reduction evaluation (TRE) in the event of multiple failures. However, upon failure of any WET test, the permittee must report the results to EPA and NMED, Surface Water Quality Bureau, in writing, within 5 business days of notification of the test failure. EPA and NMED will review the test results and determine the appropriate action necessary, if any.
- \*5 The sample shall be taken approximately 30 minutes after the expected slug of water has passed through the outfall. The expected time of arrival can be estimated by direct observations with light floatable object.
- \*6 TRC is sampled at Settling Pond.

## 2. OUTFALL 004 (Intermittent Flow) - FINAL Effluent Limits

During the period beginning the effective date of the permit and lasting through the expiration date of the permit (unless otherwise noted), the permittee is authorized to discharge hatchery wastewater to Pecos River (Segment 20.6.4.217) from Outfall 004. Such discharges shall be limited and monitored by the permittee and reported as Outfall 004, as specified below:

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS		MONITORING REQUIREMENTS	
	MINIMUM	MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
POLLUTANT				
pH	6.6 s.u.	8.8 s.u.	2/Month	Grab

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS					MONITORING REQUIREMENTS	
	lbs/day, unless noted		mg/l, unless noted (*1)			MEASUREMENT FREQUENCY	SAMPLE TYPE
POLLUTANT	30-DAY AVG	DAILY MAX	30-DAY AVG	7-DAY AVG	DAILY MAX		
Flow	Report MGD	Report MGD	***	***	***	Daily	Estimated over weir
TSS	Report	Report	10	N/A	15	2/Month (*2)	Grab
SS	N/A	N/A	0.1 ml/l	N/A	0.5 ml/l	2/Month (*2)	Grab

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS		MONITORING REQUIREMENTS	
	30-DAY AVG	48-HOUR MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
WHOLE EFFLUENT TOXICITY TESTING 48-HOUR STATIC RENEWAL (*3)				
Daphnia pulex	Report	Report	Once/6 month (*4)	Grab
Pimephales promelas	Report	Report	Once/6 month (*4)	Grab

Footnotes:

- \*1 See Appendix A of Part II of the permit for minimum quantification limits.
- \*2 The first sample event of any reporting period shall be at least 10-days from the first sample event of the previous reporting period.
- \*3 Monitoring and reporting requirements begin on the effective date of this permit. See Part II of the permit for WET testing requirements for additional WET monitoring and reporting conditions.
- \*4 Every six months when discharging. This permit does not establish requirements to automatically increase the WET testing frequency after a test failure, or to begin a toxicity reduction evaluation (TRE) in the event of multiple failures. However, upon failure of any WET test, the permittee must report the results to EPA and NMED, Surface Water Quality Bureau, in writing, within 5 business days of notification of the test failure. EPA and NMED will review the test results and determine the appropriate action necessary, if any.

## 3. OUTFALL 01B (Special Testing)- FINAL Effluent Limits: Non-FDA Approved Drugs, Medications and/or Chemicals

During the period beginning the effective date of the permit and lasting through the expiration date of the permit (unless otherwise noted), the permittee is authorized to discharge hatchery wastewater containing either non-approved Food and Drug Administration (FDA) drugs, medications or chemicals (DMC), or DMC used in a manner not consistent with FDA approval, to the Pecos River (Segment 20.6.4.217) from Outfalls 002, 003 and 004 (See Part II). Such discharges shall be limited and monitored by the permittee and reported as Outfall 01B, as specified below:

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS					MONITORING REQUIREMENTS	
	lbs/day, unless noted		mg/l, unless noted (*1)			MEASUREMENT FREQUENCY	SAMPLE TYPE
POLLUTANT	30-DAY AVG	DAILY MAX	30-DAY AVG	7-DAY AVG	DAILY MAX		
Flow	Report MGD	Report MGD	***	***	***	Daily	Estimated over weir
TRC	N/A	N/A	N/A	N/A	Report	Daily	Instantaneous Grab (*5)

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS		MONITORING REQUIREMENTS	
	30-DAY AVG	48-HOUR MINIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
WHOLE EFFLUENT TOXICITY TESTING 48-HOUR STATIC RENEWAL (*2)				
Daphnia pulex	Report	Report	Once/Use (*3)	Grab (*4)
Pimephales promelas	Report	Report	Once/Use (*3)	Grab (*4)

## Footnotes:

- \*1 See Appendix A of Part II of the permit for minimum quantification limits.
- \*2 Monitoring and reporting requirements begin on the effective date of this permit. See Part II of the permit for WET testing requirements for additional WET monitoring and reporting conditions.
- \*3 Once/Use is for intermittent use of DMC. For long-term use, only one WET shall be required on the maximum dosage. If any dose is later increased by more than 20% of the maximum dosage, then additional WET tests will be required. This permit does not establish requirements to automatically increase the WET testing frequency after a test failure, or to begin a toxicity reduction evaluation (TRE) in the event of multiple failures. However, upon failure of any WET test, the permittee must report the results to EPA and NMED, Surface Water Quality Bureau, in writing, within 5 business days of notification of the test failure. EPA and NMED will review the test results and determine the appropriate action necessary, if any.
- \*4 The sample shall be taken approximately 30 minutes after the expected time of arrival of the treated water has passed through the outfall. The expected time of arrival can be estimated by direct observations with light floatable object.
- \*5 The sample shall be taken approximately 30 minutes after the expected slug of water has passed through the outfall. The expected time of arrival can be estimated by direct observations with light floatable object.

**4. FLOATING SOLIDS, VISIBLE FOAM AND/OR OILS**

There shall be no discharge of floating solids or visible foam in other than trace amounts.

There shall be no discharge of visible films of oil, globules of oil, grease or solids in or on the water, or coatings on stream banks.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge from the final treatment unit prior to the receiving stream. The sample point shall be clearly marked by the facility if it is not at the final outfall location. There shall be no flow from any source into the piping system after the sample point and prior to the final outfall.

**B. SCHEDULES OF COMPLIANCE**

None.

**C. MONITORING AND REPORTING (MINOR DISCHARGERS)**

Monitoring results must be reported to EPA on either the electronic or paper Discharge Monitoring Report (DMR) approved formats. Monitoring results can be submitted electronically in lieu of the paper DMR Form. To submit electronically, access the NetDMR website at [www.epa.gov/netdmr](http://www.epa.gov/netdmr) and contact the [R6NetDMR@epa.gov](mailto:R6NetDMR@epa.gov) in-box for further instructions. Until you are approved for Net DMR, you must report on the Discharge Monitoring Report (DMR) Form EPA No. 3320-1 in accordance with the "General Instructions" provided on the form. No additional copies are needed if reporting electronically, however when submitting paper form EPA No. 3320-1, the permittee shall submit the original DMR signed and certified as required by Part III.D.11 and all other reports required by Part III.D. to the EPA and other agencies as required (See Part III.D.IV of the permit). Reports shall be submitted quarterly.

1. Reporting periods shall end on the last day of the months March, June, September, and December.
2. The permittee is required to submit regular quarterly reports as described above postmarked no later than the 28<sup>th</sup> day of the month following each reporting period.
3. NO DISCHARGE REPORTING

If there is no discharge from any outfall during the sampling month, place an "X" in the NO DISCHARGE box located in the upper right corner of the Discharge Monitoring Report.

**D. OVERFLOW REPORTING**

The permittee shall report all overflows with the Discharge Monitoring Report submittal. These reports shall be summarized and reported in tabular format. The summaries shall include: the date, time, duration, location, estimated volume, and cause of the overflow; observed environmental impacts from the overflow; actions taken to address the overflow; and ultimate discharge location if not contained (e.g., storm sewer system, ditch, tributary).

Overflows that endanger health or the environment shall be orally reported at (214) 665-6595, and NMED Surface Water Quality Bureau at (505) 827-0187, within 24 hours from the time the permittee

becomes aware of the circumstance. A written report of overflows that endanger health or the environment shall be provided to EPA and the NMED Surface Water Quality Bureau within 5 days of the time the permittee becomes aware of the circumstance.

#### **E. POLLUTION PREVENTION REQUIREMENTS**

The permittee shall institute a program within 12 months of the effective date of the permit (or continue an existing one) directed towards optimizing the efficiency and extending the useful life of the facility. The permittee shall consider the following items in the program:

- a. The influent loadings, flow and design capacity;
- b. The effluent quality and plant performance;
- c. The age and expected life of the wastewater treatment facility's equipment;
- d. Bypasses and overflows of the tributary sewerage system and treatment works;
- e. New developments at the facility;
- f. Operator certification and training plans and status;
- g. The financial status of the facility;
- h. Preventative maintenance programs and equipment conditions and;
- i. An overall evaluation of conditions at the facility.

**PART II - OTHER CONDITIONS****A. MINIMUM QUANTIFICATION LEVEL (MQL)**

See list of MQL's at Appendix A of Part II below. For pollutants listed on Appendix A of Part II below with MQL's, analyses must be performed to the listed MQL. If any individual analytical test result is less than the MQL listed, a value of zero (0) may be used for that pollutant result for the Discharge Monitoring Report (DMR) calculations and reporting requirements.

In addition, any additional pollutant sampling for purposes of this permit, including renewal applications or any other reporting, shall be tested to the MQL shown on the attached Appendix A of Part II.

The permittee may develop an effluent specific method detection limit (MDL) in accordance with Appendix B to 40 CFR §136. For any pollutant for which the permittee determines an effluent specific MDL, the permittee shall send to the EPA Region 6 NPDES Permits Branch (6WQ-P) a report containing QA/QC documentation, analytical results, and calculations necessary to demonstrate that the effluent specific MDL was correctly calculated. An effluent specific MQL shall be determined in accordance with the following calculation:

$$\text{MQL} = 3.3 \times \text{MDL}$$

Upon written approval by the EPA Region 6 NPDES Permits Branch (6WQ-P), the effluent specific MQL may be utilized by the permittee for all future DMR reporting requirements until/or unless changes are required for adoption of a lower MQL.

**B. 24-HOUR ORAL REPORTING: DAILY MAXIMUM LIMITATION VIOLATIONS**

Under the provisions of Part III.D.7.b.(3) of this permit, violations of daily maximum limitations for the following pollutants shall be reported orally to EPA Region 6, Compliance and Assurance Division, Water Enforcement Branch (6EN-W), Dallas, Texas, and concurrently to NMED within 24 hours from the time the permittee becomes aware of the violation followed by a written report in five days.

None

**C. PERMIT MODIFICATION AND REOPENER**

In accordance with [40 CFR Part 122.44(d)], the permit may be reopened and modified during the life of the permit if relevant portions of New Mexico's Water Quality Standards for Interstate and Intrastate Streams are revised, or new State water quality standards are established and/or remanded by the New Mexico Water Quality Control Commission.

In accordance with [40 CFR Part 122.62(s)(2)], the permit may be reopened and modified if new information is received that was not available at the time of permit issuance that would have justified the application of different permit conditions at the time of permit issuance. Permit modifications shall reflect the results of any of these actions and shall follow regulations listed at [40 CFR Part 124.5].

**D. WHOLE EFFLUENT TOXICITY TESTING (48-HOUR ACUTE NOEC FRESHWATER)**

## 1. SCOPE AND METHODOLOGY

- a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

APPLICABLE TO FINAL OUTFALL(S):	002, 003, 004
REPORTED ON DMR AS FINAL OUTFALL:	Applicable 002 or 004
EFFLUENT DILUTION SERIES:	4%, 5%, 7%, 9%, and 12%
CRITICAL DILUTION:	9%
COMPOSITE SAMPLE TYPE:	Defined at PART I
TEST SPECIES/METHODS:	40 CFR Part 136

Daphnia pulex acute static renewal 48-hour definitive toxicity test using EPA-821-R-02-012, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

Pimephales promelas (Fathead minnow) acute static renewal 48-hour definitive toxicity test using EPA-821-R-02-012, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

- b. The NOEC (No Observed Lethal Effect Concentration) is defined as the greatest effluent dilution at and below which lethality that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Acute test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution.
- c. This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.
- d. Test failure is defined as a demonstration of statistically significant lethal effects to a test species at or below the effluent critical dilution.
- e. This permit does not establish requirements to automatically increase the WET testing frequency after a test failure, or to begin a toxicity reduction evaluation (TRE) in the event of multiple test failures. However, upon failure of any WET test, the permittee must report the test results to NMED, Surface Water Quality Bureau, in writing, within 5 business days of notification the test failure. NMED will review the test results and determine the appropriate action necessary, if any.

## 2. REQUIRED TOXICITY TESTING CONDITIONS

### a. Test Acceptance

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- Each toxicity test control (0% effluent) must have a survival equal to or greater than 90%.
- The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for *Daphnia pulex* survival test, and Fathead minnow survival test.
- The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, unless significant lethal effects are exhibited for *Daphnia pulex* survival test, and Fathead minnow survival test.

Test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%. A repeat test shall be conducted within the required reporting period of any test determined to be invalid.

### b. Statistical Interpretation

For the *Daphnia pulex* survival test and the Fathead minnow survival test, the statistical analyses used to determine if there is a statistically significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect Concentration (NOEC) as described in EPA-821-R-02-012 or the most recent update thereof.

If the conditions of Test Acceptability are met in Item 2.a above and the percent survival of the test organism is equal to or greater than 90% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report an NOEC of not less than the critical dilution for the reporting requirements found in Item 3 below.

### c. Dilution Water

- Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness, and alkalinity to the closest downstream perennial water for;
  - toxicity tests conducted on effluent discharges to receiving water classified as intermittent streams; and
  - toxicity tests conducted on effluent discharges where no receiving water is available due to zero flow conditions.
- If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 2.a), the permittee may substitute synthetic dilution water

for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:

- a synthetic dilution water control which fulfills the test acceptance requirements of Item 3.a was run concurrently with the receiving water control;
- the test indicating receiving water toxicity has been carried out to completion (i.e., 48 hours);
- the permittee includes all test results indicating receiving water toxicity with the full report and information required by Item 3 below; and
- the synthetic dilution water shall have a pH, hardness, and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

- The permittee shall collect two **grab** samples from the outfall(s) listed at Item 1.a above.
- The permittee shall collect a second **grab** sample for use during the 24 hour renewal of each dilution concentration for the tests. The permittee must collect the **grab** samples so that the maximum holding time for any effluent sample shall not exceed 36 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first **grab** sample. Samples shall be chilled to 6 degrees Centigrade during collection, shipping, and/or storage.
- The permittee must collect the **grab** samples such that the effluent samples are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on an intermittent basis.
- If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must collect an effluent **grab** sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days. The effluent **grab** sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in Item 3 of this section.

3. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this Part in accordance with the Report Preparation Section of EPA 821 R 02 012, for every valid or invalid toxicity test initiated, whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of PART III.C.3 of this permit. The permittee shall submit full reports upon the specific request of the Agency. For any test

which fails, is considered invalid or which is terminated early for any reason, the full report must be submitted for agency review.

- b. A valid test for each species must be reported during each reporting period specified in PART I of this permit unless the permittee is performing a TRE which may increase the frequency of testing and reporting. Only ONE set of biomonitoring data for each species is to be recorded for each reporting period. The data submitted should reflect the LOWEST Survival results for each species during the reporting period. All invalid tests, repeat tests (for invalid tests), and retests (for tests previously failed) performed during the reporting period must be attached for EPA review.
- c. The permittee shall report the following results of each valid toxicity test. Submit retest information, if required, clearly marked as such. Only results of valid tests are to be reported.

Daphnia pulex

- If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM3D.
- Report the NOEC value for survival, Parameter No. TOM3D.
- Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM3D.

Pimephales promelas (Fathead minnow)

- If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM6C.
  - Report the NOEC value for survival, Parameter No. TOM6C.
  - Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM6C.
- d. If retests are required by NMED, enter the following codes:
- For retest number 1, Parameter 22415, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."
  - For retest number 2, Parameter 22416, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."

**E. DRUGS, MEDICATIONS and CHEMICALS (DMC)**

The permittee shall comply with reporting requirements pursuant to 40 CFR 451.3 if investigational new animal drug (INAD) or any extralabel drug is used where such the use may lead to the receiving water. Reporting is not required for an INAD or extralabel drug, previously approved by FDA, if its use is at or below the approved dosage and involves similar conditions of uses. The permittee shall also notify NMED and EPA of the use of non-FDA (U.S. Food and Drug Administration) approved drug. Notification to NMED shall be by phone within one business day and to EPA within three days of the intention. Written notification shall also be both NMED and EPA within five business days.

When the DMC used is neither approved by FDA or its use is not consistent with FDA practices, including INAD and extralabel drug with above approved dosage, such that may lead to the receiving water, the permittee shall conduct WET tests below.

**WHOLE EFFLUENT TOXICITY TESTING (48-HOUR ACUTE NOEC FRESHWATER)****1. SCOPE AND METHODOLOGY**

- a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

APPLICABLE TO FINAL OUTFALL(S):	01B
REPORTED ON DMR AS FINAL OUTFALL:	01B
EFFLUENT DILUTION SERIES:	32%, 42%, 56%, 75%, and 100%
CRITICAL DILUTION:	100%
COMPOSITE SAMPLE TYPE:	Defined at PART I
TEST SPECIES/METHODS:	40 CFR Part 136

Daphnia pulex acute static renewal 48-hour definitive toxicity test using EPA-821-R-02-012, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

Pimephales promelas (Fathead minnow) acute static renewal 48-hour definitive toxicity test using EPA-821-R-02-012, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

- b. The NOEC (No Observed Lethal Effect Concentration) is defined as the greatest effluent dilution at and below which lethality that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Acute test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution.

- c. This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.
- d. Test failure is defined as a demonstration of statistically significant lethal effects to a test species at or below the effluent critical dilution.
- e. This permit does not establish requirements to automatically increase the WET testing frequency after a test failure, or to begin a toxicity reduction evaluation (TRE) in the event of multiple test failures. However, upon failure of any WET test, the permittee must report the test results to NMED, Surface Water Quality Bureau, in writing, within 5 business days of notification the test failure. NMED will review the test results and determine the appropriate action necessary, if any.

## 2. REQUIRED TOXICITY TESTING CONDITIONS

### a. Test Acceptance

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- Each toxicity test control (0% effluent) must have a survival equal to or greater than 90%.
- The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for *Daphnia pulex* survival test, and Fathead minnow survival test.
- The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, unless significant lethal effects are exhibited for *Daphnia pulex* survival test, and Fathead minnow survival test.

Test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%. A repeat test shall be conducted within the required reporting period of any test determined to be invalid.

### b. Statistical Interpretation

For the *Daphnia pulex* survival test and the Fathead minnow survival test, the statistical analyses used to determine if there is a statistically significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect Concentration (NOEC) as described in EPA-821-R-02-012 or the most recent update thereof.

If the conditions of Test Acceptability are met in Item 2.a above and the percent survival of the test organism is equal to or greater than 90% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report an NOEC of not less than the critical dilution for the reporting requirements found in Item 3 below.

### c. Dilution Water

- Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness, and alkalinity to the closest downstream perennial water for;
  - toxicity tests conducted on effluent discharges to receiving water classified as intermittent streams; and
  - toxicity tests conducted on effluent discharges where no receiving water is available due to zero flow conditions.
- If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 2.a), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:
  - a synthetic dilution water control which fulfills the test acceptance requirements of Item 3.a was run concurrently with the receiving water control;
  - the test indicating receiving water toxicity has been carried out to completion (i.e., 48 hours);
  - the permittee includes all test results indicating receiving water toxicity with the full report and information required by Item 3 below; and
  - the synthetic dilution water shall have a pH, hardness, and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

- The permittee shall collect two **grab** samples from the outfall(s) listed at Item 1.a above.
- The permittee shall collect a second **grab** sample for use during the 24 hour renewal of each dilution concentration for the tests. The permittee must collect the **grab** samples so that the maximum holding time for any effluent sample shall not exceed 36 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first **grab** sample. Samples shall be chilled to 6 degrees Centigrade during collection, shipping, and/or storage.
- The permittee must collect the **grab** samples such that the effluent samples are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on an intermittent basis.
- If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must collect an effluent **grab** sample volume during the

period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days. The effluent **grab** sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in Item 3 of this section.

### 3. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this Part in accordance with the Report Preparation Section of EPA 821 R 02-012, for every valid or invalid toxicity test initiated, whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of PART III.C.3 of this permit. The permittee shall submit full reports upon the specific request of the Agency. For any test which fails, is considered invalid or which is terminated early for any reason, the full report must be submitted for agency review.
- b. A valid test for each species must be reported during each reporting period specified in PART I of this permit unless the permittee is performing a TRE which may increase the frequency of testing and reporting. Only ONE set of biomonitoring data for each species is to be recorded for each reporting period. The data submitted should reflect the LOWEST Survival results for each species during the reporting period. All invalid tests, repeat tests (for invalid tests), and retests (for tests previously failed) performed during the reporting period must be attached for EPA review.
- c. The permittee shall report the following results of each valid toxicity test. Submit retest information, if required, clearly marked as such. Only results of valid tests are to be reported.

#### Daphnia pulex

- If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM3D.
- Report the NOEC value for survival, Parameter No. TOM3D.
- Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM3D.

#### Pimephales promelas (Fathead minnow)

- If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM6C.
- Report the NOEC value for survival, Parameter No. TOM6C.
- Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM6C.

- d. If retests are required by NMED, enter the following codes:

- For retest number 1, Parameter 22415, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."
- For retest number 2, Parameter 22416, enter a "1" if the NOEC for survival is less than the critical dilution; otherwise, enter a "0."

#### **F. CHLORINE USEAGE AS TREATMENT**

The permittee shall not use chlorine in the hatchery operation nor discharge any chlorine that may eventually lead to the outfall(s) at the facility.

#### **G. BEST MANAGEMENT PRACTICES**

##### **1. IMPLEMENTATION**

The permittee shall develop and implement a Best Management Practices (BMP) Plan that achieves the objectives and the specific requirements listed below. A copy of the plan shall be submitted to EPA and NMED within three (3) months of the effective date of the permit. EPA shall have the right to disapprove the BMP plan within sixty (60) days of receipt of the plan. Upon receipt of a BMP denial, the permittee shall resubmit a revised Plan within 30-days. Upon either acceptance of the Plan, or no-action by EPA after the 60-day review time, the plan shall be deemed approved. The Plan shall be implemented as soon as possible but no later than six (6) months from the date of approval.

##### **2. PURPOSE**

Through implementation of the BMP Plan the permittee shall prevent or minimize the generation of and the potential for the release of pollutants from the facility to the waters of the United States through normal operations and ancillary activities.

##### **3. OBJECTIVES**

The permittee shall develop and amend the BMP Plan consistent with the following objectives for the control of pollutants.

- a. The number and quantity of pollutants and the toxicity of effluent generated, discharged or potentially discharged at the facility shall be minimized by the permittee to the extent feasible by managing each influent waste stream in the most appropriate manner.
- b. Under the BMP Plan, and any Standard Operating Procedures (SOPs) included in the Plan, the permittee shall ensure proper operation and maintenance of the treatment facility.

##### **4. REQUIREMENTS**

The BMP Plan shall be consistent with the objectives mentioned above and the general guidance contained in the publication entitled "Best Management [practices Guidance Document" (U.S. EPA 1981) or "Guidance manual for Developing Best Management Practices (BMP's)" (U.S. EPA October 1993), or any subsequent revisions to the guidance document where applicable.

The Plan shall be documented in narrative form, and shall include any necessary plot plan, drawings or maps, and shall be developed in accordance with good engineering practices. The BMP Plan shall be organized and written with the following structures:

- a. Name and location of the facility.
- b. Statement of BMP policy.
- c. The location of all monitoring (sampling) stations.
- d. Summary of all data required to the monitoring and sampled for as a permit condition.
- e. Specific management practices and standard operating procedures to achieve objective, including, but not limited to the following:
  - Modification of equipment, facilities, technology, procedures.
  - Improvement in management or general operational phases of the facility.
  - Inspections and records.
  - Reporting of BMP's incidents.

## 5. MINIMUM PRACTICES REQUIRED AND IMPLEMENTED IN THE BMP

- a. Solids Control
  - Employ efficient feed management and feeding strategies that limit feed input to the minimum amount reasonably necessary to achieve production goals and sustain targeted rates of aquatic animal growth in order to minimize potential discharges of uneaten feed and waste products to waters of the U.S.
  - In order to minimize the discharge of accumulated solids from settling ponds and basins and production systems, identify and implement procedures for routine cleaning of rearing units and off-line settling basins, and procedures to minimize any discharge of accumulated solids during the inventorying, grading and harvesting aquatic animals in the production system.
  - Remove and dispose of aquatic animal mortalities properly on a regular basis to prevent discharge to waters of the U.S., except in cases where the permitting authority authorizes such discharge in order to benefit the aquatic environment.
- b. Materials Storage
  - Ensure proper storage of drugs, pesticides, and feed in a manner designed to prevent spills that may result in the discharge of drugs, pesticides or feed to waters of the U.S.
  - Implement procedures for properly containing, cleaning, and disposing of any spilled material.
- c. Structural Maintenance
  - Inspect the production system and the wastewater treatment system on a routine basis in order to identify and promptly repair any damage.
  - Conduct regular maintenance of the production system and the wastewater treatment system in order to ensure that they are properly functioning.
- d. Recordkeeping
  - In order to calculate representative feed conversion ratios, maintain records for aquatic animal rearing units documenting the feed amounts and estimates of the numbers and weight of aquatic animals.

- Keep records documenting the frequency of cleaning, inspections, maintenance and repairs.
- e. Training
- The permittee must:
- In order to ensure the proper clean-up and disposal of spilled material adequately train all relevant facility personnel in spill prevention and how to respond in the event of a spill.
  - Train staff on the proper operation and cleaning of production and wastewater treatment systems including training in feeding procedures and proper use of equipment.

## 6. DOCUMENTATION

The permittee shall maintain a copy of the BMP Plan at the facility and shall make the plan available to EPA upon request.

## 7. MODIFICATION

The permittee shall amend a copy of the BMP Plan whenever there is a change in the facility or in the operation of the facility that increases the generation of pollutants or their release or potential release to the receiving waters. The permittee shall also amend the plan, as appropriate, when plant operations covered by the BMP Plan change. Any such changes to the BMP shall be consistent with the objective and specific requirements listed above. All changes in the BMP Plan shall be reported to EPA in writing.

## 8. MODIFICATION FOR INEFFECTIVENESS

At any time, if the BMP Plan proves to be ineffective in achieving the general objective of preventing and minimizing the generation of pollutants and their release and potential release to the receiving waters and/or meeting the specific requirements above, the permit and/or the BMP Plan shall be subject to modifications to incorporate revised BMP requirements.

**PART III - STANDARD CONDITIONS FOR NPDES PERMITS****A. GENERAL CONDITIONS****1. INTRODUCTION**

In accordance with the provisions of 40 CFR Part 122.41, et. seq., this permit incorporates by reference ALL conditions and requirements applicable to NPDES Permits set forth in the Clean Water Act, as amended, (hereinafter known as the "Act") as well as ALL applicable regulations.

**2. DUTY TO COMPLY**

The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of the Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or for denial of a permit renewal application.

**3. TOXIC POLLUTANTS**

a. Notwithstanding Part III.A.5, if any toxic effluent standard or prohibition (including any schedule of compliance specified in such effluent standard or prohibition) is promulgated under Section 307(a) of the Act for a toxic pollutant which is present in the discharge and that standard or prohibition is more stringent than any limitation on the pollutant in this permit, this permit shall be modified or revoked and reissued to conform to the toxic effluent standard or prohibition.

b. The permittee shall comply with effluent standards or prohibitions established under Section 307(a) of the Act for toxic pollutants within the time provided in the regulations that established those standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.

**4. DUTY TO REAPPLY**

If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit. The application shall be submitted at least 180 days before the expiration date of this permit. The Director may grant permission to submit an application less than 180 days in advance but no later than the permit expiration date. Continuation of expiring permits shall be governed by regulations promulgated at 40 CFR Part 122.6 and any subsequent amendments.

**5. PERMIT FLEXIBILITY**

This permit may be modified, revoked and reissued, or terminated for cause in accordance with 40 CFR 122.62-64. The filing of a request for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance, does not stay any permit condition.

**6. PROPERTY RIGHTS**

This permit does not convey any property rights of any sort, or any exclusive privilege.

**7. DUTY TO PROVIDE INFORMATION**

The permittee shall furnish to the Director, within a reasonable time, any information which the Director may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. The permittee shall also furnish to the Director, upon request, copies of records required to be kept by this permit.

**8. CRIMINAL AND CIVIL LIABILITY**

Except as provided in permit conditions on "Bypassing" and "Upsets", nothing in this permit shall be construed to relieve the permittee from civil or criminal penalties for noncompliance. Any false or materially misleading representation or concealment of information required to be reported by the provisions of the permit, the Act, or applicable regulations, which avoids or effectively defeats the regulatory purpose of the Permit may subject the Permittee to criminal enforcement pursuant to 18 U.S.C. Section 1001.

**9. OIL AND HAZARDOUS SUBSTANCE LIABILITY**

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties to which the permittee is or may be subject under Section 311 of the Act.

**10. STATE LAWS**

Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities, or penalties established pursuant to any applicable State law or regulation under authority preserved by Section 510 of the Act.

#### 11. SEVERABILITY

The provisions of this permit are severable, and if any provision of this permit or the application of any provision of this permit to any circumstance is held invalid, the application of such provision to other circumstances, and the remainder of this permit, shall not be affected thereby.

#### B. PROPER OPERATION AND MAINTENANCE

##### 1. NEED TO HALT OR REDUCE NOT A DEFENSE

It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit. The permittee is responsible for maintaining adequate safeguards to prevent the discharge of untreated or inadequately treated wastes during electrical power failure either by means of alternate power sources, standby generators or retention of inadequately treated effluent.

##### 2. DUTY TO MITIGATE

The permittee shall take all reasonable steps to minimize or prevent any discharge in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

##### 3. PROPER OPERATION AND MAINTENANCE

- a. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by permittee as efficiently as possible and in a manner which will minimize upsets and discharges of excessive pollutants and will achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of this permit.
- b. The permittee shall provide an adequate operating staff which is duly qualified to carry out operation, maintenance and testing functions required to insure compliance with the conditions of this permit.

##### 4. BYPASS OF TREATMENT FACILITIES

###### a. BYPASS NOT EXCEEDING LIMITATIONS

The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of Parts III.B.4.b. and 4.c.

###### b. NOTICE

###### (1) ANTICIPATED BYPASS

If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.

###### (2) UNANTICIPATED BYPASS

The permittee shall, within 24 hours, submit notice of an unanticipated bypass as required in Part III.D.7.

###### c. PROHIBITION OF BYPASS

(1) Bypass is prohibited, and the Director may take enforcement action against a permittee for bypass, unless:

(a) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;

(b) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and,

(c) The permittee submitted notices as required by Part III.B.4.b.

(2) The Director may allow an anticipated bypass after considering its adverse effects, if the Director determines that it will meet the three conditions listed at Part III.B.4.c(1).

## 5. UPSET CONDITIONS

### a. EFFECT OF AN UPSET

An upset constitutes an affirmative defense to an action brought for noncompliance with such technology-based permit effluent limitations if the requirements of Part III.B.5.b. are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.

### b. CONDITIONS NECESSARY FOR A DEMONSTRATION OF UPSET

A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:

- (1) An upset occurred and that the permittee can identify the cause(s) of the upset;
- (2) The permitted facility was at the time being properly operated;
- (3) The permittee submitted notice of the upset as required by Part III.D.7; and,
- (4) The permittee complied with any remedial measures required by Part III.B.2.

### c. BURDEN OF PROOF

In any enforcement proceeding, the permittee seeking to establish the occurrence of an upset has the burden of proof.

## 6. REMOVED SUBSTANCES

Unless otherwise authorized, solids, sewage sludges, filter backwash, or other pollutants removed in the course of treatment or wastewater control shall be disposed of in a manner such as to prevent any pollutant from such materials from entering navigable waters.

## 7. PERCENT REMOVAL (PUBLICLY OWNED TREATMENT WORKS)

For publicly owned treatment works, the 30-day average (or Monthly Average) percent removal for Biochemical Oxygen Demand and Total Suspended Solids shall not be less than 85 percent unless otherwise authorized by the permitting authority in accordance with 40 CFR 133.103.

## C. MONITORING AND RECORDS

### 1. INSPECTION AND ENTRY

The permittee shall allow the Director, or an authorized representative, upon the presentation of credentials and other documents as may be required by the law to:

- a. Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- c. Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices or operations regulated or required under this permit; and
- d. Sample or monitor at reasonable times, for the purpose of assuring permit compliance or as otherwise authorized by the Act, any substances or parameters at any location.

### 2. REPRESENTATIVE SAMPLING

Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.

### 3. RETENTION OF RECORDS

The permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report, or application. This period may be extended by request of the Director at any time.

### 4. RECORD CONTENTS

Records of monitoring information shall include:

- a. The date, exact place, and time of sampling or measurements;

- b. The individual(s) who performed the sampling or measurements;
- c. The date(s) and time(s) analyses were performed;
- d. The individual(s) who performed the analyses;
- e. The analytical techniques or methods used; and
- f. The results of such analyses.

#### 5. MONITORING PROCEDURES

- a. Monitoring must be conducted according to test procedures approved under 40 CFR Part 136, unless other test procedures have been specified in this permit or approved by the Regional Administrator.
- b. The permittee shall calibrate and perform maintenance procedures on all monitoring and analytical instruments at intervals frequent enough to insure accuracy of measurements and shall maintain appropriate records of such activities.
- c. An adequate analytical quality control program, including the analyses of sufficient standards, spikes, and duplicate samples to insure the accuracy of all required analytical results shall be maintained by the permittee or designated commercial laboratory.

#### 6. FLOW MEASUREMENTS

Appropriate flow measurement devices and methods consistent with accepted scientific practices shall be selected and used to ensure the accuracy and reliability of measurements of the volume of monitored discharges. The devices shall be installed, calibrated, and maintained to insure that the accuracy of the measurements is consistent with the accepted capability of that type of device. Devices selected shall be capable of measuring flows with a maximum deviation of less than 10% from true discharge rates throughout the range of expected discharge volumes.

### D. REPORTING REQUIREMENTS

#### 1. PLANNED CHANGES

##### a. INDUSTRIAL PERMITS

The permittee shall give notice to the Director as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:

- (1) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR Part 122.29(b); or,
- (2) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements listed at Part III.D.10.a.

##### b. MUNICIPAL PERMITS

Any change in the facility discharge (including the introduction of any new source or significant discharge or significant changes in the quantity or quality of existing discharges of pollutants) must be reported to the permitting authority. In no case are any new connections, increased flows, or significant changes in influent quality permitted that will cause violation of the effluent limitations specified herein.

#### 2. ANTICIPATED NONCOMPLIANCE

The permittee shall give advance notice to the Director of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.

#### 3. TRANSFERS

This permit is not transferable to any person except after notice to the Director. The Director may require modification or revocation and reissuance of the permit to change the name of the permittee and incorporate such other requirements as may be necessary under the Act.

#### 4. DISCHARGE MONITORING REPORTS AND OTHER REPORTS

Monitoring results must be reported to EPA on either the electronic or paper Discharge Monitoring Report (DMR) approved formats. Monitoring results can be submitted electronically in lieu of the paper DMR Form. To submit electronically, access the NetDMR website at [www.epa.gov/netdmr](http://www.epa.gov/netdmr) and contact the [R6NetDMR@epa.gov](mailto:R6NetDMR@epa.gov) in-box for further instructions. Until you

are approved for Net DMR, you must report on the Discharge Monitoring Report (DMR) Form EPA No. 3320-1 in accordance with the "General Instructions" provided on the form. No additional copies are needed if reporting electronically, however when submitting paper form EPA No. 3320-1, the permittee shall submit the original DMR signed and certified as required by Part III.D.11 and all other reports required by Part III.D. to the EPA at the address below. Duplicate copies of paper DMR's and all other reports shall be submitted to the appropriate State agency (ies) at the following address (es):

EPA:

Compliance Assurance and Enforcement Division  
Water Enforcement Branch (6EN-W)  
U.S. Environmental Protection Agency, Region 6  
1445 Ross Avenue  
Dallas, TX 75202-2733

New Mexico:

Program Manager  
Surface Water Quality Bureau  
New Mexico Environment Department  
P.O. Box 5469  
1190 Saint Francis Drive  
Santa Fe, NM 87502-5469

5. ADDITIONAL MONITORING BY THE PERMITTEE

If the permittee monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 CFR Part 136 or as specified in this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the Discharge Monitoring Report (DMR). Such increased monitoring frequency shall also be indicated on the DMR.

6. AVERAGING OF MEASUREMENTS

Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Director in the permit.

7. TWENTY-FOUR HOUR REPORTING

a. The permittee shall report any noncompliance which may endanger health or the environment. Notification shall be made to the EPA at the following e-mail address: R6\_NPDES\_Reporting@epa.gov, as soon as possible, but within 24 hours from the time the permittee becomes aware of the circumstance. Oral notification shall also be to the New Mexico Environment Department at (505) 827-0187 as soon as possible, but within 24 hours from the time the permittee becomes aware of the circumstance. A written submission shall be provided within 5 days of the time the permittee becomes aware of the circumstances. The report shall contain the following information:

- (1) A description of the noncompliance and its cause;
- (2) The period of noncompliance including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and,
- (3) Steps being taken to reduce, eliminate, and prevent recurrence of the noncomplying discharge.

b. The following shall be included as information which must be reported within 24 hours:

- (1) Any unanticipated bypass which exceeds any effluent limitation in the permit;
- (2) Any upset which exceeds any effluent limitation in the permit; and,
- (3) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Director in Part II (industrial permits only) of the permit to be reported within 24 hours.

c. The Director may waive the written report on a case-by-case basis if the oral report has been received within 24 hours.

8. OTHER NONCOMPLIANCE

The permittee shall report all instances of noncompliance not reported under Parts III.D.4 and D.7 and Part I.B (for industrial permits only) at the time monitoring reports are submitted. The reports shall contain the information listed at Part III.D.7.

9. OTHER INFORMATION

Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Director, it shall promptly submit such facts or information.

10. CHANGES IN DISCHARGES OF TOXIC SUBSTANCES

All existing manufacturing, commercial, mining, and silvacultural permittees shall notify the Director as soon as it knows or has reason to believe:

- a. That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant listed at 40 CFR Part 122, Appendix D, Tables II and III (excluding Total Phenols) which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
- (1) One hundred micrograms per liter (100 µg/L);
  - (2) Two hundred micrograms per liter (200 µg/L) for acrolein and acrylonitrile; five hundred micrograms per liter (500 µg/L) for 2, 4-dinitro-phenol and for 2-methyl-4, 6-dinitrophenol; and one milligram per liter (1 mg/L) for antimony;
  - (3) Five (5) times the maximum concentration value reported for that pollutant in the permit application; or
  - (4) The level established by the Director.
- b. That any activity has occurred or will occur which would result in any discharge, on a nonroutine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
- (1) Five hundred micrograms per liter (500 µg/L);
  - (2) One milligram per liter (1 mg/L) for antimony;
  - (3) Ten (10) times the maximum concentration value reported for that pollutant in the permit application; or
  - (4) The level established by the Director.

#### 11. SIGNATORY REQUIREMENTS

All applications, reports, or information submitted to the Director shall be signed and certified.

- a. ALL PERMIT APPLICATIONS shall be signed as follows:

- (1) FOR A CORPORATION - by a responsible corporate officer. For the purpose of this section, a responsible corporate officer means:
    - (a) A president, secretary, treasurer, or vice-president of the corporation in charge of a principal business function, or any other person who performs similar policy or decision making functions for the corporation; or,
    - (b) The manager of one or more manufacturing, production, or operating facilities, provided, the manager is authorized to make management decisions which govern the operation of the regulated facility including having the explicit or implicit duty of making major capital investment recommendations, and initiating and directing other comprehensive measures to assure long term environmental compliance with environmental laws and regulations; the manager can ensure that the necessary systems are established or actions taken to gather complete and accurate information for permit application requirements; and where authority to sign documents has been assigned or delegated to the manager in accordance with corporate procedures.
  - (2) FOR A PARTNERSHIP OR SOLE PROPRIETORSHIP - by a general partner or the proprietor, respectively.
  - (3) FOR A MUNICIPALITY, STATE, FEDERAL, OR OTHER PUBLIC AGENCY - by either a principal executive officer or ranking elected official. For purposes of this section, a principal executive officer of a Federal agency includes:
    - (a) The chief executive officer of the agency, or
    - (b) A senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency.
- b. ALL REPORTS required by the permit and other information requested by the Director shall be signed by a person described above or by a duly authorized representative of that person. A person is a duly authorized representative only if:
- (1) The authorization is made in writing by a person described above;
  - (2) The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity, such as the position of plant manager, operator of a well or a well field, superintendent, or position of equivalent responsibility, or an individual or position having overall responsibility for environmental

matters for the company. A duly authorized representative may thus be either a named individual or an individual occupying a named position; and,

(3) The written authorization is submitted to the Director.

c. CERTIFICATION

Any person signing a document under this section shall make the following certification:

"I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations."

12. AVAILABILITY OF REPORTS

Except for applications, effluent data permits, and other data specified in 40 CFR 122.7, any information submitted pursuant to this permit may be claimed as confidential by the submitter. If no claim is made at the time of submission, information may be made available to the public without further notice.

E. PENALTIES FOR VIOLATIONS OF PERMIT CONDITIONS

1. CRIMINAL

a. NEGLIGENT VIOLATIONS

The Act provides that any person who negligently violates permit conditions implementing Section 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to a fine of not less than \$2,500 nor more than \$25,000 per day of violation, or by imprisonment for not more than 1 year, or both. In the case of a second or subsequent conviction for a negligent violation, a person shall be subject to criminal penalties of not more than \$50,000 per day of violation, or by imprisonment of not more than 2 years, or both.

b. KNOWING VIOLATIONS

The Act provides that any person who knowingly violates permit conditions implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to a fine of not less than \$5,000 nor more than \$50,000 per day of violation, or by imprisonment for not more than 3 years, or both. In the case of a second or subsequent conviction for a knowing violation, a person shall be subject to criminal penalties of not more than \$100,000 per day of violation, or imprisonment of not more than 6 years, or both.

c. KNOWING ENDANGERMENT

The Act provides that any person who knowingly violates permit conditions implementing Sections 301, 302, 303, 306, 307, 308, 318, or 405 of the Act and who knows at that time that he is placing another person in imminent danger of death or serious bodily injury is subject to a fine of not more than \$250,000, or by imprisonment for not more than 15 years, or both. In the case of a second or subsequent conviction for a knowing endangerment violation, a person shall be subject to a fine of not more than \$500,000 or by imprisonment of not more than 30 years, or both. An organization, as defined in section 309(c)(3)(B)(iii) of the CWA, shall, upon conviction of violating the imminent danger provision, be subject to a fine of not more than \$1,000,000 and can be fined up to \$2,000,000 for second or subsequent convictions.

d. FALSE STATEMENTS

The Act provides that any person who knowingly makes any false material statement, representation, or certification in any application, record, report, plan, or other document filed or required to be maintained under the Act or who knowingly falsifies, tampers with, or renders inaccurate, any monitoring device or method required to be maintained under the Act, shall upon conviction, be punished by a fine of not more than \$10,000, or by imprisonment for not more than 2 years, or by both. If a conviction of a person is for a violation committed after a first conviction of such person under this paragraph, punishment shall be by a fine of not more than \$20,000 per day of violation, or by imprisonment of not more than 4 years, or by both. (See Section 309.c.4 of the Clean Water Act)

2. CIVIL PENALTIES

The Act provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to a civil penalty not to exceed \$37,500 per day for each violation.

3. ADMINISTRATIVE PENALTIES

The Act provides that any person who violates a permit condition implementing Sections 301, 302, 306, 307, 308, 318, or 405 of the Act is subject to an administrative penalty, as follows:

a. CLASS I PENALTY

Not to exceed \$16,000 per violation nor shall the maximum amount exceed \$37,500.

b. CLASS II PENALTY

Not to exceed \$16,000 per day for each day during which the violation continues nor shall the maximum amount exceed \$177,500.

F. DEFINITIONS

All definitions contained in Section 502 of the Act shall apply to this permit and are incorporated herein by reference. Unless otherwise specified in this permit, additional definitions of words or phrases used in this permit are as follows:

1. ACT means the Clean Water Act (33 U.S.C. 1251 et. seq.), as amended.
2. ADMINISTRATOR means the Administrator of the U.S. Environmental Protection Agency.
3. APPLICABLE EFFLUENT STANDARDS AND LIMITATIONS means all state and Federal effluent standards and limitations to which a discharge is subject under the Act, including, but not limited to, effluent limitations, standards or performance, toxic effluent standards and prohibitions, and pretreatment standards.
4. APPLICABLE WATER QUALITY STANDARDS means all water quality standards to which a discharge is subject under the Act.
5. BYPASS means the intentional diversion of waste streams from any portion of a treatment facility.
6. DAILY DISCHARGE means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in terms of mass, the "daily discharge" is calculated as the total mass of the pollutant discharged over the sampling day. For pollutants with limitations expressed in other units of measurement, the "daily discharge" is calculated as the average measurement of the pollutant over the sampling day. "Daily discharge" determination of concentration made using a composite sample shall be the concentration of the composite sample. When grab samples are used, the "daily discharge" determination of concentration shall be arithmetic average (weighted by flow value) of all samples collected during that sampling day.
7. DAILY MAXIMUM discharge limitation means the highest allowable "daily discharge" during the calendar month.
8. DIRECTOR means the U.S. Environmental Protection Agency Regional Administrator or an authorized representative.
9. ENVIRONMENTAL PROTECTION AGENCY means the U.S. Environmental Protection Agency.
10. GRAB SAMPLE means an individual sample collected in less than 15 minutes.
11. INDUSTRIAL USER means a non-domestic discharger, as identified in 40 CFR 403, introducing pollutants to a publicly owned treatment works.
12. MONTHLY AVERAGE (also known as DAILY AVERAGE) discharge limitations means the highest allowable average of "daily discharge(s)" over a calendar month, calculated as the sum of all "daily discharge(s)" measured during a calendar month divided by the number of "daily discharge(s)" measured during that month. When the permit establishes daily average concentration effluent limitations or conditions, the daily average concentration means the arithmetic average (weighted by flow) of all "daily discharge(s)" of concentration determined during the calendar month where C = daily concentration, F = daily flow, and n = number of daily samples; daily average discharge =
 
$$\frac{C_1F_1 + C_2F_2 + \dots + C_nF_n}{F_1 + F_2 + \dots + F_n}$$
13. NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM means the national program for issuing, modifying, revoking and reissuing, terminating, monitoring and enforcing permits, and imposing and enforcing pretreatment requirements, under Sections 307, 318, 402, and 405 of the Act.
14. SEVERE PROPERTY DAMAGE means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

15. SEWAGE SLUDGE means the solids, residues, and precipitates separated from or created in sewage by the unit processes of a publicly owned treatment works. Sewage as used in this definition means any wastes, including wastes from humans, households, commercial establishments, industries, and storm water runoff that are discharged to or otherwise enter a publicly owned treatment works.
16. TREATMENT WORKS means any devices and systems used in the storage, treatment, recycling and reclamation of municipal sewage and industrial wastes of a liquid nature to implement Section 201 of the Act, or necessary to recycle or reuse water at the most economical cost over the estimated life of the works, including intercepting sewers, sewage collection systems, pumping, power and other equipment, and their appurtenances, extension, improvement, remodeling, additions, and alterations thereof.
17. UPSET means an exceptional incident in which there is unintentional and temporary noncompliance with technology-based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
18. FOR FECAL COLIFORM BACTERIA, a sample consists of one effluent grab portion collected during a 24-hour period at peak loads.
19. The term "MGD" shall mean million gallons per day.
20. The term "mg/L" shall mean milligrams per liter or parts per million (ppm).
21. The term "µg/L" shall mean micrograms per liter or parts per billion (ppb).
22. MUNICIPAL TERMS
  - a. 7-DAY AVERAGE or WEEKLY AVERAGE, other than for fecal coliform bacteria, is the arithmetic mean of the daily values for all effluent samples collected during a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week. The 7-day average for fecal coliform bacteria is the geometric mean of the values for all effluent samples collected during a calendar week.
  - b. 30-DAY AVERAGE or MONTHLY AVERAGE, other than for fecal coliform bacteria, is the arithmetic mean of the daily values for all effluent samples collected during a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. The 30-day average for fecal coliform bacteria is the geometric mean of the values for all effluent samples collected during a calendar month.
  - c. 24-HOUR COMPOSITE SAMPLE consists of a minimum of 12 effluent portions collected at equal time intervals over the 24-hour period and combined proportional to flow or a sample collected at frequent intervals proportional to flow over the 24-hour period.
  - d. 12-HOUR COMPOSITE SAMPLE consists of 12 effluent portions collected no closer together than one hour and composited according to flow. The daily sampling intervals shall include the highest flow periods.
  - e. 6-HOUR COMPOSITE SAMPLE consists of six effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow.
  - f. 3-HOUR COMPOSITE SAMPLE consists of three effluent portions collected no closer together than one hour (with the first portion collected no earlier than 10:00 a.m.) and composited according to flow.

## APPENDIX A of PART II

The following Minimum Quantification Levels (MQL's) are to be used for reporting pollutant data for NPDES permit applications and/or compliance reporting.

POLLUTANTS	MQL µg/l	POLLUTANTS	MQL µg/l
<b>METALS, RADIOACTIVITY, CYANIDE and CHLORINE</b>			
Aluminum	2.5	Molybdenum	10
Antimony	60	Nickel	0.5
Arsenic	0.5	Selenium	5
Barium	100	Silver	0.5
Beryllium	0.5	Thallium	0.5
Boron	100	Uranium	0.1
Cadmium	1	Vanadium	50
Chromium	10	Zinc	20
Cobalt	50	Cyanide	10
Copper	0.5	Cyanide, weak acid dissociable	10
Lead	0.5	Total Residual Chlorine	33
Mercury *1	0.0005 0.005		
<b>DIOXIN</b>			
2,3,7,8-TCDD	0.00001		
<b>VOLATILE COMPOUNDS</b>			
Acrolein	50	1,3-Dichloropropylene	10
Acrylonitrile	20	Ethylbenzene	10
Benzene	10	Methyl Bromide	50
Bromoform	10	Methylene Chloride	20
Carbon Tetrachloride	2	1,1,2,2-Tetrachloroethane	10
Chlorobenzene	10	Tetrachloroethylene	10
Chlorodibromomethane	10	Toluene	10
Chloroform	50	1,2-trans-Dichloroethylene	10
Dichlorobromomethane	10	1,1,2-Trichloroethane	10
1,2-Dichloroethane	10	Trichloroethylene	10
1,1-Dichloroethylene	10	Vinyl Chloride	10
1,2-Dichloropropane	10		
<b>ACID COMPOUNDS</b>			
2-Chlorophenol	10	2,4-Dinitrophenol	50
2,4-Dichlorophenol	10	Pentachlorophenol	5
2,4-Dimethylphenol	10	Phenol	10
4,6-Dinitro-o-Cresol	50	2,4,6-Trichlorophenol	10

POLLUTANTS	MQL µg/l	POLLUTANTS	MQL µg/l
<b>BASE/NEUTRAL</b>			
Acenaphthene	10	Dimethyl Phthalate	10
Anthracene	10	Di-n-Butyl Phthalate	10
Benzidine	50	2,4-Dinitrotoluene	10
Benzo(a)anthracene	5	1,2-Diphenylhydrazine	20
Benzo(a)pyrene	5	Fluoranthene	10
3,4-Benzofluoranthene	10	Fluorene	10
Benzo(k)fluoranthene	5	Hexachlorobenzene	5
Bis(2-chloroethyl)Ether	10	Hexachlorobutadiene	10
Bis(2-chloroisopropyl)Ether	10	Hexachlorocyclopentadiene	10
Bis(2-ethylhexyl)Phthalate	10	Hexachloroethane	20
Butyl Benzyl Phthalate	10	Indeno(1,2,3-cd)Pyrene	5
2-Chloronaphthalene	10	Isophorone	10
Chrysene	5	Nitrobenzene	10
Dibenzo(a,h)anthracene	5	n-Nitrosodimethylamine	50
1,2-Dichlorobenzene	10	n-Nitrosodi-n-Propylamine	20
1,3-Dichlorobenzene	10	n-Nitrosodiphenylamine	20
1,4-Dichlorobenzene	10	Pyrene	10
3,3'-Dichlorobenzidine	5	1,2,4-Trichlorobenzene	10
Diethyl Phthalate	10		
<b>PESTICIDES AND PCBS</b>			
Aldrin	0.01	Beta-Endosulfan	0.02
Alpha-BHC	0.05	Endosulfan sulfate	0.02
Beta-BHC	0.05	Endrin	0.02
Gamma-BHC	0.05	Endrin Aldehyde	0.1
Chlordane	0.2	Heptachlor	0.01
4,4'-DDT and derivatives	0.02	Heptachlor Epoxide	0.01
Dieldrin	0.02	PCBs	0.2
Alpha-Endosulfan	0.01	Toxaphene	0.3

(MQL's Revised November 1, 2007)

## Footnotes:

\*1 Default MQL for Mercury is 0.005 unless Part I of your permit requires the more sensitive Method 1631 (Oxidation / Purge and Trap / Cold vapor Atomic Fluorescence Spectrometry), then the MQL shall be 0.0005.