



**BILL RICHARDSON**  
Governor

*State of New Mexico*  
**ENVIRONMENT DEPARTMENT**  
**Petroleum Storage Tank Bureau**

*2044 Galisteo Street*  
*Santa Fe, New Mexico 87505*  
*Telephone (505) 984-1741*  
*Fax (505) 984-1738*



**RON CURRY**  
Secretary

**JIM NORTON**  
Director

**AGENDA – PSTB STAKEHOLDER MEETING**

Albuquerque: BLM Building, 435 Montano NE  
Wednesday May 9, 2007

- 9:00 am Greeting: Jim Davis, Bureau Chief
- 9:15 am Overview of Regulation Revisions
- Statutory and regulatory requirements for revising rules
  - Re-numbering and re-formatting changes throughout
  - Fewer written approvals from NMED required
  - Greater consistency between forms and regulations
  - Questions and comments from Stakeholders
- 9:45 am Part 1: Definitions
- Water systems and sources triggering secondary containment (Federal Energy Policy Act "FEPA" requirement)
  - Corrosion expert (term used by accrediting associations)
  - Farm tank and flow-through process tank (identical to EPA's definitions)
  - Loading rack (AST rules now specifically address these)
  - Motor fuel dispenser (from FEPA, new containment requirement)
  - Replace (from FEPA, triggers secondary containment)
  - Suggestions from Stakeholders
- 10:30 am Break
- 10:45 am Parts 2 and 3: Registration and Annual Fees
- Clearer transfer requirements (20.5.2.9)
  - More detail for registration information, to match form (20.5.2.13)
  - Provisions for registration certificate after transfer (20.5.2.15)
  - New requirement for a correct mailing address (20.5.2.16)
  - Due date for fees clarified (20.5.3.8)
  - New section on timeliness and postmarks, due date on Saturday, Sunday or holiday, similar to Taxation & Revenue Dept. provisions (20.5.3.10)
  - Suggestions from Stakeholders
- 11:30-1 Lunch on your own

- 1:00 pm      Part 4: New and Upgraded Storage Tank Systems
- Shorter and easier to find sections
  - Compatibility required for entire system (20.5.4.8)
  - 1998 upgrade standards laid out (20.5.4.13)
  - Secondary containment for USTs from Energy Policy Act; required for new and replaced tanks, piping, dispensers unless prove to NMED that no part of UST system within 1,000 feet of well, water system, or water source (20.5.4.15)
  - New requirement for information on used ASTs (20.5.4.19)
  - Containment sumps where aboveground piping moves underground (20.5.4.20.D)
  - Report required on coating/lining and geo-synthetic liner of AST secondary containment (20.5.4.29)
  - Specific vent requirements for ASTs (20.5.4.30)
  - New requirements for loading racks (20.5.4.34)
  - Close USTs used as ASTs July 1, 2011 (20.5.4.35)
  - Clarification of notification requirements before installation (20.5.4.37)
  - Listed requirements for application for alternate method (20.5.4.38)
  - Questions and comments from Stakeholders
- 2:15 pm      Part 5: General Operating Requirements
- Operation and maintenance plan, with emergency response (20.5.5.8)
  - Determination if repair, replacement or modification needed (20.5.5.17)
  - Clarified notification of repair, replacement, modification (20.5.5.21)
  - Disclaimer for NMED review of plans (20.5.5.22)
  - New alternate methods section (20.5.5.23)
  - Additional changes proposed by Stakeholders
- 3:00 pm      Additional comments, questions, concerns raised by Stakeholders
- Future meeting schedule
  - Methods for reviewing and commenting on draft rule revisions
- 3:30 pm      Conclusion