

**New Mexico Environment Department – Petroleum Storage Tank Bureau
Public Record on Underground Storage Tank (USTs)**

Public Record Date Posted: November 28, 2011

General Information

Total Number of UST facilities	1244
Total Number of USTs	3880

Summary Information for On-site Inspections

Number of UST facilities Inspected	744	
Inspection Period Dates	From: 10/1/2010	To: 9/30/2011
Percent Compliance (Combined Measures ¹)	66%	

Summary Information for Releases

Number of Confirmed UST Releases	10	
Release Reporting Period Dates	From: 10/1/2010	To: 9/30/2011

Summary Information for Release Sources and Causes

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	# ²	% ²	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	2	20	1	10					1	10						
Piping	2	20					1	10	1	10						
Dispenser	0	0														
STP ³ Area	1	10					1	10								
Delivery Problem	3	30			3	30										
Flex Connector	0	0														
Other	2	20													2	20
Totals	10	100	1	10	3	30	2	20	2	20					2	20

Notes: (1) Number and percent of underground storage tank (UST) facilities in significant operational compliance with release prevention and release detection regulations of the Petroleum Storage Tank regulations.

(2) # = Number, % = percent of total number

(3) STP = Submersible Turbine Pump

Site specific information on confirmed releases can be obtained by making a public information request to:
Melissa Mascareñas
Inspection of Public Records Officer
1190 St. Francis Drive, Suite N-4050 Santa Fe, NM 87505
Or fax: (505) 827-1628 Or email: melissa.mascarenas@state.nm.us