

**New Mexico Environment Department – Petroleum Storage Tank Bureau
Public Record on Underground Storage Tank (USTs)**

Public Record Date Posted: November 13, 2015

General Information

Total Number of UST facilities	1228
Total Number of USTs	3259

Summary Information for On-site Inspections

Number of UST facilities Inspected	550	
Inspection Period Dates	From: 10/1/2014	To: 9/30/2015
Percent Compliance (Combined Measures ¹)	61%	

Summary Information for Releases

Number of Confirmed UST Releases	25	
Release Reporting Period Dates	From: 10/1/2014	To: 9/30/2015

Summary Information for Release Sources and Causes

Source			Cause													
			Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown	
	# ²	% ²	#	%	#	%	#	%	#	%	#	%	#	%	#	%
Tank	7	28			1	4			5	20					1	4
Piping	2	8							2	8						
Dispenser	8	32	1	4			1	4					5	20	1	4
STP ³ Area	0	0														
Delivery Problem	0	0														
Flex Connector	1	4							1	4						
Other	7	28			2	8									5	20
Totals	25	100	1	4	3	12	1	4	8	32			5	20	7	28

Notes: (1) Number and percent of underground storage tank (UST) facilities in significant operational compliance with release prevention and release detection regulations of the Petroleum Storage Tank regulations.

(2) # = Number, % = percent of total number

(3) STP = Submersible Turbine Pump

Site specific information on confirmed releases can be obtained by making a public information request to:

Melissa Mascareñas
Inspection of Public Records Officer
1190 St. Francis Drive, Suite N-4050 Santa Fe, NM 87505
Or fax: (505) 827-1628 or email: melissa.mascarenas@state.nm.us