

**ATTACHMENT ~~D~~E**

**INSPECTION SCHEDULE, PROCESS AND FORMS**

(This page intentionally blank)

**ATTACHMENT-~~D~~E**  
**INSPECTION SCHEDULE, PROCESS AND FORMS**

**TABLE OF CONTENTS**

Introduction ..... 1

E-1 Inspection Schedule ..... 1

    E-1a General Inspection Requirements ..... 3

        E-1a(1) Types of Problems ..... 3

        E-1a(2) Frequency of Inspections ..... 4

        E-1a(3) Monitoring Systems ..... 4

    E-1b Specific Process Inspection Requirements ..... 4

        E-1b(1) Container Inspection ..... 4

        E-1b(2) Miscellaneous Unit Inspection ..... 6

References ..... 6

## LIST OF FIGURES

| <b>Figure</b> | <b>Title</b>                 |
|---------------|------------------------------|
| Figure E-1    | Typical Inspection Checklist |
| Figure E-2    | Typical Logbook Entry        |

## LIST OF TABLES

| <b>Table</b> | <b>Title</b>                                      |
|--------------|---|
| Table E-1    | Inspection Schedule/Procedures                    |
| Table E-1a   | RH TRU Mixed Waste Inspection Schedule/Procedures |
| Table E-2    | Monitoring Schedule                               |

## ATTACHMENT-~~D~~ E

### INSPECTION SCHEDULE, PROCESS AND FORMS

#### Introduction

This Permit Attachment describes the facility inspections (including container inspections) that are conducted to detect malfunctions, deterioration, operator errors, and discharges that may cause or lead to releases of hazardous waste or hazardous waste constituents to the environment or that could be a threat to human health.

#### ~~D~~ E-1 Inspection Schedule

Equipment instrumental in preventing, detecting, or responding to environmental or human health hazards, such as monitoring equipment, safety and emergency equipment, security devices, and operating or structural equipment are inspected. The equipment will be inspected for malfunctions, deterioration, potential for operator errors, and discharges which could lead to a release of hazardous waste constituents to the environment or pose a threat to human health.

The WIPP facility has developed and will maintain a series of written procedures that include all the detailed inspection procedures and forms necessary to comply with 20.4.1.500 NMAC (incorporating 40 CFR §264.15(b)), during the Disposal Phase. Tables ~~D~~ E-1 and ~~D~~ E-1a list each item or system requiring inspection under these regulations, the inspection frequency, the organization responsible for the inspection, the applicable inspection procedure, and what to look for during the inspection. 20.4.1.500 NMAC (incorporating 40 CFR §§264.15(b), 264.174, and 264.602) list requirements that are applicable to the WIPP facility.

Operational procedures detailing the inspections required under 20.4.1.500 NMAC (incorporating 40 CFR §§264.15(a) and (b)), are maintained in electronic format on the WIPP computer network, in the Operating Record and, as appropriate, in controlled document locations at the WIPP facility. Frequency of inspections is discussed in detail in Section ~~D~~ E-1a(2). Inspections are conducted often enough to identify problems in time to correct them before they pose a threat to human health or the environment and are based on regulatory requirements. The operational procedures assign responsibility for conducting the inspection, the frequency of each inspection, the types of problems to be watched for, what to do if items fail inspection, directions on record keeping, and inspector signature, date, and time. The operational procedures are maintained at the WIPP facility. Tables ~~D~~ E-1 and ~~D~~ E-1a summarize inspections, frequencies, responsible organizations, personnel making the inspection (by job title), and the types of anticipated problems as well as the references for the operational procedures. Inspection records are maintained at the WIPP site for three years ~~by the responsible organization shown in Tables D-1 and D-1a. Beginning March 1, 2009 with the effective date of this Permit, records that are over the three year retention period are either maintained at the WIPP site or transferred to the WIPP Records Archive located in Carlsbad, NM until closure. The records maintained at the WIPP Records Archive are stored in facilities that are temperature and humidity controlled especially for the long term storage of records and readily retrievable and available for inspection.~~

Waste handling equipment and area inspections are typically controlled through established procedures and the results are recorded in logbooks or on data sheets. Operators are trained to

1 consult the logbook to identify the status of any piece of waste handling equipment prior to its  
2 use. Once a piece of equipment is identified to be operable, a preoperational inspection is  
3 initiated in accordance with the appropriate inspection procedure in Tables ~~D E~~-1, ~~D E~~-1a, or in  
4 operational procedures. Inspection results as described below are entered in the applicable  
5 logbook.

6 Inspections include identifying malfunctions or deteriorating equipment and structures.  
7 Inspection results and data, including deficiencies, discrepancies, or needed repairs are  
8 recorded. A negative inspection result does not necessarily lead to a repair. A deficiency, such  
9 as low fluid level, may be corrected by the inspector immediately. A discrepancy, such as an  
10 increasing trend of a data point, may necessitate additional inspection prior to the next  
11 scheduled frequency. The actions taken (corrected, additional inspection, or Action Request  
12 (**AR**) for repair submitted) are recorded on the inspection form, the WIPP automated  
13 Maintenance Management tracking program (**CHAMPS**) work order sheet, or the equipment  
14 logbook, whichever is applicable.

15 Items that are operational with restrictions are tagged with those restrictions. Items that are not  
16 operational are tagged and locked to prevent their use. Tagged and locked items are listed on  
17 the Tagout/Lockout Index. Once a scheduled repair or replacement is accomplished in  
18 accordance with the work authorization procedures, the tag or lock is removed from the item in  
19 accordance with the equipment tagout/lockout procedures. Normally, the individual inspecting  
20 the equipment/system is not qualified to make repairs and consequently, prepares an AR if  
21 repairs are needed. The AR is tracked by the CHAMPS system through the work control  
22 process. When parts are received and work instructions are completed, the work order can be  
23 scheduled on the Plan of the Day (**POD**). The POD is held daily to ensure facility configuration  
24 can support scheduled work items and to allocate and coordinate the resources necessary to  
25 complete the items.

26 Work orders are released for work by the responsible organization. When repairs are complete  
27 the responsible organization tests the equipment to ensure the repairs corrected the problem,  
28 then closes out the work order, to return the equipment to an operational status for normal  
29 operations to resume. Implementation of these procedures constitutes compliance with  
30 20.4.1.500 NMAC (incorporating 40 CFR §264.15(c)).

31 Requirements of 20.4.1.500 NMAC (incorporating 40 CFR §264.15(d)), are met by the  
32 inspections for each item or system included in Tables ~~D E~~-1 and ~~D E~~-1a. ~~Beginning March 1,~~  
33 2009 with the effective date of this Permit, the results of the inspections are maintained in the  
34 operating record for at least three years and are then transferred to the WIPP Records Archive  
35 where they are maintained until closure. The inspection logs or summary records include the  
36 date and time of inspection, the name of the inspector, a notation of the observations made, and  
37 the date and nature of any repairs or other remedial actions. Major pieces of waste handling  
38 equipment are inspected using proceduralized inspections. Current copies of inspection forms  
39 are maintained in the Operating Record. Non-administrative changes (i.e., changes that affect  
40 the frequency or content of inspections) to inspection forms must be submitted to the NMED in  
41 accordance with the appropriate portions of 20 NMAC 4.1.900 (incorporating 40 CFR §270.42).  
42 The status of these pieces of equipment is maintained in an equipment logbook that is separate  
43 from the checklist. The logbook contains information regarding the condition of the equipment.  
44 Equipment operators are required, by the inspection checklist, to consult the logbook as the first  
45 activity in the inspection procedure. This logbook is maintained in the operating record. CH  
46 transuranic (**TRU**) mixed waste equipment that is controlled by a logbook includes the waste

1 handling fork-lifts, all waste handling cranes, the adjustable center of gravity lift fixture, the CH  
2 TRU underground transporter, the facility transfer vehicle, the trailer jockey, and the push-pull  
3 attachment. RH TRU mixed waste equipment that is controlled by a logbook includes the  
4 140/25-ton RH Bay overhead bridge crane, cask transfer cars, 25-ton cask unloading room  
5 crane, transfer cell shuttle car, RH Bay cask lifting yoke, facility grapple, 6.2-ton overhead hoist,  
6 facility cask rotating device, hot cell overhead powered manipulator, 15-ton hot cell crane,  
7 facility cask transfer car, 41-ton forklift, facility cask, and horizontal emplacement and retrieval  
8 equipment. Inspections of the Cask Unloading Room, Hot Cell, Transfer Cell, Facility Cask  
9 Loading Room, RH Bay and radiation monitoring equipment will be recorded on data sheets. In  
10 addition to the inspections listed in Tables ~~D E~~-1 and ~~D E~~-1a, many pieces of equipment are  
11 subject to regular preventive maintenance. This includes more in-depth inspections of  
12 mechanical systems, load testing of lifting systems, calibration of measurement equipment and  
13 other actions as recommended by the equipment manufacturer or as required by DOE Orders.  
14 These preventive maintenance activities along with the inspections in Tables ~~D E~~-1 and ~~D E~~-1a  
15 make mechanical failure of waste handling equipment unlikely. The WIPP Safety Analysis  
16 Report (DOE, 1999) and the WIPP Remote-Handled Waste Preliminary Safety Analysis Report  
17 (RH PSAR) (DOE, 2000) contain the results of a systematic analysis of waste handling  
18 equipment and the hazards associated with potential mechanical failures. Equipment subject to  
19 failures that cannot practically be mitigated is retained for analysis and is the basis for  
20 contingency planning. The inspection procedures maintained in the Operating Record for  
21 operational and preventive maintenance are implemented to assure the equipment is  
22 maintained. An example equipment inspection checklist and a typical logbook form are shown  
23 as Figures ~~D E~~-1 and ~~D E~~-2. Actual checklists or forms are maintained within the Operating  
24 Record.

#### 25 ~~D E~~-1a General Inspection Requirements

26 Tables ~~D E~~-1, ~~D E~~-1a, and ~~D E~~-2 of this Permit Attachment list the major categories of  
27 monitoring equipment, safety and emergency systems, security devices, and operating and  
28 structural equipment that are important to the prevention or detection of, or the response to,  
29 environmental or human health hazards caused by hazardous waste. These systems may  
30 include numerous subsystems. These systems are inspected according to the frequency listed  
31 in Tables ~~D E~~-1 and ~~D E~~-1a, a copy of which is maintained at the WIPP facility. The frequency  
32 of inspections is based on the nature of the equipment or the hazard and regulatory  
33 requirements. When in use, daily inspections are made of areas subject to spills, such as TRU  
34 mixed waste loading and unloading areas in the WHB Unit, looking for deterioration in  
35 structures, mechanical items, floor coatings, equipment, malfunctions, etc., in accordance with  
36 20.4.1.500 NMAC (incorporating 40 CFR §264.15(b)(4)).

37 As required in 20.4.1.500 NMAC (incorporating 40 CFR §264.33), the WIPP facility inspection  
38 procedures for communication and alarm systems, fire-protection equipment, and spill control  
39 and decontamination equipment include provisions for testing and maintenance to ensure that  
40 the equipment will be operable in an emergency.

#### 41 ~~D E~~-1a(1) Types of Problems

42 The inspections for the systems, equipment, structures, etc., listed in Tables ~~D E~~-1 and ~~D E~~-1a,  
43 include the types of problems (e.g., malfunctions, visible cracks in coatings or welds, and  
44 deterioration) to be looked for during the inspection of each item or system, if applicable, and  
45 are in compliance with 20.4.1.500 NMAC (incorporating 40 CFR §264.15(b)(3)).

1 | DE-1a(2) Frequency of Inspections

2 | Tables ~~DE~~-1, ~~DE~~-1a, and ~~DE~~-2 of this Permit Attachment list the inspection frequencies and  
3 | monitoring schedule for equipment and systems subject to the 20.4.1 NMAC hazardous waste  
4 | management requirements. The frequency is based on the rate of possible deterioration of the  
5 | equipment and the probability of an environmental or human health incident if the deterioration  
6 | or malfunction, or any operator error, goes undetected between inspections. Areas subject to  
7 | spills, such as loading and unloading areas, are inspected daily when in use, consistent with the  
8 | requirements of 20.4.1.500 NMAC (incorporating 40 CFR §264.15(b)(4)).

9 | When RH TRU mixed waste is present in the RH Complex, inspections are conducted visually  
10 | and/or using closed-circuit video cameras in order to manage worker dose and to minimize  
11 | occupational radiation exposures to as low as reasonably achievable (**ALARA**). More extensive  
12 | inspections of these areas are performed at least annually during routine maintenance periods  
13 | and when RH TRU mixed waste is not present.

14 | DE-1a(3) Monitoring Systems

15 | There are two monitoring systems used at the WIPP to provide assurance that facility systems  
16 | are operating correctly, that areas can be used safely, and that there have been no releases of  
17 | hazardous waste constituents. These systems are shown in Table ~~DE~~-2 and include the  
18 | geomechanical monitoring system and the central monitoring system (**CMS**). The  
19 | geomechanical monitoring system is used to assess the condition of mined excavations to  
20 | assure no unsafe conditions are allowed to develop. The CMS continuously assesses the status  
21 | of the fixed radiation monitoring equipment, electrical power, fire alarm systems, ventilation  
22 | system, and other facility systems including water tank levels. In addition, the CMS collects data  
23 | from the meteorological monitoring system.

24 | DE-1b Specific Process Inspection Requirements

25 | 20.4.1.500 NMAC (incorporating 40 CFR §264.15(b)(4)), requires inspections of specific  
26 | portions of a facility, rather than the general facility. These include container storage areas and  
27 | miscellaneous units. Both are addressed below.

28 | DE-1b(1) Container Inspection

29 | Containers are used to manage TRU mixed waste at the WIPP facility. These containers are  
30 | described in Permit Module III. Off-site CH TRU mixed waste will arrive in 55-gallon drums  
31 | arranged as seven (7)-packs, in Ten Drum Overpacks (**TDOP**), in 85-gallon drums arranged as  
32 | four (4) packs, in 100-gallon drums arranged as three (3) packs, or in standard waste boxes  
33 | (**SWB**). The waste containers will be visually inspected to ensure that the waste containers are  
34 | in good condition and that there are no signs that a release has occurred. This visual inspection  
35 | shall not include the center drums of 7-packs and waste containers positioned such that visual  
36 | observation is precluded due to the arrangement of waste assemblies on the facility pallets. If  
37 | CH TRU mixed waste handling operations should stop for any reason with containers located on  
38 | the TRUPACT-II Unloading Dock (**TRUDOCK** storage area of the WHB Unit) in the Contact-  
39 | Handled Packages, primary waste container inspections could not be accomplished until the  
40 | containers of waste are removed from the shipping containers.

1 As described in Permit Attachment ~~MA~~1, Section ~~MA~~1-1d(3), RH TRU mixed waste will arrive  
2 in containers inside Nuclear Regulatory Commission (**NRC**)-certified casks designed to provide  
3 shielding and facilitate safe handling. Canisters, will be loaded singly into an RH-TRU 72-B  
4 cask. Drums will be loaded into a CNS 10-160B cask. The cask will be visually inspected upon  
5 arrival. Because RH TRU mixed waste is stored in the Parking Area Unit in sealed casks, there  
6 are no additional requirements for engineered secondary containment systems. Following  
7 removal of the canisters and drums, the interior of the cask will be inspected and surveyed for  
8 evidence of contamination that may have occurred during transport.

9 RH TRU mixed waste is handled and stored in the RH Complex of the WHB. The RH Complex  
10 includes the following: RH Bay, the Cask Unloading Room, the Hot Cell, the Transfer Cell, and  
11 the Facility Cask Loading Room. As RH TRU mixed waste is held in canisters within a canister  
12 rack the physical inspection of the drum or canister is not possible. Inspections of RH TRU  
13 mixed waste in these areas occurs remotely via closed-circuit cameras a minimum of once  
14 weekly when stored waste is present. Because RH TRU mixed waste is in sealed casks, there  
15 are no additional requirements for engineered secondary containment systems. However, the  
16 floors in the RH Complex (including the RH Bay, Facility Cask Loading Room and Cask  
17 Unloading Room) are coated concrete and during normal operations (i.e., when waste is  
18 present), the floor of the RH Complex is inspected visually or by using close-circuit cameras on  
19 a weekly basis to verify that it is in good condition and free of visible cracks and gaps.

20 Inspections of RH TRU mixed waste containers stored in the Hot Cell and Transfer Cell are  
21 conducted using remotely operated cameras. RH TRU mixed waste in the Hot Cell is stored in  
22 either drums or canisters. The containers in the Hot Cell are inspected to ensure that they are in  
23 acceptable condition. RH TRU mixed waste in the Transfer Cell is stored in the RH-TRU 72-B  
24 cask or shielded insert; therefore, inspections in this area focus on the integrity of the cask or  
25 shielded insert. RH TRU mixed waste in the Facility Cask Loading Room is stored in the facility  
26 cask; therefore, inspections in this area focus on the integrity of the facility cask.

27 Inspections will be conducted in the Parking Area Unit at a frequency not less than once weekly  
28 when waste is present. These inspections are applicable to loaded Contact-Handled and  
29 Remote-Handled Packages. The perimeter fence located at the lateral limit of the Parking Area  
30 Unit, coupled with personnel access restrictions into the WHB Unit, will provide the needed  
31 security. The perimeter fence and the southern border of the WHB shall mark the lateral limit of  
32 the Parking Area Unit. Radiologically controlled areas can be established temporarily with  
33 barricades. More permanent structures can be installed. The western boundary can be  
34 established with temporary barricades since this area is within the perimeter fence. Access to  
35 radiologically controlled areas will only be permitted to personnel who have completed General  
36 Employee Radiological Training (**GERT**), a program defined by the Permittees, or escorted by  
37 personnel who have completed GERT. This program ensures that personnel have adequate  
38 knowledge to understand radiological posting they may encounter at the WIPP site. The fence  
39 of the Radiologically Controlled Area, south from the WHB airlocks, was moved to provide more  
40 maneuvering space for the trucks delivering waste. Since TRU mixed waste to be stored in the  
41 Parking Area Unit will be in sealed Contact-Handled or Remote-Handled Packages, there will be  
42 no additional requirements for engineered secondary containment systems. Inspections of the  
43 Contact-Handled and Remote-Handled Packages stored in the Parking Area Unit shall be  
44 conducted at a frequency no less than once weekly and will focus on the inventory and integrity  
45 of the shipping containers and the spacing between trailers carrying the Contact-Handled or  
46 Remote-Handled Packages. This spacing will be maintained at a minimum of four feet.

1 Container inspections will be included as part of the surface TRU mixed waste handling areas  
2 (i.e. Parking Area Unit and WHB Unit) inspections described in Tables ~~D E~~-1 and ~~D E~~-1a. These  
3 inspections will also include the Derived Waste Storage Areas of the WHB Unit. The Derived  
4 Waste Storage Areas will consist of containers of 55 or 85-gallon drums or SWBs for CH TRU  
5 mixed waste and 55-gallon drums for RH TRU mixed waste. A Satellite accumulation area  
6 (**SAA**) may be required in an area adjacent to the TRUDOCKs for CH TRU mixed waste. A SAA  
7 may also be required in the RH Bay and Hot Cell for RH TRU mixed waste. These SAAs will be  
8 set up on an as needed basis at or near the point of generation and the derived waste will be  
9 discarded into the active derived waste container. All SAAs will be inspected in accordance with  
10 20.4.1.300 NMAC (incorporating 40 CFR §262.34).

11 ~~D E~~-1b(2) Miscellaneous Unit Inspection

12 20.4.1.500 NMAC (incorporating 40 CFR §264.602), requires that inspections required in  
13 20.4.1.500 NMAC (incorporating 40 CFR §264.15 and §264.33), as well as any additional  
14 requirements needed to protect human health and the environment, be met. The requirements  
15 of 20.4.1.500 NMAC (incorporating 40 CFR §264.15 and §264.33) are discussed in Section ~~D~~  
16 ~~E~~-1 of this Permit Attachment, along with how the WIPP facility complies with those  
17 requirements for standard types of inspections. Inspection frequencies for geomechanical  
18 monitoring equipment are provided in Table ~~D E~~-1. The monitoring schedule for geomechanical  
19 instrumentation is given in Table ~~D E~~-2.

20 References

21 DOE, 1999. "WIPP Safety Analysis Report," DOE/WIPP-95-2065. Rev. 4, U.S. Department of  
22 Energy. Washington, D.C.

23 DOE, 2000. "WIPP Remote-Handled Waste Preliminary Safety Analysis" (RH PSAR), U.S.  
24 Department of Energy. Washington, D.C.

1

## FIGURES

1

(This page intentionally blank)

| TYPICAL EQUIPMENT<br>WEEKLY CHECK LIST  |           |                            |
|---|-----------|----------------------------|
| <input checked="" type="checkbox"/> <b>OK</b> <input checked="" type="checkbox"/> <b>Adjustment Made</b> <input type="checkbox"/> <b>Repairs Required</b><br>AR Written <input type="checkbox"/> Yes <input type="checkbox"/> No      AR # _____<br>(check or complete appropriate information) |           |                            |
| ITEM INSPECTED  | Condition | Comments/Corrective Action |
| <b>Mechanical Checks:</b> (examples)  |           |                            |
| Oil level   |           |                            |
| Radiator fluid level  |           |                            |
| Automatic transmission fluid level  |           |                            |
| Operate all valves/check gauges   |           |                            |
| Emergency brake   |           |                            |
| Fuel level (> ¾ full)   |           |                            |
| Oil pressure (at warm idle)   |           |                            |
| Tire Pressure   |           |                            |
| Sirens, horn, & back-up alarm   |           |                            |
| <b>Deterioration Checks:</b> (examples)   |           |                            |
| Fan belts   |           |                            |
| Battery (terminals, cables)   |           |                            |
| Run generator 5 min.  |           |                            |
| Hose, nozzles & valves  |           |                            |
| <b>Leaks/Spills Checks:</b> (examples)  |           |                            |
| Leaks around pump   |           |                            |
| Foam tank level   |           |                            |
| <b>Required Equipment:</b> (examples)   |           |                            |
| Inspect SCBAs (> 4050 psi)  |           |                            |
| Hand tools & equipment  |           |                            |
| Trauma Kit  |           |                            |
| <b>Inspected by:</b> _____  |           |                            |
| Print Name  | Signature | Time/Date                  |
| <b>Inspected by:</b> _____  |           |                            |
| Print Name  | Signature | Time/Date                  |
| <b>Reviewed by:</b> _____   |           |                            |
| Print Name  | Signature | Time/Date                  |
| <b>Comments:</b> _____  |           |                            |
| _____   |           |                            |
| _____   |           |                            |

**NOTE: All items that are mandatory for every inspection form are shown in bold.**

**Figure ~~D E~~-1  
 Typical Inspection Checklist**



1

## TABLES

1

(This page intentionally blank)

1  
2

**Table ~~D~~E-1**  
**Inspection Schedule/Procedures**

| <b>System/Equipment Name</b>  | <b>Responsible Organization</b> | <b>Inspection a Frequency and Job Title of Personnel Normally Making Inspection</b> | <b>Procedure Number and Inspection Criteria</b>   |
|---|---------------------------------|---|---|
| Air Intake Shaft Hoist  | Underground Operations          | Preoperational <sup>c</sup> See Lists 1b and c                                      | WP 04-HO1004<br>Inspecting for Deterioration <sup>b</sup> , Safety Equipment, Communication Systems, and Mechanical Operability <sup>m</sup> in accordance with Mine Safety and Health Administration (MSHA) requirements |
| Ambulances (Surface and Underground) and related emergency supplies and equipment | Emergency Services              | Weekly<br>See List 11   | PM000030<br>Inspecting for Mechanical Operability <sup>m</sup> , Deterioration <sup>b</sup> , and Required Equipment <sup>n</sup>   |
| Adjustable Center of Gravity Lift Fixture   | Waste Handling                  | Preoperational<br>See List 8  | WP 05-WH1410<br>Inspecting for Mechanical Operability <sup>m</sup> and Deterioration <sup>b</sup>   |
| Backup Power Supply Diesel Generators   | Facility Operations             | Monthly<br>See List 3   | WP 04-ED1301<br>Inspecting for Mechanical Operability <sup>m</sup> and Leaks/Spills by starting and operating both generators. Results of this inspection are logged in accordance with WP 04-AD3008.                     |
| Facility Inspections (Water Diversion Berms)                                      | Facility Engineering            | Annually<br>See List 4  | WP 10-WC3008<br>Inspecting for Damage, Impediments to water flow, and Deterioration <sup>b</sup>  |
| Central Monitoring Systems (CMS)  | Facility Operations             | Continuous<br>See List 3  | Automatic Self-Checking   |
| Contact-Handled (CH) TRU Underground Transporter                                  | Waste Handling                  | Preoperational<br>See List 8  | WP 05-WH1603<br>Inspecting for Mechanical Operability <sup>m</sup> , Deterioration <sup>b</sup> , and area around transporter clear of obstacles  |
| Facility Transfer Vehicle   | Waste Handling                  | Preoperational<br>See List 8  | WP 05-WH1406 and WP 05-WH1408<br>Inspecting for Mechanical Operability <sup>m</sup> , Deterioration <sup>b</sup> , path clear of obstacles, and guards in the proper place  |

| <b>System/Equipment Name</b>  | <b>Responsible Organization</b> | <b>Inspection a Frequency and Job Title of Personnel Normally Making Inspection</b> | <b>Procedure Number and Inspection Criteria</b>  |
|---|---------------------------------|---|--|
| Exhaust Shaft   | Underground Operations          | Quarterly<br>See List 1a  | PM041099<br>Inspecting for Deterioration <sup>b</sup> and Leaks/Spills   |
| Eye Wash and Shower Equipment   | Equipment Custodian             | Weekly<br>See List 5  | WP 12-IS1832<br>Inspecting for Deterioration <sup>b</sup>  |
|   |                                 | Semi-annually<br>See List 2a  | WP 12-IS1832<br>Inspecting for Deterioration <sup>b</sup> and Fluid Levels—Replace as Required   |
| Fire Detection and Alarm System   | Emergency Services              | Semiannually<br>See List 11   | PM000027<br>Inspecting for Deterioration <sup>b</sup> , Operability of indicator lights and, underground fuel station dry chemical suppression system. Inspection is per NFPA 17 |
| Fire Extinguishers <sup>j</sup>   | Emergency Services              | Monthly<br>See List 11  | PM000036<br>Inspecting for Deterioration <sup>b</sup> , Leaks/Spills, Expiration, seals, fullness, and pressure  |
| Fire Hoses  | Emergency Services              | Annually (minimum)<br>See List 11   | PM000031<br>Inspecting for Deterioration <sup>b</sup> and Leaks/Spills   |
| Fire Hydrants   | Emergency Services              | Semi-annual/ annually<br>See List 11  | PM000034<br>Inspecting for Deterioration <sup>b</sup> and Leaks/Spills   |
| Fire Pumps  | Emergency Services              | Weekly/annually<br>See List 11  | WP 12-FP0026<br>Inspecting for Deterioration <sup>b</sup> , Leaks/Spills, valves, and panel lights   |
| Fire Sprinkler Systems  | Emergency Services              | Monthly/ quarterly<br>See List 11   | WP 12-FP0025<br>Inspecting for Deterioration <sup>b</sup> , Leaks/Spills, static pressures, and removable strainers  |
| Fire and Emergency Response Trucks (Seagrave Fire Apparatus, Emergency One Apparatus, and Underground Rescue Truck) | Emergency Services              | Weekly<br>See List 11   | PM000033<br>Inspecting for Mechanical Operability <sup>m</sup> , Deterioration <sup>b</sup> , Leaks/Spills, and Required Equipment <sup>n</sup>                                  |

| <b>System/Equipment Name</b>   | <b>Responsible Organization</b>     | <b>Inspection a Frequency and Job Title of Personnel Normally Making Inspection</b> | <b>Procedure Number and Inspection Criteria</b>  |
|--|-------------------------------------|---|--|
| Forklifts Used for Waste Handling (Electric and Diesel forklifts, Push-Pull Attachment)  | Waste Handling                      | Preoperational<br>See List 8  | WP 05-WH1401, WP 05-WH1402, WP 05-WH1403, and WP 05-WH1412<br><br>Inspecting for Mechanical Operability <sup>m</sup> , Deterioration <sup>b</sup> , and On board fire suppression system |
| Hazardous Material Response Equipment  | Emergency Services                  | Weekly<br>See List 11   | PM000033<br><br>Inspecting for Mechanical Operability <sup>m</sup> , Deterioration <sup>b</sup> , and Required Equipment <sup>n</sup>  |
| Miners First Aid Station   | Emergency Services                  | Quarterly<br>See List 11  | PM000035<br><br>Inspecting for Required Equipment <sup>n</sup>   |
| Mine Pager Phones (between surface and underground)  | Facility Operations                 | Monthly<br>See List 3   | WP 04-PC3017<br><br>Testing of PA and Underground Alarms and Mine Page Phones at essential locations   |
| MSHA Air Quality Monitor   | Maintenance/ Underground Operations | Daily <sup>l</sup><br>See Lists 1 and 10  | WP 12-IH1828<br><br>Inspecting for Air Quality Monitoring Equipment Functional Check   |
| Perimeter Fence, Gates, Signs  | Security                            | Daily<br>See List 6   | PF0-008<br><br>Inspecting for Deterioration <sup>b</sup> and Posted Warnings   |
| Personal Protective Equipment (not otherwise contained in emergency vehicles or issued to individuals):<br>—Self-Contained Breathing Apparatus | Emergency Services                  | Weekly<br>See List 11   | PM000029<br><br>Inspecting for Deterioration <sup>b</sup> and Pressure   |
| Public Address (and Intercom System)   | Facility Operations                 | Monthly<br>See List 3   | WP 04-PC3017<br><br>Testing of PA and Underground Alarms and Mine Page Phones at essential locations Systems operated in test mode   |
| Radio Equipment  | Facility Operations                 | Daily <sup>j</sup><br>See List 3  | Radios are operated daily and are repaired upon failure  |
| Rescue Truck (Surface and Underground)   | Emergency Services                  | Weekly<br>See List 11   | PM000030 and PM000033<br><br>Inspecting for Mechanical Operability <sup>m</sup> , Deterioration <sup>b</sup> , Leaks/Spills, and Required Equipment <sup>n</sup>                         |

| <b>System/Equipment Name</b>                           | <b>Responsible Organization</b> | <b>Inspection a Frequency and Job Title of Personnel Normally Making Inspection</b> | <b>Procedure Number and Inspection Criteria</b>  |
|--|---------------------------------|---|--|
| Salt Handling Shaft Hoist                              | Underground Operations          | Preoperational<br>See List 1b and c   | WP 04-HO1002<br>Inspecting for Deterioration <sup>b</sup> , Safety Equipment, Communication Systems, and Mechanical Operability <sup>m</sup> in accordance with MSHA requirements                    |
| Self-Rescuers  | Underground Operations          | Quarterly<br>See List 1c  | WP 04-AU1026<br>Inspecting for Deterioration <sup>b</sup> and Functionality in accordance with MSHA requirements   |
| Surface TRU Mixed Waste Handling Area <sup>k</sup>     | Waste Handling                  | Preoperational or Weekly <sup>e</sup><br>See List 8                                 | WP 05-WH1101<br>Inspecting for Deterioration <sup>b</sup> , Leaks/Spills, Required Aisle Space, Posted Warnings, Communication Systems, Container Condition, and Floor coating integrity             |
| TRU Mixed Waste Decontamination Equipment              | Waste Handling                  | Annually<br>See List 8  | WP 05-WH1101<br>Inspecting for Required Equipment <sup>n</sup>   |
| Underground Openings—Roof Bolts and Travelways         | Underground Operations          | Weekly<br>See List 1a   | WP 04-AU1007<br>Inspecting for Deterioration <sup>b</sup>  |
| Underground—Geomechanical Instrumentation System (GIS) | Geotechnical Engineering        | Monthly<br>See List 9   | WP 07-EU1301<br>Inspecting for Deterioration <sup>b</sup>  |
| Underground TRU Mixed Waste Disposal Area              | Waste Handling                  | Preoperational<br>See List 8  | WP 05-WH1810<br>Inspecting for Deterioration <sup>b</sup> , Leaks/Spills, mine pager phones, equipment, unobstructed access, signs, debris, and ventilation  |
| Uninterruptible Power Supply (Central UPS)             | Facility Operations             | Daily<br>See List 3   | WP 04-ED1542<br>Inspecting for Mechanical Operability <sup>m</sup> and Deterioration <sup>b</sup> with no malfunction alarms. Results of this inspection are logged in accordance with WP 04-AD3008. |
| TDOP Upender   | Waste Handling                  | Preoperational<br>See List 8  | WP 05-WH1010<br>Inspecting for Mechanical Operability <sup>m</sup> and Deterioration <sup>b</sup>  |

| <b>System/Equipment Name</b> | <b>Responsible Organization</b> | <b>Inspection a Frequency and Job Title of Personnel Normally Making Inspection</b> | <b>Procedure Number and Inspection Criteria</b>   |
|------------------------------|---------------------------------|---|---|
| Vehicle Siren                | Emergency Services              | Weekly<br>See List 11   | Functional Test included with inspection of the Ambulances, Fire Trucks, and Rescue Trucks  |
| Ventilation Exhaust          | Maintenance Operations          | Quarterly<br>See List 10  | IC041098<br>Check for Deterioration <sup>b</sup> and Calibration of Mine Ventilation Rate Monitoring Equipment  |
| Waste Handling Cranes        | Waste Handling                  | Preoperational<br>See List 8  | WP 05-WH1407<br>Inspecting for Mechanical Operability <sup>m</sup> , Deterioration <sup>b</sup> , and Leaks/Spills  |
| Waste Hoist                  | Underground Operations          | Preoperational<br>See List 1b and c   | WP 04-HO1003<br>Inspecting for Deterioration <sup>b</sup> , Safety Equipment, Communication Systems, and Mechanical Operability <sup>m</sup> , Leaks/Spills, in accordance with MSHA requirements |
| Water Tank Level             | Facility Operations             | Daily<br>See List 3   | SDD-WD00<br>Inspecting for Deterioration <sup>b</sup> , and water levels. Results of this inspection are logged in accordance with WP 04-AD3008.  |
| Push-Pull Attachment         | Waste Handling                  | Preoperational<br>See List 8  | WP 05-WH1401<br>Inspecting for Damage and Deterioration <sup>b</sup>  |
| Trailer Jockey               | Waste Handling                  | Preoperational<br>See List 8  | WP 05-WH1405<br>Inspecting for Mechanical Operability <sup>m</sup> and Deterioration <sup>b</sup>   |
| Explosion-Isolation Walls    | Underground Operations          | Quarterly<br>See List 1   | Integrity and Deterioration <sup>b</sup> of Accessible Areas  |
| Bulkhead in Filled Panels    | Underground Operations          | Monthly<br>See List 1   | Integrity and Deterioration <sup>b</sup> of Accessible Areas  |

1 |  
2

**Table D E-1 (Continued)**  
**Inspection Schedule/Procedures Lists**

List 1: Underground Operations

- a. Mining Technician \*
- Senior Mining Technician \*
- Continuous Mining Specialist \*
- Senior Mining Specialist \*
- Mine OPS Supervisor \*
- b. Waste Hoist Operator
- Waste Hoist Shaft Tender
- c. U/G Facility Operations\* - Self Rescuers
- Shaft Technician \*
- d. Operations Engineer
- Supervisor U/G Services\*
- Senior Operations Engineer\*

List 2: Industrial Safety

- a. Safety Technician \*
- Senior Safety Technician \*
- Safety Specialist \*
- Safety Engineer \*
- Industrial Hygienist \*
- b. Fire Protection Engineering \*

List 3: Facility Operations

- Facilities Technician \*
- Senior Facilities Technician \*
- Facility Operations Specialist \*
- Central Monitoring Room Operator \*
- Central Monitoring Room Specialist \*
- Operations Engineer
- Senior Operations Engineer \*
- Facility Shift Manager
- Operations Technical Coordinator \*

List 4: Facility Engineering

- Senior Engineer \*

List 5: General

- Equipment Custodian\*

List 6: Security

- Security Protective \*
- Security Protective Supervisor \*

List 8: Waste Handling

- Manager, Waste Operations
- TRU-Waste Handler

List 9: Geotechnical Engineering

- Engineer Technician \*
- Associate Engineer \*
- Engineer \*
- Senior Engineer \*
- Principal Engineer\*

List 10: Maintenance Operations

- Maintenance Technician \*
- Maintenance Specialist \*
- Senior Maintenance Specialist \*
- Contractor \*

List 11: Emergency Services

- Qualified Emergency Services Personnel
- Fire Protection Technician

1  
2

**Table ~~D~~E-1 (Continued)**  
**Inspection Schedule/Procedures Notes**

- a Inspection may be accomplished as part of or in addition to regularly scheduled preventive maintenance inspections for each item or system. Certain structural systems of the WHB, Waste Hoist and Station A are also subject to inspection following severe natural events including earthquakes, tornados, and severe storms. Structural systems include columns, beams, girders, anchor bolts and concrete walls.
- b Deterioration includes: obvious visible cracks, erosion, salt build-up, damage, corrosion, loose or missing parts, malfunctions, and structural deterioration.
- c "Preoperational" signifies that inspections are required prior to the first use during a calendar day. For calendar days in which the equipment is not in use, no inspections are required. For an area this includes: area is clean and free of obstructions (for emergency equipment); adequate aisle space; emergency and communications equipment is readily available, properly located and sign-posted, visible, and operational. For equipment, this includes: checking fluid levels, pressures, valve and switch positions, battery charge levels, pressures, general cleanliness, and that all functional components and emergency equipment is present and operational.
- e These weekly inspections apply to container storage areas when containers of waste are present for a week or more.
- g In addition, the water tank levels are maintained by the CMR and level readouts are available at any time.
- h This organization is responsible for obtaining licenses for radios and frequency assignments. They do periodic checks of frequencies and handle repairs which are performed by a vendor.
- i Radios are not routinely "inspected." They are operated daily and many are used in day-to-day operations. They are used until they fail, at which time they are replaced and repaired. Radios are used routinely by Emergency Services, Security, Environmental Monitoring, and Facility Operations.
- j Fire extinguisher inspection is paperless. Information is recorded into a database using barcodes. The database is then printed out.
- k Surface CH TRU mixed waste handling areas include the Parking Area Unit, the WHB unit, and unloading areas.
- l No log forms are used for daily readings. However, readings that are out of tolerance are reported to the CMR and logged by CMR operator. Inspection includes daily functional checks of portable equipment.
- m Mechanical Operability means that the equipment has been checked and is operating in accordance with site safety requirements (e.g. proper fluid levels and tire pressure; functioning lights, alarms, sirens, and power/battery units; and belts, cables, nuts/bolts, and gears in good condition), as appropriate.
- n Required Equipment means that the equipment identified in Table F-6 is available and usable (i.e. not expired/depleted and works as designed).
- \* Positions are not considered RCRA positions (i.e., personnel do not manage TRU mixed waste).

1  
2

**Table D E-1a**  
**RH TRU Mixed Waste Inspection Schedule/Procedures**

| System/<br>Equipment<br>Name        | Responsible<br>Organization <sup>J</sup> | Inspection <sup>a</sup><br>Frequency and Job<br>Title of Personnel<br>Normally Making<br>Inspection <sup>J</sup> | Procedure<br>Number<br>(Latest<br>Revision)                      | Inspection Criteria        |                  |   |
|-------------------------------------|--|--|--|----------------------------|------------------|---|
|                                     |  |  |  | Deterioration <sup>b</sup> | Leaks/<br>spills | Other   |
| Cask<br>Transfer<br>Car(s)          | Waste<br>Operations                      | Pre-evolution <sup>c,d,e</sup><br>See List 1   | WP05-WH1701<br>PM041187<br>(Semi-Annual)                         | Yes                        | NA               | Pre-evolution Checks and<br>Operating Instructions.<br>Mechanical Inspection for<br>Wear and Lubrication  |
| RH Bay<br>Overhead<br>Bridge Crane  | Waste<br>Operations                      | Preoperational <sup>c,d,e,i</sup><br>See List 1  | WP05-WH1741<br>PM041232<br>(Quarterly)<br>PM041117<br>(Annual)   | Yes                        | Yes              | Pre-operational Checks<br>and Operating<br>Instructions.<br>Mechanical Inspection for<br>Wear and Lubrication   |
| Facility Cask                       | Waste<br>Operations                      | Pre-evolution <sup>c,d,e,f</sup><br>See List 1   | WP05-WH1713<br>PM041201<br>(Annual)<br>PM041203<br>(Annual)      | Yes                        | NA               | Pre-evolution Checks and<br>Operating Instructions.<br>Mechanical Inspection for<br>Wear and Lubrication.<br>Electrical PM.                             |
| RH Bay Cask<br>Lifting Yoke         | Waste<br>Operations                      | Preoperational <sup>c,d,e,i</sup><br>See List 1  | WP05-WH1741<br>PM041169<br>(Annual)                              | Yes                        | NA               | Pre-operational Checks<br>and Operating<br>Instructions.<br>Mechanical Inspection for<br>Wear and Lubrication   |
| Facility Cask<br>Transfer Car       | Waste<br>Operations                      | Pre-evolution <sup>c,d,e,f</sup><br>See List 1   | WP05-WH1704<br>PM041186<br>(Quarterly)<br>PM041195<br>(Annual)   | Yes                        | Yes              | Pre-evolution Checks and<br>Operating Instructions.<br>Mechanical Inspection for<br>Wear and Lubrication<br>Electrical Inspection                       |
| Facility Cask<br>Rotating<br>Device | Waste<br>Operations                      | Pre-evolution <sup>c,d,e,f</sup><br>See List 1   | WP05-WH1713<br>PM041175<br>(Annual)<br>PM041176<br>(Annual)      | Yes                        | Yes              | Pre-evolution Checks and<br>Operating Instructions.<br>Mechanical Inspection for<br>Wear and Lubrication<br>Electrical Inspection                       |
| Facility<br>Grapple                 | Waste<br>Operations                      | Pre-evolution <sup>c,d,e,f</sup><br>See List 1   | WP05-WH1721<br>PM041172<br>(Quarterly)<br>PM041177<br>(Annual)   | Yes                        | NA               | Pre-evolution Checks and<br>Operating Instructions.<br>Mechanical Inspection for<br>Wear. Non-Destructive<br>Examination                                |
| 6.25-Ton<br>Grapple Hoist           | Waste<br>Operations                      | Pre-evolution <sup>c,d,e,f</sup><br>See List 1   | WP05-WH1721<br>PM041173<br>(Annual)                              | Yes                        | Yes              | Pre-evolution Checks and<br>Operating Instructions.<br>Mechanical Inspection for<br>Wear and Lubrication  |
| Transfer Cell<br>Shuttle Car        | Waste<br>Operations                      | Pre-evolution <sup>c,d,e,f</sup><br>See List 1   | WP05-WH1705<br>PM041184<br>(Semi-Annual)<br>PM041222<br>(Annual) | Yes                        | Yes              | Pre-evolution Pre-<br>operational Checks and<br>Operating Instructions.<br>Mechanical Inspection for<br>Wear and Lubrication.<br>Electrical Inspection. |

| System/<br>Equipment<br>Name                   | Responsible<br>Organization <sup>J</sup> | Inspection <sup>a</sup><br>Frequency and Job<br>Title of Personnel<br>Normally Making<br>Inspection <sup>J</sup> | Procedure<br>Number<br>(Latest<br>Revision)  | Inspection Criteria        |                  |  |
|--|--|--|--|----------------------------|------------------|--|
|  |  |  |  | Deterioration <sup>b</sup> | Leaks/<br>spills | Other  |
| Cask<br>Unloading<br>Room                      | Waste<br>Operations                      | Preoperational <sup>c,d,e,f,h,i</sup><br>See List 1  | WP05-WH1744  | Yes                        | NA               | Floor integrity  |
| Hot Cell                                       | Waste<br>Operations                      | Preoperational <sup>c,d,e,f,g,h,i</sup><br>See List 1  | WP05-WH1744  | Yes                        | NA               | Floor integrity  |
| Hot Cell<br>Overhead<br>Powered<br>Manipulator | Waste<br>Operations                      | Preoperational <sup>c,d,e,i</sup><br>See List 1  | WP05-WH1743<br>PM041215<br>(Annual)<br>PM041216<br>(Annual)<br>IC411037<br>(Annual)                            | Yes                        | Yes              | Pre-operational Checks<br>and Operating<br>Instructions.<br>Mechanical Inspection for<br>Wear and Lubrication.<br>Electrical Inspection.<br>Load Cell Calibration  |
| Hot Cell<br>Bridge Crane                       | Waste<br>Operations                      | Preoperational <sup>c,d,e,i</sup><br>See List 1  | WP05-WH1742<br>PM041217<br>(Annual)<br>PM041209<br>(Annual)<br>IC411038<br>(Annual)                            | Yes                        | Yes              | Pre-operational Checks<br>and Operating<br>Instructions.<br>Mechanical Inspection for<br>Wear and Lubrication.<br>Electrical Inspection.<br>Load Cell Calibration. |
| Transfer Cell                                  | Waste<br>Operations                      | Preoperational <sup>c,d,e,f,h,i</sup><br>See List 1  | WP05-WH1744  | Yes                        | NA               | Floor integrity  |
| Facility Cask<br>Loading<br>Room               | Waste<br>Operations                      | Preoperational <sup>c,d,e,f,h,i</sup><br>See List 1  | WP05-WH1744  | Yes                        | NA               | Floor integrity  |
| Closed<br>Circuit<br>Television<br>Camera      | Waste<br>Operations                      | Preoperational <sup>c,i</sup><br>See List 1  | WP05-WH1757  | NA                         | NA               | Operability  |
| Radiation<br>Monitoring<br>Equipment           | Radiation<br>Control                     | Preoperational <sup>c,d,e</sup><br>See List 2  | WP12-HP1245<br>IC240010<br>WP12-HP1307<br>IC240007<br>WP12-HP1314<br>(Annual)                                  | Yes                        | NA               | Operability Checks,<br>Functional Checks,<br>Instrument calibrations,<br>Flow Calibration,<br>Efficiency Checks.   |
| Cask<br>Unloading<br>Room Crane                | Waste<br>Operations                      | Preoperational <sup>c,d,e,i</sup><br>See List 1  | WP05-WH1719<br>PM041190<br>(Quarterly)<br>PM041191<br>(Annual)<br>PM041192<br>(Annual)<br>IC411035<br>(Annual) | Yes                        | Yes              | Pre-operational Checks<br>and Operating<br>Instructions.<br>Mechanical Inspection for<br>Wear and Lubrication.<br>Electrical Inspection.<br>Load Cell Calibration. |

| System/<br>Equipment<br>Name                            | Responsible<br>Organization <sup>j</sup> | Inspection <sup>a</sup><br>Frequency and Job<br>Title of Personnel<br>Normally Making<br>Inspection <sup>j</sup> | Procedure<br>Number<br>(Latest<br>Revision)   | Inspection Criteria        |                  |  |
|---|--|--|---|----------------------------|------------------|--|
|   |  |  |   | Deterioration <sup>b</sup> | Leaks/<br>spills | Other  |
| Horizontal<br>Emplacement<br>and Retrieval<br>Equipment | Waste<br>Operations                      | Pre-evolution <sup>c,d,e,f</sup><br>See List 1   | WP05-WH1700<br>PM052010<br>(Semi-Annual) <sup>k</sup><br>PM052011<br>(Annual)<br>PM052013<br>PM052012<br>PM052014<br>(Annual) | Yes                        | Yes              | Assembly and Operating<br>Instructions. Electrical<br>Inspection. Position<br>Transducer Calibration.<br>Tilt Sensor Calibration.  |
| 41-Ton<br>Forklift                                      | Waste<br>Operations                      | Preoperational <sup>c,d,e,i</sup><br>See List 1  | WP05-WH1602<br>PM074061<br>PM052003<br>(Hours of Use)<br>PM074027<br>(Quarterly)<br>PM074029 &<br>PM074051<br>(Annual)        | Yes                        | Yes              | Pre-Operational Checks.<br>PM performed every 100<br>hours of operation, every<br>500 hours of operation or<br>every 5 Years.<br>Quarterly Engine<br>Emission Test.<br>Annual Electrical<br>Inspection.<br>Annual NDE. |
| RH Bay  | Waste<br>Operations                      | Preoperational <sup>c,d,e,h,i</sup><br>See List 1  | WP05-WH1744   | Yes                        | NA               | Floor integrity  |
| Surface RH<br>TRU Mixed<br>Waste<br>Handling<br>Area    | Waste<br>Operations                      | Preoperational <sup>i</sup><br>See List 1  | WP- 05<br>WH1744  | Yes                        | Yes              | Posted Warning,<br>Communications  |

1  
2

**Table ~~D~~E-1a (Continued)**  
**RH TRU Mixed Waste Inspection Schedule/Procedures Lists**

List 1: Waste Operations

RH Waste Handling Engineer  
Qualified TRU-Waste Handler

List 2: Radiological Control

Radiological Control Technician

1 |  
2

**Table ~~D E~~-1a (Continued)**  
**RH TRU Mixed Waste Inspection Schedule/Procedures Notes**

- a Inspection may be accomplished as part of or in addition to regularly scheduled preventive maintenance inspections for each item or system. Certain structural systems of the WHB are also subject to inspection following severe natural events including earthquakes, tornados, and severe storms. Structural systems include columns, beams, girders, anchor bolts, and concrete walls.
- b Deterioration includes: visible cracks, erosion, salt build-up, damage, corrosion, loose or missing parts, malfunctions, and structural deterioration.
- c "Pre-evolution" signifies that inspections are required prior to equipment use in the waste handling process. (An evolution is considered to be from the receipt of a cask into the RH Bay through canister emplacement in the underground.) For an area, preoperational inspection includes: area is clean and free of obstructions (for emergency equipment); adequate aisle space; emergency and communications equipment is readily available, properly located and sign-posted, visible, and operational. For equipment, this includes: checking fluid levels, pressures, valve and switch positions, battery charge levels, pressures, general cleanliness, and that functional components and emergency equipment are present and operational. When the equipment is not in use, no inspections are required.
- d When equipment needs to be inspected while handling waste (i.e., during waste unloading or transfer operations), general cleanliness and functional components will be inspected to detect any problem that may harm human health or the environment. The inspection will verify that emergency equipment is present.
- e Inspection of RH TRU mixed waste equipment and areas in the RH Complex applies only after RH TRU mixed waste receipt begins.
- f The inspection/maintenance activities associated with these pieces of equipment are performed when the RH Complex is empty of RH TRU mixed waste. If contamination is present, a radiation work permit may be needed.
- g For the Hot Cell and Transfer Cell, if RH TRU mixed waste is present, camera inspections will be performed in lieu of physical inspection.
- h The integrity of the floor coating will be inspected weekly if RH TRU mixed waste is present.
- i "Preoperational" signifies that inspections are required prior to the first use in a calendar day.
- J Responsible organizations refers to the organization that owns the equipment. Preventive Maintenance (PM) procedures are conducted by either mine maintenance or surface operations maintenance personnel and Instrument Calibration (IC) procedures are conducted by instrument and calibration maintenance personnel.
- k Inspection will be performed after 250 evolutions (actual and training emplacements), if such usage occurs prior to the semi-annual inspection.

1  
2

**Table ~~D~~E-2  
 Monitoring Schedule**

| <b>System/Equipment Name</b> | <b>Responsible Organization</b> | <b>Monitoring Frequency</b> | <b>Purpose</b>   |
|------------------------------|---------------------------------|-----------------------------|--|
| Geomechanical <sup>b</sup>   | Geotechnical Engineering        | Monthly                     | To evaluate the geotechnical performance of the underground facility and to detect ground conditions that could affect operational safety  |
| Central Monitoring System    | Facility Operations             | System Dependent            | Monitor and provide status for the following facility parameters:<br>Electrical Power Status <sup>d</sup><br>Fire Alarm System <sup>e</sup><br>Ventilation System Status <sup>f</sup><br>Meteorological Data System <sup>g</sup><br>Facility Systems (compressors <sup>g</sup> , pumps <sup>h</sup> , water tank levels <sup>i</sup> , waste hoists <sup>j</sup> ) |

<sup>b</sup> Equipment is listed as Underground-Geomechanical Instrumentation System (GIS) in Table ~~D~~E-1.

<sup>d</sup> Equipment listed as Backup Power Supply Diesel Generator in Table ~~D~~E-1.

<sup>e</sup> Equipment listed as Fire Detection and Alarm System in Table ~~D~~E-1.

<sup>f</sup> Equipment listed as Ventilation Exhaust in Table ~~D~~E-1.

<sup>g</sup> Not RCRA equipment.

<sup>h</sup> Equipment listed as Fire Pumps in Table ~~D~~E-1.

<sup>i</sup> Equipment listed as Water Tank Level in Table ~~D~~E-1.

<sup>j</sup> Equipment listed as Waste Hoist in Table ~~D~~E-1.

3