



November 16, 2021

New Mexico Environment Department
Air Quality Bureau, Title V Permitting Section
525 Camino de los Marquez, Suite 1
Santa Fe, NM 87505-1816

RECEIVED

NOV 17 2021

Air Quality Bureau

**RE: Lucid Energy Delaware, LLC
Red Hills Gas Processing Plant
Lea County, New Mexico
Title V Revision Application, Permit Number P-278**

Dear Air Quality Bureau:

Alliant Environmental, LLC is submitting this Title V revision application on behalf of Lucid Energy Delaware, LLC (Lucid) for its Red Hills Gas Processing Plant. The Red Hills Gas Processing Plant is currently permitted under NSR Permit number 4310-M5 and Title V Permit number P-278.

With this application, Lucid is proposing to update the Red Hills Gas Processing Plant Title V Permit, number P-278, so that it reflects the most recent revision to the site's NSR Permit, number 4310-M5. These revisions will include Unit IDs changes, serial number updates, operating capacities changes, updated emissions, etc. All equipment to be included in Title V permit number P-278 are listed in the Section 2 Tables.

There is one (1) compact disk included with this submittal (attached to the last page of the two-hole punched application) which includes the entire Title V PDF application, the word documents for forms UA1 and UA3, the excel workbook of form UA2, and an emission calculation spreadsheet.

If you have any questions regarding this submittal or require additional information, please feel free to contact Michael Nowak at (214) 420-4950 or by email at mnowak@lucid-energy.com or Martin Schluep at (505) 205-4819 or by e-mail at mschluep@alliantenv.com.

Sincerely,

ALLIANT ENVIRONMENTAL, LLC

Melissa Fetman
Graduate Environmental Engineer

<p>Mail Application To:</p> <p>New Mexico Environment Department Air Quality Bureau Permits Section 525 Camino de los Marquez, Suite 1 Santa Fe, New Mexico, 87505</p> <p>Phone: (505) 476-4300 Fax: (505) 476-4375 www.env.nm.gov/aqb</p>		<p>For Department use only:</p> <p style="font-size: 2em; color: blue; text-align: center;">RECEIVED</p> <p style="color: red; text-align: center;">NOV 17 2021</p> <p style="color: blue; text-align: center; font-size: 1.2em;">Air Quality Bureau</p> <p>AI RS No.:</p>
---	---	---

Universal Air Quality Permit Application

Use this application for NOI, NSR, or Title V sources.

Use this application for: the initial application, modifications, technical revisions, and renewals. For technical revisions, complete Sections, 1-A, 1-B, 2-E, 3, 9 and any other sections that are relevant to the requested action; coordination with the Air Quality Bureau permit staff prior to submittal is encouraged to clarify submittal requirements and to determine if more or less than these sections of the application are needed. Use this application for streamline permits as well. See Section 1-I for submittal instructions for other permits.

This application is submitted as (check all that apply): Request for a No Permit Required Determination (no fee)
 Updating an application currently under NMED review. Include this page and all pages that are being updated (no fee required).
 Construction Status: Not Constructed Existing Permitted (or NOI) Facility Existing Non-permitted (or NOI) Facility
 Minor Source: a NOI 20.2.73 NMAC 20.2.72 NMAC application or revision 20.2.72.300 NMAC Streamline application
 Title V Source: Title V (new) Title V renewal TV minor mod. TV significant mod. TV Acid Rain: New Renewal
 PSD Major Source: PSD major source (new) minor modification to a PSD source a PSD major modification

Acknowledgements:

I acknowledge that a pre-application meeting is available to me upon request. Title V Operating, Title IV Acid Rain, and NPR applications have no fees.
 \$500 NSR application Filing Fee enclosed **OR** The full permit fee associated with 10 fee points (required w/ streamline applications).
 Check No.: [redacted] in the amount of [redacted]
 I acknowledge the required submittal format for the hard copy application is printed double sided 'head-to-toe', 2-hole punched (except the Sect. 2 landscape tables is printed 'head-to-head'), numbered tab separators. Incl. a copy of the check on a separate page.
 I acknowledge there is an annual fee for permits in addition to the permit review fee: www.env.nm.gov/air-quality/permit-fees-2/.
 This facility qualifies for the small business fee reduction per 20.2.75.11.C. NMAC. The full \$500.00 filing fee is included with this application and I understand the fee reduction will be calculated in the balance due invoice. The Small Business Certification Form has been previously submitted or is included with this application. (Small Business Environmental Assistance Program Information: www.env.nm.gov/air-quality/small-biz-eap-2/.)

Citation: Please provide the **low level citation** under which this application is being submitted: **20.2.70.300 NMAC** (e.g. application for a new minor source would be 20.2.72.200.A NMAC, one example for a Technical Permit Revision is 20.2.72.219.B.1.b NMAC, a Title V acid rain application would be: 20.2.70.200.C NMAC)

Section 1 – Facility Information

Section 1-A: Company Information

		AI # if known (see 1 st 3 to 5 #s of permit IDEA ID No.): 29885	Updating Permit/NOI #: P-278
1	Facility Name: Red Hills Gas Processing Plant	Plant primary SIC Code (4 digits): 1311	
		Plant NAIC code (6 digits): 211120	
a	Facility Street Address (If no facility street address, provide directions from a prominent landmark): 1934 W NM Highway 128, Jal, NM 88252		
2	Plant Operator Company Name: Lucid Energy Delaware, LLC	Phone/Fax: 214-420-4974	
a	Plant Operator Address: 201 South 4th Street, Artesia, NM 88210		

b	Plant Operator's New Mexico Corporate ID or Tax ID: 36-4825214	
3	Plant Owner(s) name(s): Lucid Energy Delaware, LLC	Phone/Fax: 214-420-4974
a	Plant Owner(s) Mailing Address(s): P.O. Box 158, Artesia, NM 88211-0158	
4	Bill To (Company): Lucid Energy Delaware, LLC	Phone/Fax: 214-420-4974
a	Mailing Address: P.O. Box 158, Artesia, NM 88211-0158	E-mail: AP@lucid-energy.com
5	<input checked="" type="checkbox"/> Preparer: Alliant Environmental, LLC <input checked="" type="checkbox"/> Consultant: Martin Schluep	Phone/Fax: 505-205-4819
a	Mailing Address: 7804 Pan American Fwy., Suite 5 Albuquerque, NM 87109	E-mail: mschluep@alliantenv.com
6	Plant Operator Contact: Chris Kassen	Phone/Fax: 214-420-4974
a	Address: P.O. Box 158, Artesia, NM 88211-0158	E-mail: Ckassen@lucid-energy.com
7	Air Permit Contact: Michael Nowak	Title: Environmental Air Technician
a	E-mail: MNowak@lucid-energy.com	Phone/Fax: 214-420-4950
b	Mailing Address: P.O. Box 158, Artesia, NM 88211-0158	
c	The designated Air permit Contact will receive all official correspondence (i.e. letters, permits) from the Air Quality Bureau.	

Section 1-B: Current Facility Status

1.a	Has this facility already been constructed? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.b If yes to question 1.a, is it currently operating in New Mexico? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
2	If yes to question 1.a, was the existing facility subject to a Notice of Intent (NOI) (20.2.73 NMAC) before submittal of this application? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If yes to question 1.a, was the existing facility subject to a construction permit (20.2.72 NMAC) before submittal of this application? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
3	Is the facility currently shut down? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If yes, give month and year of shut down (MM/YY): N/A
4	Was this facility constructed before 8/31/1972 and continuously operated since 1972? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
5	If Yes to question 3, has this facility been modified (see 20.2.72.7.P NMAC) or the capacity increased since 8/31/1972? <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
6	Does this facility have a Title V operating permit (20.2.70 NMAC)? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	If yes, the permit No. is: P-278
7	Has this facility been issued a No Permit Required (NPR)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If yes, the NPR No. is: N/A
8	Has this facility been issued a Notice of Intent (NOI)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If yes, the NOI No. is: N/A
9	Does this facility have a construction permit (20.2.72/20.2.74 NMAC)? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	If yes, the permit No. is: 4310-M5
10	Is this facility registered under a General permit (GCP-1, GCP-2, etc.)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	If yes, the register No. is: N/A

Section 1-C: Facility Input Capacity & Production Rate

1	What is the facility's maximum input capacity, specify units (reference here and list capacities in Section 20, if more room is required)			
a	Current	Hourly: 30.625 MMscfh	Daily: 735 MMscfd	Annually: 268,275 MMscfy
b	Proposed	Hourly: 50.417 MMscfh	Daily: 1210 MMscfd	Annually: 441,650 MMscfy
2	What is the facility's maximum production rate, specify units (reference here and list capacities in Section 20, if more room is required)			
a	Current	Hourly: 30.625 MMscfh	Daily: 735 MMscfd	Annually: 268,275 MMscfy
b	Proposed	Hourly: 50.417 MMscfh	Daily: 1210 MMscfd	Annually: 441,650 MMscfy

Section 1-D: Facility Location Information

1	Section: 13	Range: 33E	Township: 24S	County: Lea	Elevation (ft): 3582
2	UTM Zone: <input type="checkbox"/> 12 or <input checked="" type="checkbox"/> 13			Datum: <input type="checkbox"/> NAD 27 <input type="checkbox"/> NAD 83 <input checked="" type="checkbox"/> WGS 84	
a	UTM E (in meters, to nearest 10 meters): 639,100 m			UTM N (in meters, to nearest 10 meters): 3,564,550 m	
b	AND Latitude (deg., min., sec.): 32° 12' 38"			Longitude (deg., min., sec.): 103° 31' 26"	
3	Name and zip code of nearest New Mexico town: Jal, NM 88252				
4	Detailed Driving Instructions from nearest NM town (attach a road map if necessary): East of Carlsbad on Hwy 62/180 to State Road 31 south to Hwy 128. Go east for approximately 27 miles. Plant is on left just before MM 29.				
5	The facility is 24 miles WNW of Jal, NM				
6	Status of land at facility (check one): <input checked="" type="checkbox"/> Private <input type="checkbox"/> Indian/Pueblo <input type="checkbox"/> Federal BLM <input type="checkbox"/> Federal Forest Service <input type="checkbox"/> Other (specify)				
7	List all municipalities, Indian tribes, and counties within a ten (10) mile radius (20.2.72.203.B.2 NMAC) of the property on which the facility is proposed to be constructed or operated: Lea County				
8	20.2.72 NMAC applications only : Will the property on which the facility is proposed to be constructed or operated be closer than 50 km (31 miles) to other states, Bernalillo County, or a Class I area (see www.env.nm.gov/aqb/modeling/class1areas.html)? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No (20.2.72.206.A.7 NMAC) If yes, list all with corresponding distances in kilometers: 43 km from Texas state line.				
9	Name nearest Class I area: Carlsbad Caverns				
10	Shortest distance (in km) from facility boundary to the boundary of the nearest Class I area (to the nearest 10 meters): 53.0				
11	Distance (meters) from the perimeter of the Area of Operations (AO is defined as the plant site inclusive of all disturbed lands, including mining overburden removal areas) to nearest residence, school or occupied structure: >1600 m				
12	Method(s) used to delineate the Restricted Area: Continuous Fencing "Restricted Area" is an area to which public entry is effectively precluded. Effective barriers include continuous fencing, continuous walls, or other continuous barriers approved by the Department, such as rugged physical terrain with steep grade that would require special equipment to traverse. If a large property is completely enclosed by fencing, a restricted area within the property may be identified with signage only. Public roads cannot be part of a Restricted Area.				
13	Does the owner/operator intend to operate this source as a portable stationary source as defined in 20.2.72.7.X NMAC? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No A portable stationary source is not a mobile source, such as an automobile, but a source that can be installed permanently at one location or that can be re-installed at various locations, such as a hot mix asphalt plant that is moved to different job sites.				
14	Will this facility operate in conjunction with other air regulated parties on the same property? <input checked="" type="checkbox"/> No <input type="checkbox"/> Yes If yes, what is the name and permit number (if known) of the other facility? N/A				

Section 1-E: Proposed Operating Schedule (The 1-E.1 & 1-E.2 operating schedules may become conditions in the permit.)

1	Facility maximum operating ($\frac{\text{hours}}{\text{day}}$): 24	($\frac{\text{days}}{\text{week}}$): 7	($\frac{\text{weeks}}{\text{year}}$): 52	($\frac{\text{hours}}{\text{year}}$): 8760
2	Facility's maximum daily operating schedule (if less than 24 $\frac{\text{hours}}{\text{day}}$)? Start: N/A		<input type="checkbox"/> AM <input type="checkbox"/> PM	End: N/A ~A M ~PM
3	Month and year of anticipated start of construction: TBD			
4	Month and year of anticipated construction completion: TBD			
5	Month and year of anticipated startup of new or modified facility: TBD			
6	Will this facility operate at this site for more than one year? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			

Section 1-F: Other Facility Information

1	Are there any current Notice of Violations (NOV), compliance orders, or any other compliance or enforcement issues related to this facility? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If yes, specify: N/A	
a	If yes, NOV date or description of issue: N/A	NOV Tracking No: N/A

b	Is this application in response to any issue listed in 1-F, 1 or 1a above? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No If Yes, provide the 1c & 1d info below:		
c	Document Title: N/A	Date: N/A	Requirement # (or page # and paragraph #): N/A
d	Provide the required text to be inserted in this permit: N/A		
2	Is air quality dispersion modeling or modeling waiver being submitted with this application? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
3	Does this facility require an "Air Toxics" permit under 20.2.72.400 NMAC & 20.2.72.502, Tables A and/or B? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
4	Will this facility be a source of federal Hazardous Air Pollutants (HAP)? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
a	If Yes, what type of source? <input checked="" type="checkbox"/> Major (<input type="checkbox"/> ≥10 tpy of any single HAP OR <input checked="" type="checkbox"/> ≥25 tpy of any combination of HAPS) OR <input type="checkbox"/> Minor (<input type="checkbox"/> <10 tpy of any single HAP AND <input type="checkbox"/> <25 tpy of any combination of HAPS)		
5	Is any unit exempt under 20.2.72.202.B.3 NMAC? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
a	If yes, include the name of company providing commercial electric power to the facility: <u>Xcel Energy</u> Commercial power is purchased from a commercial utility company, which specifically does not include power generated on site for the sole purpose of the user.		

Section 1-G: Streamline Application

(This section applies to 20.2.72.300 NMAC Streamline applications only)

1	<input type="checkbox"/> I have filled out Section 18, "Addendum for Streamline Applications." <input checked="" type="checkbox"/> N/A (This is not a Streamline application.)
---	--

Section 1-H: Current Title V Information - Required for all applications from TV Sources

(Title V-source required information for all applications submitted pursuant to 20.2.72 NMAC (Minor Construction Permits), or 20.2.74/20.2.79 NMAC (Major PSD/NNSR applications), and/or 20.2.70 NMAC (Title V))

1	Responsible Official (R.O.) (20.2.70.300.D.2 NMAC): Matt Eales	Phone: 832-496-7513
a	R.O. Title: Vice President - EHSR	R.O. e-mail: meales@lucid-energy.com
b	R. O. Address: 3100 McKinnon Street #800, Dallas, TX 75201	
2	Alternate Responsible Official (20.2.70.300.D.2 NMAC): Mike Latchem	Phone: 214-420-4950
a	A. R.O. Title: President & CEO	A. R.O. e-mail: mlatchem@lucid-energy.com
b	A. R. O. Address: 3100 McKinnon Street #800, Dallas, TX 75201	
3	Company's Corporate or Partnership Relationship to any other Air Quality Permittee (List the names of any companies that have operating (20.2.70 NMAC) permits and with whom the applicant for this permit has a corporate or partnership relationship): N/A	
4	Name of Parent Company ("Parent Company" means the primary name of the organization that owns the company to be permitted wholly or in part.): Lucid Energy Group, LLC	
a	Address of Parent Company: 3100 McKinnon Street #800, Dallas, TX 75201	
5	Names of Subsidiary Companies ("Subsidiary Companies" means organizations, branches, divisions or subsidiaries, which are owned, wholly or in part, by the company to be permitted.): Lucid Energy Delaware, LLC and Lucid Artesia Company	
6	Telephone numbers & names of the owners' agents and site contacts familiar with plant operations: Air Permit Contact: Michael Nowak Phone: 214-420-4950, Email: MNowak@lucid-energy.com	
7	Affected Programs to include Other States, local air pollution control programs (i.e. Bernalillo) and Indian tribes: Will the property on which the facility is proposed to be constructed or operated be closer than 80 km (50 miles) from other states, local pollution control programs, and Indian tribes and pueblos (20.2.70.402.A.2 and 20.2.70.7.B)? If yes, state which ones and provide the distances in kilometers: States: Texas – 43 km; Local Air Pollution Programs: Not Applicable; Tribes and Pueblos: Not Applicable	

Section 1-I – Submittal Requirements

Each 20.2.73 NMAC (NOI), a 20.2.70 NMAC (Title V), a 20.2.72 NMAC (NSR minor source), or 20.2.74 NMAC (PSD) application package shall consist of the following:

Hard Copy Submittal Requirements:

- 1) One hard copy **original signed and notarized application package printed double sided ‘head-to-toe’ 2-hole punched** as we bind the document on top, not on the side; except Section 2 (landscape tables), which should be **head-to-head**. Please use **numbered tab separators** in the hard copy submittal(s) as this facilitates the review process. For NOI submittals only, hard copies of UA1, Tables 2A, 2D & 2F, Section 3 and the signed Certification Page are required. **Please include a copy of the check on a separate page.**
- 2) If the application is for a minor NSR, PSD, NNSR, or Title V application, include one working hard **copy** for Department use. This **copy** should be printed in book form, 3-hole punched, and **must be double sided**. Note that this is in addition to the head-to-toe 2-hole punched copy required in 1) above. Minor NSR Technical Permit revisions (20.2.72.219.B NMAC) only need to fill out Sections 1-A, 1-B, 3, and should fill out those portions of other Section(s) relevant to the technical permit revision. TV Minor Modifications need only fill out Sections 1-A, 1-B, 1-H, 3, and those portions of other Section(s) relevant to the minor modification. NMED may require additional portions of the application to be submitted, as needed.
- 3) The entire NOI or Permit application package, including the full modeling study, should be submitted electronically. Electronic files for applications for NOIs, any type of General Construction Permit (GCP), or technical revisions to NSRs must be submitted with compact disk (CD) or digital versatile disc (DVD). For these permit application submittals, **two CD** copies are required (in sleeves, not crystal cases, please), with additional CD copies as specified below. NOI applications require only a **single CD** submittal. Electronic files for other New Source Review (construction) permits/permit modifications or Title V permits/permit modifications can be submitted on CD/DVD or sent through AQB’s secure file transfer service.

Electronic files sent by (check one):

CD/DVD attached to paper application

secure electronic transfer. Air Permit Contact Name _____

Email _____

Phone number _____

a. If the file transfer service is chosen by the applicant, after receipt of the application, the Bureau will email the applicant with instructions for submitting the electronic files through a secure file transfer service. Submission of the electronic files through the file transfer service needs to be completed within 3 business days after the invitation is received, so the applicant should ensure that the files are ready when sending the hard copy of the application. The applicant will not need a password to complete the transfer. **Do not use the file transfer service for NOIs, any type of GCP, or technical revisions to NSR permits.**

- 4) Optionally, the applicant may submit the files with the application on compact disk (CD) or digital versatile disc (DVD) following the instructions above and the instructions in 5 for applications subject to PSD review.
- 5) If **air dispersion modeling** is required by the application type, include the **NMED Modeling Waiver** and/or electronic air dispersion modeling report, input, and output files. The dispersion modeling **summary report only** should be submitted as hard copy(ies) unless otherwise indicated by the Bureau.
- 6) If the applicant submits the electronic files on CD and the application is subject to PSD review under 20.2.74 NMAC (PSD) or NNSR under 20.2.79 NMC include,
 - a. one additional CD copy for US EPA,
 - b. one additional CD copy for each federal land manager affected (NPS, USFS, FWS, USDI) and,
 - c. one additional CD copy for each affected regulatory agency other than the Air Quality Bureau.

If the application is submitted electronically through the secure file transfer service, these extra CDs do not need to be submitted.

Electronic Submittal Requirements [in addition to the required hard copy(ies)]:

- 1) All required electronic documents shall be submitted as 2 separate CDs or submitted through the AQB secure file transfer service. Submit a single PDF document of the entire application as submitted and the individual documents comprising the application.
- 2) The documents should also be submitted in Microsoft Office compatible file format (Word, Excel, etc.) allowing us to access the text and formulas in the documents (copy & paste). Any documents that cannot be submitted in a Microsoft Office compatible

format shall be saved as a PDF file from within the electronic document that created the file. If you are unable to provide Microsoft office compatible electronic files or internally generated PDF files of files (items that were not created electronically: i.e. brochures, maps, graphics, etc.), submit these items in hard copy format. We must be able to review the formulas and inputs that calculated the emissions.

- 3) It is preferred that this application form be submitted as 4 electronic files (**3 MSWord docs**: Universal Application section 1 [UA1], Universal Application section 3-19 [UA3], and Universal Application 4, the modeling report [UA4]) and **1 Excel file** of the tables (Universal Application section 2 [UA2]). Please include as many of the 3-19 Sections as practical in a single MS Word electronic document. Create separate electronic file(s) if a single file becomes too large or if portions must be saved in a file format other than MS Word.
- 4) The **electronic file names** shall be a maximum of 25 characters long (including spaces, if any). The format of the electronic Universal Application shall be in the format: "A-3423-FacilityName". The "A" distinguishes the file as an application submittal, as opposed to other documents the Department itself puts into the database. Thus, all electronic application submittals should begin with "A-". Modifications to existing facilities should use the **core permit number** (i.e. '3423') the Department assigned to the facility as the next 4 digits. Use 'XXXX' for new facility applications. The format of any separate electronic submittals (additional submittals such as non-Word attachments, re-submittals, application updates) and Section document shall be in the format: "A-3423-9-description", where "9" stands for the **section #** (in this case Section 9-Public Notice). Please refrain, as much as possible, from submitting any scanned documents as this file format is extremely large, which uses up too much storage capacity in our database. Please take the time to fill out the **header information** throughout all submittals as this will identify any loose pages, including the Application Date (date submitted) & Revision number (0 for original, 1, 2, etc.; which will help keep track of subsequent partial update(s) to the original submittal. Do not use special symbols (#, @, etc.) in file names. The footer information should not be modified by the applicant.

Table of Contents

Section 1:	General Facility Information
Section 2:	Tables
Section 3:	Application Summary
Section 4:	Process Flow Sheet
Section 5:	Plot Plan Drawn to Scale
Section 6:	All Calculations
Section 7:	Information Used to Determine Emissions
Section 8:	Map(s)
Section 9:	Proof of Public Notice
Section 10:	Written Description of the Routine Operations of the Facility
Section 11:	Source Determination
Section 12:	PSD Applicability Determination for All Sources & Special Requirements for a PSD Application
Section 13:	Discussion Demonstrating Compliance with Each Applicable State & Federal Regulation
Section 14:	Operational Plan to Mitigate Emissions
Section 15:	Alternative Operating Scenarios
Section 16:	Air Dispersion Modeling
Section 17:	Compliance Test History
Section 18:	Addendum for Streamline Applications (streamline applications only)
Section 19:	Requirements for the Title V (20.2.70 NMAC) Program (Title V applications only)
Section 20:	Other Relevant Information
Section 21:	Addendum for Landfill Applications
Section 22:	Certification Page

Table 2-A: Regulated Emission Sources

Unit and stack numbering must correspond throughout the application package. If applying for a NOI under 20.2.73 NMAC, equipment exemptions under 2.72.202 NMAC do not apply.

Unit Number ¹	Source Description	Make	Model #	Serial #	Manufacturer's Rated Capacity ³ (Specify Units)	Requested Permitted Capacity ³ (Specify Units)	Date of Manufacture ²	Controlled by Unit #	Source Classification Code (SCC)	For Each Piece of Equipment, Check One	RICE Ignition Type (CI, SI, 4SLB, 4SRB, 2SLB) ⁴	Replacing Unit No.
							Date of Construction/Reconstruction ²	Emissions vented to Stack #				
1-EP-1	Hot Oil Heater	New Point Thermal	DHV 100/50C	7163	35.3 MMBtu/hr	35.3 MMBtu/hr	2011	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
1-EP-2	Flare - Cryo 1 Train SSM	Callidus	RTA-20 Air-Assisted Tip	F-201113 Tag #: 29-1001	75 MMscf/d	75 MMscf/d	2012	N/A	31000205	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
1-EP-3	Glycol Dehydrator Flash Tank & Still Vent - Service 1 Train	Tryer Process Equipment	N/A	Tag #: 29-302 V-101 / V-110	70 MMscf/d	70 MMscf/d	2012	EP-5	31000301	<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
1-EP-4	Amine Unit Flash Tank & Still Vent - Service 1 Train	Allied Equip. BCKK	N/A	P211097 31-205	70 MMscf/d	70 MMscf/d	2012	EP-5	31000305	<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
1.5-EP-1g	10k Stabilizer Heater	Tulsa Heaters Midstream	N/A	MJ19-423	22.61 MMBtu/hr	22.61 MMBtu/hr	2019	N/A	31000205	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
4-EP-1g	HMO Heater	New Point Thermal, LP	DHV 100/50C	7163	4.5 MMBtu/hr	4.5 MMBtu/hr	2011	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
2-EP-1a	Mol Sieve Heater - Cryo 2 Train	Hectac	HCI-5010-40-G	HI14-266	5.6 MMBtu/hr	5.6 MMBtu/hr	2017	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
2-EP-1b	HMO Heater - Cryo 2 Train	Hectac	HCI-8010-40-D-G	HI14-267	23.65 MMBtu/hr	23.65 MMBtu/hr	2017	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
2-EP-1e	Glycol Dehydrator Reboiler	Reset Energy	N/A	F-6	3 MMBtu/hr	3 MMBtu/hr	2017	N/A	31000404	<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
2-EP-2a	Flare SSM - Cryo 2 Train	Zeeco	N/A	24675	200 MMscf/d	200 MMscf/d	2017	N/A	31000205	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
2-EP-4	Amine Unit Flash Tank & Still Vent - Service 2 Train	PBP Fabrication Inc	N/A	483	200 MMscf/d	200 MMscf/d	2017	EP-5	31000305	<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
2-EP-1h	Amine Unit Reboiler	HMI	2BKU30/50-312	1016-5059A-1	55 MMBtu/hr	55 MMBtu/hr	2017	N/A	31000404	<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
2a-EP-1d	Amine Unit Reboiler	HMI	2BKU30/50-312	1016-5059A-2	55 MMBtu/hr	55 MMBtu/hr	2017	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
2a-EP-3	Glycol Dehydrator Flash Tank & Still Vent - Service 2 Train	Reset Energy	N/A	Tah # T-2701	200 MMscf/d	200 MMscf/d	2017	EP-5	31000301	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A

Unit Number ¹	Source Description	Make	Model #	Serial #	Manufacturer's Rated Capacity ³ (Specify Units)	Requested Permitted Capacity ³ (Specify Units)	Date of Manufacture ²	Controlled by Unit #	Source Classification Code (SCC)	For Each Piece of Equipment, Check One	RICE Ignition Type (CI, SI, 4SLB, 4SRB, 2SLB) ⁴	Replacing Unit No.
							Date of Construction/Reconstruction ²	Emissions vented to Stack #				
2.5-EP-4	Amine Unit Flash Tank & Still Vent (High H2S Handling #1)	Reset Energy	N/A	226	60 MMscf/d	60 MMscf/d	2018	AGI 1 & 2.5-EP-5	31000305	<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2018	AGI 1 & 2.5-EP-5				
2.5-EP-1d	Amine Unit Reboiler (High H2S Handling #1)	Sigma	HC2-20.0-HENG	J17133-001	25 MMBtu/hr	25 MMBtu/hr	2018	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2018	2.5-EP-1d				
2.5-EP-5	Flare - AGI System 1 SSM (High H2S Handling #1)	Tulsa Combustion	N/A	17-09-2126	6.4 MMscf/d	6.4 MMscf/d	2018	N/A	31000205	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2018	2.5-EP-5				
3-EP-1a	Mol Sieve Heater - Cryo 3 Train	Tulsa Heaters Midstream	H-741	MJ17-265	7.29 MMBtu/hr	7.29 MMBtu/hr	2018	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2018	3-EP-1a				
3-EP-1b	HMO Heater - Cryo 3 Train	Tulsa Heaters Midstream	H-781	MJ17-266	17.55 MMBtu/hr	17.55 MMBtu/hr	2018	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2018	3-EP-1b				
3-EP-1d	Amine Unit Reboiler	DEVCO	N/A	16025904-A	55 MMBtu/hr	55 MMBtu/hr	2018	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2018	3-EP-1d				
3-EP-1e	Glycol Dehydrator Reboiler	Reset Energy	N/A	H-6301	3 MMBtu/hr	3 MMBtu/hr	2019	N/A	31000404	<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2019	3-EP-1e				
3-EP-1h	Amine Unit Reboiler	DEVCO	N/A	16025904-A	55 MMBtu/hr	55 MMBtu/hr	2018	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2018	3-EP-1h				
3-EP-2a	Flare SSM - Cryo 3 Train	Zeeco	N/A	Tag#: FL-5100	200 MMscf/d	200 MMscf/d	2018	N/A	31000205	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2018	3-EP-2a				
3-EP-3	Glycol Dehydrator Flash Tank & Still Vent - Service 3 Train	ISTI/RAMA	N/A	14469-01	200 MMscf/d	200 MMscf/d	2018	EP-6	31000301	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2018	EP-6				
3-EP-4	Amine Unit Flash Tank & Still Vent Service - 3 Train	Reset Energy	N/A	V-01-01	200 MMscf/d	200 MMscf/d	2016	EP-8	31000305	<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2016	EP-8				
4-EP-1a	Mol Sieve Heater - Cryo 4 Train	Tulsa Heaters Midstream	H-741	MJ17-271	7.29 MMBtu/hr	7.29 MMBtu/hr	2017	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2017	4-EP-1a				
4-EP-1b	HMO Heater - Cryo 4 Train	Tulsa Heaters Midstream	H-781	MJ17-272	17.55 MMBtu/hr	17.55 MMBtu/hr	2017	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2017	4-EP-1b				
4-EP-2a	Flare SSM - Cryo 4 Train	Zeeco	FI-45100	10507-128182	200 MMscf/d	200 MMscf/d	2019	N/A	31000205	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2019	4-EP-2a				
EP-5	Thermal Oxidizer (TO)	Zeeco	N/A	Tag #: TO-5500	28 MMBtu/hr	28 MMBtu/hr	2012	N/A	31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
							2012	EP-5				

Unit Number ¹	Source Description	Make	Model #	Serial #	Manufacturer's Rated Capacity ³ (Specify Units)	Requested Permitted Capacity ³ (Specify Units)	Date of Manufacture ²		Controlled by Unit #	Source Classification Code (SCC)	For Each Piece of Equipment, Check One	RICE Ignition Type (CI, SI, 4SLB, 4SRB, 2SLB) ⁴	Replacing Unit No.
							Date of Construction/Reconstruction ²	Emissions vented to Stack #					
EP-6	Thermal Oxidizer (TO)	Zeeeco	N/A	37954	28 MMBtu/hr	28 MMBtu/hr	2012	N/A		31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
EP-7	Enclosed Combustion Device (ECD) – Condensate Tank Control	TBD	TBD	TBD	1.55 MMBtu/hr	1.55 MMBtu/hr	TBD	N/A		31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
EP-9	Flare - Sour Slop Tank Control	Tulsa Combustion	N/A	PO-170084-07	6 MMBtu/hr	6 MMBtu/hr	TBD	N/A		31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
1-T	Condensate Storage Tanks 1-T-1, 1-T-2, 1-T-3, 1-T-4, 1-T-5, 1-T-6	Palmer Palmer Palmer Palmer Palmer Permian Tank	N/A	ST-26092 ST-26093 ST-26094 ST-26095 ST-26091 F52974	500 bbl each	500 bbl each	2012	EP-7		40400311	<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
1-Load	Condensate Loading Emissions	Palmer	LIC-NO/12F0067	5t-26095	TBD	TBD	2011	EP-7		40400250	<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
2-Load	Sour Slop Tank Loading Emissions	API	TK6100	201749	TBD	TBD	2018	N/A		40400250	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
2-T	H2S Sour Slop Tank 2-T-1 & 2-T-2	Tank & Vessel Builders, L.P.	N/A	201749 201750	500 bbl each	500 bbl each	TBD	EP-9		40400311	<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
FUG	Fugitive Emissions from Cryo Trains 1 to 4; Service Trains 1 to 3; Tanks: 1-T-1 to 1-T-6 & 2-T-1 to 2-T-2; Loading: 1-Load, 2-Load	N/A	N/A	N/A	N/A	N/A	TBD	N/A		31088811	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input checked="" type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
HAUL	Fugitive Emissions	N/A	N/A	N/A	N/A	N/A	N/A	N/A		31088811	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input checked="" type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
4-EP-1d	Amine Unit Reboiler	Heterick Manufacturing	2BWU3D/5D-31	1218-5288A-2	55 MMBtu/hr	55 MMBtu/hr	2019	N/A		31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input checked="" type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
4-EP-1e	Glycol Dehydrator Reboiler	Reset Energy	N/A	F-15	3 MMBtu/hr	3 MMBtu/hr	2019	N/A		31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input checked="" type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A
4-EP-1h	Amine Unit Reboiler	TBD	TBD	TBD	55 MMBtu/hr	55 MMBtu/hr	TBD	N/A		31000404	<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input checked="" type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced	N/A	N/A

Unit Number ¹	Source Description	Make	Model #	Serial #	Manufacturer's Rated Capacity ³ (Specify Units)	Requested Permitted Capacity ³ (Specify Units)	Date of Manufacture ²	Controlled by Unit #	Source Classification Code (SCC)	For Each Piece of Equipment, Check One	RICE Ignition Type (CI, SI, 4SLB, 4SRB, 2SLB) ⁴	Replacing Unit No.	
							Date of Construction/Reconstruction ²	Emissions vented to Stack #					
4-EP-3	Glycol Dehydrator Flash Tank & Still Vent – Service Train 4	Reset Energy	V-5101	320	200 MMscf/d	200 MMscf/d	2019	EP-6	31000301	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							2019	EP-6					
EP-8	Thermal Oxidizer (TO)	Zeeco	N/A	5500	28 MMBtu/hr	28 MMBtu/hr	2012	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							2012	EP-8					
4-EP-4	Amine Unit Flash Tank & Still Vent – Service Train 4	BPB	V-45520	483	200 MMscf/d	200 MMscf/d	2019	EP-6	31000305	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							2019	EP-6					
5-EP-1a	Amine Unit & Glycol Dehydrator Reboiler	TBD	TBD	TBD	70 MMBtu/hr	70 MMBtu/hr	TBD	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	5-EP-1a					
5-EP-1b	Amine Unit & Glycol Dehydrator Reboiler	TBD	TBD	TBD	70 MMBtu/hr	70 MMBtu/hr	TBD	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	5-EP-1b					
5-EP-1c	Mole Sieve Heater - Cryo 5 Train	Tulsa Heaters Midstream	SHO500	MJ19-384	7.29 MMBtu/hr	7.29 MMBtu/hr	2019	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							2019	5-EP-1c					
5-EP-1d	HMO Heater - Cryo 5 Train	Tulsa Heaters Midstream	SHO2500	MJ18-370	17.55 MMBtu/hr	17.55 MMBtu/hr	TBD	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	5-EP-1d					
5-EP-1e	Glycol Dehydrator Flash Tank & Still Vent – Service 5 Train	Gemstar	V-55520	4262	230 MMscf/d	230 MMscf/d	2019	EP-10	31000301	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							2019	EP-10					
5-EP-1f	Amine Unit Flash Tank & Still Vent – Service 5 Train	Reset Energy	V-53101	348	250 MMscf/d	250 MMscf/d	2020	EP-10	31000305	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							2020	EP-10					
5-EP-2	Flare SSM - Cryo 5 & 6 Trains	Zeeco	FI-55100	42009	230 MMscf/d	230 MMscf/d	2020	N/A	31000205	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							2020	5-EP-2					
6-EP-1a	Amine Unit & Glycol Dehydrator Reboiler	TBD	TBD	TBD	70 MMBtu/hr	70 MMBtu/hr	TBD	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	6-EP-1a					
6-EP-1b	Amine Unit & Glycol Dehydrator Reboiler	TBD	TBD	TBD	70 MMBtu/hr	70 MMBtu/hr	TBD	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	6-EP-1b					
6-EP-1c	Mole Sieve Heater – Cryo 6 Train	TBD	TBD	TBD	7.29 MMBtu/hr	7.29 MMBtu/hr	TBD	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	6-EP-1c					
6-EP-1d	HMO Heater – Cryo 6	TBD	TBD	TBD	17.55 MMBtu/hr	17.55 MMBtu/hr	TBD	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	6-EP-1d					

Unit Number ¹	Source Description	Make	Model #	Serial #	Manufacturer's Rated Capacity ³ (Specify Units)	Requested Permitted Capacity ³ (Specify Units)	Date of Manufacture ²	Controlled by Unit #	Source Classification Code (SCC)	For Each Piece of Equipment, Check One	RICE Ignition Type (CI, SI, 4SLB, 4SRB, 2SLB) ⁴	Replacing Unit No.
							Date of Construction/Reconstruction ²	Emissions vented to Stack #				
6-EP-1e	Glycol Dehydrator Flash Tank & Still Vent – Service 6 Train	TBD	TBD	TBD	230 MMscf/d	230 MMscf/d	TBD	EP-10	31000301	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	EP-10				
6-EP-1f	Amine Unit Flash Tank & Still Vent – Service 6 Train	TBD	TBD	TBD	250 MMscf/d	250 MMscf/d	TBD	EP-10	31000305	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	EP-10				
7-EP-1c	Mole Sieve Heater – Cryo 7 Train	TBD	TBD	TBD	7.29 MMBtu/hr	7.29 MMBtu/hr	TBD	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	7-EP-1c				
7-EP-1d	HMO Heater – Cryo 7 Train	TBD	TBD	TBD	17.55 MMBtu/hr	17.55 MMBtu/hr	TBD	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	7-EP-1d				
7-EP-2	Flare SSM - Cryo 7 Train	TBD	TBD	TBD	230 MMscf/d	230 MMscf/d	TBD	N/A	31000205	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	7-EP-2				
5.5-EP-1a	Amine Unit Reboiler (High H2S Handling #2)	TBD	TBD	TBD	70 MMBtu/hr	70 MMBtu/hr	TBD	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	5.5-EP-1a				
5.5-EP-1b	Flare - AGI System 2 SSM (High H2S Handling #2)	TBD	TBD	TBD	8.2 MMscf/d	8.2 MMscf/d	TBD	N/A	31000205	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	5.5-EP-1b				
5.5-EP-1c	Amine Unit Flash Tank & Still Vent (High H2S Handling #2)	TBD	TBD	TBD	60 MMscf/d	60 MMscf/d	TBD	AGI 2 & 5.5-EP-1b	31000205	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	AGI 2 & 5.5-EP-1b				
3-T	Condensate Storage Tanks 3-T-1, 3-T- 2, 3-T-3, 3-T-4, 3-T-5, 3-T-6	Palmer Palmer Palmer	12F-0067 12F-0067 12F-0067	5t-1938923 5t-1938921 5t-1938922	500 bbl each	500 bbl each	2019	EP-12	40400311	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							2019	EP-12				
							TBD	EP-13				
4-T	Sour Water Tanks 4-T-1, 4-T-2	TBD	TBD	TBD	500 bbl each	500 bbl each	TBD	EP-13	40400311	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	EP-13				
5-T	Slop Tanks 5-T-1, 5-T-2, 5-T-3, 5-T-4	TBD	TBD	TBD	400 bbl each	400 bbl each	TBD	N/A	40400311	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	N/A				
3-LOAD	Condensate Loading Emissions	TBD	TBD	TBD	TBD	TBD	TBD	EP-12	40400250	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	EP-12				
4-LOAD	Sour Water Tanks Loading Emissions	TBD	TBD	TBD	TBD	TBD	TBD	N/A	40400250	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	N/A				

Unit Number ¹	Source Description	Make	Model #	Serial #	Manufacturer's Rated Capacity ³ (Specify Units)	Requested Permitted Capacity ³ (Specify Units)	Date of Manufacture ²	Controlled by Unit #	Source Classification Code (SCC)	For Each Piece of Equipment, Check One	RICE Ignition Type (CI, SI, 4SRB, 2SLB) ⁴	Replacing Unit No.	
							Date of Construction/Reconstruction ²	Emissions vented to Stack #					
5-LOAD	Slop Tanks Loading Emissions	TBD	TBD	TBD	TBD	TBD	TBD	N/A	40400250	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	N/A					
EP-10	Thermal Oxidizer (TO)	TBD	TBD	TBD	112 MMBtu/hr	112 MMBtu/hr	TBD	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	EP-10					
EP-11	SSM Venting during SSM of Thermal Oxidizer	N/A	N/A	N/A	N/A	N/A	TBD	N/A	31000404	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	EP-11					
EP-12	Enclosed Combustion Device (ECD) - Condensate Tank Control	TBD	TBD	TBD	1.2 MMBtu/hr	1.2 MMBtu/hr	TBD	N/A	31000205	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	EP-12					
EP-13	Flare - Sour Water Tanks Control	TBD	TBD	TBD	1.84 MMBtu/hr	1.84 MMBtu/hr	TBD	N/A	31000205	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	EP-13					
2-EP-1t	SSM Venting - Cryo Train 2	TBD	TBD	TBD	N/A	N/A	TBD	N/A	30600402	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	2-EP-1t					
3-EP-1t	SSM Venting - Cryo Train 3	TBD	TBD	TBD	N/A	N/A	TBD	N/A	30600402	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	3-EP-1t					
4-EP-1t	SSM Venting - Cryo Train 4	TBD	TBD	TBD	N/A	N/A	TBD	N/A	30600402	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	4-EP-1t					
5-EP-1t	SSM Venting - Cryo Train 5	TBD	TBD	TBD	N/A	N/A	TBD	N/A	30600402	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	5-EP-1t					
6-EP-1t	SSM Venting - Cryo Train 6	TBD	TBD	TBD	N/A	N/A	TBD	N/A	30600402	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	6-EP-1t					
7-EP-1t	SSM Venting - Cryo Train 7	TBD	TBD	TBD	N/A	N/A	TBD	N/A	30600402	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							TBD	7-EP-1t					
SSM/M	Miscellaneous Venting due to Startup, Shutdown and Maintenance and Malfunction (SSM/M)	N/A	N/A	N/A	N/A	N/A	2012	N/A	N/A	<input type="checkbox"/> Existing (unchanged) <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> To Be Modified	<input type="checkbox"/> To be Removed <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To be Replaced	N/A	N/A
							2012	N/A					

Unit Number ¹	Source Description	Make	Model #	Serial #	Manufacturer's Rated Capacity ³ (Specify Units)	Requested Permitted Capacity ³ (Specify Units)	Date of Manufacture ²	Controlled by Unit #	Source Classification Code (SCC)	For Each Piece of Equipment, Check One	RICE Ignition Type (CI, SI, 4SLB, 4SRB, 2SLB) ⁴	Replacing Unit No.
							Date of Construction/Reconstruction ²	Emissions vented to Stack #				
FUG-1	Fugitive Emissions from Cryo Trains 5 to 7; Service Trains 4 to 6; Tanks 3-T-1 to 3-T-6, 4-T-1 to 4-T-2, 5-T-1 to 5-T-4; Loading 3-Load, 4-Load, 5-Load	N/A	N/A	N/A	N/A	N/A	N/A	N/A	31088811	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							N/A	N/A				
HAUL-1	Fugitive Emissions	N/A	N/A	N/A	N/A	N/A	N/A	N/A	31088811	<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input checked="" type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced	N/A	N/A
							N/A	N/A				
										<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced		
										<input type="checkbox"/> Existing (unchanged) <input type="checkbox"/> To be Removed <input type="checkbox"/> New/Additional <input type="checkbox"/> Replacement Unit <input type="checkbox"/> To Be Modified <input type="checkbox"/> To be Replaced		

¹ Unit numbers must correspond to unit numbers in the previous permit unless a complete cross reference table of all units in both permits is provided.

² Specify dates required to determine regulatory applicability.

³ To properly account for power conversion efficiencies, generator set rated capacity shall be reported as the rated capacity of the engine in horsepower, not the kilowatt capacity of the generator set.

⁴ "4SLB" means four stroke lean burn engine, "4SRB" means four stroke rich burn engine, "2SLB" means two stroke lean burn engine, "CI" means compression ignition, and "SI" means spark ignition

Table 2-B: Insignificant Activities¹ (20.2.70 NMAC) OR Exempted Equipment (20.2.72 NMAC)

All 20.2.70 NMAC (Title V) applications must list all Insignificant Activities in this table. All 20.2.72 NMAC applications must list Exempted Equipment in this table. If equipment listed on this table is exempt under 20.2.72.202.B.5, include emissions calculations and emissions totals for 202.B.5 "similar functions" units, operations, and activities in Section 6, Calculations. Equipment and activities exempted under 20.2.72.202 NMAC may not necessarily be Insignificant under 20.2.70 NMAC (and vice versa). Unit & stack numbering must be consistent throughout the application package. Per Exemptions Policy 02-012.00 (see http://www.env.nm.gov/aqb/permit/aqb_pol.html), 20.2.72.202.B NMAC Exemptions do not apply, but 20.2.72.202.A NMAC exemptions do apply to NOI facilities under 20.2.73 NMAC. List 20.2.72.301.D.4 NMAC Auxiliary Equipment for Streamline applications in Table 2-A. The List of Insignificant Activities (for TV) can be found online at <https://www.env.nm.gov/wp-content/uploads/sites/2/2017/10/InsignificantListTitleV.pdf>. TV sources may elect to enter both TV Insignificant Activities and Part 72 Exemptions on this form.

Unit Number	Source Description	Manufacturer	Model No.	Max Capacity	List Specific 20.2.72.202 NMAC Exemption (e.g. 20.2.72.202.B.5)	Date of Manufacture /Reconstruction ²	For Each Piece of Equipment, Check One
			Serial No.	Capacity Units	Insignificant Activity citation (e.g. IA List Item #1.a)	Date of Installation /Construction ²	
SmT-1	Amine Storage Tank	N/A	N/A	120	20.2.72.202.B.2		<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced
			N/A	bb1			
SmT-2	Lube Oil Storage Tank	N/A	N/A	120	20.2.72.202.B.2		<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced
			N/A	bb1			
SmT-3	Glycol Storage Tank	N/A	N/A	120	20.2.72.202.B.2		<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced
			N/A	bb1			
SmT-4	Oily Wastewater Tank	N/A	N/A	210	20.2.72.202.B.2		<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced
			N/A	bb1			
SmT-5	Oil Storage	N/A	N/A	120	20.2.72.202.B.5		<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced
			N/A	bb1			
1-Gen-1	Emergency Generator	Caterpillar	CG137	TBD	20.2.72.202.B.3	24-05-12	<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced
			WRX00112	TBD			
SmT-6	Wastewater Tank	N/A	N/A	500	20.2.72.202.B.2		<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced
			N/A	bb1			
SmT-7	Wastewater Tank	N/A	N/A	500	20.2.72.202.B.2		<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced
			N/A	bb1			
SmT-8	Wastewater Tank	N/A	N/A	210	20.2.72.202.B.2		<input checked="" type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced
			N/A	bb1			
SmT-9	Amine Storage Tank	N/A	N/A	210	20.2.72.202.B.2		<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input checked="" type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced
			N/A	bb1			
SmT-10	Glycol Storage Tank	N/A	N/A	210	20.2.72.202.B.2		<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input checked="" type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced
			N/A	bb1			
HAUL/ HAUL-1	Haul Road Emissions	N/A	N/A	N/A	20.2.72.202.B.5		<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input checked="" type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced
			N/A	N/A			
							<input type="checkbox"/> Existing (unchanged) ~ To be Removed <input type="checkbox"/> New/Additional ~ Replacement Unit <input type="checkbox"/> To Be Modified ~ To be Replaced

¹ Insignificant activities exempted due to size or production rate are defined in 20.2.70.300.D.6, 20.2.70.7.Q NMAC, and the NMED/AQB List of Insignificant Activities, dated September 15, 2008. Emissions from these insignificant activities do not need to be reported, unless specifically requested.

² Specify date(s) required to determine regulatory applicability.

Table 2-C: Emissions Control Equipment

Unit and stack numbering must correspond throughout the application package. Only list control equipment for TAPs if the TAP's maximum uncontrolled emissions rate is over its respective threshold as listed in 20.2.72 NMAC, Subpart V, Tables A and B. In accordance with 20.2.72.203.A(3) and (8) NMAC, 20.2.70.300.D(5)(b) and (e) NMAC, and 20.2.73.200.B(7) NMAC, the permittee shall report all control devices and list each pollutant controlled by the control device regardless if the applicant takes credit for the reduction in emissions.

Control Equipment Unit No.	Control Equipment Description	Date Installed	Controlled Pollutant(s)	Controlling Emissions for Unit Number(s) ¹	Efficiency (% Control by Weight)	Method used to Estimate Efficiency
1-BTEX-1	Condenser	TBD	VOC, HAP	1-EP-3	98%	Condenser Curves
2a-BTEX-1	Condenser	TBD	VOC, HAP	2a-EP-3	98%	Condenser Curves
3-BTEX-1	Condenser	TBD	VOC, HAP	3-EP-3	98%	Condenser Curves
4-BTEX-1	Condenser	TBD	VOC, HAP	4-EP-3	98%	Condenser Curves
5-BTEX-1	Condenser	TBD	VOC, HAP	5-EP-1f	98%	Condenser Curves
6-BTEX-1	Condenser	TBD	VOC, HAP	6-EP-1f	98%	Condenser Curves
EP-5	Thermal Oxidizer (TO)	TBD	VOC, HAP	1-EP-3, 1-EP-4, 2-EP-4, 2a-EP-3	98%	Manufacturer
EP-6	Thermal Oxidizer (TO)	TBD	VOC, HAP	3-EP-3, 3-EP-4	98%	Manufacturer
EP-7	Enclosed Combustion Device (ECD) – Condensate Tank Control	TBD	VOC, HAP	1-T, 1-Load	98%	Manufacturer
EP-8	Thermal Oxidizer (TO)	TBD	VOC, HAP	4-EP-3, 4-EP-4	98%	Manufacturer
1-EP-2	Flare - Cryo 1 Train SSM	TBD	VOC, HAP	Facility Wide SSM	98%	Manufacturer
2-EP-2a	Flare SSM - Cryo 2 Train	TBD	VOC, HAP	Facility Wide SSM	98%	Manufacturer
2.5-EP-5	Flare - AGI System 1 SSM (High H2S Handling #1)	TBD	VOC, HAP	2.5-EP-4	98%	Manufacturer
3-EP-2a	Flare SSM - Cryo 3 Train	TBD	VOC, HAP	Facility Wide SSM	98%	Manufacturer
4-EP-2a	Flare SSM - Cryo 4 Train	TBD	VOC, HAP	Facility Wide SSM	98%	Manufacturer
EP-9	Flare - Sour Slop Tank Control	TBD	VOC, HAP, H2S	2-T, 2-Load	95%	NMED Guidance
5-EP-2	Flare SSM - Cryo 5 & 6 Trains	TBD	VOC, HAP, H2S	Cryo Train 5 & 6 SSM	98%	Manufacturer
7-EP-2	Flare SSM - Cryo 7 Train	TBD	VOC, HAP, H2S	Cryo Train 7 SSM	98%	Manufacturer
5.5-EP-1b	Flare - AGI System 2 SSM (High H2S Handling #2)	TBD	VOC, HAP, H2S	AGI 2 SSM	98%	Manufacturer
EP-12	Enclosed Combustion Device (ECD) - Condensate Tank Control	TBD	VOC, HAP, H2S	3-T-1, 3-T- 2,3-T-3, 3-T-4, 3-T-5, 3-T-6 & 3-LOAD	95%	Manufacturer
EP-10	Thermal Oxidizer (TO)	TBD	VOC, HAP, H2S	5-EP-1e, 6-EP-1e, 5-EP-1f, 6-EP-1f	99% VOC, 98% H2S	Manufacturer
EP-13	Flare - Sour Water Tanks Control	TBD	VOC, HAP, H2S	4-T-1, 4-T-2 & 4-LOAD	95%	Manufacturer

¹ List each control device on a separate line. For each control device, list all emission units controlled by the control device.

Table 2-D: Maximum Emissions (under normal operating conditions)

~ This Table was intentionally left blank because it would be identical to Table 2-E.

Maximum Emissions are the emissions at maximum capacity and prior to (in the absence of) pollution control, emission-reducing process equipment, or any other emission reduction. Calculate the hourly emissions using the worst case hourly emissions for each pollutant. For each pollutant, calculate the annual emissions as if the facility were operating at maximum plant capacity without pollution controls for 8760 hours per year, unless otherwise approved by the Department. List Hazardous Air Pollutants (HAP) & Toxic Air Pollutants (TAPs) in Table 2-I. Unit & stack numbering must be consistent throughout the application package. Fill all cells in this table with the emission numbers or a "-" symbol. A "--" symbol indicates that emissions of this pollutant are not expected. Numbers shall be expressed to at least 2 decimal points (e.g. 0.41, 1.41, or 1.41E-4).

Unit No.	NOx		CO		VOC		SOx		PM ¹		PM10 ¹		PM2.5 ¹		H ₂ S		Lead	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
1-EP-1	3.46	15.16	2.91	12.73	0.19	0.83	0.02	0.08	0.26	1.15	0.26	1.15	0.26	1.15	-	-	-	-
1-EP-2 ²	0.18	0.78	0.81	3.56	-	-	0.002	0.01	-	-	-	-	-	-	1.8E-05	7.8E-05	-	-
1-EP-3	-	-	-	-	110.07	482.10	-	-	-	-	-	-	-	-	9.8E-06	4.3E-05	-	-
1-EP-4	-	-	-	-	10.12	44.33	-	-	-	-	-	-	-	-	1.77	7.74	-	-
1.5-EP-1g	0.90	3.96	0.93	4.06	0.09	0.40	0.01	0.05	0.14	0.59	0.14	0.59	0.14	0.59	-	-	-	-
4-EP-1g	0.22	0.97	0.37	1.62	0.02	0.11	0.02	0.10	0.03	0.15	0.03	0.15	0.03	0.11	-	-	-	-
2-EP-1a	0.27	1.20	0.46	2.02	0.03	0.13	0.03	0.12	0.04	0.18	0.04	0.18	0.03	0.14	-	-	-	-
2-EP-1b	1.16	5.08	1.31	5.75	0.09	0.38	0.12	0.52	0.12	0.52	0.12	0.52	0.13	0.58	-	-	-	-
2-EP-1c	0.29	1.29	0.25	1.08	0.02	0.07	0.002	0.01	0.02	0.10	0.02	0.10	0.02	0.10	-	-	-	-
2-EP-2a ²	0.18	0.78	0.81	3.56	-	-	0.002	0.01	-	-	-	-	-	-	1.8E-05	7.8E-05	-	-
2-EP-4	-	-	-	-	66.22	290.07	-	-	-	-	-	-	-	-	5.26	23.03	-	-
2-EP-1h	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	-	-
2a-EP-1d	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	-	-
2a-EP-3	-	-	-	-	109.47	479.49	-	-	-	-	-	-	-	-	1.1E-05	4.8E-05	-	-
2.5-EP-4	-	-	-	-	10.65	46.66	-	-	-	-	-	-	-	-	612.94	2684.68	-	-
2.5-EP-1d	2.45	10.74	2.06	9.02	0.13	0.59	0.01	0.06	0.19	0.82	0.19	0.82	0.19	0.82	-	-	-	-
2.5-EP-5 ³	16.28	1.22	74.21	5.58	0.21	0.01	1155.37	74.54	-	-	-	-	-	-	0.0016	0.00012	-	-
3-EP-1a	0.36	1.57	0.46	2.02	0.03	0.13	0.04	0.16	0.04	0.18	0.04	0.18	0.04	0.18	-	-	-	-
3-EP-1b	0.86	3.77	1.31	5.75	0.09	0.38	0.09	0.38	0.12	0.52	0.12	0.52	0.10	0.43	-	-	-	-
3-EP-1d	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	-	-
3-EP-1c	0.29	1.29	0.25	1.08	0.02	0.07	0.002	0.01	0.02	0.10	0.02	0.10	0.02	0.10	-	-	-	-
3-EP-1h	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	-	-
3-EP-2a ²	0.18	0.78	0.81	3.56	-	-	0.002	0.01	-	-	-	-	-	-	1.8E-05	7.8E-05	-	-
3-EP-3	-	-	-	-	109.41	479.20	-	-	-	-	-	-	-	-	9.5E-06	4.2E-05	-	-
3-EP-4	-	-	-	-	72.35	316.90	-	-	-	-	-	-	-	-	5.03	22.04	-	-
4-EP-1a	0.36	1.57	0.46	2.02	0.03	0.13	0.04	0.16	0.04	0.18	0.04	0.18	0.04	0.18	-	-	-	-
4-EP-1b	0.86	3.77	1.31	5.75	0.09	0.38	0.09	0.38	0.12	0.52	0.12	0.52	0.10	0.43	-	-	-	-
4-EP-2a ²	0.18	0.78	0.81	3.56	-	-	0.002	0.01	-	-	-	-	-	-	1.8E-05	7.8E-05	-	-
4-EP-3	-	-	-	-	109.16	478.13	-	-	-	-	-	-	-	-	1.0E-05	4.5E-05	-	-
4-EP-4	-	-	-	-	68.61	300.52	-	-	-	-	-	-	-	-	5.29	23.17	-	-

Unit No.	NOx		CO		VOC		SOx		PM ¹		PM10 ¹		PM2.5 ¹		H ₂ S		Lead		
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	
EP-5	No emissions from these units in an uncontrolled scenario.																		
EP-6																			
EP-7																			
EP-9																			
1-T	-	-	-	-	*	46.00	-	-	-	-	-	-	-	-	-	-	-	-	-
2-T	-	-	-	-	*	529.80	-	-	-	-	-	-	-	-	-	0.261	*	-	-
1-Load	-	-	-	-	*	129.20	-	-	-	-	-	-	-	-	-	-	-	-	-
2-Load	-	-	-	-	*	48.20	-	-	-	-	-	-	-	-	0.012	0.007	-	-	-
FUG	-	-	-	-	*	103.61	-	-	-	-	-	-	-	-	*	0.004	-	-	-
HAUL	-	-	-	-	-	-	-	-	3.50	1.36	*	*	*	*	-	-	-	-	-
4-EP-1d	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	-	-	-
4-EP-1e	0.29	1.29	0.25	1.08	0.02	0.07	0.00	0.01	0.02	0.10	0.02	0.10	0.02	0.10	-	-	-	-	-
4-EP-1h	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	-	-	-
EP-8	No emissions from this unit in an uncontrolled scenario.																		
5-EP-1a	3.43	15.03	3.50	15.33	0.38	1.65	0.35	1.53	0.52	2.28	0.52	2.28	0.39	1.71	-	-	-	-	-
5-EP-1b	3.43	15.03	3.50	15.33	0.38	1.65	0.35	1.53	0.52	2.28	0.52	2.28	0.39	1.71	-	-	-	-	-
5-EP-1c	0.36	1.57	0.60	2.63	0.04	0.17	0.04	0.16	0.05	0.24	0.05	0.24	0.04	0.18	-	-	-	-	-
5-EP-1d	0.86	3.77	1.45	6.33	0.09	0.41	0.09	0.38	0.13	0.24	0.13	0.24	0.04	0.43	-	-	-	-	-
5-EP-1e	-	-	-	-	146.92	643.53	-	-	-	-	-	-	-	-	0.000	0.000	-	-	-
5-EP-1f	-	-	-	-	35.83	156.92	-	-	-	-	-	-	-	-	1.874	8.209	-	-	-
5-EP-2 ²	0.34	1.51	0.69	3.01	0.00	0.02	0.01	0.004	-	-	-	-	-	-	0.00	0.00	-	-	-
6-EP-1a	3.43	15.03	3.50	15.33	0.38	1.65	0.35	1.53	0.52	2.28	0.52	2.28	0.39	1.71	-	-	-	-	-
6-EP-1b	3.43	15.03	3.50	15.33	0.38	1.65	0.35	1.53	0.52	2.28	0.52	2.28	0.39	1.71	-	-	-	-	-
6-EP-1c	0.36	1.57	0.60	2.63	0.04	0.17	0.04	0.16	0.05	0.24	0.05	0.24	0.04	0.18	-	-	-	-	-
6-EP-1d	0.86	3.77	1.45	6.33	0.09	0.41	0.09	0.38	0.13	0.57	0.13	0.57	0.10	0.43	-	-	-	-	-
6-EP-1e	-	-	-	-	146.92	643.53	-	-	-	-	-	-	-	-	0.000	0.000	-	-	-
6-EP-1f	-	-	-	-	35.83	156.92	-	-	-	-	-	-	-	-	1.874	8.209	-	-	-
7-EP-1c	0.36	1.57	0.60	2.63	0.04	0.17	0.04	0.16	0.05	0.24	0.05	0.24	0.04	0.18	-	-	-	-	-
7-EP-1d	0.86	3.77	1.45	6.33	0.09	0.41	0.09	0.38	0.13	0.57	0.13	0.57	0.10	0.43	-	-	-	-	-
7-EP-2 ²	0.34	1.51	0.69	3.01	0.004	0.02	0.01	0.004	-	-	-	-	-	-	0.0001	0.0006	-	-	-
5.5-EP-1a	3.43	15.03	3.50	15.33	0.38	1.65	0.35	1.53	0.52	2.28	0.52	2.28	0.39	1.71	-	-	-	-	-
5.5-EP-1b ²	0.05	0.23	0.11	0.47	0.002	0.01	0.002	0.01	-	-	-	-	-	-	0.00002	0.00009	-	-	-
3-T	-	-	-	-	31.50	137.97	-	-	-	-	-	-	-	-	0.00000	0.00000	-	-	-
4-T	-	-	-	-	5.96	26.09	-	-	-	-	-	-	-	-	0.001	0.006	-	-	-
5-T	-	-	-	-	0.33	1.45	-	-	-	-	-	-	-	-	0.0000	0.0000	-	-	-
3-LOAD	-	-	-	-	71.22	105.14	-	-	-	-	-	-	-	-	0.0000	0.0000	-	-	-
4-LOAD	-	-	-	-	66.70	4.49	-	-	-	-	-	-	-	-	0.010	0.001	-	-	-
5-LOAD	-	-	-	-	3.52	0.66	-	-	-	-	-	-	-	-	0.0000	0.0000	-	-	-

Unit No.	NOx		CO		VOC		SOx		PM ¹		PM10 ¹		PM2.5 ¹		H ₂ S		Lead	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
EP-10	No emissions from these units in an uncontrolled scenario.																	
EP-11																		
EP-12																		
EP-13																		
2-EP-1t	-	-	-	-	2.12	0.01	-	-	-	-	-	-	-	-	0.0819	0.0003	-	-
3-EP-1t	-	-	-	-	2.12	0.01	-	-	-	-	-	-	-	-	0.0819	0.0003	-	-
4-EP-1t	-	-	-	-	2.12	0.01	-	-	-	-	-	-	-	-	0.0819	0.0003	-	-
5-EP-1t	-	-	-	-	2.12	0.01	-	-	-	-	-	-	-	-	0.0819	0.0003	-	-
6-EP-1t	-	-	-	-	2.12	0.01	-	-	-	-	-	-	-	-	0.0819	0.0003	-	-
7-EP-1t	-	-	-	-	2.12	0.01	-	-	-	-	-	-	-	-	0.0819	0.0003	-	-
MSS/M	-	-	-	-	0.17	0.73	-	-	-	-	-	-	-	-	-	-	-	-
FUG-1	-	-	-	-	22.01	96.41	-	-	-	-	-	-	-	-	0.0003	0.0014	-	-
HAUL-1	-	-	-	-	-	-	-	-	2.46	1.60	*	*	*	*	-	-	-	-
Totals	56.43	177.14	127.30	238.14	1,250.82	5,769.64	1,158.16	86.66	12.75	32.36	6.79	29.40	5.89	26.06	634.55	2,777.35	-	-

¹Condensable Particulate Matter: Include condensable particulate matter emissions for PM10 and PM2.5 if the source is a combustion source. Do not include condensable particulate matter for PM unless PM is set equal to PM10 and PM2.5. Particulate matter (PM) is not subject to an ambient air quality standard, but PM is a regulated air pollutant under PSD (20.2.74 NMAC) and Title V (20.2.70 NMAC).

²Represents pilot + purge/sweep gas emissions only

³Represents pilot + purge + assist gas emissions only

Table 2-E: Requested Allowable Emissions

Unit & stack numbering must be consistent throughout the application package. Fill all cells in this table with the emission numbers or a "-" symbol. A "--" symbol indicates that emissions of this pollutant are not expected. Numbers shall be expressed to at least 2 decimal points (e.g. 0.41, 1.41, or 1.41E⁻⁴).

Unit No.	NOx		CO		VOC		SOx		PM ¹		PM10 ¹		PM2.5 ¹		H ₂ S		Lead	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
1-EP-1	3.46	15.16	2.91	12.73	0.19	0.83	0.02	0.08	0.26	1.15	0.26	1.15	0.26	1.15	-	-	-	-
1-EP-2 ²	0.18	0.78	0.81	3.56	-	-	0.002	0.01	-	-	-	-	-	-	1.79E-05	7.82E-05	-	-
1-EP-3 ⁴	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	-	-	-	-
1-EP-4 ⁴	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	0.00	0.00	-	-
1.5-EP-1g	0.90	3.96	0.93	4.06	0.09	0.40	0.01	0.05	0.14	0.59	0.14	0.59	0.14	0.59	-	-	-	-
4-EP-1g	0.22	0.97	0.37	1.62	0.02	0.11	0.02	0.10	0.03	0.15	0.03	0.15	0.03	0.11	-	-	-	-
2-EP-1a	0.27	1.20	0.46	2.02	0.03	0.13	0.03	0.12	0.04	0.18	0.04	0.18	0.03	0.14	-	-	-	-
2-EP-1b	1.16	5.08	1.31	5.75	0.09	0.38	0.12	0.52	0.12	0.52	0.12	0.52	0.13	0.58	-	-	-	-
2-EP-1c	0.29	1.29	0.25	1.08	0.02	0.07	0.002	0.01	0.02	0.10	0.02	0.10	0.02	0.10	-	-	-	-
2-EP-2a ²	0.18	0.78	0.81	3.56	-	-	0.002	0.01	-	-	-	-	-	-	1.79E-05	7.82E-05	-	-
2-EP-4 ⁴	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	0.00	0.00	-	-
2-EP-1h	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	-	-
2a-EP-1d	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	-	-
2a-EP-3 ⁴	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	-	-	-	-
2.5-EP-4 ⁵	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	0.00	0.00	-	-
2.5-EP-1d	2.45	10.74	2.06	9.02	0.13	0.59	0.01	0.06	0.19	0.82	0.19	0.82	0.19	0.82	-	-	-	-
2.5-EP-5 ²	0.002	0.01	0.01	0.04	-	-	0.000	0.001	-	-	-	-	-	-	-	-	-	-
3-EP-1a	0.36	1.57	0.46	2.02	0.03	0.13	0.04	0.16	0.04	0.18	0.04	0.18	0.04	0.18	-	-	-	-
3-EP-1b	0.86	3.77	1.31	5.75	0.09	0.38	0.09	0.38	0.12	0.52	0.12	0.52	0.10	0.43	-	-	-	-
3-EP-1d	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	-	-
3-EP-1c	0.29	1.29	0.25	1.08	0.02	0.07	0.00	0.01	0.02	0.10	0.02	0.10	0.02	0.10	-	-	-	-
3-EP-1h	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	-	-
3-EP-2a ²	0.18	0.78	0.81	3.56	-	-	0.00	0.01	-	-	-	-	-	-	1.79E-05	7.82E-05	-	-
3-EP-3 ⁶	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	-	-	-	-
3-EP-4 ⁶	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	0.00	0.00	-	-
4-EP-1a	0.36	1.57	0.46	2.02	0.03	0.13	0.04	0.16	0.04	0.18	0.04	0.18	0.04	0.18	-	-	-	-
4-EP-1b	0.86	3.77	1.31	5.75	0.09	0.38	0.09	0.38	0.12	0.52	0.12	0.52	0.10	0.43	-	-	-	-
4-EP-2a ²	0.18	0.78	0.81	3.56	-	-	0.00	0.01	-	-	-	-	-	-	1.79E-05	7.82E-05	-	-
4-EP-3 ⁷	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	-	-	-	-
4-EP-4 ⁷	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	0.00	0.00	-	-

Unit No.	NOx		CO		VOC		SOx		PM ¹		PM10 ¹		PM2.5 ¹		H ₂ S		Lead	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
EP-5	5.50	24.09	3.50	15.33	5.92	25.92	13.22	57.91	0.21	0.91	0.21	0.91	0.21	0.91	0.14	0.62	-	-
EP-6	5.50	24.09	3.50	15.33	3.64	15.92	9.47	41.49	0.21	0.91	0.21	0.91	0.21	0.91	0.10	0.44	-	-
EP-7	0.59	2.58	0.49	2.16	0.80	3.50	-	-	0.04	0.20	0.04	0.20	0.04	0.20	-	-	-	-
EP-9	0.36	1.57	1.64	7.17	6.42	28.14	0.12	0.50	-	-	-	-	-	-	-	-	-	-
1-T ⁸	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	-	-	-	-
2-T ⁹	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	0.00	0.00	-	-
1-Load ⁸	-	-	-	-	*	0.00	-	-	-	-	-	-	-	-	0.00	0.00	-	-
2-Load ⁹	-	-	-	-	*	14.46	-	-	-	-	-	-	-	-	-	-	-	-
FUG	-	-	-	-	*	103.61	-	-	-	-	-	-	-	-	*	0.001	-	-
HAUL ⁴	-	-	-	-	-	-	-	-	3.50	1.36	*	*	*	*	-	-	-	-
4-EP-1d	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	-	-
4-EP-1c	0.29	1.29	0.25	1.08	0.02	0.07	0.00	0.01	0.02	0.10	0.02	0.10	0.02	0.10	-	-	-	-
4-EP-1h	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	-	-
EP-8	5.50	24.09	3.50	15.33	3.56	15.57	9.96	43.61	0.21	0.91	0.21	0.91	0.21	0.91	0.11	0.46	-	-
5-EP-1a	3.43	15.03	3.50	15.33	0.38	1.65	0.35	1.53	0.52	2.28	0.52	2.28	0.39	1.71	-	-	-	-
5-EP-1b	3.43	15.03	3.50	15.33	0.38	1.65	0.35	1.53	0.52	2.28	0.52	2.28	0.39	1.71	-	-	-	-
5-EP-1c	0.36	1.57	0.60	2.63	0.04	0.17	0.04	0.16	0.05	0.24	0.05	0.24	0.04	0.18	-	-	-	-
5-EP-1d	0.86	3.77	1.45	6.33	0.09	0.41	0.09	0.38	0.13	0.57	0.13	0.57	0.10	0.43	-	-	-	-
5-EP-1e ¹⁰	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	-	-	-	-
5-EP-1f ¹⁰	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	0.00	0.00	-	-
5-EP-2 ²	0.34	1.51	0.69	3.01	0.004	0.02	0.01	0.00	-	-	-	-	-	-	1.30E-04	5.69E-04	-	-
6-EP-1a	3.43	15.03	3.50	15.33	0.38	1.65	0.35	1.53	0.52	2.28	0.52	2.28	0.39	1.71	-	-	-	-
6-EP-1b	3.43	15.03	3.50	15.33	0.38	1.65	0.35	1.53	0.52	2.28	0.52	2.28	0.39	1.71	-	-	-	-
6-EP-1c	0.36	1.57	0.60	2.63	0.04	0.17	0.04	0.16	0.05	0.24	0.05	0.24	0.04	0.18	-	-	-	-
6-EP-1d	0.86	3.77	1.45	6.33	0.09	0.41	0.09	0.38	0.13	0.57	0.13	0.57	0.10	0.43	-	-	-	-
6-EP-1e ¹⁰	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	-	-	-	-
6-EP-1f ¹⁰	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	0.00	0.00	-	-
7-EP-1c	0.36	1.57	0.60	2.63	0.04	0.17	0.04	0.16	0.05	0.24	0.05	0.24	0.04	0.18	-	-	-	-
7-EP-1d	0.86	3.77	1.45	6.33	0.09	0.41	0.09	0.38	0.13	0.57	0.13	0.57	0.10	0.43	-	-	-	-
7-EP-2 ²	0.34	1.51	0.69	3.01	0.004	0.02	0.01	0.00	-	-	-	-	-	-	1.30E-04	5.69E-04	-	-
5.5-EP-1a	3.43	15.03	3.50	15.33	0.38	1.65	0.35	1.53	0.52	2.28	0.52	2.28	0.39	1.71	-	-	-	-
5.5-EP-1b ²	0.05	0.23	0.11	0.47	0.002	0.01	0.002	0.01	-	-	-	-	-	-	0.00	0.00	-	-
5.5-EP-1c ¹¹	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	0.00	0.00	-	-

Unit No.	NOx		CO		VOC		SOx		PM ¹		PM10 ¹		PM2.5 ¹		H ₂ S		Lead	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
3-T ¹²	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	-	-	-	-
4-T ¹³	-	-	-	-	-	-	-	-	-	-	-	-	-	-	0.00	0.00	-	-
5-T	-	-	-	-	*	1.45	-	-	-	-	-	-	-	-	0.0000	0.0000	-	-
3-LOAD	-	-	-	-	*	31.54	-	-	-	-	-	-	-	-	0.0000	0.0000	-	-
4-LOAD	-	-	-	-	*	1.35	-	-	-	-	-	-	-	-	0.01	0.001	-	-
5-LOAD	-	-	-	-	*	0.66	-	-	-	-	-	-	-	-	0.0000	0.0000	-	-
EP-10	16.40	69.97	9.98	42.49	3.66	15.68	0.74	30.24	9.40	40.33	9.40	40.33	7.05	30.25	0.08	0.32	-	-
EP-12	0.17	0.20	0.33	0.40	4.07	10.58	0.00	0.00	-	-	-	-	-	-	0.00004	0.00001	-	-
EP-13	0.15	1.12	0.90	3.94	3.62	0.89	0.08	0.03	-	-	-	-	-	-	0.002	0.0006	-	-
FUG-1	-	-	-	-	22.01	96.41	-	-	-	-	-	-	-	-	0.0003	0.0014		
HAUL-1 ⁴	-	-	-	-	-	-	-	-	2.46	1.60	*	*	*	*	-	-		
Totals	74.32	323.62	76.96	334.76	58.60	387.23	36.38	185.90	22.82	75.97	16.86	73.00	13.67	59.25	0.44	1.84	-	-

¹ **Condensable Particulate Matter:** Include condensable particulate matter emissions for PM10 and PM2.5 if the source is a combustion source. Do not include condensable particulate matter for PM unless PM is set equal to PM10 and PM2.5. Particulate matter (PM) is not subject to an ambient air quality standard, but it is a regulated air pollutant under PSD (20.2.74 NMAC) and Title V (20.2.70 NMAC).

² Represents pilot + purge/sweep gas emissions only

³ Represents pilot + purge + assist gas emissions only

⁴ Emissions controlled by unit EP-5

⁵ Emissions controlled by AGI well 1 and Flare 2.5-EP-5

⁶ Emissions controlled by unit EP-6

⁷ Emissions controlled by unit EP-8

⁸ Emissions controlled by unit EP-7

⁹ Emissions controlled by unit EP-9

¹⁰ Emissions controlled by unit EP-10

¹¹ Emissions controlled by AGI well 2 and Flare 5.5-EP-1b

¹² Emissions controlled by unit EP-12

¹³ Emissions controlled by unit EP-13

¹⁴ Haul Road emissions under 0.5 tpy are exempt under 20.2.72.202.B.5

Table 2-F: Additional Emissions during Startup, Shutdown, and Routine Maintenance (SSM)

This table is intentionally left blank since all emissions at this facility due to routine or predictable startup, shutdown, or scheduled maintenance are no higher than those listed in Table 2-E and a malfunction emission limit is not already permitted or requested. If you are required to report GHG emissions as described in Section 6a, include any GHG emissions during Startup, Shutdown, and/or Scheduled Maintenance (SSM) in Table 2-P. Provide an explanations of SSM emissions in Section 6 and 6a.

All applications for facilities that have emissions during routine or predictable startup, shutdown or scheduled maintenance (SSM)¹, including NOI applications, must include in this table the Maximum Emissions during routine or predictable startup, shutdown and scheduled maintenance (20.2.7 NMAC, 20.2.72.203.A.3 NMAC, 20.2.73.200.D.2 NMAC). In Section 6 and 6a, provide emissions calculations for all SSM emissions reported in this table. Refer to "Guidance for Submittal of Startup, Shutdown, Maintenance Emissions in Permit Applications (https://www.env.nm.gov/aqb/permit/aqb_pol.html) for more detailed instructions. Numbers shall be expressed to at least 2 decimal points (e.g. 0.41, 1.41, or 1.41E-4).

Unit No.	NOx		CO		VOC		SOx		PM ²		PM10 ²		PM2.5 ²		H ₂ S		Lead	
	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
1-EP-2	256.05	1.54	1167.30	7.00	859.82	5.16	6.21	0.04	-	-	-	-	-	-	0.067	0.001	-	-
2-EP-2a	682.81	4.10	3112.79	18.68	2292.86	13.76	16.57	0.10	-	-	-	-	-	-	0.180	0.001	-	-
3-EP-2a	682.81	4.10	3112.79	18.68	2292.86	13.76	16.57	0.10	-	-	-	-	-	-	0.180	0.001	-	-
4-EP-2a	682.81	4.10	3112.80	18.68	2292.86	13.76	16.57	0.11	-	-	-	-	-	-	0.180	0.001	-	-
2.5-EP-5	16.28	1.21	74.20	5.54	0.21	0.01	1155.40	74.50	-	-	-	-	-	-	12.300	0.790		
5-EP-2	1658.43	9.95	3310.85	19.87	2430.99	14.58	0.00	0.00	-	-	-	-	-	-	0.000	0.001	-	-
7-EP-2	1658.43	9.95	3310.85	19.87	2430.99	14.58	0.00	0.00	-	-	-	-	-	-	0.000	0.001	-	-
5.5-EP-1b	12.40	0.40	28.76	1.04	9.08	0.53	2684.66	162.10	-	-	-	-	-	-	28.580	1.720	-	-
EP-11	0.00	0.00	0.00	0.00	365.50	32.02	0.00	0.00	-	-	-	-	-	-	3.748	0.328	-	-
SSM/M	-	-	-	-	0.17	0.73	-	-	-	-	-	-	-	-	-	-	-	-
2-EP-1t	-	-	-	-	2.12	0.01	-	-	-	-	-	-	-	-	0.0819	0.0003	-	-
3-EP-1t	-	-	-	-	2.12	0.01	-	-	-	-	-	-	-	-	0.0819	0.0003	-	-
4-EP-1t	-	-	-	-	2.12	0.01	-	-	-	-	-	-	-	-	0.0819	0.0003	-	-
5-EP-1t	-	-	-	-	2.12	0.01	-	-	-	-	-	-	-	-	0.0819	0.0003	-	-
6-EP-1t	-	-	-	-	2.12	0.01	-	-	-	-	-	-	-	-	0.0819	0.0003	-	-
7-EP-1t	-	-	-	-	2.12	0.01	-	-	-	-	-	-	-	-	0.0819	0.0003	-	-
Totals	5,650.02	35.35	17,230.34	109.36	12,988.06	108.94	3,895.98	236.95	-	-	-	-	-	-	45.73	2.85	-	-

¹ For instance, if the short term steady-state Table 2-E emissions are 5 lb/hr and the SSM rate is 12 lb/hr, enter 7 lb/hr in this table. If the annual steady-state Table 2-E emissions are 21.9 TPY, and the number of scheduled SSM events result in annual emissions of 31.9 TPY, enter 10.0 TPY in the table below.

² **Condensable Particulate Matter:** Include condensable particulate matter emissions for PM10 and PM2.5 if the source is a combustion source. Do not include condensable particulate matter for PM unless PM is set equal to PM10 and PM2.5. Particulate matter (PM) is not subject to an ambient air quality standard, but it is a regulated air pollutant under PSD (20.2.74 NMAC) and Title V (20.2.70 NMAC).

Table 2-G: Stack Exit and Fugitive Emission Rates for Special Stacks

I have elected to leave this table blank because this facility does not have any stacks/vents that split emissions from a single source or combine emissions from more than one source listed in table 2-A. Additionally, the emission rates of all stacks match the Requested allowable emission rates stated in Table 2-E.

Use this table to list stack emissions (requested allowable) from split and combined stacks. List Toxic Air Pollutants (TAPs) and Hazardous Air Pollutants (HAPs) in Table 2-I. List all fugitives that are associated with the normal, routine, and non-emergency operation of the facility. Unit and stack numbering must correspond throughout the application package. Refer to Table 2-E for instructions on use of the “-“ symbol and on significant figures.

Stack No.	Serving Unit Number(s) from Table 2-A	NOx		CO		VOC		SOx		PM		PM10		PM2.5		~ H ₂ S or ~ Lead	
		lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
Totals:																	

Table 2-H: Stack Exit Conditions

Unit and stack numbering must correspond throughout the application package. Include the stack exit conditions for each unit that emits from a stack, including blowdown venting parameters and tank emissions. If the facility has multiple operating scenarios, complete a separate Table 2-H for each scenario and, for each, type scenario name here:

Stack Number	Serving Unit Number(s) from Table 2-A	Orientation (H=Horizontal V=Vertical)	Rain Caps (Yes or No)	Height Above Ground (ft)	Temp. (F)	Flow Rate		Moisture by Volume (%)	Velocity (ft/sec)	Inside Diameter (ft)
						(acfs)	(dscfs)			
1-EP-1	1-EP-1	V	N	50.00	624.00	247.87	N/A	N/A	18.18	4.17
1-EP-2	1-EP-2	V	N	75.00	1831.73	106283.64	N/A	N/A	65.62	45.41
1.5-EP-1g	1.5-EP-1g	V	N	37.00	624.00	126.41	N/A	N/A	29.64	2.33
4-EP-1g	4-EP-1g	V	N	13.25	120.00	18.54	N/A	N/A	5.90	2.00
2-EP-1a	2-EP-1a	V	N	15.88	624.00	39.22	N/A	N/A	22.19	1.50
2-EP-1b	2-EP-1b	V	N	22.44	110.00	84.71	N/A	N/A	7.34	3.83
2-EP-1e	2-EP-1e	V	N	22.75	624.00	21.01	N/A	N/A	6.69	2.00
2-EP-2a	2-EP-2a	V	N	75.00	1831.73	275310.95	N/A	N/A	65.62	72.09
2-EP-1h	2-EP-1h	V	N	24.79	424.99	71.97	N/A	N/A	7.48	3.50
2a-EP-1d	2a-EP-1d	V	N	24.79	424.99	71.97	N/A	N/A	7.48	3.50
2.5-EP-1d	2.5-EP-1d	V	N	22.88	624.00	140.44	N/A	N/A	25.14	2.67
2.5-EP-5	2.5-EP-5	V	N	149.00	1831.73	7334.90	N/A	N/A	65.62	11.93
3-EP-1a	3-EP-1a	V	N	22.00	550.00	32.56	N/A	N/A	23.33	1.33
3-EP-1b	3-EP-1b	V	N	25.83	429.00	82.91	N/A	N/A	19.39	2.33
3-EP-1d	3-EP-1d	V	N	14.99	424.99	71.97	N/A	N/A	40.72	1.50
3-EP-1e	3-EP-1e	V	N	20.01	624.00	21.00	N/A	N/A	54.56	0.70
3-EP-1h	3-EP-1h	V	N	14.99	424.99	71.97	N/A	N/A	40.72	1.50
3-EP-2a	3-EP-2a	V	N	75.00	1831.73	275310.95	N/A	N/A	65.62	73.09
4-EP-1a	4-EP-1a	V	N	22.00	377.00	39.22	N/A	N/A	28.09	1.33
4-EP-1b	4-EP-1b	V	N	25.83	429.00	111.65	N/A	N/A	26.11	2.33
4-EP-1d	4-EP-1d	V	N	32.67	425.00	94.00	N/A	N/A	7.48	4.00
4-EP-1e	4-EP-1e	V	N	22.75	624.00	21.00	N/A	N/A	6.68	2.00
4-EP-1h	4-EP-1h	V	N	32.67	424.99	94.00	N/A	N/A	7.48	4.00
4-EP-2a	4-EP-2a	V	N	75.00	1831.73	275310.95	N/A	N/A	65.62	73.09
EP-5	EP-5	V	N	76.00	1500.01	354.93	N/A	N/A	4.52	10.00

Stack Number	Serving Unit Number(s) from Table 2-A	Orientation (H=Horizontal V=Vertical)	Rain Caps (Yes or No)	Height Above Ground (ft)	Temp. (F)	Flow Rate		Moisture by Volume (%)	Velocity (ft/sec)	Inside Diameter (ft)
						(acfs)	(dscfs)			
EP-6	EP-6	V	N	50.00	1500.01	354.93	N/A	N/A	9.22	7.00
EP-7	EP-7	V	N	36.00	1400.00	72.53	N/A	N/A	3.25	5.33
EP-8	EP-8	V	N	76.00	1500.01	354.93	N/A	N/A	5.41	9.14
EP-9	EP-9	V	N	20.00	1831.73	146.73	N/A	N/A	65.62	1.69
5-EP-1a	5-EP-1a	V	N	36.00	501.01	701.20	N/A	N/A	55.80	4.00
5-EP-1b	5-EP-1b	V	N	36.00	501.01	701.20	N/A	N/A	55.80	4.00
5-EP-1c	5-EP-1c	V	N	22.00	447.00	68.80	N/A	N/A	49.30	1.33
5-EP-1d	5-EP-1d	V	N	25.83	468.00	168.00	N/A	N/A	39.30	2.33
5-EP-2	5-EP-2	V	N	199.00	1831.73	352130.56	N/A	N/A	65.62	82.66
6-EP-1a	6-EP-1a	V	N	36.00	501.01	701.20	N/A	N/A	55.80	4.00
6-EP-1b	6-EP-1b	V	N	36.00	501.01	701.20	N/A	N/A	55.80	4.00
6-EP-1c	6-EP-1c	V	N	22.00	447.00	68.80	N/A	N/A	49.30	1.33
6-EP-1d	6-EP-1d	V	N	25.83	468.00	168.00	N/A	N/A	39.30	2.33
7-EP-1c	7-EP-1c	V	N	22.00	447.00	68.80	N/A	N/A	49.30	1.33
7-EP-1d	7-EP-1d	V	N	25.83	468.00	168.00	N/A	N/A	39.30	2.33
7-EP-2	7-EP-2	V	N	199.00	1831.73	352130.56	N/A	N/A	65.62	82.66
EP-12	EP-12	V	N	40.00	1400.00	2898.86	N/A	N/A	65.62	7.50
5.5-EP-1a	5.5-EP-1a	V	N	36.00	479.00	679.84	N/A	N/A	54.10	4.00
5.5-EP-1b	5.5-EP-1b	V	N	300.00	1831.73	56232.49	N/A	N/A	65.62	37.42
5-T-1	5-T-1	V	N	20.00	80.01	0.00	N/A	N/A	0.03	0.25
5-T-2	5-T-2	V	N	20.00	80.01	0.00	N/A	N/A	0.03	0.25
5-T-3	5-T-3	V	N	20.00	80.01	0.00	N/A	N/A	0.03	0.25
5-T-4	5-T-4	V	N	20.00	80.01	0.00	N/A	N/A	0.03	0.25
EP-10	EP-10	V	N	70.00	1800.00	341.99	N/A	N/A	385.71	1.06
EP-11	EP-11	V	N	60.00	1600.00	224.56	N/A	N/A	102.93	1.67
EP-13	EP-13	V	N	20.00	1831.73	0.12	N/A	N/A	65.62	0.05
4-T-1	4-T-2	V	N	40.00	110.89	0.00	N/A	N/A	0.03	0.25
4-T-2	LOAD-4	V	N	40.00	110.89	0.00	N/A	N/A	0.03	0.25

Stack Number	Serving Unit Number(s) from Table 2-A	Orientation (H=Horizontal V=Vertical)	Rain Caps (Yes or No)	Height Above Ground (ft)	Temp. (F)	Flow Rate		Moisture by Volume (%)	Velocity (ft/sec)	Inside Diameter (ft)
						(acfs)	(dscfs)			
LOAD-4	LOAD-4	V	N	10.00	110.89	0.21	N/A	N/A	4.37	0.25
LOAD-2	LOAD-2	V	N	10.00	110.89	0.21	N/A	N/A	4.37	0.25
7EP1TA	7EP1TA	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
6EP1TA	6EP1TA	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
4EP1TA	4EP1TA	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
5EP1TA	5EP1TA	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
3EP1TA	3EP1TA	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
2EP1TA	2EP1TA	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
7EP1TB	7EP1TB	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
6EP1TB	6EP1TB	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
4EP1TB	4EP1TB	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
5EP1TB	5EP1TB	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
3EP1TB	3EP1TB	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
2EP1TB	2EP1TB	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
7EP1TC	7EP1TC	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
6EP1TC	6EP1TC	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
4EP1TC	4EP1TC	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
5EP1TC	5EP1TC	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
3EP1TC	3EP1TC	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
2EP1TC	2EP1TC	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
7EP1TD	7EP1TD	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
6EP1TD	6EP1TD	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
4EP1TD	4EP1TD	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
5EP1TD	5EP1TD	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
3EP1TD	3EP1TD	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25
2EP1TD	2EP1TD	V	N	30.00	100.00	0.78	N/A	N/A	15.96	0.25

Table 2-I: Stack Exit and Fugitive Emission Rates for HAPs and TAPs

In the table below, report the Potential to Emit for each HAP from each regulated emission unit listed in Table 2-A, only if the entire facility emits the HAP at a rate greater than or equal to one (1) ton per year. For each such emission unit, HAPs shall be reported to the nearest 0.1 tpy. Each facility-wide Individual HAP total and the facility-wide Total HAPs shall be the sum of all HAP sources calculated to the nearest 0.1 ton per year. Per 20.2.72.403.A.1 NMAC, facilities not exempt [see 20.2.72.402.C NMAC] from TAP permitting shall report each TAP that has an uncontrolled emission rate in excess of its pounds per hour screening level specified in 20.2.72.502 NMAC. TAPs shall be reported using one more significant figure than the number of significant figures shown in the pound per hour threshold corresponding to the substance. Use the HAP nomenclature as it appears in Section 112 (b) of the 1990 CAAA and the TAP nomenclature as it listed in 20.2.72.502 NMAC. Include tank-flashing emissions estimates of HAPs in this table. For each HAP or TAP listed, fill all cells in this table with the emission numbers or a "-" symbol. A "-" symbol indicates that emissions of this pollutant are not expected or the pollutant is emitted in a quantity less than the threshold amounts described above.

Stack No.	Unit No.(s)	Total HAPs		Benzene ☑ HAP or ~ TAP		Toluene ☑ HAP or ~ TAP		Ethylbenzene ☑ HAP or ~ TAP		n-Hexane ☑ HAP or ~ TAP		^{2,2,4-} Trimethylpentane ☑ HAP or ~ TAP		Styrene ☑ HAP or ~ TAP		Xylene ☑ HAP or ~ TAP		Provide Pollutant Name Here HAP or ~ TAP	
		lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
1-EP-1	1-EP-1	0.51	2.23	0.026	0.12	0.036	0.16	0.075	0.33	0.050	0.22	0.10	0.44	0.073	0.32	0.047	0.20		
1-EP-2	1-EP-2	46.23	0.28	3.09	0.02	1.60	0.01	0.16	0.0009	40.61	0.24	-	-	-	-	0.77	0.005		
1-EP-3	1-EP-3	Emissions from 1-EP-3 are controlled by the thermal oxidizer, unit EP-5. Controlled emissions are represented under unit EP-5.																	
1-EP-4	1-EP-4	Emissions from 1-EP-4 are controlled by the thermal oxidizer, unit EP-5. Controlled emissions are represented under unit EP-5.																	
1.5-EP-1g	1.5-EP-1g	0.26	1.14	0.0135	0.059	0.018	0.080	0.038	0.17	0.025	0.1109	0.051	0.22	0.037	0.16	0.024	0.104		
4-EP-1g	4-EP-1g	0.01	0.04	0.0000	0.000	0.000	0.000	-	-	0.009	0.0385	-	-	-	-	-	-		
2-EP-1a	2-EP-1a	0.08	0.35	0.0042	0.018	0.0057	0.025	0.012	0.052	0.0079	0.035	0.016	0.070	0.012	0.051	0.007397	0.032		
2-EP-1b	2-EP-1b	0.23	1.01	0.012	0.052	0.016	0.071	0.034	0.15	0.022	0.098	0.045	0.20	0.033	0.15	0.021	0.092		
2-EP-1e	2-EP-1e	0.043	0.19	0.0022	0.0098	0.0031	0.013	0.0063	0.028	0.0042	0.019	0.0085	0.037	0.0062	0.027	0.0040	0.017		
2-EP-2a	2-EP-2a	123.27	0.74	8.2	0.049	4.3	0.026	0.42	0.0025	108.3	0.65	-	-	-	-	2.1	0.012		
2-EP-4	2-EP-4	Emissions from 2-EP-4 are controlled by unit EP-5. Controlled emissions are represented under unit EP-5.																	
2-EP-1h	2-EP-1h	0.79	3.47	0.041	0.18	0.056	0.24	0.12	0.51	0.077	0.34	0.16	0.68	0.11	0.50	0.073	0.32		
2a-EP-1d	2a-EP-1d	0.79	3.47	0.041	0.18	0.056	0.24	0.12	0.51	0.077	0.34	0.16	0.68	0.11	0.50	0.073	0.32		
2a-EP-3	2a-EP-3	Emissions from 2a-EP-3 are controlled by unit EP-5. Controlled emissions are represented under unit EP-5.																	
2.5-E-4	2.5-EP-4	Emissions from unit 2.5-EP-4 are controlled by the Acid Gas Injection Well (AGI). During AGI compressor downtime the controlled emissions are represented under the Emergency AGI Flare, unit 2.5-EP-5.																	
2.5-EP-1d	2.5-EP-1d	0.29	1.26	0.015	0.066	0.020	0.089	0.042	0.19	0.028	0.12	0.057	0.25	0.042	0.18	0.026	0.12		
2.5-EP-5	2.5-EP-5	0.005	0.0003	-	-	-	-	-	-	0.0053	0.00034	-	-	-	-	-	-		
3-EP-1a	3-EP-1a	0.08	0.35	0.0042	0.018	0.0057	0.025	0.012	0.052	0.0079	0.035	0.016	0.070	0.012	0.051	0.007397	0.032		
3-EP-1b	3-EP-1b	0.23	1.01	0.012	0.052	0.016	0.071	0.034	0.15	0.022	0.098	0.045	0.20	0.033	0.15	0.021	0.092		
3-EP-1d	3-EP-1d	0.79	3.47	0.041	0.18	0.056	0.24	0.12	0.51	0.077	0.34	0.16	0.68	0.11	0.50	0.073	0.32		
3-EP-1e	3-EP-1e	0.04	0.19	0.0022	0.0098	0.0031	0.013	0.0063	0.028	0.0042	0.019	0.0085	0.037	0.0062	0.027	0.0040	0.017		
3-EP-1h	3-EP-1h	0.79	3.47	0.041	0.18	0.056	0.24	0.12	0.51	0.077	0.34	0.16	0.68	0.11	0.50	0.073	0.32		
3-EP-2a	3-EP-2a	123.27	0.74	8.2	0.049	4.3	0.026	0.42	0.0025	108.3	0.65	-	-	-	-	2.1	0.012		
3-EP-3	3-EP-3	Emissions from unit 3-EP-3 are routed to the thermal oxidizer unit EP-6. Controlled emissions are represented under unit EP-6.																	
3-EP-4	3-EP-4	Emissions from unit 3-EP-4 are routed to the thermal oxidizer unit EP-6. Controlled emissions are represented under unit EP-6.																	
4-EP-1a	4-EP-1a	0.08	0.35	0.0042	0.018	0.0057	0.025	0.012	0.052	0.0079	0.035	0.016	0.070	0.012	0.051	0.007397	0.032		
4-EP-1b	4-EP-1b	0.23	1.01	0.012	0.052	0.016	0.071	0.034	0.15	0.022	0.098	0.045	0.20	0.033	0.15	0.021	0.092		
4-EP-1d	4-EP-1d	0.79	3.47	0.041	0.18	0.056	0.24	0.12	0.51	0.077	0.34	0.16	0.68	0.11	0.50	0.073	0.32		
4-EP-1e	4-EP-1e	0.043	0.19	0.0022	0.0098	0.0031	0.013	0.0063	0.028	0.0042	0.019	0.0085	0.037	0.0062	0.027	0.0040	0.017		
4-EP-1h	4-EP-1h	0.79	3.47	0.041	0.18	0.056	0.24	0.12	0.51	0.077	0.34	0.16	0.68	0.11	0.50	0.073	0.32		

Stack No.	Unit No.(s)	Total HAPs		Benzene ☑ HAP or ~ TAP		Toluene ☑ HAP or ~ TAP		Ethylbenzene ☑ HAP or ~ TAP		n-Hexane ☑ HAP or ~ TAP		Trimethylpentane ☑ HAP or ~ TAP		Styrene ☑ HAP or ~ TAP		Xylene ☑ HAP or ~ TAP		Provide Pollutant Name Here HAP or ~ TAP	
		lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
4-EP-2a	4-EP-2a	123.3	0.74	8.2	0.049	4.3	0.026	0.42	0.0025	108.3	0.65	-	-	-	-	2.1	0.012		
4-EP-3	4-EP-3	Emissions from unit 4-EP-3 are routed to the thermal oxidizer unit EP-8. Controlled emissions are represented under unit EP-8.																	
4-EP-4	4-EP-4	Emissions from unit 4-EP-4 are routed to the thermal oxidizer unit EP-8. Controlled emissions are represented under unit EP-8.																	
EP-5	EP-5	2.64	11.58	1.43	6.26	0.56	2.46	0.03	0.11	0.34	1.48	-	-	-	-	0.14	0.61		
EP-6	EP-6	1.82	7.95	1.04	4.55	0.41	1.79	0.02	0.08	0.24	1.06	-	-	-	-	0.11	0.48		
EP-7	EP-7	0.01	0.03	0.005	0.02	0.001	0.004	0.00003	0.0001	-	-	0.0011	0.0046	-	-	0.0001	0.0006		
EP-8	EP-8	1.77	7.74	1.01	4.43	0.39	1.73	0.02	0.08	0.24	1.05	-	-	-	-	0.10	0.46		
EP-9	EP-9	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-	-	0.00	0.00	-	-	0.00	0.00		
1-T	1-T	Emissions from units 1-T-1 to 1-T-6 are routed to the enclosed combustion device, unit EP-7. Controlled emissions are represented under unit EP-7.																	
2-T	2-T	Emissions from units 2-T are routed to the sour slop tank control flare unit EP-9. Controlled emissions are represented under unit EP-9.																	
1-Load	1-Load	Emissions from unit 1-Load are routed to the enclosed combustion device, unit EP-7. Controlled emissions are represented under unit EP-7.																	
FUG	FUG	-	7.14	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-
5-EP-1a	5-EP-1a	0.13	0.58	0.00	0.0007	0.0003	0.0011	-	-	0.13	0.58	-	-	-	-	-	-		
5-EP-1b	5-EP-1b	0.12	0.54	0.00	0.0006	0.0002	0.0010	-	-	0.12	0.54	-	-	-	-	-	-		
5-EP-1c	5-EP-1c	0.01	0.06	0.00	0.0001	0.0000	0.0001	-	-	0.01	0.06	-	-	-	-	-	-		
5-EP-1d	5-EP-1d	0.03	0.14	0.00	0.0002	0.0001	0.0003	-	-	0.03	0.14	-	-	-	-	-	-		
5-EP-1e	5-EP-1e	Emissions from unit 5-EP-1e are routed to the thermal oxidizer unit EP-10. Controlled emissions are represented under unit EP-10.																	
5-EP-1f	5-EP-1f	Emissions from unit 5-EP-1f are routed to the thermal oxidizer unit EP-10. Controlled emissions are represented under unit EP-10.																	
5-EP-2	5-EP-2	144.28	0.87	3.60	0.02	0.89	0.01	0.04	0.00	139.59	0.84	0.86	0.01	-	-	0.16	0.00		
6-EP-1a	6-EP-1a	0.12	0.54	0.0001	0.0006	0.0002	0.0010	-	-	0.12	0.54	-	-	-	-	-	-		
6-EP-1b	6-EP-1b	0.12	0.54	0.0001	0.0006	0.0002	0.0010	-	-	0.12	0.54	-	-	-	-	-	-		
6-EP-1c	6-EP-1c	0.01	0.06	0.0000	0.0001	0.0000	0.0001	-	-	0.01	0.06	-	-	-	-	-	-		
6-EP-1d	6-EP-1d	0.03	0.14	0.0000	0.0002	0.0001	0.0003	-	-	0.03	0.14	-	-	-	-	-	-		
6-EP-1e	6-EP-1e	Emissions from unit 6-EP-1e are routed to the thermal oxidizer unit EP-10. Controlled emissions are represented under unit EP-10.																	
6-EP-1f	6-EP-1f	Emissions from unit 6-EP-1f are routed to the thermal oxidizer unit EP-10. Controlled emissions are represented under unit EP-10.																	
7-EP-1c	7-EP-1c	0.01	0.06	0.00002	0.0001	0.0000	0.0001	-	-	0.01	0.06	-	-	-	-	-	-		
7-EP-1d	7-EP-1d	0.03	0.14	0.00004	0.0002	0.0001	0.0003	-	-	0.03	0.14	-	-	-	-	-	-		
7-EP-2	7-EP-2	144.28	0.87	3.60	0.02	0.89	0.01	0.04	0.0002	139.59	0.84	0.86	0.01	-	-	0.16	0.001		
5.5-EP-1a	5.5-EP-1a	0.12	0.54	0.0001	0.0006	0.0002	0.0010	-	-	0.12	0.54	-	-	-	-	-	-		
5.5-EP-1b	5.5-EP-1b	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	-	-	0.0000	0.0000		
3-T	3-T	Emissions from tanks 3-T-1 to 3-T-6 are routed to the enclosed combustor unit EP-12. Controlled emissions are represented under unit EP-12.																	
4-T	4-T	Emissions from tanks 4-T-1 to 4-T-2 are routed to the flare unit EP-13. Controlled emissions are represented under unit EP-13.																	
5-T	5-T	0.03	0.14	0.03	0.14	-	-	-	-	-	-	-	-	-	-	-	-		
3-LOAD	3-LOAD	0.32	0.47	0.32	0.47	-	-	-	-	-	-	-	-	-	-	-	-		
4-LOAD	4-LOAD	0.00	0.00	0.00	0.00	-	-	-	-	-	-	-	-	-	-	-	-		
5-LOAD	5-LOAD	0.26	0.05	0.26	0.05	-	-	-	-	-	-	-	-	-	-	-	-		
EP-10	EP-10	1.66	7.13	0.75	3.22	0.24	1.05	0.01	0.04	0.60	2.58	0.01	0.03	-	-	0.05	0.21		
EP-11	EP-11	165.47	14.41	75.07	6.54	24.40	2.12	0.99	0.09	60.17	5.24	0.00	0.00	-	-	4.83	0.42		
EP-12	EP-12	0.03	0.11	0.02	0.10	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	-	-	0.00	0.01		

Stack No.	Unit No.(s)	Total HAPs		Benzene <input checked="" type="checkbox"/> HAP or ~ TAP		Toluene <input checked="" type="checkbox"/> HAP or ~ TAP		Ethylbenzene <input checked="" type="checkbox"/> HAP or ~ TAP		n-Hexane <input checked="" type="checkbox"/> HAP or ~ TAP		2,2,4-Trimethylpentane <input checked="" type="checkbox"/> HAP or ~ TAP		Styrene <input checked="" type="checkbox"/> HAP or ~ TAP		Xylene <input checked="" type="checkbox"/> HAP or ~ TAP		Provide Pollutant Name Here HAP or ~ TAP	
		lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
EP-13	EP-13	0.02	0.002	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.02	0.002	0.0000	0.0000			0.0000	0.0000		
2-EP-1t	2-EP-1t	0.0000	0.0000	0.0000	0.0000	-	-	-	-	-	-	-	-	-	-	-	-	-	
3-EP-1t	3-EP-1t	0.0000	0.0000	0.0000	0.0000	-	-	-	-	-	-	-	-	-	-	-	-	-	
4-EP-1t	4-EP-1t	0.0000	0.0000	0.0000	0.0000	-	-	-	-	-	-	-	-	-	-	-	-	-	
5-EP-1t	5-EP-1t	0.0000	0.0000	0.0000	0.0000	-	-	-	-	-	-	-	-	-	-	-	-	-	
6-EP-1t	6-EP-1t	0.0000	0.0000	0.0000	0.0000	-	-	-	-	-	-	-	-	-	-	-	-	-	
7-EP-1t	7-EP-1t	0.0000	0.0000	0.0000	0.0000	-	-	-	-	-	-	-	-	-	-	-	-	-	
FUG-1	FUG-1	0.83	3.62	0.83	3.62	-	-	-	-	-	-	-	-	-	-	-	-	-	
Totals:		887.12	98.07	116.11	31.17	42.68	11.36	3.57	4.82	707.73	21.58	3.09	5.98	0.98	4.34	13.18	4.99		

Table 2-J: Fuel

Specify fuel characteristics and usage. Unit and stack numbering must correspond throughout the application package.

Unit No.	Fuel Type (low sulfur Diesel, ultra low sulfur diesel, Natural Gas, Coal, ...)	Fuel Source: purchased commercial, pipeline quality natural gas, residue gas, raw/field natural gas, process gas (e.g. SRU tail gas) or other	Specify Units				
			Lower Heating Value	Hourly Usage	Annual Usage	% Sulfur	% Ash
1-EP-1	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	33,619 scf/hr	294.5 MMscf/yr	N/A	N/A
1-EP-2	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	2,500 scf/hr	21.9 MMscf/yr	N/A	N/A
1.5-EP-1g	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	11,428.6 scf/hr	100.1 MMscf/yr	N/A	N/A
4-EP-1g	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	11,428.6 scf/hr	100.1 MMscf/yr	N/A	N/A
2-EP-1a	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	5,333.3 scf/hr	46.7 MMscf/yr	N/A	N/A
2-EP-1b	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	15,190.5 scf/hr	133.1 MMscf/yr	N/A	N/A
2-EP-1e	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	2,381 scf/hr	20.9 MMscf/yr	N/A	N/A
2-EP-1h	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	52,381 scf/hr	458.9 MMscf/yr	N/A	N/A
2-EP-2a	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	2,500 scf/hr	21.9 MMscf/yr	N/A	N/A
2a-EP-1d	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	52,381 scf/hr	458.9 MMscf/yr	N/A	N/A
2.5-EP-1d	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	19,047.6 scf/hr	166.9 MMscf/yr	N/A	N/A
2.5-EP-5	Natural Gas	Pipeline Quality Natural Gas	925 btu/scf	222,852.4 scf/hr	1952.2 MMscf/yr	N/A	N/A
3-EP-1a	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	5,333.3 scf/hr	46.7 MMscf/yr	N/A	N/A
3-EP-1b	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	15,190.5 scf/hr	133.1 MMscf/yr	N/A	N/A
3-EP-1d	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	52,381 scf/hr	458.9 MMscf/yr	N/A	N/A
3-EP-1e	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	2,381 scf/hr	20.9 MMscf/yr	N/A	N/A
3-EP-1h	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	52,381 scf/hr	458.9 MMscf/yr	N/A	N/A
3-EP-2a	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	2,500 scf/hr	21.9 MMscf/yr	N/A	N/A
4-EP-1a	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	5,333.3 scf/hr	46.7 MMscf/yr	N/A	N/A

Unit No.	Fuel Type (low sulfur Diesel, ultra low sulfur diesel, Natural Gas, Coal, ...)	Fuel Source: purchased commercial, pipeline quality natural gas, residue gas, raw/field natural gas, process gas (e.g. SRU tail gas) or other	Specify Units				
			Lower Heating Value	Hourly Usage	Annual Usage	% Sulfur	% Ash
4-EP-1b	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	15,190.5 scf/hr	133.1 MMscf/yr	N/A	N/A
4-EP-1d	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	52,381 scf/hr	458.9 MMscf/yr	N/A	N/A
4-EP-1e	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	2,381 scf/hr	20.9 MMscf/yr	N/A	N/A
4-EP-1h	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	52,381 scf/hr	458.9 MMscf/yr	N/A	N/A
4-EP-2a	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	2,500 scf/hr	21.9 MMscf/yr	N/A	N/A
EP-5	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	26,666.7 scf/hr	233.6 MMscf/yr	N/A	N/A
EP-6	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	26,666.7 scf/hr	233.6 MMscf/yr	N/A	N/A
EP-7	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	462.2 scf/hr	4.0 MMscf/yr	N/A	N/A
EP-8	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	26,666.7 scf/hr	233.6 MMscf/yr	N/A	N/A
EP-9	Natural Gas	Pipeline Quality Natural Gas	1050 btu/scf	12 scf/hr	0.105 MMscf/yr	N/A	N/A
5-EP-1a	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	68,627 scf/hr	601.2 MMscf/yr	N/A	N/A
5-EP-1b	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	68,627 scf/hr	601.2 MMscf/yr	N/A	N/A
6-EP-1a	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	68,627 scf/hr	601.2 MMscf/yr	N/A	N/A
6-EP-1b	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	68,627 scf/hr	601.2 MMscf/yr	N/A	N/A
5-EP-1c	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	7,147 scf/hr	62.6 MMscf/yr	N/A	N/A
5-EP-1d	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	17,206 scf/hr	150.7 MMscf/yr	N/A	N/A
6-EP-1c	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	7,147 scf/hr	62.6 MMscf/yr	N/A	N/A
6-EP-1d	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	17,206 scf/hr	150.7 MMscf/yr	N/A	N/A
7-EP-1c	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	7,147 scf/hr	62.6 MMscf/yr	N/A	N/A
7-EP-1d	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	17,206 scf/hr	150.7 MMscf/yr	N/A	N/A
5.5-EP-1a	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	68,627 scf/hr	601.2 MMscf/yr	N/A	N/A

Unit No.	Fuel Type (low sulfur Diesel, ultra low sulfur diesel, Natural Gas, Coal, ...)	Fuel Source: purchased commercial, pipeline quality natural gas, residue gas, raw/field natural gas, process gas (e.g. SRU tail gas) or other	Specify Units				
			Lower Heating Value	Hourly Usage	Annual Usage	% Sulfur	% Ash
EP-10	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	109,804 scf/hr	961.9 MMscf/yr	N/A	N/A
5-EP-2	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	2445 scf/hr	21.4 MMscf/hr	N/A	N/A
7-EP-2	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	2445 scf/hr	21.4 MMscf/hr	N/A	N/A
5.5-EP-1b	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	380 scf/hr	3.3 MMscf/hr	N/A	N/A
EP-12	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	65 scf/hr	0.6 MMscf/hr	N/A	N/A
EP-13	Natural Gas	Pipeline Quality Natural Gas	1020 btu/scf	65 scf/hr	0.6 MMscf/hr	N/A	N/A

Table 2-K: Liquid Data for Tanks Listed in Table 2-L

For each tank, list the liquid(s) to be stored in each tank. If it is expected that a tank may store a variety of hydrocarbon liquids, enter "mixed hydrocarbons" in the Composition column for that tank and enter the corresponding data of the most volatile liquid to be stored in the tank. If tank is to be used for storage of different materials, list all the materials in the "All Calculations" attachment, run the newest version of TANKS on each, and use the material with the highest emission rate to determine maximum uncontrolled and requested allowable emissions rate. The permit will specify the most volatile category of liquids that may be stored in each tank. Include appropriate tank-flashing modeling input data. Use additional sheets if necessary. Unit and stack numbering must correspond throughout the application package.

Tank No.	SCC Code	Material Name	Composition	Liquid Density (lb/gal)	Vapor Molecular Weight (lb/lb*mol)	Average Storage Conditions		Max Storage Conditions	
						Temperature (°F)	True Vapor Pressure (psia)	Temperature (°F)	True Vapor Pressure (psia)
1-T-1	40400311	Condensate	Mixed Hydrocarbons	5.4	85.2	120.4	13.1	120.4	13.1
1-T-2	40400311	Condensate	Mixed Hydrocarbons	5.4	85.2	120.4	13.1	120.4	13.1
1-T-3	40400311	Condensate	Mixed Hydrocarbons	5.4	85.2	120.4	13.1	120.4	13.1
1-T-4	40400311	Condensate	Mixed Hydrocarbons	5.4	85.2	120.4	13.1	120.4	13.1
1-T-5	40400311	Condensate	Mixed Hydrocarbons	5.4	85.2	120.4	13.1	120.4	13.1
1-T-6	40400311	Condensate	Mixed Hydrocarbons	5.4	85.2	120.4	13.1	120.4	13.1
2-T-1	40400311	Condensate	Water	8.25	22.25	119.9	14.6	119.9	14.6
2-T-2	40400311	Condensate	Water	8.25	22.75	119.9	14.6	119.9	14.6
3-T-1	40400311	Condensate	Mixed Hydrocarbons	5.39087	75.03	111.21	9.06	111.21	9.06
3-T-2	40400311	Condensate	Mixed Hydrocarbons	5.39087	75.03	111.21	9.06	111.21	9.06
3-T-3	40400311	Condensate	Mixed Hydrocarbons	5.39087	75.03	111.21	9.06	111.21	9.06
3-T-4	40400311	Condensate	Mixed Hydrocarbons	5.39087	75.03	111.21	9.06	111.21	9.06
3-T-5	40400311	Condensate	Mixed Hydrocarbons	5.39087	75.03	111.21	9.06	111.21	9.06
3-T-6	40400311	Condensate	Mixed Hydrocarbons	5.39087	75.03	111.21	9.06	111.21	9.06
4-T-1	40400311	Sour Water	Water	8.3	40	110.89	16.49	110.89	16.49
4-T-2	40400311	Sour Water	Water	8.3	40	110.89	16.49	110.89	16.49
5-T-1	40400311	Slop	Hydrocarbon Contacted Wastewater	8.3	19.56	111.62	15.39	111.62	15.39
5-T-2	40400311	Slop	Hydrocarbon Contacted Wastewater	8.3	19.56	111.62	15.39	111.62	15.39
5-T-3	40400311	Slop	Hydrocarbon Contacted Wastewater	8.3	19.56	111.62	15.39	111.62	15.39
5-T-4	40400311	Slop	Hydrocarbon Contacted Wastewater	8.3	19.56	111.62	15.39	111.62	15.39

Table 2-L: Tank Data

Include appropriate tank-flashing modeling input data. Use an addendum to this table for unlisted data categories. Unit and stack numbering must correspond throughout the application package. Use additional sheets if necessary. See reference Table 2-L2. Note: 1.00 bbl = 10.159 M3 = 42.0 gal

Tank No.	Date Installed	Materials Stored	Seal Type (refer to Table 2-LR below)	Roof Type (refer to Table 2-LR below)	Capacity		Diameter (M)	Vapor Space (M)	Color (from Table VI-C)		Paint Condition (from Table VI-C)	Annual Throughput (gal/yr)	Turn-overs (per year)
					(bbl)	(M ³)			Roof	Shell			
1-T-1		Condensate			500	79.5	4.72		OT - Tan	OT - Tan	Good	5,110,000	243.3
1-T-2		Condensate			500	79.5	4.72		OT - Tan	OT - Tan	Good	5,110,000	243.3
1-T-3		Condensate			500	79.5	4.72		OT - Tan	OT - Tan	Good	5,110,000	243.3
1-T-4		Condensate			500	79.5	4.72		OT - Tan	OT - Tan	Good	5,110,000	243.3
1-T-5		Condensate			500	79.5	4.72		OT - Tan	OT - Tan	Good	5,110,000	243.3
1-T-6		Condensate			500	79.5	4.72		OT - Tan	OT - Tan	Good	5,110,000	243.3
2-T-1		Sour Water			500	79.5	4.72		OT - Tan	OT - Tan	Good	9,198,000	438.0
2-T-2		Sour Water			500	79.5	4.72		OT - Tan	OT - Tan	Good	9,198,000	438.0
3-T-1		Condensate			500	79.5	4.72		OT - Tan	OT - Tan	Good	8,217,300	364.0
3-T-2		Condensate			500	79.5	4.72		OT - Tan	OT - Tan	Good	8,217,300	364.0
3-T-3		Condensate			500	79.5	4.72		OT - Tan	OT - Tan	Good	8,217,300	364.0
3-T-4		Condensate			500	79.5	4.72		OT - Tan	OT - Tan	Good	8,217,300	364.0
3-T-5		Condensate			500	79.5	4.72		OT - Tan	OT - Tan	Good	8,217,300	364.0
3-T-6		Condensate			500	79.5	4.72		OT - Tan	OT - Tan	Good	8,217,300	364.0
4-T-1		Sour Water			500	79.5	4.72		OT - Tan	OT - Tan	Good	670,950	30.0
4-T-2		Sour Water			500	79.5	4.72		OT - Tan	OT - Tan	Good	670,950	30.0
5-T-1		Slop			400	39.4	3.66		OT - Tan	OT - Tan	Good	933,912	55.0
5-T-2		Slop			400	39.4	3.66		OT - Tan	OT - Tan	Good	933,912	55.0
5-T-3		Slop			400	39.4	3.66		OT - Tan	OT - Tan	Good	933,912	55.0
5-T-4		Slop			400	39.4	3.66		OT - Tan	OT - Tan	Good	933,912	55.0

Table 2-L2: Liquid Storage Tank Data Codes Reference Table

Roof Type	Seal Type, Welded Tank Seal Type		Seal Type, Riveted Tank Seal Type		Roof, Shell Color	Paint Condition
	Mechanical Shoe Seal	Liquid-mounted resilient seal	Vapor-mounted resilient seal	Seal Type		
FX: Fixed Roof					WH: White	Good
IF: Internal Floating Roof	A: Primary only	A: Primary only	A: Primary only	A: Mechanical shoe, primary only	AS: Aluminum (specular)	Poor
EF: External Floating Roof	B: Shoe-mounted secondary	B: Weather shield	B: Weather shield	B: Shoe-mounted secondary	AD: Aluminum (diffuse)	
P: Pressure	C: Rim-mounted secondary	C: Rim-mounted secondary	C: Rim-mounted secondary	C: Rim-mounted secondary	LG: Light Gray	
					MG: Medium Gray	
					BL: Black	
					OT: Other (specify)	

Note: 1.00 bbl = 0.159 M³ = 42.0 gal

Table 2-M: Materials Processed and Produced (Use additional sheets as necessary.)

Material Processed				Material Produced			
Description	Chemical Composition	Phase (Gas, Liquid, or Solid)	Quantity (specify units)	Description	Chemical Composition	Phase	Quantity (specify units)
Natural Gas	Mixed Hydrocarbons	Gas	1210 MMSCFD	Natural Gas	Mixed Hydrocarbons	Gas	1210 MMSCFD
				Condensate	Condensate	Liquid	79,963,800 gal/yr
				Natural Gas Liquids	Natural Gas Liquids	Liquid	60,000 bpd

Table 2-N: CEM Equipment

Enter Continuous Emissions Measurement (CEM) Data in this table. If CEM data will be used as part of a federally enforceable permit condition, or used to satisfy the requirements of a state or federal regulation, include a copy of the CEM's manufacturer specification sheet in the Information Used to Determine Emissions attachment. Unit and stack numbering must correspond throughout the application package. Use additional sheets if necessary.

Stack No.	Pollutant(s)	Manufacturer	Model No.	Serial No.	Sample Frequency	Averaging Time	Range	Sensitivity	Accuracy
Not applicable. There is no CEM equipment used at this facility.									

Table 2-O: Parametric Emissions Measurement Equipment

Unit and stack numbering must correspond throughout the application package. Use additional sheets if necessary.

Unit No.	Parameter/Pollutant Measured	Location of Measurement	Unit of Measure	Acceptable Range	Frequency of Maintenance	Nature of Maintenance	Method of Recording	Averaging Time
Not applicable. There is no PEM equipment used at this facility.								

Table 2-P: Greenhouse Gas Emissions

Applications submitted under 20.2.70, 20.2.72, & 20.2.74 NMAC are required to complete this Table. Power plants, Title V major sources, and PSD major sources must report and calculate all GHG emissions for each unit. Applicants must report potential emission rates in short tons per year (see Section 6.a for assistance). Include GHG emissions during Startup, Shutdown, and Scheduled Maintenance in this table. For minor source facilities that are not power plants, are not Title V, or are not PSD, there are three options for reporting GHGs 1) report GHGs for each individual piece of equipment; 2) report all GHGs from a group of unit types, for example report all combustion source GHGs as a single unit and all venting GHG as a second separate unit; OR 3) check the following box ~ By checking this box, the applicant acknowledges the total CO2e emissions are less than 75,000 tons per year.

		CO ₂ ton/yr	N ₂ O ton/yr	CH ₄ ton/yr	SF ₆ ton/yr	PFC/HFC ton/yr ²					Total GHG Mass Basis ton/yr ⁴	Total CO ₂ e ton/yr ⁵
Unit No.	GWP_s¹	1	298	25	22,800	footnote 3						
1-EP-1	mass GHG	18086.10	0.03	0.34							18,086.47	
	CO ₂ e	18086.10	10.16	8.52								18,104.78
1-EP-2	mass GHG	2770.60	0.00	10.88							2,781.49	
	CO ₂ e	2770.60	1.48	272.00								3,044.09
1.5-EP-1g	mass GHG	9222.40	0.02	0.17							9,222.59	
	CO ₂ e	9222.40	5.18	4.35								9,231.92
4-EP-1g	mass GHG	9222.40	0.02	0.17							9,222.59	
	CO ₂ e	9222.40	5.18	4.35								9,231.92
2-EP-1a	mass GHG	2869.20	0.01	0.05							2,869.26	
	CO ₂ e	2869.20	1.61	1.35								2,872.16
2-EP-1b	mass GHG	8172.10	0.02	0.15							8,172.27	
	CO ₂ e	8172.10	4.59	3.85								8,180.54
2-EP-1e	mass GHG	1537.10	0.00	0.03							1,537.13	
	CO ₂ e	1537.10	0.86	0.72								1,538.69
2-EP-2a	mass GHG	7388.30	0.01	29.01							7,417.33	
	CO ₂ e	7388.30	3.96	725.34								8,117.60
2-EP-1h	mass GHG	28179.50	0.05	0.53							28,180.08	
	CO ₂ e	28179.50	15.83	13.28								28,208.60
2a-EP-1d	mass GHG	28179.50	0.05	0.53							28,180.08	
	CO ₂ e	28179.50	15.83	13.28								28,208.60
2.5-EP-1d	mass GHG	10247.10	0.02	0.19							10,247.31	
	CO ₂ e	10247.10	5.76	4.83								10,257.68
2.5-EP-5	mass GHG	19331.90	0.00	1.89							19,333.79	
	CO ₂ e	19331.90	0.02	47.18								19,379.10
3-EP-1a	mass GHG	2869.20	0.01	0.05							2,869.26	
	CO ₂ e	2869.20	1.61	1.35								2,872.16
3-EP-1b	mass GHG	8172.10	0.02	0.15							8,172.27	
	CO ₂ e	8172.10	4.59	3.85								8,180.54

3-EP-1d	mass GHG	28179.50	0.05	0.53							28,180.08	
	CO2e	28179.50	15.83	13.28								28,208.60
3-EP-1e	mass GHG	1537.10	0.00	0.03							1,537.13	
	CO2e	1537.10	0.86	0.72								1,538.69
3-EP-1h	mass GHG	28179.50	0.05	0.53							28,180.08	
	CO2e	28179.50	15.83	13.28								28,208.60
3-EP-2a	mass GHG	7388.30	0.01	29.01							7,417.33	
	CO2e	7388.30	3.96	725.34								8,117.60
4-EP-1a	mass GHG	2869.20	0.01	0.05							2,869.26	
	CO2e	2869.20	1.61	1.35								2,872.16
4-EP-1b	mass GHG	8172.10	0.02	0.15							8,172.27	
	CO2e	8172.10	4.59	3.85								8,180.54
4-EP-1d	mass GHG	28179.50	0.05	0.53							28,180.08	
	CO2e	28179.50	15.83	13.28								28,208.60
4-EP-1e	mass GHG	1537.10	0.00	0.03							1,537.13	
	CO2e	1537.10	0.86	0.72								1,538.69
4-EP-1h	mass GHG	28179.50	0.05	0.53							28,180.08	
	CO2e	28179.50	15.83	13.28								28,208.60
4-EP-2a	mass GHG	7388.30	0.01	29.01							7,417.33	
	CO2e	7388.30	3.96	725.34								8,117.60
EP-5	mass GHG	14345.95	0.03	0.27							14,346.24	
	CO,e	14345.95	8.06	6.76								14,360.76
EP-6	mass GHG	14345.95	0.03	0.27							14,346.24	
	CO,e	14345.95	8.06	6.76								14,360.76
EP-7	mass GHG	796.69	0.00	0.02							796.70	
	CO,e	796.69	0.45	0.38								797.51
EP-8	mass GHG	14345.95	0.03	0.27							14,346.24	
	CO,e	14345.95	8.06	6.76								14,360.76
EP-9	mass GHG	2700.62	0.01	0.05							2,700.67	
	CO,e	2700.62	1.52	1.27								2,703.40
FUG	mass GHG	7.63	0.00	33.95							41.58	
	CO2e	7.63	0.00	848.75								856.38
5-EP-1a	mass GHG	32727.80	0.06	0.62							32,728.48	
	CO2e	32727.80	18.48	15.50								32,761.78
5-EP-1b	mass GHG	32727.80	0.06	0.62							32,728.48	
	CO2e	32727.80	18.48	15.50								32,761.78

5-EP-1c	mass GHG	3408.40	0.01	0.06							3,408.47	
	CO ₂ e	3408.40	1.79	1.50								3,411.69
5-EP-1d	mass GHG	8205.30	0.02	0.15							8,205.47	
	CO ₂ e	8205.30	4.47	3.75								8,213.52
5-EP-1e	mass GHG	1839.60	0.00	23.77							1,863.37	
	CO ₂ e	1839.60	0.89	594.25								2,434.74
5-EP-1f	mass GHG	5276.29	0.00	0.00							5,276.29	
	CO ₂ e	5276.29	0.00	0.00								5,276.29
5-EP-2	mass GHG	7952.60	0.01	34.64							7,987.25	
	CO ₂ e	7952.60	4.17	866.00								8,822.77
6-EP-1a	mass GHG	32727.80	0.06	0.62							32,728.48	
	CO ₂ e	32727.80	18.48	15.50								32,761.78
6-EP-1b	mass GHG	32727.80	0.06	0.62							32,728.48	
	CO ₂ e	32727.80	18.48	15.50								32,761.78
6-EP-1c	mass GHG	3408.40	0.01	0.06							3,408.47	
	CO ₂ e	3408.40	1.79	1.50								3,411.69
6-EP-1d	mass GHG	8205.30	0.02	0.15							8,205.47	
	CO ₂ e	8205.30	4.47	3.75								8,213.52
6-EP-1e	mass GHG	1839.60	0.00	23.77							1,863.37	
	CO ₂ e	1839.60	0.89	594.25								2,434.74
6-EP-1f	mass GHG	5276.29	0.00	0.00							5,276.29	
	CO ₂ e	5276.29	0.00	0.00								5,276.29
7-EP-1c	mass GHG	3408.40	0.01	0.06							3,408.47	
	CO ₂ e	3408.40	1.79	1.50								3,411.69
7-EP-1d	mass GHG	8205.30	0.02	0.15							8,205.47	
	CO ₂ e	8205.30	4.47	3.75								8,213.52
7-EP-2	mass GHG	7952.60	0.01	34.64							7,987.25	
	CO ₂ e	7952.60	4.17	866.00								8,822.77
5.5-EP-1a	mass GHG	32727.80	0.06	0.62							32,728.48	
	CO ₂ e	32727.80	18.48	15.50								32,761.78
5.5-EP-1b	mass GHG	911.70	0.00	1.21							912.91	
	CO ₂ e	911.70	0.00	30.25								941.95
EP-10	mass GHG	52058.20	0.10	0.98							52,059.28	
	CO ₂ e	52058.20	29.20	24.50								52,111.90
EP-11	mass GHG	9158.89	0.00	6.55							9,165.44	
	CO ₂ e	9158.89	0.00	163.73								9,322.62
EP-12	mass GHG	360.30	0.00	0.51							360.81	
	CO ₂ e	360.30	0.30	12.75								373.35
EP-13	mass GHG	932.30	0.00	2.92							935.22	
	CO ₂ e	932.30	0.60	73.00								1,005.90

2-EP-1t	mass GHG	0.00	0.00	4.37							4.38	
	CO ₂ e	0.00	0.00	109.36								109.36
3-EP-1t	mass GHG	0.00	0.00	4.37							4.38	
	CO ₂ e	0.00	0.00	109.36								109.36
4-EP-1t	mass GHG	0.00	0.00	4.37							4.38	
	CO ₂ e	0.00	0.00	109.36								109.36
5-EP-1t	mass GHG	0.00	0.00	4.37							4.38	
	CO ₂ e	0.00	0.00	109.36								109.36
6-EP-1t	mass GHG	0.00	0.00	4.37							4.38	
	CO ₂ e	0.00	0.00	109.36								109.36
7-EP-1t	mass GHG	0.00	0.00	4.37							4.38	
	CO ₂ e	0.00	0.00	109.36								109.36
FUG-1	mass GHG	4462.60	0.00	20848.80							25,311.40	
	CO ₂ e	4462.60	0.00	521220.00								525,682.60
	mass GHG											
	CO ₂ e											
	mass GHG											
	CO ₂ e											
Total	mass GHG										662,049.74	
	CO ₂ e											1,169,914.27

¹ GWP (Global Warming Potential): Applicants must use the most current GWPs codified in Table A-1 of 40 CFR part 98. GWPs are subject to change, therefore, applicants need to check 40 CFR 98 to confirm C

² For HFCs or PFCs describe the specific HFC or PFC compound and use a separate column for each individual compound.

³ For each new compound, enter the appropriate GWP for each HFC or PFC compound from Table A-1 in 40 CFR 98.

⁴ Green house gas emissions on a mass basis is the ton per year green house gas emission before adjustment with its GWP.

⁵ CO₂e means Carbon Dioxide Equivalent and is calculated by multiplying the TPY mass emissions of the green house gas by its GWP.

Section 3

Application Summary

The **Application Summary** shall include a brief description of the facility and its process, the type of permit application, the applicable regulation (i.e. 20.2.72.200.A.X, or 20.2.73 NMAC) under which the application is being submitted, and any air quality permit numbers associated with this site. If this facility is to be collocated with another facility, provide details of the other facility including permit number(s). In case of a revision or modification to a facility, provide the lowest level regulatory citation (i.e. 20.2.72.219.B.1.d NMAC) under which the revision or modification is being requested. Also describe the proposed changes from the original permit, how the proposed modification will affect the facility's operations and emissions, de-bottlenecking impacts, and changes to the facility's major/minor status (both PSD & Title V).

The **Process Summary** shall include a brief description of the facility and its processes.

Startup, Shutdown, and Maintenance (SSM) routine or predictable emissions: Provide an overview of how SSM emissions are accounted for in this application. Refer to "Guidance for Submittal of Startup, Shutdown, Maintenance Emissions in Permit Applications (http://www.env.nm.gov/aqb/permit/app_form.html) for more detailed instructions on SSM emissions.

Lucid Energy Delaware, LLC (Lucid) owns and operates the Red Hills Gas Processing Plant (Red Hills) in Lea County, NM. The Red Hills Gas Processing Plant dehydrates and removes CO₂ and natural gas liquids from sweet field gas for transportation via a sales pipeline. With this application, Lucid is proposing to update the Red Hills Gas Processing Plant Title V Permit, number P-278, so that it reflects the most recent revision to the site's NSR Permit, number 4310-M5. These revisions will include Unit IDs changes, serial number updates, operating capacities changes, updated emissions, etc. All equipment to be included in Title V permit number P-278 are listed in the Section 2 Tables.

Project Description:

The purpose of this application is to update Title V Permit P278 to match NSR permit 4310-M5, issued December 30, 2019. The most recent revisions to NSR permit 4310-M5 included adding three amine and dehydrator services (Red Hills Gas Processing #4, #5 and #6), three cryogenic process trains (Cryogenic plant #5, #6 and #7), and an acid gas injection system. New contracts executed first, and second quarter of 2019 necessitated the addition of gas processing capacity at Red Hills. Lucid has also received updated forecasts from its producers that showed increment of approximately 300 MMSCFD from the one provided in 2017. The addition of the (3) amine and dehydrator services, (3) cryogenic plants and (1) acid gas injection well, are needed to process the gas from these contracts and are based on the anticipated plans for the facility for the next 2 years.

This modification will meet the increasing demand of natural gas processing, which is necessary to treat the produced gas stream to enable it to meet the natural gas pipeline industry's quality specifications. The new equipment will utilize the latest processing and emissions technology as provided later in this permit application. Lucid is proud to have infrastructure to support southeastern New Mexico's rapidly increasing production and is committed to ensuring world class compliance with New Mexico environmental rules and regulations.


All equipment and their associated emissions are included in the Section 2 Tables of this application.


Section 4

Process Flow Sheet

A **process flow sheet** and/or block diagram indicating the individual equipment, all emission points and types of control applied to those points. The unit numbering system should be consistent throughout this application.

A process flow diagram is attached.





MATCH ON FIGURE B

MATCH ON FIGURE B




FIGURE C

Section 5

Plot Plan Drawn To Scale

A **plot plan drawn to scale** showing emissions points, roads, structures, tanks, and fences of property owned, leased, or under direct control of the applicant. This plot plan must clearly designate the restricted area as defined in UA1, Section 1-D.12. The unit numbering system should be consistent throughout this application.

A plot plan is attached.




LEGEND


- ROAD EDGE
- - - - - FENCE
- E-E-E-E-ELEC EXISTENTIAL LINES
- P-P-P-P-PIPELINE
- - - - - SECTION LINE
- - - - - PROPERTY BOUNDARY
- # # SECTION CORNER

NOTES

1. NOT USE.
2. ENTERPRISE PRODUCTS METER STATION EXISTS CURRENTLY ON SOUTH BORDER OF RED HILLS NORTH. THIS STATION WILL BE RELOCATED TO THE NORTH BORDER.
3. EQUIPMENT LOCATED ACCORDING TO THE FOLLOWING:
 TRAIN 1 - CENTER OF FLARE
 N 442820.80
 E 792041.20
 TRAIN 2 -
 N XXX
 E XXX
 TRAIN 3 -
 N XXX
 E XXX
 TRAIN 4 -
 N XXX
 E XXX
 ACID GAS INJECTION (AGI)
 N XXX
 E XXX
 COORDINATES DEVELOPED BY PROSPECT SURVEY



PRELIMINARY
NOT FOR CONSTRUCTION



DRAWING NO.	TITLE	REVISIONS				REVISIONS					
		REV	DATE	BY	APP'D	DESCRIPTION	REV	DATE	BY	APP'D	DESCRIPTION

C	05/09/19				ISSUED FOR CLIENT REVIEW
B	05/08/19				ISSUED FOR CLIENT REVIEW
A	04/22/19				ISSUED FOR INTERNAL REVIEW
REV	DATE	BY	APP'D		PRELIMINARY ISSUE

SCALE	AS SHOWN	MO DAY YR		Harris Group
DRAWN	STS	04/18/19		
CHK'D				
APP'D				
APP'D				
APPROVED				
DATE				
PROJECT	61526.00	DRAWING NUMBER	C550001	CIVIL SITE PLAN RED HILLS PLANT JAL, NEW MEXICO

P:\061526.00\Drawings\C550001.dwg 5/9/2019 ssmson

Section 6

All Calculations

Show all calculations used to determine both the hourly and annual controlled and uncontrolled emission rates. All calculations shall be performed keeping a minimum of three significant figures. Document the source of each emission factor used (if an emission rate is carried forward and not revised, then a statement to that effect is required). If identical units are being permitted and will be subject to the same operating conditions, submit calculations for only one unit and a note specifying what other units to which the calculations apply. All formulas and calculations used to calculate emissions must be submitted. The "Calculations" tab in the UA2 has been provided to allow calculations to be linked to the emissions tables. Add additional "Calc" tabs as needed. If the UA2 or other spread sheets are used, all calculation spread sheet(s) shall be submitted electronically in Microsoft Excel compatible format so that formulas and input values can be checked. Format all spread sheets and calculations such that the reviewer can follow the logic and verify the input values. Define all variables. If calculation spread sheets are not used, provide the original formulas with defined variables. Additionally, provide subsequent formulas showing the input values for each variable in the formula. All calculations, including those calculations are imbedded in the Calc tab of the UA2 portion of the application, the printed Calc tab(s), should be submitted under this section.

Tank Flashing Calculations: The information provided to the AQB shall include a discussion of the method used to estimate tank-flashing emissions, relative thresholds (i.e., NOI, permit, or major source (NSPS, PSD or Title V)), accuracy of the model, the input and output from simulation models and software, all calculations, documentation of any assumptions used, descriptions of sampling methods and conditions, copies of any lab sample analysis. If Hysis is used, all relevant input parameters shall be reported, including separator pressure, gas throughput, and all other relevant parameters necessary for flashing calculation.

SSM Calculations: It is the applicant's responsibility to provide an estimate of SSM emissions or to provide justification for not doing so. In this Section, provide emissions calculations for Startup, Shutdown, and Routine Maintenance (SSM) emissions listed in the Section 2 SSM and/or Section 22 GHG Tables and the rationale for why the others are reported as zero (or left blank in the SSM/GHG Tables). Refer to "Guidance for Submittal of Startup, Shutdown, Maintenance Emissions in Permit Applications (http://www.env.nm.gov/aqb/permit/app_form.html) for more detailed instructions on calculating SSM emissions. If SSM emissions are greater than those reported in the Section 2, Requested Allowables Table, modeling may be required to ensure compliance with the standards whether the application is NSR or Title V. Refer to the Modeling Section of this application for more guidance on modeling requirements.

Glycol Dehydrator Calculations: The information provided to the AQB shall include the manufacturer's maximum design recirculation rate for the glycol pump. If GRI-Glycalc is used, the full input summary report shall be included as well as a copy of the gas analysis that was used.

Road Calculations: Calculate fugitive particulate emissions and enter haul road fugitives in Tables 2-A, 2-D and 2-E for:

1. If you transport raw material, process material and/or product into or out of or within the facility and have PER emissions greater than 0.5 tpy.
2. If you transport raw material, process material and/or product into or out of the facility more frequently than one round trip per day.

Significant Figures:

- A. All emissions standards are deemed to have at least two significant figures, but not more than three significant figures.
- B. At least 5 significant figures shall be retained in all intermediate calculations.
- C. In calculating emissions to determine compliance with an emission standard, the following rounding off procedures shall be used:
 - (1) If the first digit to be discarded is less than the number 5, the last digit retained shall not be changed;
 - (2) If the first digit discarded is greater than the number 5, or if it is the number 5 followed by at least one digit other than the number zero, the last figure retained shall be increased by one unit; **and**
 - (3) If the first digit discarded is exactly the number 5, followed only by zeros, the last digit retained shall be rounded upward if it is an odd number, but no adjustment shall be made if it is an even number.
 - (4) The final result of the calculation shall be expressed in the units of the standard.

Control Devices: In accordance with 20.2.72.203.A(3) and (8) NMAC, 20.2.70.300.D(5)(b) and (e) NMAC, and 20.2.73.200.B(7) NMAC, the permittee shall report all control devices and list each pollutant controlled by the control device

regardless if the applicant takes credit for the reduction in emissions. The applicant can indicate in this section of the application if they chose to not take credit for the reduction in emission rates. For notices of intent submitted under 20.2.73 NMAC, only uncontrolled emission rates can be considered to determine applicability unless the state or federal Acts require the control. This information is necessary to determine if federally enforceable conditions are necessary for the control device, and/or if the control device produces its own regulated pollutants or increases emission rates of other pollutants.

Note: the emissions units listed below are the units being added to the Title V permit with this application.

Heaters (Units 5-EP-1c, 5-EP-1d, 6-EP-1c, 6-EP-1d, 7-EP-1c, 7-EP-1d)

NO_x, CO, VOC, PM, SO₂ and hazardous emissions were calculated using AP-42 factors for external natural gas combustion sources in Tables 1.4-1, 1.4-2 and 1.4-3. As a conservative measure, it was assumed that PM(Total) = PM₁₀ and PM (condensable) = PM_{2.5}. Greenhouse gas emissions were estimated using methodology from 40 CFR Part 98 and emission factors from Tables C-1 and C-2 of Part 98.

Reboilers (Units 5-EP-1a, 5-EP-1b, 6-EP-1a, 6-EP-1b and 5.5-EP-1a)

NO_x, VOC, PM, SO₂ and hazardous emissions were calculated using AP-42 factors for external natural gas combustion sources in Tables 1.4-1, 1.4-2 and 1.4-3. The CO emissions were calculated based on the manufacturer's spec sheet with a safety factor of 50%. As a conservative measure, it was assumed that PM(Total) = PM₁₀ and PM (condensable) = PM_{2.5}. Greenhouse gas emissions were estimated using methodology from 40 CFR Part 98 and emission factors from Tables C-1 and C-2 of Part 98.

Reboilers (Units 4-EP-1d, 4-EP-1e, and 4-EP-1h)

NO_x, CO, VOC, PM, SO₂ and hazardous emissions were calculated using AP-42 factors for external natural gas combustion sources in Tables 1.4-1, 1.4-2 and 1.4-3. As a conservative measure, it was assumed that PM(Total) = PM₁₀ and PM (condensable) = PM_{2.5}. Greenhouse gas emissions were estimated using methodology from 40 CFR Part 98 and emission factors from Tables C-1 and C-2 of Part 98.

Glycol Dehydrators (Units 4-EP-3, 5-EP-1e, and 6-EP-1e)

All emissions from these units are calculated using ProMax. The glycol flash will be routed back to the process. The regenerator emissions will be routed to a thermal oxidizer. Controlled emissions from these units will be represented under the thermal oxidizer used for control. Emissions during maintenance and malfunction are accounted for in thermal oxidizer SSM. Greenhouse gas emissions were estimated using methodology from 40 CFR Part 98 and emission factors from Tables C-1 and C-2 of Part 98.

Amine Vents (Units 4-EP-4, 5-EP-1f, and 6-EP-1f)

All emissions from these units are calculated using ProMax. The amine flash is routed back to the process. The regenerator emissions from the amine units are routed to a thermal oxidizer. Controlled emissions are represented under unit the thermal oxidizer used for control. Emissions during maintenance and malfunction are accounted for in thermal oxidizer SSM. Greenhouse gas emissions were estimated using methodology from 40 CFR Part 98 and emission factors from Tables C-1 and C-2 of Part 98.

Flare SSM (Units 5-EP-2 and 7-EP-2)

The plant flares are used for flaring during startup, shutdown, maintenance and upset conditions. The only steady state conditions associated with these flares are from the pilot and purge gas streams. SSM from the plant flare is due to various maintenance activities throughout the facility per manufacturer's recommended maintenance schedules. These maintenance activities include but are not limited to compressor catalyst changes, blowdowns for associated maintenance throughout the facility, instrumental calibrations, and process safety device maintenance.

The basis of the flaring calculations are the expected composition and maximum expected volumes of the gas. The SO₂ composition is based on a 98% molar conversion of H₂S to SO₂. NO_x and CO emissions for both scenarios are calculated using AP-42 Table 13.5-1 emission factors. VOC emissions are calculated from the VOC volume fraction of the inlet gas to the flare, the specific volume of the VOC fraction of the inlet gas, and a 98% destruction efficiency. The ProMax inlet gas analysis can be found in Section 7. Emissions of greenhouse gases are calculated using methodology from 40 CFR Subpart 98.233(n).

AGI Flare SSM (Unit 5.5-EP-1b)

When the AGI well is inoperable due to maintenance or upset conditions, acid gas will be flared for limited periods at the acid gas flare. Under startup, shutdown, maintenance, and upset conditions the AGI well could be offline. During times when the AGI well is down, the sour gas will be sent to the acid gas flare. The gas routed to the flare will also be curtailed to half by switching to the backup compressor within 30 minutes or by reducing the inlet flow during SSM operations. The expected composition and maximum expected volumes of the acid gas are used as the basis of the flaring calculations. The acid gas is

expected to be relatively low heat content, so assist gas sufficient to raise the heat content of the flared gas may be added. The targeted assist gas volume is 2 MMscf/d. The SO₂ composition is based on a 98% molar conversion of H₂S to SO₂. NO_x and CO emissions for both scenarios are calculated using AP-42 Table 13.5-1 emission factors. Emissions of greenhouse gases are calculated using methodology from 40 CFR Subpart 98.233(n).

Thermal Oxidizes (Unit EP-5 and EP-6)

NO_x, CO, emissions were updated using the manufacture's spec sheet. PM, and SO₂ emissions were calculated using AP-42 factors for external natural gas combustion sources in Tables 1.4-1 and 1.4-2. HAP and VOC emissions were calculated using streams from ProMax. Greenhouse gas emissions were estimated using methodology from 40 CFR Part 98 and emission factors from Tables C-1 and C-2 of Part 98.

Thermal Oxidizes (Unit EP-8 and EP-10)

NO_x, CO, emissions were calculated using the manufacture's spec sheet. PM, and SO₂ emissions were calculated using AP-42 factors for external natural gas combustion sources in Tables 1.4-1 and 1.4-2. HAP and VOC emissions were calculated using streams from ProMax. Greenhouse gas emissions were estimated using methodology from 40 CFR Part 98 and emission factors from Tables C-1 and C-2 of Part 98.

Thermal Oxidizers SSM (Unit EP-11)

This accounts for emissions during startup shutdown and maintenance and upset conditions from the thermal oxidizer. VOC and HAPs emissions were calculated from ProMax run 1.4-1 and 1.4-2. HAP and VOC emissions were calculated using streams from ProMax. Greenhouse gas emissions were estimated using methodology from 40 CFR Part 98 and emission factors from Tables C-1 and C-2 of Part 98.

Enclosed Combustion Device (Unit EP-12)

NO_x, CO, and SO₂ emissions were calculated using AP-42 factors for external natural gas combustion sources in Tables 1.4-1 and 1.4-2. HAP and VOC emissions were calculated using streams from ProMax. Greenhouse gas emissions were estimated using methodology from 40 CFR Part 98 and emission factors from Tables C-1 and C-2 of Part 98.

Sour Water Tank Flare (Unit EP-13)

NO_x, CO, and SO₂ emissions were calculated using AP-42 factors for external natural gas combustion sources in Tables 1.4-1 and 1.4-2. HAP and VOC emissions were calculated using streams from ProMax and vapor head gas analysis. Greenhouse gas emissions were estimated using methodology from 40 CFR Part 98 and emission factors from Tables C-1 and C-2 of Part 98.

Condensate Storage Tanks (Unit 3-T)

Unit 3-T represents six connected 500 bbl condensate storage tanks. Uncontrolled emissions are calculated using ProMax. Controlled emissions will be routed to the enclosed combustion device, unit EP-10.

Sour Water Tank (Unit 4-T)

Unit 4-T represents two connected 500 bbl sour slop tanks. Uncontrolled emissions are calculated using ProMax. Controlled emissions will be routed to the sour slop tank control flare, unit EP-9.

Slop Tank (Unit 5-T)

Unit 5-T represents two connected 500 bbl slop tanks. Uncontrolled emissions are calculated using ProMax.

Loading Emissions (Unit 3-Load, 4-Load, and 5-Load)

Emissions from loading of condensate out of the facility by truck were estimated using Equation 1 in AP-42 Section 5.2-4. The requested loading of condensate out of the facility is 3129.6 bbl/day. The flash from loading is captured and routed back to the tanks and the enclosed combustor. Emissions from 4-Load are routed to the sour water tanks. 5-Load trucking operations are vented to the atmosphere. The requested loading of sour slop and slop out of the facility are 87 bbl/day and 242 bbl/day respectively.

MSS Blowdowns (Units 2-EP-1t, 3-EP-1t, 4-EP-1t, 5-EP-1t, 6-EP-1t, 7-EP-1t)

Emissions from blowdown of the residue compressor from train 2, 3, 4, 5, 6 and 7 during maintenance activities are vented to the atmosphere. Each train has 4 electric compressors, each with 470 acf of blowdown volume. To be conservative, these events are assumed to vent for an hour and occur for 8 times/year. For the purpose of simplicity, one blowdown emission point consists of the total volume from the 4 compressors at each train.

Miscellaneous Startup, shutdown and Maintenance (SSM/M)

This accounts for miscellaneous startup, shutdown and maintenance activities at the facility.

Fugitive Emissions (Unit FUG-1)

Fugitive emissions were estimated using emission factors from Table 2-4 of EPA Protocol for Equipment Leak Emission Estimates, November 1995, EPA-453/R-95-017. Component counts were estimated as previously permitted. The percent VOC and HAPs are from the inlet gas analysis dated 8/22/2012. The percent VOC in liquids conservatively assumed to be 100%. The percent H₂S in liquids is zero. The percent of HAPs in the liquids is estimated based on the ratio of VOC and HAP in the previous gas analysis. Total HAPs is the sum of n-Hexane, Benzene, Toluene, Ethylbenzene, and Xylene.

Haul Road Emissions (Unit HAUL-1)

Unpaved haul road emissions were estimated based on Equations 1a and 2 of AP-42 Section 13.2.1 (1/11). Particle size multipliers and constants for these equations are found in AP-42 Table 13.2.2-2, Industrial Roads. Silt content is taken from AP-42 Table 13.2.2-1 and annual wet days is from AP-42 Figure 13.2.2-1. The control efficiency from base course is from the NMED guidance document entitled Department Accepted Values For: Aggregate Handling, Storage Pile, and Haul Road Emissions. The length of the haul road is estimated from Google Earth.

Section 6.a

Green House Gas Emissions

(Submitting under 20.2.70, 20.2.72 20.2.74 NMAC)

Title V (20.2.70 NMAC), Minor NSR (20.2.72 NMAC), and PSD (20.2.74 NMAC) applicants must estimate and report greenhouse gas (GHG) emissions to verify the emission rates reported in the public notice, determine applicability to 40 CFR 60 Subparts, and to evaluate Prevention of Significant Deterioration (PSD) applicability. GHG emissions that are subject to air permit regulations consist of the sum of an aggregate group of these six greenhouse gases: carbon dioxide (CO₂), nitrous oxide (N₂O), methane (CH₄), hydrofluorocarbons (HFCs), perfluorocarbons (PFCs), and sulfur hexafluoride (SF₆).

Calculating GHG Emissions:

1. Calculate the ton per year (tpy) GHG mass emissions and GHG CO₂e emissions from your facility.
2. GHG mass emissions are the sum of the total annual tons of greenhouse gases without adjusting with the global warming potentials (GWPs). GHG CO₂e emissions are the sum of the mass emissions of each individual GHG multiplied by its GWP found in Table A-1 in 40 CFR 98 Mandatory Greenhouse Gas Reporting.
3. Emissions from routine or predictable start up, shut down, and maintenance must be included.
4. Report GHG mass and GHG CO₂e emissions in Table 2-P of this application. Emissions are reported in **short** tons per year and represent each emission unit's Potential to Emit (PTE).
5. All Title V major sources, PSD major sources, and all power plants, whether major or not, must calculate and report GHG mass and CO₂e emissions for each unit in Table 2-P.
6. For minor source facilities that are not power plants, are not Title V, and are not PSD there are three options for reporting GHGs in Table 2-P: 1) report GHGs for each individual piece of equipment; 2) report all GHGs from a group of unit types, for example report all combustion source GHGs as a single unit and all venting GHGs as a second separate unit; 3) or check the following ~ By checking this box, the applicant acknowledges the total CO₂e emissions are less than 75,000 tons per year.

Sources for Calculating GHG Emissions:

- Manufacturer's Data
- AP-42 Compilation of Air Pollutant Emission Factors at <http://www.epa.gov/ttn/chief/ap42/index.html>
- EPA's Internet emission factor database WebFIRE at <http://cfpub.epa.gov/webfire/>
- 40 CFR 98 Mandatory Green House Gas Reporting except that tons should be reported in short tons rather than in metric tons for the purpose of PSD applicability.
- API Compendium of Greenhouse Gas Emissions Methodologies for the Oil and Natural Gas Industry. August 2009 or most recent version.
- Sources listed on EPA's NSR Resources for Estimating GHG Emissions at <http://www.epa.gov/nsr/clean-air-act-permitting-greenhouse-gases>:

Global Warming Potentials (GWP):

Applicants must use the Global Warming Potentials codified in Table A-1 of the most recent version of 40 CFR 98 Mandatory Greenhouse Gas Reporting. The GWP for a particular GHG is the ratio of heat trapped by one unit mass of the GHG to that of one unit mass of CO₂ over a specified time period.

"Greenhouse gas" for the purpose of air permit regulations is defined as the aggregate group of the following six gases: carbon dioxide, nitrous oxide, methane, hydrofluorocarbons, perfluorocarbons, and sulfur hexafluoride. **(20.2.70.7 NMAC, 20.2.74.7 NMAC)**. You may also find GHGs defined in 40 CFR 86.1818-12(a).

Metric to Short Ton Conversion:

Short tons for GHGs and other regulated pollutants are the standard unit of measure for PSD and title V permitting programs. 40 CFR 98 Mandatory Greenhouse Reporting requires metric tons.

1 metric ton = 1.10231 short tons (per Table A-2 to Subpart A of Part 98 – Units of Measure Conversions)

GHG emissions are included in this application, as applicable.

Facility-wide Emissions Summary

Uncontrolled Emissions

Unit	Equipment Description	NO _x		CO		VOC		SO ₂		TSP		PM ₁₀		PM _{2.5}		H ₂ S		Total HAP		Benzene		Toluene		Ethylbenzene		n-Hexane		2,2,4-Trimethylpentane		Styrene		Xylene		CO _{2e}	CH ₄	N ₂ O			
		lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
1-EP-1	Hot Oil Heater	3.46	15.16	2.91	12.73	0.19	0.83	0.02	0.08	0.26	1.15	0.26	1.15	0.26	1.15	0.00	0.00	0.51	2.23	0.03	0.12	0.04	0.16	0.07	0.33	0.05	0.22	0.10	0.44	0.07	0.32	0.05	0.20	18086.14	0.34	0.03			
1-EP-2	Flare (SSM)	0.18	0.78	0.81	3.56	-	-	0.00	0.01	-	-	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	1206.54	8.99	0.00		
1-EP-3	Glycol Dehydrator	-	-	-	-	110.07	482.10	-	-	-	-	-	-	-	-	0.00	0.00	38.84	170.11	17.12	75.00	7.35	32.20	0.34	1.48	12.45	54.51	-	-	-	-	1.58	6.92	0.14	17.16	-	-		
1-EP-4	Amine Vent	-	-	-	-	10.12	44.33	-	-	-	-	-	-	-	-	1.77	7.74	7.25	31.77	5.10	22.33	1.62	7.08	0.07	0.30	0.02	0.10	-	-	-	-	0.45	1.96	73505.69	36.21	-	-		
1.5-EP-1g	10k Stabilizer Heater	0.90	3.96	0.93	4.06	0.09	0.40	0.012	0.054	0.14	0.59	0.14	0.59	0.14	0.59	-	-	0.26	1.14	0.01	0.06	0.02	0.08	0.04	0.17	0.03	0.11	0.05	0.22	0.04	0.16	0.02	0.10	9222.39	0.17	0.02			
4-EP-1g	10k Stabilizer Heater	0.22	0.97	0.37	1.62	0.02	0.11	0.02	0.10	0.03	0.15	0.03	0.15	0.03	0.11	-	-	0.01	0.04	0.00	0.00	0.00	0.00	-	-	-	0.01	0.04	-	-	-	-	-	-	-	-	-		
2-EP-1a	Mol Sieve Heater	0.27	1.20	0.46	2.02	0.03	0.13	0.03	0.12	0.04	0.18	0.04	0.18	0.03	0.14	-	-	0.08	0.35	0.00	0.02	0.01	0.02	0.01	0.05	0.01	0.03	0.02	0.07	0.01	0.05	0.01	0.03	2869.19	0.05	0.01			
2-EP-1b	Cryo HMO Heater	1.16	5.08	1.31	5.75	0.09	0.38	0.12	0.52	0.12	0.52	0.12	0.52	0.13	0.58	-	-	0.23	1.01	0.01	0.05	0.02	0.07	0.03	0.15	0.02	0.10	0.05	0.20	0.03	0.15	0.02	0.09	8172.07	0.15	0.02			
2-EP-1e	Glycol Reboiler	0.29	1.29	0.25	1.08	0.02	0.07	0.00	0.01	0.02	0.10	0.02	0.10	0.02	0.10	-	-	0.04	0.19	0.00	0.01	0.00	0.01	0.01	0.03	0.00	0.02	0.01	0.04	0.01	0.03	0.00	0.02	1537.07	0.03	0.00			
2-EP-2a	Emergency Flare A (inlet)	0.18	0.78	0.81	3.56	-	-	0.00	0.01	-	-	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	1206.54	8.99	0.00	
2-EP-4	Amine Vent	-	-	-	-	66.22	290.07	-	-	-	-	-	-	-	-	5.26	23.03	46.29	202.75	31.23	136.79	11.07	48.49	0.49	2.13	0.22	0.96	-	-	-	-	3.28	14.38	220136.43	193.32	-	-		
2-EP-1h	Amine Reboiler	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	0.79	3.47	0.04	0.18	0.06	0.24	0.12	0.51	0.08	0.34	0.16	0.68	0.11	0.50	0.07	0.32	28179.54	0.53	0.05			
2a-EP-1d	Amine Reboiler	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	0.79	3.47	0.04	0.18	0.06	0.24	0.12	0.51	0.08	0.34	0.16	0.68	0.11	0.50	0.07	0.32	28179.54	0.53	0.05			
2a-EP-3	Glycol Dehydrator	-	-	-	-	109.47	479.49	-	-	-	-	-	-	-	-	-	0.00	0.00	39.79	174.28	17.98	78.74	8.01	35.10	0.37	1.61	4.19	18.37	-	-	1.66	7.25	0.29	18.37	-	-			
2.5-EP-4	Amine Vent	-	-	-	-	10.65	46.66	-	-	-	-	-	-	-	-	-	-	612.94	2684.68	0.26	1.16	-	-	-	-	-	-	-	-	-	-	-	-	-	-	13027.29	66.01	-	
2.5-EP-1d	Amine Reboiler	2.45	10.74	2.06	9.02	0.13	0.59	0.01	0.06	0.19	0.82	0.19	0.82	0.19	0.82	-	-	0.29	1.26	0.01	0.07	0.02	0.09	0.04	0.19	0.03	0.12	0.06	0.25	0.04	0.18	0.03	0.12	10247.10	0.19	0.02			
2.5-EP-5	Emergency AGI Flare	15.91	1.20	72.54	5.48	-	-	1.59	0.12	-	-	-	-	-	-	0.00	0.00	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	1846.52	13.65	0.00			
3-EP-1a	Mol Sieve Heater	0.36	1.57	0.46	2.02	0.03	0.13	0.04	0.16	0.04	0.18	0.04	0.18	0.04	0.18	-	-	0.08	0.35	0.00	0.02	0.01	0.02	0.01	0.05	0.01	0.03	0.02	0.07	0.01	0.05	0.01	0.03	2869.19	0.05	0.01			
3-EP-1b	Cryo HMO Heater	0.86	3.77	1.31	5.75	0.09	0.38	0.09	0.38	0.12	0.52	0.12	0.52	0.10	0.43	-	-	0.23	1.01	0.01	0.05	0.02	0.07	0.03	0.15	0.02	0.10	0.05	0.20	0.03	0.15	0.02	0.09	8172.07	0.15	0.02			
3-EP-1d	Amine Reboiler	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	0.79	3.47	0.04	0.18	0.06	0.24	0.12	0.51	0.08	0.34	0.16	0.68	0.11	0.50	0.07	0.32	28179.54	0.53	0.05			
3-EP-1e	Glycol Reboiler	0.29	1.29	0.25	1.08	0.02	0.07	0.00	0.01	0.02	0.10	0.02	0.10	0.02	0.10	-	-	0.04	0.19	0.00	0.01	0.00	0.01	0.01	0.03	0.00	0.02	0.01	0.04	0.01	0.03	0.00	0.02	1537.07	0.03	0.00			
3-EP-1h	Amine Reboiler	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	0.79	3.47	0.04	0.18	0.06	0.24	0.12	0.51	0.08	0.34	0.16	0.68	0.11	0.50	0.07	0.32	28179.54	0.53	0.05			
3-EP-2a	Flare (SSM)	0.18	0.78	0.81	3.56	-	-	0.00	0.01	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	1206.54	8.99	0.00
3-EP-3	Glycol Dehydrator	-	-	-	-	109.41	479.20	-	-	-	-	-	-	-	-	-	0.00	0.00	39.50	173.03	17.69	77.49	7.94	34.78	0.37	1.62	11.85	51.89	-	-	-	-	1.65	7.23	0.00	18.37	-	-	
3-EP-4	Amine Vent	-	-	-	-	72.35	316.90	-	-	-	-	-	-	-	-	5.03	22.04	51.28	224.63	34.23	149.91	12.44	54.49	0.55	2.40	0.24	1.05	-	-	-	-	3.83	16.77	210715.39	199.46	-	-		
4-EP-1a	Mol Sieve Heater	0.36	1.57	0.46	2.02	0.03	0.13	0.04	0.16	0.04	0.18	0.04	0.18	0.04	0.18	-	-	0.08	0.35	0.00	0.02	0.01	0.02	0.01	0.05	0.01	0.03	0.02	0.07	0.01	0.05	0.01	0.03	2869.19	0.05	0.01			
4-EP-1b	Cryo HMO Heater	0.86	3.77	1.31	5.75	0.09	0.38	0.09	0.38	0.12	0.52	0.12	0.52	0.10	0.43	-	-	0.23	1.01	0.01	0.05	0.02	0.07	0.03	0.15	0.02	0.10	0.05	0.20	0.03	0.15	0.02	0.09	8172.07	0.15	0.02			
4-EP-2a	Flare (SSM)	0.18	0.78	0.81	3.56	-	-	0.00	0.01	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	1206.54	8.99	0.00	
EP-5	Thermal Oxidizer	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
EP-6	Thermal Oxidizer	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
EP-7	Enclosed Combustion Device	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
EP-8	Thermal Oxidizer	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
EP-9	Sour Slop Tank Control Flare	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
No emissions from these units in an uncontrolled scenario.																																							
1-T	Condensate Storage Tank	-	-	-	-	-	46.00	-	-	-	-	-	-	-	-	-	-	0.38	0.26	0.05	0.00	0.00	0.00	0.00	0.00	0.06	0.01	-	-	-	-	-	-	-	-				
2-T	H2S Sour Slop Tank	-	-	-	-	-	529.80	-	-	-	-	-	-	-	-	-	-	0.26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-	-	-	-	-	-	0.09	-	-			
1-Load	Loading Emissions	-	-	-	-	-	129.2																																

Controlled Emissions

Unit	Equipment Description	NO _x		CO		VOC		SO ₂		TSP		PM ₁₀		PM _{2.5}		H ₂ S		Total HAP		Benzene		Toluene		Ethylbenzene		n-Hexane		2,2,4-Trimethylpentane		Styrene		Xylene		CO _{2e}	CH ₄	N ₂ O	
		lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr	lb/hr	ton/yr
1-EP-1	Hot Oil Heater	3.46	15.16	2.91	12.73	0.19	0.83	0.02	0.08	0.26	1.15	0.26	1.15	0.26	1.15	-	-	0.51	2.23	0.03	0.12	0.04	0.16	0.07	0.33	0.05	0.22	0.10	0.44	0.07	0.32	0.05	0.20	18086.14	0.34	0.03	
1-EP-2	Flare (SSM)	256.23	2.32	1168.11	10.57	859.82	5.16	6.21	0.04	-	-	-	-	-	-	-	0.007	0.0005	46.23	0.28	3.08	0.02	1.60	0.01	0.16	0.00	40.61	0.24	-	-	-	0.77	0.00	2770.62	10.88	0.00	
1-EP-3	Glycol Dehydrator	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
1-EP-4	Amine Vent	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Emissions from 1-EP-3 are controlled by the thermal oxidizer, unit EP-5. Controlled emissions are represented under unit EP-5.																				Emissions from 1-EP-4 are controlled by the thermal oxidizer, unit EP-5. Controlled emissions are represented under unit EP-5.																	
1.5-EP-1g	10k Stabilizer Heater	0.90	3.96	0.93	4.06	0.09	0.40	0.012	0.054	0.136	0.59	0.136	0.59	0.136	0.59	-	-	0.26	1.14	0.01	0.06	0.02	0.08	0.04	0.17	0.03	0.11	0.05	0.22	0.04	0.16	0.02	0.10	9222.39	0.17	0.02	
4-EP-1g	10k Stabilizer Heater	0.22	0.97	0.37	1.62	0.02	0.11	0.022	0.098	0.03	0.15	0.034	0.15	0.03	0.11	-	-	0.0088	0.039	0.0000	0.0000	0.0000	0.0001	-	-	0.0088	0.0385	-	-	-	-	-	-	-	-	-	
2-EP-1a	Mol Sieve Heater	0.27	1.20	0.46	2.02	0.03	0.13	0.03	0.12	0.04	0.18	0.042	0.18	0.031	0.14	-	-	0.08	0.35	0.00	0.02	0.01	0.02	0.01	0.05	0.01	0.03	0.02	0.07	0.01	0.05	0.01	0.03	2869.19	0.05	0.01	
2-EP-1b	Cryo HMO Heater	1.16	5.08	1.31	5.75	0.09	0.38	0.12	0.52	0.12	0.52	0.176	0.77	0.13	0.58	-	-	0.23	1.01	0.01	0.05	0.02	0.07	0.03	0.15	0.02	0.10	0.05	0.20	0.03	0.15	0.02	0.09	8172.07	0.15	0.02	
2-EP-1e	Glycol Reboiler	0.29	1.29	0.25	1.08	0.02	0.07	0.002	0.01	0.02	0.10	0.022	0.10	0.02	0.10	-	-	0.04	0.19	0.00	0.01	0.00	0.01	0.01	0.03	0.00	0.02	0.01	0.04	0.01	0.03	0.00	0.02	1537.07	0.03	0.00	
2-EP-2a	Flare (SSM)	682.98	4.88	3113.60	22.24	2292.86	13.76	16.57	0.11	-	-	-	-	-	-	-	0.18	0.00	123.27	0.74	8.25	0.05	4.26	0.03	0.42	0.00	108.29	0.65	-	-	-	-	2.06	0.01	7388.33	29.01	0.01
2-EP-4	Amine Vent	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2-EP-1h	Amine Reboiler	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	0.79	3.47	0.04	0.18	0.06	0.24	0.12	0.51	0.08	0.34	0.16	0.68	0.11	0.50	0.07	0.32	28179.54	0.53	0.05	
2a-EP-1d	Amine Reboiler	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	0.79	3.47	0.04	0.18	0.06	0.24	0.12	0.51	0.08	0.34	0.16	0.68	0.11	0.50	0.07	0.32	28179.54	0.53	0.05	
2a-EP-3	Glycol Dehydrator	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2.5-EP-4	Amine Vent	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2.5-EP-4	Amine Reboiler	2.45	10.74	2.06	9.02	0.13	0.59	0.01	0.06	0.19	0.82	0.19	0.82	0.19	0.82	-	-	0.29	1.26	0.01	0.07	0.02	0.09	0.04	0.19	0.03	0.12	0.06	0.25	0.04	0.18	0.03	0.12	10247.10	0.19	0.02	
2.5-EP-5	Emergency AGI Flare	16.28	1.22	74.21	5.58	0.21	0.01	1155.37	74.52	-	-	-	-	-	-	-	12.26	0.79	0.01	0.0003	-	-	-	-	-	-	-	-	-	-	-	-	-	-	19331.88	1.89	0.00
Emissions from unit 2.5-EP-4 are controlled by the Acid Gas Injection Well (AGI). During AGI compressor downtime the controlled emissions are represented under the Emergency AGI Flare, unit 2.5-EP-5.																				Emissions from 2a-EP-3 are controlled by unit EP-5. Controlled emissions are represented under unit EP-5.																	
3-EP-1a	Mol Sieve Heater	0.36	1.57	0.46	2.02	0.03	0.13	0.036	0.16	0.04	0.18	0.05	0.24	0.04	0.18	-	-	0.08	0.35	0.00	0.02	0.01	0.02	0.01	0.05	0.01	0.03	0.02	0.07	0.01	0.05	0.01	0.03	2869.19	0.05	0.01	
3-EP-1b	Cryo HMO Heater	0.86	3.77	1.31	5.75	0.09	0.38	0.087	0.38	0.12	0.52	0.13	0.57	0.10	0.43	-	-	0.23	1.01	0.01	0.05	0.02	0.07	0.03	0.15	0.02	0.10	0.05	0.20	0.03	0.15	0.02	0.09	8172.07	0.15	0.02	
3-EP-1d	Amine Reboiler	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	0.79	3.47	0.04	0.18	0.06	0.24	0.12	0.51	0.08	0.34	0.16	0.68	0.11	0.50	0.07	0.32	28179.54	0.53	0.05	
3-EP-1e	Glycol Reboiler	0.29	1.29	0.25	1.08	0.02	0.07	0.002	0.01	0.02	0.10	0.02	0.10	0.02	0.10	-	-	0.04	0.19	0.00	0.01	0.00	0.01	0.01	0.03	0.00	0.02	0.01	0.04	0.01	0.03	0.00	0.02	1537.07	0.03	0.00	
3-EP-1h	Amine Reboiler	1.02	4.46	2.07	9.05	0.30	1.30	0.03	0.13	0.41	1.79	0.41	1.79	0.41	1.79	-	-	0.79	3.47	0.04	0.18	0.06	0.24	0.12	0.51	0.08	0.34	0.16	0.68	0.11	0.50	0.07	0.32	28179.54	0.53	0.05	
3-EP-2a	Flare (SSM)	682.98	4.88	3113.60	22.24	2292.86	13.76	16.57	0.11	-	-	-	-	-	-	-	0.18	0.00	123.27	0.74	8.25	0.05	4.26	0.03	0.42	0.00	108.29	0.65	-	-	-	-	2.06	0.01	7388.33	29.01	0.01
3-EP-3	Glycol Dehydrator	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-		
3-EP-4	Amine Vent	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
Emissions from units 3-EP-3 and 3-EP-4 are routed to the thermal oxidizer unit EP-6. Controlled emissions are represented under unit EP-6.																				Emissions from units 3-EP-3 and 3-EP-4 are routed to the thermal oxidizer unit EP-6. Controlled emissions are represented under unit EP-6.																	
4-EP-1a	Mol Sieve Heater	0.36	1.57	0.46	2.02	0.03	0.13	0.036	0.16	0.04	0.18	0.05	0.24	0.04	0.18	-	-	0.08	0.35	0.00	0.02	0.01	0.02	0.01	0.05	0.01	0.03	0.02	0.07	0.01	0.05	0.01	0.03	2869.19	0.05	0.01	
4-EP-1b	Cryo HMO Heater	0.86	3.77	1.31	5.75	0.09	0.38	0.087	0.38	0.12	0.52	0.13	0.57	0.10	0.43	-	-	0.23	1.01	0.01	0.05	0.02	0.07	0.03	0.15	0.02	0.10	0.05	0.20	0.03	0.15	0.02	0.09	8172.07	0.15	0.02	
4-EP-2a	Flare (SSM)	682.98	4.88	3113.60	22.24	2292.86	13.76	16.57	0.11	-	-	-	-	-	-	-	0.18	0.00	123.27	0.74	8.25	0.05	4.26	0.03	0.42	0.00	108.29	0.65	-	-	-	-	2.06	0.01	7388.33	29.01	0.01
EP-5	Thermal Oxidizer	5.50	24.09	3.50	15.33	5.92	25.92	13.22	57.91	0.21	0.91	0.21	0.91	0.21	0.91	0.14	0.62	2.64	11.58	1.43	6.26	0.56	2.46	0.03	0.11	0.34	1.48	-	-	-	-	0.14	0.61	14345.95	0.27	0.03	
EP-6	Thermal Oxidizer	5.50	24.09	3.50	15.33	5.92	25.92	13.22	57.91	0.21	0.91	0.21	0.91	0.21	0.91	0.10	0.44	1.82	7.95	1.04	4.55	0.41	1.79	0.02	0.08	0.24	1.06	-	-	-	-	0.11	0.48	14345.95	0.27	0.03	
EP-7	Enclosed Combustion Device	0.59	2.58	0.49	2.16	0.80	3.50	0.40	1.64	0.04	0.20	0.04	0.20	0.04	0.20	-	-	0.01	0.03	0.00	0.02	0.00	0.00	0.00	0.00	0.00	-	-	-	-	0.00	0.00	796.69	0.02	0.00		
EP-9	Sour Slop Tank Control Flare	0.36	1.57	0.46	2.02	0.03	0.13	0.036	0.16	0.04	0.18	0.05	0.24	0.04	0.18	-	-	0.08	0.35	0.00	0.02	0.01	0.02	0.01	0.05	0.01	0.03	0.02	0.07	0.01	0.05	0.01	0.03	2869.19	0.05	0.01	
1-T	Condensate Storage Tank	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
2-T	H2S Sour Slop Tank	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	-	
1-Load	Loading Emissions	-	-	-	-																																



Oil and Gas Emissions Spreadsheet

Revised 10/2/2014

General Notes

***** Before beginning, make sure to enable macros, so that this spreadsheet will run properly. ***** See the links below for more information on creating a trusted location and enabling macros for this spreadsheet.

[Enable Macro Link](#)

[Trusted Location Link](#)

See comments in individual cells and other written notes. Cells with red corners contain comments; place cursor anywhere in a cell which has a red corner, to view comment. These were added to guide you through using this spreadsheet and make it as easy as possible to use.

This spreadsheet should be used as follows: (1) Enter information into this Facility Information spreadsheet tab, (2) after running the macro (which is explained below), fill out the emission calculation tabs, (3) populate the Emissions Summary table (you press a button on the Emissions Summary tab and the macro will populate the table with the values from the emission calculation tabs), and (4) go through the impacts review tabs (if applicable). This basically means estimate what each of the individual source emissions are, then summarize them in a table, then evaluate the impact of the emissions (if impacts review is applicable).

If you want to use any of the impacts review tabs, you will need to have answered "Yes" to the initial question of "Are you using this to meet the new Barnett Shale area rule requirements?". You can press the "Reset" button at the bottom of this tab to have the question pop up again.

Yellow cells require information to be entered. Red cells contain calculated values.

Worst case emissions must be estimated on both an hourly and annual basis for air permitting purposes.

Hourly emissions must be based on worst case maximum parameters realistically expected to occur over the course of any one hour. As an example, where ambient temperature is used as a parameter to estimate hourly emissions, the maximum temperature from the hottest day of the year must be used.

Annual emissions can be based on average parameters. As an example, where ambient temperature is used as a parameter to estimate annual emissions, the average ambient temperature may be used.

Planned Maintenance, Start-up, and Shutdown (MSS): As of January 5, 2014, all planned emissions from oil and gas facilities must be authorized. This includes planned MSS emissions.

Planned MSS emissions may be authorized under 30 TAC § 106.359, 30 TAC § 106.352(a)-(k), or the non-rule standard permit if:

1. the emissions are the direct result of a planned maintenance activity, or
2. the root cause of the emissions is from a planned maintenance activity.

Oil and Gas Site General Information	
Administrative Information	
Company Name	Lucid Energy Delaware, LLC
Facility/Well Name	Red Hills Gas Processing Plant
Field Name	
Nearest City/Town	Jal
API Number/SIC Code	
Latitude/Longitude	
County	Lea
Are you using a Form PI-7, PI-7-CERT, APD-CERT, PI-7 and APD-CERT, or are you using ePermits?	
Customer Number, CNxxxxxxxx (if known)	
Regulated Entity Number, RNxxxxxxxx (if known)	
Technical Information	
Natural Gas Site Throughput (MMSCF/day):	494.588
Oil/Condensate Site Throughput (bbl/day):	3129.6
Produced Water Site Throughput (bbl/day):	87
Are there any sour gas streams at this site?	Yes
Is this site currently operational/producing?	Yes
What is the date of the site start of construction or the date that the project changes were implemented (whichever is applicable to this project, anticipated date if in the future)?	
Has this site been registered before?	Yes

<u>Equipment/Processes at Site</u>		
Before entering any numbers into the Equipment/Processes section of the table below, please make sure to review all of the comments in the cells of the table. These should make it clear what numbers need to be entered and where they need to be entered.		
<u>Equipment/Process Types</u>	<u>How many for this project?</u>	<u>How many for this site?</u>
Fugitives	5	5
IC Engines	0	0
Turbines	0	0
Diesel Engines	0	0
Heaters-Boilers	14	14
Oil / Condensate Tanks	12	12
Produced Water Tanks	4	4
Miscellaneous Tanks	6	6
Loading Jobs	4	4
Glycol Units	2	2
Amine Units	2	2
Vapor Recovery Units	0	0
Flares-Vapor Combustors	6	6
Thermal Oxidizers	3	3
MSS Blowdowns	8	8
MSS FLR Tank Landing Loss	0	0
MSS Tank Non Forced Vent	0	0
MSS Tank Forced Vent Degas	0	0
MSS Defaults	1	1
MSS Paint Blast	0	0
MSS Other	0	0
Other	0	0

When you are finished entering information on this tab, press the "Run" button below. When it is pressed, the spreadsheet tabs needed will be added and the "Emissions Summary" tab will also be added with the number of rows corresponding to the number of emission points in this registration.

Before pressing "Run", please make sure to review all of the comments in the cells of the table above. These should make it clear what numbers need to be entered and where they need to be entered.

The spreadsheet can be reset if needed by pressing the "Reset" button below. If the "Reset" button is pressed, everything will be cleared and you can start over (the added sheets will disappear along with any data entered into the sheets). When the "Reset" button is pressed and there is anything to clear, a question will pop up asking "Delete all macro created worksheets?". Then if you click "Yes", the question will pop back up asking "Are you using this to meet the new Barnett Shale area requirements?".

If the "Run" button is pressed a second time, everything will be cleared and you can start over (the added sheets will disappear along with any data entered into the sheets). When the "Run" button is pressed a second time, a question will pop up asking "Delete all macro created worksheets?". The question will not pop back up asking "Are you using this to meet the new Barnett Shale area requirements?".

Do not press "Run" again or "Reset", unless you intend to clear all of the added sheets (and any data entered into the sheets). This means that it is important to make sure the right numbers of each equipment/process type are entered. If it is possible that an extra piece of equipment could be included, include it because it is better to have too many entered than not enough.

Run

Reset

Next Tab

Gas and Liquid Analyses

A) Enter information into the yellow boxes.

B) The purpose of this tab is to extract information from a lab analysis that will be used in emission calculations. Unlike the other other tabs which calculate emissions, nothing from this tab gets pulled to the Emissions Summary table. The big pieces of information needed for emissions estimates are the VOC, benzene, and H₂S weight percents. Sampling of gas and liquid streams from appropriate process sampling points is required in order to determine composition or other properties needed to estimate emissions such as heat content, specific gravity, and vapor pressure. It is essential that stream lab analyses/reports include a measurement of H₂S, individual HAPs, and at least all those hydrocarbons up to at least 10 carbon atoms per molecule (C10+).

C) There are two boxes on the left, for gas and liquid analyses, which take component weight percent inputs and there are two boxes on the right, for gas and liquid analyses, which take component mole percent inputs. You can either fill out the weight percent box OR the mole percent box, depending on what informaton you have available to you.

The boxes are set up in the following arrangement:

Gas Analysis Wt% Inputs	Gas Analysis Mol% Inputs
Liquid Analysis Wt% Inputs	Liquid Analysis Mol% Inputs

D) If weight percents are provided on the lab report, use the boxes on the left. If only mole percents are provided on the lab report, use the boxes on the right.

E) Make sure to select whether you are inputting weight percents or mole percents from the pull down menus below.

F) If you are using the weight percent boxes (left two), in addition to the component weight percents, you need to enter the gas molecular weight (molecular weight of the total sample) and the gas and liquid H₂S content in parts per million by volume (H₂S ppmv). This will allow for the calculation of the gas specific gravity and the long tons of sulfur per day in the gas, and the determination of sweet versus sour gas.

G) If you are using the mole percent boxes (right two), in addition to the component mole percents, you need to enter a real value, specific to this sample, for the molecular weight of the deacnes plus (C10+) fraction. You may use the default values listed below for the moleclar weights of the other hexanes (C6), other heptanes (C7), other ocatnes (C8), and nonanes (C9) fractions, unless you have a more accurate number. If you enter number other than the default, you need to explain where the number came from and why it is appropriate to use.

H) What is expected to be included on these tables is the the inlet gas and liquid streams (the liquid would most likely be sampled from a separator if there is separation at the site). These tables can also be used for any sampled gas and liquid streams as needed. If needed, make a copy of this tab.

I) Use the box provided below for entering any notes necessary.

For the gas sample, I am inputting (pick from list):

mole percents

Select whether weight percents or mole percents are being entered for this gas sample.

Then fill out this table **OR** fill out this table.

Gas Analysis - Use if the Inputs are Weight Percents	
Analysis Identifier/Name	
What site is the sample from?	
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).	
Where in the process was the sample taken?	
What is the temperature and pressure of the sample (include units)?	
Who analyzed the sample?	
Date of sample:	
Component	weight %
hydrogen	
helium	
nitrogen	
CO2	
H2S	
methane (C1)	
ethane (C2)	
propane (C3)	
butanes (C4)	
pentanes (C5)	
benzene	
other hexanes (C6)	
toluene	
other heptanes (C7)	
ethylbenzene	
xylenes (o, m, p)	
other octanes (C8)	
nonanes (C9)	
decans plus (C10+)	
Totals:	0.0000
VOC (Non-methane, Non-ethane hydrocarbons)	
VOC content of total sample	
VOC weight% =	0.0000
VOC weight fraction =	0.0000
VOC content of hydrocarbon fraction only	
VOC weight% =	#DIV/0!
VOC weight fraction =	#DIV/0!
Hydrogen Sulfide	
H2S weight% =	0.0000
H2S weight fraction =	0.00E+00
H2S ppm _v =	0.00
H2S ppm _{wT} =	0.00
H ₂ S grains/100 SCF =	0.0000
SWEET GAS	
Constants:	
	453.59237 mol/lb-mol
	0.06479891 grams/grain
	385.48 scf/lb-mol
	34.08188 g/mol, lb/lb-mol
	H2S mw
Benzene	
Benzene content of total sample	
Benzene weight% =	0.0000
Benzene weight fraction =	0.0000
Benzene content of hydrocarbon fraction only	
Benzene weight% =	#DIV/0!
Benzene weight fraction =	#DIV/0!
Constants:	
Gas Molecular Weight =	28.97 air mw
Gas Specific Gravity =	0.00
	385.48 scf/lb-mol
Gas Throughput (MMscf/day)=	494.588
Long Tons Sulfur Compounds per Day =	0

Gas Analysis - Use if the Inputs are Mole Percents				
Analysis Identifier/Name	Inlet Gas			
Where was the sample taken?	Amine inlet			
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).	Site Specific, ProMax			
Where in the process was the sample taken?	Inlet at the Amine process			
What is the temperature and pressure of the sample (include units)?	70 F @ 914.696 psia			
Who analyzed the sample?	ProMax			
Date of sample:	6/17/2019			
Component	mole %	Molecular Weight (grams/mole, lb/lb-mol)	grams per 100 moles of gas	weight %
hydrogen	0.0000	2.01588	0	0.0000
helium	0.0000	4.0026	0	0.0000
nitrogen	2.1268	28.01340	60	2.6186
CO2	5.6291	44.00950	248	10.8883
H2S	0.0002	34.08188	0	0.0003
methane (C1)	72.0489	16.04246	1156	50.8010
ethane (C2)	10.8894	30.06904	327	14.3912
propane (C3)	5.7037	44.09562	252	11.0541
butanes (C4)	2.3766	58.12220	138	6.0711
pentanes (C5)	0.7628	72.14878	55	2.4190
benzene	0.0142	78.110000	1	0.0488
other hexanes (C6)	0.4215	86.18000	36	1.5966
toluene	0.0043	92.140000	0	0.0174
other heptanes (C7)	0.0114	100.20000	1	0.0501
ethylbenzene	0.0002	106.170000	0	0.0011
xylenes (o, m, p)	0.0011	106.170000	0	0.0052
other octanes (C8)	0.0046	114.23000	1	0.0231
nonanes (C9)	0.0021	128.26000	0	0.0118
decans plus (C10+)	0.0030	18.01528	0	0.0024
Totals:	99.9999	22.75	2275	100.00
VOC (Non-methane, Non-ethane hydrocarbons)				
VOC content of total sample				
VOC weight% =	21.3005			
VOC weight fraction =	0.2130			
VOC content of hydrocarbon fraction only				
VOC weight% =	24.6270			
VOC weight fraction =	0.2463			
Hydrogen Sulfide				
H2S weight% =	0.0003			
H2S weight fraction =	3.00E-06			
H2S ppm _v =	2			
H2S ppm _{wT} =	3.00			
H ₂ S grains/100 SCF =	0.1238			
SWEET GAS				
Constants:				
	453.59237 mol/lb-mol			
	0.06479891 grams/grain			
	385.48 scf/lb-mol			
	34.08188 g/mol, lb/lb-mol			
	H2S mw			
Benzene				
Benzene content of total sample				
Benzene weight% =	0.0488			
Benzene weight fraction =	0.0005			
Benzene content of hydrocarbon fraction only				
Benzene weight% =	0.0564			
Benzene weight fraction =	0.0006			
Constants:				
Gas Molecular Weight =	22.75			
Gas Specific Gravity =	0.79			
	28.97 air mw			
	385.48 scf/lb-mol			
Gas Throughput (MMscf/day)=	494.588			
Long Tons Sulfur Compounds per Day =	0.0390431			

For the liquid sample, I am inputting (pick from list):

Select whether weight percents or mole percents are being entered for this liquid sample.

Then fill out this table **OR** fill out this table.

Liquid Analysis - Use if the Inputs are <u>Weight</u> Percents	
Analysis Identifier/Name	
What site is the sample from?	
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).	
Where in the process was the sample taken?	
What is the temperature and pressure of the sample (include units)?	
Who analyzed the sample?	
Date of sample:	
Component	weight %
hydrogen	
helium	
nitrogen	
CO2	
H2S	
methane (C1)	
ethane (C2)	
propane (C3)	
butanes (C4)	
pentanes (C5)	
benzene	
other hexanes (C6)	
toluene	
other heptanes (C7)	
ethylbenzene	
xylenes (o, m, p)	
other octanes (C8)	
nonanes (C9)	
decans plus (C10+)	
Totals:	0.0000
VOC (Non-methane, Non-ethane hydrocarbons)	
VOC content of total sample	
VOC weight% =	0.0000
VOC weight fraction =	0.0000
VOC content of hydrocarbon fraction only	
VOC weight% =	#DIV/0!
VOC weight fraction =	#DIV/0!
Hydrogen Sulfide	
H2S weight% =	0.0000
H2S weight fraction =	0.00E+00
H2S ppm _v =	
H2S ppm _{wT} =	0.00
Benzene	
Benzene content of total sample	
Benzene weight% =	0.0000
Benzene weight fraction =	0.0000
Benzene content of hydrocarbon fraction only	
Benzene weight% =	#DIV/0!
Benzene weight fraction =	#DIV/0!

Liquid Analysis - Use if the Inputs are <u>Mole</u> Percents				
Analysis Identifier/Name				
What site is the sample from?				
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).				
Where in the process was the sample taken?				
What is the temperature and pressure of the sample (include units)?				
Who analyzed the sample?				
Date of sample:				
Component	mole %	Molecular Weight (grams/mole, lb/lb-mol)	grams per 100 moles of gas	weight %
hydrogen		2.01588	0	#DIV/0!
helium		4.0026	0	#DIV/0!
nitrogen		28.01340	0	#DIV/0!
CO2		44.00950	0	#DIV/0!
H2S		34.08188	0	#DIV/0!
methane (C1)		16.04246	0	#DIV/0!
ethane (C2)		30.06904	0	#DIV/0!
propane (C3)		44.09562	0	#DIV/0!
butanes (C4)		58.12220	0	#DIV/0!
pentanes (C5)		72.14878	0	#DIV/0!
benzene		78.110000	0	#DIV/0!
other hexanes (C6)		86.18000	0	#DIV/0!
toluene		92.140000	0	#DIV/0!
other heptanes (C7)		100.20000	0	#DIV/0!
ethylbenzene		106.170000	0	#DIV/0!
xylenes (o, m, p)		106.170000	0	#DIV/0!
other octanes (C8)		114.23000	0	#DIV/0!
nonanes (C9)		128.26000	0	#DIV/0!
decans plus (C10+)			0	#DIV/0!
Totals:	0.0000		0.00	0
VOC (Non-methane, Non-ethane hydrocarbons)				
VOC content of total sample				
VOC weight% =	#DIV/0!			
VOC weight fraction =	#DIV/0!			
VOC content of hydrocarbon fraction only				
VOC weight% =	#DIV/0!			
VOC weight fraction =	#DIV/0!			
Hydrogen Sulfide				
H2S weight% =	#DIV/0!			
H2S weight fraction =	#DIV/0!			
H2S ppm _v =	0.00			
H2S ppm _{wT} =	#DIV/0!			
Benzene				
Benzene content of total sample				
Benzene weight% =	#DIV/0!			
Benzene weight fraction =	#DIV/0!			
Benzene content of hydrocarbon fraction only				
Benzene weight% =	#DIV/0!			
Benzene weight fraction =	#DIV/0!			

Enter any notes here:	
-----------------------	--

Gas and Liquid Analyses

A) Enter information into the yellow boxes.

B) The purpose of this tab is to extract information from a lab analysis that will be used in emission calculations. Unlike the other other tabs which calculate emissions, nothing from this tab gets pulled to the Emissions Summary table. The big pieces of information needed for emissions estimates are the VOC, benzene, and H₂S weight percents. Sampling of gas and liquid streams from appropriate process sampling points is required in order to determine composition or other properties needed to estimate emissions such as heat content, specific gravity, and vapor pressure. It is essential that stream lab analyses/reports include a measurement of H₂S, individual HAPs, and at least all those hydrocarbons up to at least 10 carbon atoms per molecule (C10+).

C) There are two boxes on the left, for gas and liquid analyses, which take component weight percent inputs and there are two boxes on the right, for gas and liquid analyses, which take component mole percent inputs. You can either fill out the weight percent box OR the mole percent box, depending on what informaton you have available to you.

The boxes are set up in the following arrangement:

Gas Analysis Wt% Inputs	Gas Analysis Mol% Inputs
Liquid Analysis Wt% Inputs	Liquid Analysis Mol% Inputs

D) If weight percents are provided on the lab report, use the boxes on the left. If only mole percents are provided on the lab report, use the boxes on the right.

E) Make sure to select whether you are inputting weight percents or mole percents from the pull down menus below.

F) If you are using the weight percent boxes (left two), in addition to the component weight percents, you need to enter the gas molecular weight (molecular weight of the total sample) and the gas and liquid H₂S content in parts per million by volume (H₂S ppmv). This will allow for the calculation of the gas specific gravity and the long tons of sulfur per day in the gas, and the determination of sweet versus sour gas.

G) If you are using the mole percent boxes (right two), in addition to the component mole percents, you need to enter a real value, specific to this sample, for the molecular weight of the deacnes plus (C10+) fraction. You may use the default values listed below for the moleclar weights of the other hexanes (C6), other heptanes (C7), other ocatnes (C8), and nonanes (C9) fractions, unless you have a more accurate number. If you enter number other than the default, you need to explain where the number came from and why it is appropriate to use.

H) What is expected to be included on these tables is the the inlet gas and liquid streams (the liquid would most likely be sampled from a separator if there is separation at the site). These tables can also be used for any sampled gas and liquid streams as needed. If needed, make a copy of this tab.

I) Use the box provided below for entering any notes necessary.

For the gas sample, I am inputting (pick from list):

mole percents

Select whether weight percents or mole percents are being entered for this gas sample.

Then fill out this table **OR** fill out this table.

Gas Analysis - Use if the Inputs are Weight Percents	
Analysis Identifier/Name	
What site is the sample from?	
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).	
Where in the process was the sample taken?	
What is the temperature and pressure of the sample (include units)?	
Who analyzed the sample?	
Date of sample:	
Component	weight %
hydrogen	
helium	
nitrogen	
CO2	
H2S	
methane (C1)	
ethane (C2)	
propane (C3)	
butanes (C4)	
pentanes (C5)	
benzene	
other hexanes (C6)	
toluene	
other heptanes (C7)	
ethylbenzene	
xylenes (o, m, p)	
other octanes (C8)	
nonanes (C9)	
decenes plus (C10+)	
Totals:	0.0000
VOC (Non-methane, Non-ethane hydrocarbons)	
VOC content of total sample	
VOC weight% =	0.0000
VOC weight fraction =	0.0000
VOC content of hydrocarbon fraction only	
VOC weight% =	#DIV/0!
VOC weight fraction =	#DIV/0!
Hydrogen Sulfide	
H2S weight% =	0.0000
H2S weight fraction =	0.00E+00
H2S ppm _v =	
H2S ppm _{wT} =	0.00
H ₂ S grains/100 SCF =	0.0000
SWEET GAS	
Constants:	
	453.59237 mol/lb-mol
	0.06479891 grams/grain
	385.48 scf/lb-mol
	34.08188 g/mol, lb/lb-mol
	H2S mw
Benzene	
Benzene content of total sample	
Benzene weight% =	0.0000
Benzene weight fraction =	0.0000
Benzene content of hydrocarbon fraction only	
Benzene weight% =	#DIV/0!
Benzene weight fraction =	#DIV/0!
Constants:	
Gas Molecular Weight =	28.97 air mw
Gas Specific Gravity =	0.00
	385.48 scf/lb-mol
Gas Throughput (MMscf/day) =	494.588
Long Tons Sulfur Compounds per Day =	0

Gas Analysis - Use if the Inputs are Mole Percents				
Analysis Identifier/Name	Fuel Gas			
Where was the sample taken?				
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).	Site Specific			
Where in the process was the sample taken?				
What is the temperature and pressure of the sample (include units)?				
Who analyzed the sample?				
Date of sample:				
Component	mole %	Molecular Weight (grams/mole, lb/lb-mol)	grams per 100 moles of gas	weight %
hydrogen	0.0000	2.01588	0	0.0000
helium	0.0000	4.0026	0	0.0000
nitrogen	3.3400	28.01340	94	5.5630
CO2	0.0100	44.00950	0	0.0262
H2S	0.0030	34.08188	0	0.0061
methane (C1)	94.0500	16.04246	1509	89.7065
ethane (C2)	2.5400	30.06904	76	4.5410
propane (C3)	0.0600	44.09562	3	0.1573
butanes (C4)		58.12220	0	0.0000
pentanes (C5)		72.14878	0	0.0000
benzene		78.110000	0	0.0000
other hexanes (C6)		86.18000	0	0.0000
toluene		92.140000	0	0.0000
other heptanes (C7)		100.20000	0	0.0000
ethylbenzene		106.170000	0	0.0000
xylenes (o, m, p)		106.170000	0	0.0000
other octanes (C8)		114.23000	0	0.0000
nonanes (C9)		128.26000	0	0.0000
decenes plus (C10+)		142.28000	0	0.0000
Totals:	100.0030	16.82	1682	100.00
VOC (Non-methane, Non-ethane hydrocarbons)				
VOC content of total sample				
VOC weight% =	0.1573			
VOC weight fraction =	0.0016			
VOC content of hydrocarbon fraction only				
VOC weight% =	0.1666			
VOC weight fraction =	0.0017			
Hydrogen Sulfide				
H2S weight% =	0.0061			
H2S weight fraction =	6.08E-05			
H2S ppm _v =	30			
H2S ppm _{wT} =	60.79			
H ₂ S grains/100 SCF =	1.8567			
SOUR GAS				
Constants:				
	453.59237 mol/lb-mol			
	0.06479891 grams/grain			
	385.48 scf/lb-mol			
Benzene				
Benzene content of total sample				
Benzene weight% =	0.0000			
Benzene weight fraction =	0.0000			
Benzene content of hydrocarbon fraction only				
Benzene weight% =	0.0000			
Benzene weight fraction =	0.0000			
Constants:				
Gas Molecular Weight =	16.82			
Gas Specific Gravity =	0.58			
	28.97 air mw			
	385.48 scf/lb-mol			
Gas Throughput (MMscf/day) =	494.588			
Long Tons Sulfur Compounds per Day =	0.5856467			

For the liquid sample, I am inputting
(pick from list):

Select whether weight percents or mole percents are being entered for this liquid sample.

Then fill out this table **OR** fill out this table.

Liquid Analysis - Use if the Inputs are Weight Percents	
Analysis Identifier/Name	
What site is the sample from?	
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).	
Where in the process was the sample taken?	
What is the temperature and pressure of the sample (include units)?	
Who analyzed the sample?	
Date of sample:	
Component	weight %
hydrogen	
helium	
nitrogen	
CO2	
H2S	
methane (C1)	
ethane (C2)	
propane (C3)	
butanes (C4)	
pentanes (C5)	
benzene	
other hexanes (C6)	
toluene	
other heptanes (C7)	
ethylbenzene	
xylenes (o, m, p)	
other octanes (C8)	
nonanes (C9)	
decanes plus (C10+)	
Totals:	0.0000
VOC (Non-methane, Non-ethane hydrocarbons)	
VOC content of total sample	
VOC weight% =	0.0000
VOC weight fraction =	0.0000
VOC content of hydrocarbon fraction only	
VOC weight% =	#DIV/0!
VOC weight fraction =	#DIV/0!
Hydrogen Sulfide	
H2S weight% =	0.0000
H2S weight fraction =	0.00E+00
H2S ppm _v =	
H2S ppm _{WT} =	0.00
Benzene	
Benzene content of total sample	
Benzene weight% =	0.0000
Benzene weight fraction =	0.0000
Benzene content of hydrocarbon fraction only	
Benzene weight% =	#DIV/0!
Benzene weight fraction =	#DIV/0!

Liquid Analysis - Use if the Inputs are Mole Percents				
Analysis Identifier/Name	to mole sieve			
What site is the sample from?				
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).				
Where in the process was the sample taken?				
What is the temperature and pressure of the sample (include units)?				
Who analyzed the sample?				
Date of sample:				
Component	mole %	Molecular Weight (grams/mole, lb/lb-mol)	grams per 100 moles of gas	weight %
hydrogen		2.01588	0	#DIV/0!
helium		4.0026	0	#DIV/0!
nitrogen		28.01340	0	#DIV/0!
CO2		44.00950	0	#DIV/0!
H2S		34.08188	0	#DIV/0!
methane (C1)		16.04246	0	#DIV/0!
ethane (C2)		30.06904	0	#DIV/0!
propane (C3)		44.09562	0	#DIV/0!
butanes (C4)		58.12220	0	#DIV/0!
pentanes (C5)		72.14878	0	#DIV/0!
benzene		78.110000	0	#DIV/0!
other hexanes (C6)		86.18000	0	#DIV/0!
toluene		92.140000	0	#DIV/0!
other heptanes (C7)		100.20000	0	#DIV/0!
ethylbenzene		106.170000	0	#DIV/0!
xylenes (o, m, p)		106.170000	0	#DIV/0!
other octanes (C8)		114.23000	0	#DIV/0!
nonanes (C9)		128.26000	0	#DIV/0!
decanes plus (C10+)			0	#DIV/0!
Totals:	0.0000	0.00	0	#DIV/0!
VOC (Non-methane, Non-ethane hydrocarbons)				
VOC content of total sample				
VOC weight% =	#DIV/0!			
VOC weight fraction =	#DIV/0!			
VOC content of hydrocarbon fraction only				
VOC weight% =	#DIV/0!			
VOC weight fraction =	#DIV/0!			
Hydrogen Sulfide				
H2S weight% =	#DIV/0!			
H2S weight fraction =	#DIV/0!			
H2S ppm _v =	0.00			
H2S ppm _{WT} =	#DIV/0!			
Benzene				
Benzene content of total sample				
Benzene weight% =	#DIV/0!			
Benzene weight fraction =	#DIV/0!			
Benzene content of hydrocarbon fraction only				
Benzene weight% =	#DIV/0!			
Benzene weight fraction =	#DIV/0!			

Enter any notes here:

Gas and Liquid Analyses

A) Enter information into the yellow boxes.

B) The purpose of this tab is to extract information from a lab analysis that will be used in emission calculations. Unlike the other other tabs which calculate emissions, nothing from this tab gets pulled to the Emissions Summary table. The big pieces of information needed for emissions estimates are the VOC, benzene, and H₂S weight percents. Sampling of gas and liquid streams from appropriate process sampling points is required in order to determine composition or other properties needed to estimate emissions such as heat content, specific gravity, and vapor pressure. It is essential that stream lab analyses/reports include a measurement of H₂S, individual HAPs, and at least all those hydrocarbons up to at least 10 carbon atoms per molecule (C10+).

C) There are two boxes on the left, for gas and liquid analyses, which take component weight percent inputs and there are two boxes on the right, for gas and liquid analyses, which take component mole percent inputs. You can either fill out the weight percent box OR the mole percent box, depending on what informaton you have available to you.

The boxes are set up in the following arrangement:

Gas Analysis Wt% Inputs	Gas Analysis Mol% Inputs
Liquid Analysis Wt% Inputs	Liquid Analysis Mol% Inputs

D) If weight percents are provided on the lab report, use the boxes on the left. If only mole percents are provided on the lab report, use the boxes on the right.

E) Make sure to select whether you are inputting weight percents or mole percents from the pull down menus below.

F) If you are using the weight percent boxes (left two), in addition to the component weight percents, you need to enter the gas molecular weight (molecular weight of the total sample) and the gas and liquid H₂S content in parts per million by volume (H₂S ppmv). This will allow for the calculation of the gas specific gravity and the long tons of sulfur per day in the gas, and the determination of sweet versus sour gas.

G) If you are using the mole percent boxes (right two), in addition to the component mole percents, you need to enter a real value, specific to this sample, for the molecular weight of the deacnes plus (C10+) fraction. You may use the default values listed below for the moleclar weights of the other hexanes (C6), other heptanes (C7), other ocatnes (C8), and nonanes (C9) fractions, unless you have a more accurate number. If you enter number other than the default, you need to explain where the number came from and why it is appropriate to use.

H) What is expected to be included on these tables is the the inlet gas and liquid streams (the liquid would most likely be sampled from a separator if there is separation at the site). These tables can also be used for any sampled gas and liquid streams as needed. If needed, make a copy of this tab.

I) Use the box provided below for entering any notes necessary.

For the gas sample, I am inputting (pick from list):

mole percents

Select whether weight percents or mole percents are being entered for this gas sample.

Then fill out this table **OR** fill out this table.

Gas Analysis - Use if the Inputs are Weight Percents	
Analysis Identifier/Name	
What site is the sample from?	
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).	
Where in the process was the sample taken?	
What is the temperature and pressure of the sample (include units)?	
Who analyzed the sample?	
Date of sample:	
Component	weight %
hydrogen	
helium	
nitrogen	
CO2	
H2S	
methane (C1)	
ethane (C2)	
propane (C3)	
butanes (C4)	
pentanes (C5)	
benzene	
other hexanes (C6)	
toluene	
other heptanes (C7)	
ethylbenzene	
xylenes (o, m, p)	
other octanes (C8)	
nonanes (C9)	
decans plus (C10+)	
Totals:	0.0000
VOC (Non-methane, Non-ethane hydrocarbons)	
VOC content of total sample	
VOC weight% =	0.0000
VOC weight fraction =	0.0000
VOC content of hydrocarbon fraction only	
VOC weight% =	#DIV/0!
VOC weight fraction =	#DIV/0!
Hydrogen Sulfide	
H2S weight% =	0.0000
H2S weight fraction =	0.00E+00
H2S ppm _v =	
H2S ppm _{wT} =	0.00
H ₂ S grains/100 SCF =	0.0000
SWEET GAS	
Constants:	
	453.59237 mol/lb-mol
	0.06479891 grams/grain
	385.48 scf/lb-mol
	34.08188 g/mol, lb/lb-mol
	H2S mw
Benzene	
Benzene content of total sample	
Benzene weight% =	0.0000
Benzene weight fraction =	0.0000
Benzene content of hydrocarbon fraction only	
Benzene weight% =	#DIV/0!
Benzene weight fraction =	#DIV/0!
Constants:	
Gas Molecular Weight =	28.97 air mw
Gas Specific Gravity =	0.00
Gas Throughput (MMscf/day) =	494.588
Long Tons Sulfur Compounds per Day =	0

Gas Analysis - Use if the Inputs are Mole Percents				
Analysis Identifier/Name	Mole Sieve Stream			
Where was the sample taken?	Promax			
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).	Site Specific			
Where in the process was the sample taken?	Mole sieve stream			
What is the temperature and pressure of the sample (include units)?				
Who analyzed the sample?				
Date of sample:	6/17/2019			
Component	mole %	Molecular Weight (grams/mole, lb/lb-mol)	grams per 100 moles of gas	weight %
hydrogen	0.0000	2.01588	0	0.0000
helium	0.0000	4.0026	0	0.0000
nitrogen	2.2762	28.01340	64	3.0033
CO2	0.0071	44.00950	0	0.0148
H2S	0.0000	34.08188	0	0.0000
methane (C1)	76.8491	16.04246	1233	58.0669
ethane (C2)	11.5013	30.06904	346	16.2887
propane (C3)	5.9246	44.09562	261	12.3048
butanes (C4)	2.3778	58.12220	138	6.5092
pentanes (C5)	0.7102	72.14878	51	2.4134
benzene	0.0091	78.110000	1	0.0335
other hexanes (C6)	0.3201	86.18000	28	1.2995
toluene	0.0019	92.140000	0	0.0083
other heptanes (C7)	0.0064	100.20000	1	0.0304
ethylbenzene	0.0001	106.170000	0	0.0003
xylenes (o, m, p)	0.0003	106.170000	0	0.0015
other octanes (C8)	0.0023	114.23000	0	0.0122
nonanes (C9)	0.0004	128.26000	0	0.0024
decans plus (C10+)	0.0129	18.01528	0	0.0110
Totals:	99.9999	21.23	2123	100.00
VOC (Non-methane, Non-ethane hydrocarbons)				
VOC content of total sample				
VOC weight% =	22.6264			
VOC weight fraction =	0.2263			
VOC content of hydrocarbon fraction only				
VOC weight% =	23.3305			
VOC weight fraction =	0.2333			
Hydrogen Sulfide				
H2S weight% =	0.0000			
H2S weight fraction =	0.00E+00			
H2S ppm _v =	0			
H2S ppm _{wT} =	0.00			
H ₂ S grains/100 SCF =	0.0000			
SWEET GAS				
Constants:				
	453.59237 mol/lb-mol			
	0.06479891 grams/grain			
	385.48 scf/lb-mol			
	34.08188 g/mol, lb/lb-mol			
	H2S mw			
Benzene				
Benzene content of total sample				
Benzene weight% =	0.0335			
Benzene weight fraction =	0.0003			
Benzene content of hydrocarbon fraction only				
Benzene weight% =	0.0345			
Benzene weight fraction =	0.0003			
Constants:				
Gas Molecular Weight =	21.23			
Gas Specific Gravity =	0.73			
Gas Throughput (MMscf/day) =	494.588			
Long Tons Sulfur Compounds per Day =	0			

For the liquid sample, I am inputting
(pick from list):

Select whether weight percents or mole percents are being entered for this liquid sample.

Then fill out this table **OR** fill out this table.

Liquid Analysis - Use if the Inputs are <u>Weight Percents</u>	
Analysis Identifier/Name	
What site is the sample from?	
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).	
Where in the process was the sample taken?	
What is the temperature and pressure of the sample (include units)?	
Who analyzed the sample?	
Date of sample:	
Component	weight %
hydrogen	
helium	
nitrogen	
CO2	
H2S	
methane (C1)	
ethane (C2)	
propane (C3)	
butanes (C4)	
pentanes (C5)	
benzene	
other hexanes (C6)	
toluene	
other heptanes (C7)	
ethylbenzene	
xylenes (o, m, p)	
other octanes (C8)	
nonanes (C9)	
decans plus (C10+)	
Totals:	0.0000
VOC (Non-methane, Non-ethane hydrocarbons)	
VOC content of total sample	
VOC weight% =	0.0000
VOC weight fraction =	0.0000
VOC content of hydrocarbon fraction only	
VOC weight% =	#DIV/0!
VOC weight fraction =	#DIV/0!
Hydrogen Sulfide	
H2S weight% =	0.0000
H2S weight fraction =	0.00E+00
H2S ppm _v =	
H2S ppm _{WT} =	0.00
Benzene	
Benzene content of total sample	
Benzene weight% =	0.0000
Benzene weight fraction =	0.0000
Benzene content of hydrocarbon fraction only	
Benzene weight% =	#DIV/0!
Benzene weight fraction =	#DIV/0!

Liquid Analysis - Use if the Inputs are <u>Mole Percents</u>				
Analysis Identifier/Name	900 gpm compressor			
What site is the sample from?				
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).				
Where in the process was the sample taken?				
What is the temperature and pressure of the sample (include units)?				
Who analyzed the sample?				
Date of sample:				
Component	mole %	Molecular Weight (grams/mole, lb/lb-mol)	grams per 100 moles of gas	weight %
hydrogen		2.01588	0	#DIV/0!
helium		4.0026	0	#DIV/0!
nitrogen		28.01340	0	#DIV/0!
CO2		44.00950	0	#DIV/0!
H2S		34.08188	0	#DIV/0!
methane (C1)		16.04246	0	#DIV/0!
ethane (C2)		30.06904	0	#DIV/0!
propane (C3)		44.09562	0	#DIV/0!
butanes (C4)		58.12220	0	#DIV/0!
pentanes (C5)		72.14878	0	#DIV/0!
benzene		78.110000	0	#DIV/0!
other hexanes (C6)		86.18000	0	#DIV/0!
toluene		92.140000	0	#DIV/0!
other heptanes (C7)		100.20000	0	#DIV/0!
ethylbenzene		106.170000	0	#DIV/0!
xylenes (o, m, p)		106.170000	0	#DIV/0!
other octanes (C8)		114.23000	0	#DIV/0!
nonanes (C9)		128.26000	0	#DIV/0!
decans plus (C10+)		18.01600	0	#DIV/0!
Totals:	0.0000	0.00	0	#DIV/0!
VOC (Non-methane, Non-ethane hydrocarbons)				
VOC content of total sample				
VOC weight% =	#DIV/0!			
VOC weight fraction =	#DIV/0!			
VOC content of hydrocarbon fraction only				
VOC weight% =	#DIV/0!			
VOC weight fraction =	#DIV/0!			
Hydrogen Sulfide				
H2S weight% =	#DIV/0!			
H2S weight fraction =	#DIV/0!			
H2S ppm _v =	0.00			
H2S ppm _{WT} =	#DIV/0!			
Benzene				
Benzene content of total sample				
Benzene weight% =	#DIV/0!			
Benzene weight fraction =	#DIV/0!			
Benzene content of hydrocarbon fraction only				
Benzene weight% =	#DIV/0!			
Benzene weight fraction =	#DIV/0!			

Enter any notes here:

Gas and Liquid Analyses

A) Enter information into the yellow boxes.

B) The purpose of this tab is to extract information from a lab analysis that will be used in emission calculations. Unlike the other other tabs which calculate emissions, nothing from this tab gets pulled to the Emissions Summary table. The big pieces of information needed for emissions estimates are the VOC, benzene, and H₂S weight percents. Sampling of gas and liquid streams from appropriate process sampling points is required in order to determine composition or other properties needed to estimate emissions such as heat content, specific gravity, and vapor pressure. It is essential that stream lab analyses/reports include a measurement of H₂S, individual HAPs, and at least all those hydrocarbons up to at least 10 carbon atoms per molecule (C10+).

C) There are two boxes on the left, for gas and liquid analyses, which take component weight percent inputs and there are two boxes on the right, for gas and liquid analyses, which take component mole percent inputs. You can either fill out the weight percent box OR the mole percent box, depending on what informaton you have available to you.

The boxes are set up in the following arrangement:

Gas Analysis Wt% Inputs	Gas Analysis Mol% Inputs
Liquid Analysis Wt% Inputs	Liquid Analysis Mol% Inputs

D) If weight percents are provided on the lab report, use the boxes on the left. If only mole percents are provided on the lab report, use the boxes on the right.

E) Make sure to select whether you are inputting weight percents or mole percents from the pull down menus below.

F) If you are using the weight percent boxes (left two), in addition to the component weight percents, you need to enter the gas molecular weight (molecular weight of the total sample) and the gas and liquid H₂S content in parts per million by volume (H₂S ppmv). This will allow for the calculation of the gas specific gravity and the long tons of sulfur per day in the gas, and the determination of sweet versus sour gas.

G) If you are using the mole percent boxes (right two), in addition to the component mole percents, you need to enter a real value, specific to this sample, for the molecular weight of the deacnes plus (C10+) fraction. You may use the default values listed below for the moleclar weights of the other hexanes (C6), other heptanes (C7), other ocatnes (C8), and nonanes (C9) fractions, unless you have a more accurate number. If you enter number other than the default, you need to explain where the number came from and why it is appropriate to use.

H) What is expected to be included on these tables is the the inlet gas and liquid streams (the liquid would most likely be sampled from a separator if there is separation at the site). These tables can also be used for any sampled gas and liquid streams as needed. If needed, make a copy of this tab.

I) Use the box provided below for entering any notes necessary.

For the gas sample, I am inputting (pick from list):

mole percents

Select whether weight percents or mole percents are being entered for this gas sample.

Then fill out this table **OR** fill out this table.

Gas Analysis - Use if the Inputs are Weight Percents	
Analysis Identifier/Name	
What site is the sample from?	
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).	
Where in the process was the sample taken?	
What is the temperature and pressure of the sample (include units)?	
Who analyzed the sample?	
Date of sample:	
Component	weight %
hydrogen	
helium	
nitrogen	
CO2	
H2S	
methane (C1)	
ethane (C2)	
propane (C3)	
butanes (C4)	
pentanes (C5)	
benzene	
other hexanes (C6)	
toluene	
other heptanes (C7)	
ethylbenzene	
xylenes (o, m, p)	
other octanes (C8)	
nonanes (C9)	
decans plus (C10+)	
Totals:	0.0000
VOC (Non-methane, Non-ethane hydrocarbons)	
VOC content of total sample	
VOC weight% =	0.0000
VOC weight fraction =	0.0000
VOC content of hydrocarbon fraction only	
VOC weight% =	#DIV/0!
VOC weight fraction =	#DIV/0!
Hydrogen Sulfide	
H2S weight% =	0.0000
H2S weight fraction =	0.00E+00
H2S ppm _v =	
H2S ppm _{wT} =	0.00
H ₂ S grains/100 SCF =	0.0000
SWEET GAS	
Constants:	
	453.59237 mol/lb-mol
	0.06479891 grams/grain
	385.48 scf/lb-mol
	34.08188 g/mol, lb/lb-mol
	H2S mw
Benzene	
Benzene content of total sample	
Benzene weight% =	0.0000
Benzene weight fraction =	0.0000
Benzene content of hydrocarbon fraction only	
Benzene weight% =	#DIV/0!
Benzene weight fraction =	#DIV/0!
Constants:	
Gas Molecular Weight =	28.97 air mw
Gas Specific Gravity =	0.00
Gas Throughput (MMscf/day) =	494.588
Long Tons Sulfur Compounds per Day =	0

Gas Analysis - Use if the Inputs are Mole Percents				
Analysis Identifier/Name	AGI Flare - 900 gpm			
Where was the sample taken?	Promax			
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).	Site Specific			
Where in the process was the sample taken?	AGI #2 Compressor			
What is the temperature and pressure of the sample (include units)?				
Who analyzed the sample?				
Date of sample:				
Component	mole %	Molecular Weight (grams/mole, lb/lb-mol)	grams per 100 moles of gas	weight %
hydrogen	0.0000	2.01588	0	0.0000
helium	0.0000	4.0026	0	0.0000
nitrogen	0.0002	28.01340	0	0.0001
CO2	80.1854	44.00950	3529	86.3047
H2S	12.5711	34.08188	428	10.4783
methane (C1)	0.0908	16.04246	1	0.0356
ethane (C2)	0.0259	30.06904	1	0.0190
propane (C3)	0.0167	44.09562	1	0.0180
butanes (C4)	0.0046	58.12220	0	0.0065
pentanes (C5)	0.0020	72.14878	0	0.0035
benzene	0.0000	78.110000	0	0.0000
other hexanes (C6)	0.0027	86.18000	0	0.0056
toluene	0.0000	92.140000	0	0.0000
other heptanes (C7)		100.20000	0	0.0000
ethylbenzene		106.170000	0	0.0000
xylenes (o, m, p)		106.170000	0	0.0000
other octanes (C8)		114.23000	0	0.0000
nonanes (C9)		128.26000	0	0.0000
decans plus (C10+)	7.1010	18.01528	128	3.1286
Totals:	100.0002	40.89	4089	100.00
VOC (Non-methane, Non-ethane hydrocarbons)				
VOC content of total sample				
VOC weight% =	3.1622			
VOC weight fraction =	0.0316			
VOC content of hydrocarbon fraction only				
VOC weight% =	98.3022			
VOC weight fraction =	0.9830			
Hydrogen Sulfide				
H2S weight% =	10.4783			
H2S weight fraction =	1.05E-01			
H2S ppm _v =	125711			
H2S ppm _{wT} =	104782.79			
H ₂ S grains/100 SCF =	7780.1897			
SOUR GAS				
Constants:				
	453.59237 mol/lb-mol			
	0.06479891 grams/grain			
	385.48 scf/lb-mol			
Benzene				
Benzene content of total sample				
Benzene weight% =	0.0000			
Benzene weight fraction =	0.0000			
Benzene content of hydrocarbon fraction only				
Benzene weight% =	0.0000			
Benzene weight fraction =	0.0000			
Constants:				
Gas Molecular Weight =	40.89			
Gas Specific Gravity =	1.41			
Gas Throughput (MMscf/day) =	494.588			
Long Tons Sulfur Compounds per Day =	2454.0743			

For the liquid sample, I am inputting
(pick from list):

Select whether weight percents or mole percents are being entered for this liquid sample.

Then fill out this table **OR** fill out this table.

Liquid Analysis - Use if the Inputs are <u>Weight Percents</u>	
Analysis Identifier/Name	
What site is the sample from?	
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).	
Where in the process was the sample taken?	
What is the temperature and pressure of the sample (include units)?	
Who analyzed the sample?	
Date of sample:	
Component	weight %
hydrogen	
helium	
nitrogen	
CO2	
H2S	
methane (C1)	
ethane (C2)	
propane (C3)	
butanes (C4)	
pentanes (C5)	
benzene	
other hexanes (C6)	
toluene	
other heptanes (C7)	
ethylbenzene	
xylenes (o, m, p)	
other octanes (C8)	
nonanes (C9)	
decanes plus (C10+)	
Totals:	0.0000
VOC (Non-methane, Non-ethane hydrocarbons)	
VOC content of total sample	
VOC weight% =	0.0000
VOC weight fraction =	0.0000
VOC content of hydrocarbon fraction only	
VOC weight% =	#DIV/0!
VOC weight fraction =	#DIV/0!
Hydrogen Sulfide	
H2S weight% =	0.0000
H2S weight fraction =	0.00E+00
H2S ppm _v =	
H2S ppm _{WT} =	0.00
Benzene	
Benzene content of total sample	
Benzene weight% =	0.0000
Benzene weight fraction =	0.0000
Benzene content of hydrocarbon fraction only	
Benzene weight% =	#DIV/0!
Benzene weight fraction =	#DIV/0!

Liquid Analysis - Use if the Inputs are <u>Mole Percents</u>				
Analysis Identifier/Name				
What site is the sample from?				
If the sample is from a representative site, explain how this sampled stream is representative of the similar stream at this site (use the notes box provided below if more space is needed).				
Where in the process was the sample taken?				
What is the temperature and pressure of the sample (include units)?				
Who analyzed the sample?				
Date of sample:				
Component	mole %	Molecular Weight (grams/mole, lb/lb-mol)	grams per 100 moles of gas	weight %
hydrogen		2.01588	0	#DIV/0!
helium		4.0026	0	#DIV/0!
nitrogen		28.01340	0	#DIV/0!
CO2		44.00950	0	#DIV/0!
H2S		34.08188	0	#DIV/0!
methane (C1)		16.04246	0	#DIV/0!
ethane (C2)		30.06904	0	#DIV/0!
propane (C3)		44.09562	0	#DIV/0!
butanes (C4)		58.12220	0	#DIV/0!
pentanes (C5)		72.14878	0	#DIV/0!
benzene		78.110000	0	#DIV/0!
other hexanes (C6)		86.18000	0	#DIV/0!
toluene		92.140000	0	#DIV/0!
other heptanes (C7)		100.20000	0	#DIV/0!
ethylbenzene		106.170000	0	#DIV/0!
xylenes (o, m, p)		106.170000	0	#DIV/0!
other octanes (C8)		114.23000	0	#DIV/0!
nonanes (C9)		128.26000	0	#DIV/0!
decanes plus (C10+)		18.01600	0	#DIV/0!
Totals:	0.0000	0.00	0	#DIV/0!
VOC (Non-methane, Non-ethane hydrocarbons)				
VOC content of total sample				
VOC weight% =	#DIV/0!			
VOC weight fraction =	#DIV/0!			
VOC content of hydrocarbon fraction only				
VOC weight% =	#DIV/0!			
VOC weight fraction =	#DIV/0!			
Hydrogen Sulfide				
H2S weight% =	#DIV/0!			
H2S weight fraction =	#DIV/0!			
H2S ppm _v =	0.00			
H2S ppm _{WT} =	#DIV/0!			
Benzene				
Benzene content of total sample				
Benzene weight% =	#DIV/0!			
Benzene weight fraction =	#DIV/0!			
Benzene content of hydrocarbon fraction only				
Benzene weight% =	#DIV/0!			
Benzene weight fraction =	#DIV/0!			

Enter any notes here:

Red Hills Gas Processing Plant
Facility-Wide Fugitive Emissions

Analysis¹

Stream	% VOC	% HAP	% CO ₂	% CH ₄	% H ₂ S
Vapor	27%	1%	11%	49%	0.0017%
Light liquid	100%	10%	0%	13%	0%
Heavy liquid	100%	10%	0%	13%	0%

Totals

Uncontrolled Rate					Controlled Rate				
VOC	Total HAP	CO ₂	CH ₄	H ₂ S	VOC	Total HAP	CO ₂	CH ₄	H ₂ S
28.48	1.63	6.72	29.83	1.02E-03	23.65	1.63	6.72	29.83	1.02E-03
103.61	7.14	29.42	130.65	4.49E-03	103.61	7.14	29.42	130.65	4.49E-03

lb/hr
tpy

Train 1.0

Equip Cat	Type	Monitor Frequency	# of Components	Emission Factor ² (kg/hr/source)	Control (%) ⁴	Uncontrolled Rate					Controlled Rate					
						TOC (lb/hr)	VOC (lb/hr)	Total HAP (lb/hr)	CO ₂ (lb/hr)	CH ₄ (lb/hr)	H ₂ S (lb/hr)	VOC (lb/hr)	Total HAP (lb/hr)	CO ₂ (lb/hr)	CH ₄ (lb/hr)	H ₂ S (lb/hr)
Connector	Light Liquid	Yearly (SS)	2077	2.10E-04		0.96	0.96	0.10	0.00	0.13	0.00	0.96	0.10	0.00	0.13	0.00
Connector	Vapor	Yearly (SS)	2290	2.00E-04		1.01	0.271072328	0.014563745	0.114431168	0.490742768	1.74545E-05	0.27	0.01	0.11	0.49	1.75E-05
Press Relief Device	Light Liquid	Yearly (SS)	4	7.50E-03		0.066	0.066138	0.0066138	0	0.008730216	0.00	0.07	0.01	0.00	0.01	0.00
Press Relief Device	Vapor	Yearly (SS)	1	8.80E-03		0.019	0.005208377	0.000279827	0.002198677	0.009429119	3.35371E-07	0.01	0.00	0.00	0.01	3.35E-07
Compressor	Vapor	Yearly (SS)	0	8.80E-03		0.00	0	0	0	0	0.00	0.00	0.00	0.00	0.00	0.00
Pump	Light Liquid	Monthly (SS)	12	1.30E-03		0.034	0.03439176	0.003439176	0	0.004539712	0.00	0.03	0.00	0.00	0.00	0.00
Valve	Heavy Liquid	Monthly (SS)	1	8.40E-06		1.85E-05	1.85186E-05	1.85186E-06	0	2.40742E-06	0.00E+00	0.00	0.00	0.00	0.00	0.00
Valve	Light Liquid	Monthly (SS)	1212	2.50E-03		6.68	6.679938	0.6679938	0	0.881751816	0.00	6.68	0.67	0.00	0.88	0.00
Valve	Vapor	Monthly (SS)	1072	4.50E-03		10.63	2.855137354	0.153396306	1.205275008	5.168871421	0.000183844	2.86	0.15	1.21	5.17	1.84E-04
Total						6669										
						Total lb/hr	10.87	0.94	1.32	6.69	0.00	10.87	0.94	1.32	6.69	2.02E-04
						Total tpy	47.6	4.1	5.8	29.3	0.00	47.6	4.1	5.8	29.3	8.83E-04

Train 2
(240 cryo skid)

Equip Cat	Type	Monitor Frequency	# of Components	Factor ² (kg/hr/source)	Control (%)	Uncontrolled Rate					Controlled Rate					
						TOC (lb/hr)	VOC (lb/hr)	Total HAP (lb/hr)	CO ₂ (lb/hr)	CH ₄ (lb/hr)	H ₂ S (lb/hr)	VOC (lb/hr)	Total HAP (lb/hr)	CO ₂ (lb/hr)	CH ₄ (lb/hr)	H ₂ S (lb/hr)
Connector	Vapor	Yearly (SS)	5446	2.00E-04		2.4013	0.644654976	0.034635003	0.272136306	1.167067735	4.15E-05	0.64	0.03	0.27	1.17	4.15E-05
Press Relief Device	Vapor	Yearly (SS)	10	8.80E-03		0.1940	0.052083766	0.002798274	0.021986775	0.094291187	3.35E-06	0.05	0.00	0.02	0.09	3.35E-06
Valve	Vapor	Monthly (SS)	1338	4.50E-03		13.2739	3.563594944	0.191459195	1.504345113	6.45144586	2.29E-04	3.56	0.19	1.50	6.45	2.29E-04
Total						6794										
						Total lb/hr	4.26	0.23	1.80	7.71	2.74E-04	4.26	0.23	1.80	7.71	2.74E-04
						Total tpy	18.7	1.0	7.9	33.8	1.20E-03	18.7	1.0	7.9	33.8	1.20E-03

Train 3

Equip Cat	Type	Monitor Frequency	# of Components	Factor ² (kg/hr/source)	Control (%)	Uncontrolled Rate					Controlled Rate					
						TOC (lb/hr)	VOC (lb/hr)	Total HAP (lb/hr)	CO ₂ (lb/hr)	CH ₄ (lb/hr)	H ₂ S (lb/hr)	VOC (lb/hr)	Total HAP (lb/hr)	CO ₂ (lb/hr)	CH ₄ (lb/hr)	H ₂ S (lb/hr)
Connector	Vapor	Yearly (SS)	5446	2.00E-04		2.4013	0.644654976	0.034635003	0.272136306	1.167067735	4.15E-05	0.64	0.03	0.27	1.17	4.15E-05
Press Relief Device	Vapor	Yearly (SS)	10	8.80E-03		0.1940	0.052083766	0.002798274	0.021986775	0.094291187	3.35E-06	0.05	0.00	0.02	0.09	3.35E-06
Valve	Vapor	Monthly (SS)	1338	4.50E-03		13.2739	3.563594944	0.191459195	1.504345113	6.45144586	2.29E-04	3.56	0.19	1.50	6.45	2.29E-04
Total						6794										
						Total lb/hr	4.26	0.23	1.80	7.71	2.74E-04	4.26	0.23	1.80	7.71	2.74E-04
						Total tpy	18.7	1.0	7.9	33.8	1.20E-03	18.7	1.0	7.9	33.8	1.20E-03

Train 4

Equip Cat	Type	Monitor Frequency	# of Components	Factor ² (kg/hr/source)	Control (%)	Uncontrolled Rate						Controlled Rate					
						TOC (lb/hr)	VOC (lb/hr)	Total HAP (lb/hr)	CO ₂ (lb/hr)								
Connector	Vapor	Yearly (SS)	5446	2.00E-04		2.4013	0.644654976	0.034635003	0.272136306	1.167067735	4.15E-05	0.64	0.03	0.27	1.17	4.15E-05	
Press Relief Device	Vapor	Yearly (SS)	10	8.80E-03		0.1940	0.052083766	0.002798274	0.021986775	0.094291187	3.35E-06	0.05	0.00	0.02	0.09	3.35E-06	
Valve	Vapor	Monthly (SS)	1338	4.50E-03		13.2739	3.563594944	0.191459195	1.504345113	6.45144586	2.29E-04	3.56	0.19	1.50	6.45	2.29E-04	
Total			6794			Total lb/hr	4.26	0.23	1.80	7.71	2.74E-04	4.26	0.23	1.80	7.71	2.74E-04	
						Total tpy	18.7	1.0	7.9	33.8	1.20E-03	18.7	1.0	7.9	33.8	1.20E-03	

Note

- ¹ Analyses based on inlet gas and liquid analyses fro Red Hills Gas Plant
- ² Emission factors from Table 2-4 of the EPA Protocol for Equipment Leak Emission Estimates, November 1995
- ³ Hourly emissions are shown for informational purposes only.
- ² Control effectiveness for an LDAR Program from Table 5-2 of the EPA Protocol for Equipment Leak Emission Estimates, November 1995

Liquid Weight Percents From Analyses Tab:	
VOC wt %	#DIV/0!
Benzene wt %	#DIV/0!
H ₂ S wt %	#DIV/0!

(3)

Light Oil

number	component	emission factor (lb/hr of TOC per component)	lb/hr	tpy
1212	Valve	0.005500	6.666	29.19708
12	Pump Seal	0.028660	0.34392	1.5063696
2077	Connector	0.000463	0.961651	4.21203138
	Flange	0.000243	0	0
	Open-ended Line	0.003090	0	0
4	Other	0.016500	0.066	0.28908
Total:			8.037571	35.204561

	VOC content (wt%)	Benzene content (wt%)	H ₂ S content (wt%)	Control Efficiency (%)
Valves	100.0000	10.0000	0.0000	0.0000
Pump Seal	100.0000	10.0000	0.0000	0.0000
Connector	100.0000	10.0000	0.0000	0.0000
Flange	100.0000	10.0000	0.0000	0.0000
Open-ended Line	100.0000	10.0000	0.0000	0.0000
Other	100.0000	10.0000	0.0000	0.0000

	VOC Emissions		H ₂ S Emissions		Benzene Emissions	
	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
Valves	6.67	29.20	0.00	0.00	0.67	2.92
Pump Seal	0.34	1.51	0.00	0.00	0.03	0.15
Connector	0.96	4.21	0.00	0.00	0.10	0.42
Flange	0.00	0.00	0.00	0.00	0.00	0.00
Open-ended Line	0.00	0.00	0.00	0.00	0.00	0.00
Other	0.07	0.29	0.00	0.00	0.01	0.03
Total:	8.04	35.20	0.00	0.00	0.80	3.52

(4)

Water/Oil

number	component	emission factor (lb/hr of TOC per component)	lb/hr	tpy
	Valve	0.000216	0	0
	Pump Seal	0.000052	0	0
	Connector	0.000243	0	0
	Flange	0.000006	0	0
	Open-ended Line	0.000550	0	0
	Other	0.030900	0	0
Total:			0	0

	VOC content (wt%)	Benzene content (wt%)	H ₂ S content (wt%)	Control Efficiency (%)
Valves				
Pump Seal				
Connector				
Flange				
Open-ended Line				
Other				

	VOC Emissions		H ₂ S Emissions		Benzene Emissions	
	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
Valves	0.00	0.00	0.00	0.00	0.00	0.00
Pump Seal	0.00	0.00	0.00	0.00	0.00	0.00
Connector	0.00	0.00	0.00	0.00	0.00	0.00
Flange	0.00	0.00	0.00	0.00	0.00	0.00
Open-ended Line	0.00	0.00	0.00	0.00	0.00	0.00
Other	0.00	0.00	0.00	0.00	0.00	0.00
Total:	0.00	0.00	0.00	0.00	0.00	0.00

(5)

Fugitive Total Emissions		
	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
VOC	10.91	47.78
benzene	0.81	3.55
H ₂ S	0.00	0.00

Notes:

Reference to Emission factors used:

- Emission factors are for oil and gas production facilities (not refineries) come from the EPA's "Protocol for Equipment Leak Emission Estimates" November 1995, EPA 4531, R-95-017, Table 2-4.
- Emission factors that are not based on the EPA document are from the TCEQ "Air Permit Technical Guidance for Chemical Source Equipment Leak Fugitives (Draft October 2000)
- For fugitive calculations, VOC content should be VOC content of total hydrocarbons, not of total sample.

Enter any notes here:

Fugitives Emissions

EPN	6FUG
Name	Train 5, 6 & 7 (cryo)

A) Enter information into the yellow boxes.

B) VOC and H₂S control efficiencies may be entered (as applicable for reductions from leak detection and repair programs).

C) The vapor VOC, benzene, and H₂S weight percents may be entered. The weight percents from the Analyses tab are displayed below.

D) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

E) This sheet has five parts to it. Part (1) is for Gas Service, (2) is for Heavy Oil Service, (3) is for Light Oil Service, (4) is for Water/Oil Service, and (5) is for a combination of all the results. Fill out all applicable yellow cells in parts (1)-(4) and the final results will be in part (5).

The five parts are set up in this arrangement:

(1)	(2)
(3)	(4)
(5)	

(1)	Gas Weight Percents From Analyses Tab: VOC wt % 24.6270 Benzene wt % 0.0564 H ₂ S wt % 0.0003						
	Gas						
	number	component	emission factor (lb/hr of TOC per component)	lb/hr	tpy		
	4014	Valve	0.009920	39.81888	174.406694		
		Pump Seal	0.005290	0	0		
	16338	Connector	0.000440	7.18872	31.4865936		
		Flange	0.000860	0	0		
		Open-ended Line	0.004410	0	0		
	30	Other	0.019400	0.582	2.54916		
		Total:		47.5896	208.442448		
	VOC content (wt %)	Benzene content (wt%)	H ₂ S content (wt%)	Control Efficiency (%)			
Valves	23.3305	0.0345	0.0006	0.0000			
Pump Seal	23.3305	0.0345	0.0006	0.0000			
Connector	23.3305	0.0345	0.0006	0.0000			
Flange	23.3305	0.0345	0.0006	0.0000			
Open-ended Line	23.3305	0.0345	0.0006	0.0000			
Other	23.3305	0.0345	0.0006	0.0000			
	VOC Emissions lb/hr tpy		H₂S Emissions lb/hr tpy		Benzene Emissions lb/hr tpy		
Valves	9.29	40.69	0.00	0.00	0.01	0.06	
Pump Seal	0.00	0.00	0.00	0.00	0.00	0.00	
Connector	1.68	7.35	0.00	0.00	0.00	0.01	
Flange	0.00	0.00	0.00	0.00	0.00	0.00	
Open-ended Line	0.00	0.00	0.00	0.00	0.00	0.00	
Other	0.14	0.59	0.00	0.00	0.00	0.00	
	Total:	11.10	48.63	0.00	0.00	0.02	0.07
(2)	Liquid Weight Percents From Analyses Tab: VOC wt % #DIV/0! Benzene wt % #DIV/0! H ₂ S wt % #DIV/0!						
	Heavy Oil						
	number	component	emission factor (lb/hr of TOC per component)	lb/hr	tpy		
		Valve	0.0000185	0	0		
		Pumps	0.0011300	0	0		
		Connector	0.0000165	0	0		
		Flange	0.00000086	0	0		
		Open-ended Line	0.0003090	0	0		
		Other	0.0000683	0	0		
		Total:		0	0		
	VOC content (wt%)	Benzene content (wt%)	H ₂ S content (wt%)	Control Efficiency (%)			
Valves							
Pump Seal							
Connector							
Flange							
Open-ended Line							
Other							
	VOC Emissions lb/hr tpy		H₂S Emissions lb/hr tpy		Benzene Emissions lb/hr tpy		
Valves	0.00	0.00	0.00	0.00	0.00	0.00	
Pump Seal	0.00	0.00	0.00	0.00	0.00	0.00	
Connector	0.00	0.00	0.00	0.00	0.00	0.00	
Flange	0.00	0.00	0.00	0.00	0.00	0.00	
Open-ended Line	0.00	0.00	0.00	0.00	0.00	0.00	
Other	0.00	0.00	0.00	0.00	0.00	0.00	
	Total:	0.00	0.00	0.00	0.00	0.00	

Liquid Weight Percents From Analyses Tab:	
VOC wt %	#DIV/0!
Benzene wt %	#DIV/0!
H ₂ S wt %	#DIV/0!

(3)

Light Oil

number	component	emission factor (lb/hr of TOC per component)	lb/hr	tpy
	Valve	0.005500	0	0
	Pump Seal	0.028660	0	0
	Connector	0.000463	0	0
	Flange	0.000243	0	0
	Open-ended Line	0.003090	0	0
	Other	0.016500	0	0
Total:			0	0

	VOC content (wt%)	Benzene content (wt%)	H ₂ S content (wt%)	Control Efficiency (%)
Valves				
Pump Seal				
Connector				
Flange				
Open-ended Line				
Other				

	VOC Emissions		H ₂ S Emissions		Benzene Emissions	
	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
Valves	0.00	0.00	0.00	0.00	0.00	0.00
Pump Seal	0.00	0.00	0.00	0.00	0.00	0.00
Connector	0.00	0.00	0.00	0.00	0.00	0.00
Flange	0.00	0.00	0.00	0.00	0.00	0.00
Open-ended Line	0.00	0.00	0.00	0.00	0.00	0.00
Other	0.00	0.00	0.00	0.00	0.00	0.00
Total:	0.00	0.00	0.00	0.00	0.00	0.00

(5)

Fugitive Total Emissions		
	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
VOC	11.10	48.63
benzene	0.02	0.07
H ₂ S	0.00	0.00

Notes:

(4)

Water/Oil

number	component	emission factor (lb/hr of TOC per component)	lb/hr	tpy
	Valve	0.000216	0	0
	Pump Seal	0.000052	0	0
	Connector	0.000243	0	0
	Flange	0.000006	0	0
	Open-ended Line	0.000550	0	0
	Other	0.030900	0	0
Total:			0	0

	VOC content (wt%)	Benzene content (wt%)	H ₂ S content (wt%)	Control Efficiency (%)
Valves				
Pump Seal				
Connector				
Flange				
Open-ended Line				
Other				

	VOC Emissions		H ₂ S Emissions		Benzene Emissions	
	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
Valves	0.00	0.00	0.00	0.00	0.00	0.00
Pump Seal	0.00	0.00	0.00	0.00	0.00	0.00
Connector	0.00	0.00	0.00	0.00	0.00	0.00
Flange	0.00	0.00	0.00	0.00	0.00	0.00
Open-ended Line	0.00	0.00	0.00	0.00	0.00	0.00
Other	0.00	0.00	0.00	0.00	0.00	0.00
Total:	0.00	0.00	0.00	0.00	0.00	0.00

Reference to Emission factors used:

1. Emission factors are for oil and gas production facilities (not refineries) come from the EPA's "Protocol for Equipment Leak Emission Estimates" November 1995, EPA 4531, R-95-017, Table 2-4.

2. Emission factors that are not based on the EPA document are from the TCEQ "Air Permit Technical Guidance for Chemical Source Equipment Leak Fugitives (Draft October 2000)

3. For fugitive calculations, VOC content should be VOC content of total hydrocarbons, not of total sample.

Enter any notes here:

Heaters-Boilers Emissions

- A) Enter information into the yellow boxes.
 B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
 C) Make sure to select the correct *Emission Type* from the pull down menus below. A *VOC type* does not need to be

Heater and Boiler Emission Calculations (fueled by natural gas)					
EPN	5-EP-1a				
Name	Train 5 - Amine/Glycol Reboiler 1				
Heater/Boiler rating (MMBtu/hr):	70				
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner				(assume uncontrolled, unless specifically stated otherwise)
Operating hours/year:	8760				
Fuel Heat Value (Btu/SCF):	1020				

Pollutant	Emission Factor (lb/MMCF)	Emission Factor (lb/MMBtu)	lb/hr	tpy		
VOC	5.5	-	0.377	1.653	0.388552	1.70186
NOx	50	-	3.431	15.029	3.532295	15.47145
CO	-	0.05	3.500	15.330	3.602941	15.78088
PM ₁₀	7.6	-	0.522	2.284	0.536909	2.351661
PM _{2.5}	5.7	-	0.391	1.713	0.402682	1.763746
SO ₂	0.6	-	0.348	1.526	0.358594	1.570642

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:			
SO ₂ Mass Balance calculation:			
Fuel H ₂ S content (mol %) =	0.0030	assumptions:	
SO ₂ produced (lb/hr) =	0.3483	SO ₂ MW	64.06 lb/lb-mole
SO ₂ produced (tpy) =	1.5258	Ideal Gas L	378.61 SCF/lb-mole

Emission Type: (pick from list)
Steady State (continuous)

Enter any notes here:	Using Emission Factor for CO from the Manufacturers spec and a safety factor of 25%.
-----------------------	--

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

C) Make sure to select the correct *Emission Type* from the pull down menus below. A *VOC type* does not need to be

Heater and Boiler Emission Calculations (fueled by natural gas)				
EPN:	5-EP-1b			
Name:	Train 5 - Amine/Glycol Reboiler 1			
Heater/Boiler rating (MMBtu/hr):	70			
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled low NOx burner	(assume uncontrolled, unless specifically stated otherwise)		
Operating hours/year:	8760			
Fuel Heat Value (Btu/SCF):	1020			
Pollutant	Emission Factor (lb/MMCF)	Emission Factor (lb/MMBtu)	lb/hr	tpy
VOC	5.5	-	0.377	1.653
NOx	50	-	3.431	15.029
CO	-	0.05	3.500	15.330
PM ₁₀	7.6	-	0.522	2.284
PM _{2.5}	5.7	-	0.391	1.713
SO ₂	0.6	-	0.348	1.526

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:		
SO ₂ Mass Balance calculation:		
Fuel H ₂ S content (mol %) =	0.0030	assumptions: SO ₂ MW 64.06 lb/lb-mole Ideal Gas L 378.61 SCF/lb-mole
SO ₂ produced (lb/hr) =	0.3483	
SO ₂ produced (tpy) =	1.5258	

Emission Type: (pick from list)
Steady State (continuous)

Enter any notes here:	Using Emission Factor for CO from the Manufacturers spec and a safety factor of 25%.
-----------------------	--

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)			
EPN	5-EP-1c		
Name	Cryo Train 5 - Mole Sieve Heater		
Heater/Boiler rating (MMBtu/hr):	7.29		
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)	
Operating hours/year:	8760		
Fuel Heat Value (Btu/SCF):	1020		
Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy
VOC	5.5	0.039	0.172
NOx	50	0.357	1.565
CO	84	0.600	2.630
PM ₁₀	7.6	0.054	0.238
PM _{2.5}	5.7	0.041	0.178
SO ₂	0.6	0.036	0.159

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:			
SO ₂ Mass Balance calculation:			
Fuel H ₂ S content (mol %) =	0.0030		
SO ₂ produced (lb/hr) =	0.0363		
SO ₂ produced (tpy) =	0.1589		
		assumptions:	
		SO2 MW	64.06 lb/lb-mole
		Ideal Gas Law	378.61 SCF/lb-mole

Enter any notes here:	
-----------------------	--

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)				
EPN	5-EP-1d			
Name	Cryo Train 5 - HMO Heater			
Heater/Boiler rating (MMBtu/hr):	17.55			
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)		
Operating hours/year:	8760			
Fuel Heat Value (Btu/SCF):	1020			
Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy	
VOC	5.5	0.095	0.414	
NOx	50	0.860	3.768	
CO	84	1.445	6.330	
PM ₁₀	7.6	0.131	0.573	
PM _{2.5}	5.7	0.098	0.430	
SO ₂	0.6	0.087	0.383	

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:				
SO ₂ Mass Balance calculation:				
Fuel H ₂ S content (mol %) =	0.0030			
SO ₂ produced (lb/hr) =	0.0873			
SO ₂ produced (tpy) =	0.3825			
	assumptions:			
	SO2 MW	64.06 lb/lb-mole		
	Ideal Gas Law	378.61 SCF/lb-mole		

Enter any notes here:	PM EF = 0.014lb/MMBtu @16ppm
-----------------------	------------------------------

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

C) Make sure to select the correct *Emission Type* from the pull down menus below. A *VOC type* does not need to be

Heater and Boiler Emission Calculations (fueled by natural gas)				
EPN	6-EP-1a			
Name	Train 5 - Amine/Glycol Reboiler 1			
Heater/Boiler rating (MMBtu/hr):	70			
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner		(assume uncontrolled, unless specifically stated otherwise)	
Operating hours/year:	8760			
Fuel Heat Value (Btu/SCF):	1020			
Pollutant	Emission Factor (lb/MMCF)	Emission Factor (lb/MMBtu)	lb/hr	tpy
VOC	5.5	-	0.377	1.653
NOx	50	-	3.431	15.029
CO	-	0.05	3.500	15.330
PM ₁₀	7.6	-	0.522	2.284
PM _{2.5}	5.7	-	0.391	1.713
SO ₂	0.6	-	0.348	1.526

If the heater/boiler is fueled by Sour Gas, <u>cannot</u> use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:		
SO₂ Mass Balance calculation:		
Fuel H ₂ S content (mol %) =	0.0030	assumptions: SO ₂ MW 64.06 lb/lb-mole Ideal Gas I 378.61 SCF/lb-mole
SO ₂ produced (lb/hr) =	0.3483	
SO ₂ produced (tpy) =	1.5258	

Emission Type: (pick from list)
Steady State (continuous)

Enter any notes here:	Using Emission Factor for CO from the Manufacturers spec and a safety factor of 25%.
------------------------------	--

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

C) Make sure to select the correct *Emission Type* from the pull down menus below. A *VOC type* does not need to be

Heater and Boiler Emission Calculations (fueled by natural gas)				
EPN	6-EP-1b			
Name	Train 5 - Amine/Glycol Reboiler 1			
Heater/Boiler rating (MMBtu/hr):	70			
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)		
Operating hours/year:	8760			
Fuel Heat Value (Btu/SCF):	1020			
Pollutant	Emission Factor (lb/MMCF)	Emission Factor (lb/MMBtu)	lb/hr	tpy
VOC	5.5	-	0.377	1.653
NOx	50	-	3.431	15.029
CO	-	0.05	3.500	15.330
PM ₁₀	7.6	-	0.522	2.284
PM _{2.5}	5.7	-	0.391	1.713
SO ₂	0.6	-	0.348	1.526

If the heater/boiler is fueled by Sour Gas, <u>cannot</u> use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:		
SO ₂ Mass Balance calculation:		
Fuel H ₂ S content (mol %) =	0.0030	assumptions: SO ₂ MW 64.06 lb/lb-mole Ideal Gas L 378.61 SCF/lb-mole
SO ₂ produced (lb/hr) =	0.3483	
SO ₂ produced (tpy) =	1.5258	

Emission Type: (pick from list)
Steady State (continuous)

Enter any notes here:	Using Emission Factor for CO from the Manufacturers spec and a safety factor of 25%.
-----------------------	--

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)			
EPN	6-EP-1c		
Name	Cryo Train 6 - Mole Sieve Heater		
Heater/Boiler rating (MMBtu/hr):	7.29		
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)	
Operating hours/year:	8760		
Fuel Heat Value (Btu/SCF):	1020		

Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy
VOC	5.5	0.039	0.172
NOx	50	0.357	1.565
CO	84	0.600	2.630
PM ₁₀	7.6	0.054	0.238
PM _{2.5}	5.7	0.041	0.178
SO ₂	0.6	0.036	0.159

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:			
SO ₂ Mass Balance calculation:			
Fuel H ₂ S content (mol %) =	0.0030		
SO ₂ produced (lb/hr) =	0.0363		
SO ₂ produced (tpy) =	0.1589		
		assumptions:	
		SO2 MW	64.06 lb/lb-mole
		Ideal Gas Law	378.61 SCF/lb-mole

Enter any notes here:	
-----------------------	--

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)				
EPN	6-EP-1d			
Name	Cryo Train 6 - HMO Heater			
Heater/Boiler rating (MMBtu/hr):	17.55			
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)		
Operating hours/year:	8760			
Fuel Heat Value (Btu/SCF):	1020			
Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy	
VOC	5.5	0.095	0.414	
NOx	50	0.860	3.768	
CO	84	1.445	6.330	
PM ₁₀	7.6	0.131	0.573	
PM _{2.5}	5.7	0.098	0.430	
SO ₂	0.6	0.087	0.383	

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:				
SO ₂ Mass Balance calculation:				
Fuel H ₂ S content (mol %) =	0.0030			
SO ₂ produced (lb/hr) =	0.0873			
SO ₂ produced (tpy) =	0.3825			
	assumptions:			
	SO2 MW	64.06 lb/lb-mole		
	Ideal Gas Law	378.61 SCF/lb-mole		

Enter any notes here:	
-----------------------	--

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)			
EPN	7-EP-1c		
Name	Cryo Train 7 - Mole Sieve Heater		
Heater/Boiler rating (MMBtu/hr):	7.29		
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)	
Operating hours/year:	8760		
Fuel Heat Value (Btu/SCF):	1020		

Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy
VOC	5.5	0.039	0.172
NOx	50	0.357	1.565
CO	84	0.600	2.630
PM ₁₀	7.6	0.054	0.238
PM _{2.5}	5.7	0.041	0.178
SO ₂	0.6	0.036	0.159

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:			
SO ₂ Mass Balance calculation:			
Fuel H ₂ S content (mol %) =	0.0030		
SO ₂ produced (lb/hr) =	0.0363		
SO ₂ produced (tpy) =	0.1589		
		assumptions:	
		SO ₂ MW	64.06 lb/lb-mole
		Ideal Gas Law	378.61 SCF/lb-mole

Enter any notes here:	
-----------------------	--

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)				
EPN	7-EP-1d			
Name	Cryo Train 7 - HMO Heater			
Heater/Boiler rating (MMBtu/hr):	17.55			
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)		
Operating hours/year:	8760			
Fuel Heat Value (Btu/SCF):	1020			
Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy	
VOC	5.5	0.095	0.414	
NOx	50	0.860	3.768	
CO	84	1.445	6.330	
PM ₁₀	7.6	0.131	0.573	
PM _{2.5}	5.7	0.098	0.430	
SO ₂	0.6	0.087	0.383	

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:				
SO ₂ Mass Balance calculation:				
Fuel H ₂ S content (mol %) =	0.0030			
SO ₂ produced (lb/hr) =	0.0873			
SO ₂ produced (tpy) =	0.3825			
	assumptions:			
	SO2 MW	64.06 lb/lb-mole		
	Ideal Gas Law	378.61 SCF/lb-mole		

Enter any notes here:	
-----------------------	--

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

C) Make sure to select the correct *Emission Type* from the pull down menus below. A *VOC type* does not need to be

Heater and Boiler Emission Calculations (fueled by natural gas)				
EPN	5.5-EP-1b			
Name	AGI 2 Reboiler			
Heater/Boiler rating (MMBtu/hr):	70			
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner			(assume uncontrolled, unless specifically stated otherwise)
Operating hours/year:	8760			
Fuel Heat Value (Btu/SCF):	1020			

Pollutant	Emission Factor (lb/MMCF)	Emission Factor (lb/MMBtu)	lb/hr	tpy
VOC	5.5	-	0.377	1.653
NOx	50	-	3.431	15.029
CO	-	0.05	3.500	15.330
PM ₁₀	7.6	-	0.522	2.284
PM _{2.5}	5.7	-	0.391	1.713
SO ₂	0.6	-	0.348	1.526

If the heater/boiler is fueled by Sour Gas, <u>cannot</u> use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:		
SO ₂ Mass Balance calculation:		
Fuel H ₂ S content (mol %) =	0.0030	assumptions: SO ₂ MW 64.06 lb/lb-mole Ideal Gas L 378.61 SCF/lb-mole
SO ₂ produced (lb/hr) =	0.3483	
SO ₂ produced (tpy) =	1.5258	

Emission Type: (pick from list)
Steady State (continuous)

Enter any notes here:	Using Emission Factor for CO from the Manufacturers spec and a safety factor of 25%.
-----------------------	--

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)			
EPN	4-EP-1g		
Name	Train 4 - Stabilizer Heater		
Heater/Boiler rating (MMBtu/hr):	4.5		
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)	
Operating hours/year:	8760		
Fuel Heat Value (Btu/SCF):	1020		
Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy
VOC	5.5	0.024	0.106
NOx	50	0.221	0.966
CO	84	0.371	1.623
PM ₁₀	7.6	0.034	0.147
PM _{2.5}	5.7	0.025	0.110
SO ₂	0.6	0.022	0.098

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:			
SO ₂ Mass Balance calculation:			
Fuel H ₂ S content (mol %) =	0.0030		
SO ₂ produced (lb/hr) =	0.0224		
SO ₂ produced (tpy) =	0.0981		
		assumptions:	
		SO2 MW	64.06 lb/lb-mole
		Ideal Gas Law	378.61 SCF/lb-mole

Enter any notes here:	These are updated emissions from 4-EP-1g. Previously permitted at 18MMBtu/hr heater/boiler rating.
-----------------------	--

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)			
EPN	2-EP-1a		
Name	Train 2 - Mol Sieve Heater		
Heater/Boiler rating (MMBtu/hr):	5.6		
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)	
Operating hours/year:	8760		
Fuel Heat Value (Btu/SCF):	1020		
Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy
VOC	5.5	0.030	0.132
NOx	50	0.275	1.202
CO	84	0.461	2.020
PM ₁₀	7.6	0.042	0.183
PM _{2.5}	5.7	0.031	0.137
SO ₂	0.6	0.028	0.122

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:			
SO ₂ Mass Balance calculation:			
Fuel H ₂ S content (mol %) =	0.0030		
SO ₂ produced (lb/hr) =	0.0279		
SO ₂ produced (tpy) =	0.1221		
		assumptions:	
		SO2 MW	64.06 lb/lb-mole
		Ideal Gas Law	378.61 SCF/lb-mole

Enter any notes here:	These are updated emissions from 2-EP-1a. These are low NOx burner, previously permitted at 'below 100 MMBtu/hr, uncontrolled'.
-----------------------	---

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)			
EPN	2-EP-1b		
Name	Train 2 - HMO Heater		
Heater/Boiler rating (MMBtu/hr):	23.65		
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)	
Operating hours/year:	8760		
Fuel Heat Value (Btu/SCF):	1020		
Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy
VOC	5.5	0.128	0.559
NOx	50	1.159	5.078
CO	84	1.948	8.531
PM ₁₀	7.6	0.176	0.772
PM _{2.5}	5.7	0.132	0.579
SO ₂	0.6	0.118	0.515

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:			
SO ₂ Mass Balance calculation:			
Fuel H ₂ S content (mol %) =	0.0030		
SO ₂ produced (lb/hr) =	0.1177		
SO ₂ produced (tpy) =	0.5155		
		assumptions:	
		SO2 MW	64.06 lb/lb-mole
		Ideal Gas Law	378.61 SCF/lb-mole

Enter any notes here:	These are updated emissions from 2-EP-1b. These are low NOx burner, previously permitted at 'below 100 MMBtu/hr, uncontrolled'.
-----------------------	---

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)			
EPN	3-EP-1a		
Name	Train 3 - Mol Sieve Heater		
Heater/Boiler rating (MMBtu/hr):	7.29		
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)	
Operating hours/year:	8760		
Fuel Heat Value (Btu/SCF):	1020		

Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy
VOC	5.5	0.039	0.172
NOx	50	0.357	1.565
CO	84	0.600	2.630
PM ₁₀	7.6	0.054	0.238
PM _{2.5}	5.7	0.041	0.178
SO ₂	0.6	0.036	0.159

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:			
SO ₂ Mass Balance calculation:			
Fuel H ₂ S content (mol %) =	0.0030		
SO ₂ produced (lb/hr) =	0.0363		
SO ₂ produced (tpy) =	0.1589		
		assumptions:	
		SO2 MW	64.06 lb/lb-mole
		Ideal Gas Law	378.61 SCF/lb-mole

Enter any notes here:	These are updated emissions from 3-EP-1a. These are low NOx burner, previously permitted at 'below 100 MMBtu/hr, uncontrolled'.
-----------------------	---

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)				
EPN	3-EP-1b			
Name	Train 3 - HMO Heater			
Heater/Boiler rating (MMBtu/hr):	17.55			
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)		
Operating hours/year:	8760			
Fuel Heat Value (Btu/SCF):	1020			
Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy	
VOC	5.5	0.095	0.414	
NOx	50	0.860	3.768	
CO	84	1.445	6.330	
PM ₁₀	7.6	0.131	0.573	
PM _{2.5}	5.7	0.098	0.430	
SO ₂	0.6	0.087	0.383	

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:				
SO ₂ Mass Balance calculation:				
Fuel H ₂ S content (mol %) =	0.0030			
SO ₂ produced (lb/hr) =	0.0873			
SO ₂ produced (tpy) =	0.3825			
	assumptions:			
	SO2 MW	64.06 lb/lb-mole		
	Ideal Gas Law	378.61 SCF/lb-mole		

Enter any notes here:	These are updated emissions from 3-EP-1b. These are low NOx burner, previously permitted at 'below 100 MMBtu/hr, uncontrolled'.
-----------------------	---

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)			
EPN	4-EP-1a		
Name	Train 4 - Mol Sieve Heater		
Heater/Boiler rating (MMBtu/hr):	7.29		
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)	
Operating hours/year:	8760		
Fuel Heat Value (Btu/SCF):	1020		

Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy
VOC	5.5	0.039	0.172
NOx	50	0.357	1.565
CO	84	0.600	2.630
PM ₁₀	7.6	0.054	0.238
PM _{2.5}	5.7	0.041	0.178
SO ₂	0.6	0.036	0.159

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:			
SO ₂ Mass Balance calculation:			
Fuel H ₂ S content (mol %) =	0.0030		
SO ₂ produced (lb/hr) =	0.0363		
SO ₂ produced (tpy) =	0.1589		
		assumptions:	
		SO2 MW	64.06 lb/lb-mole
		Ideal Gas Law	378.61 SCF/lb-mole

Enter any notes here:	These are updated emissions from 4-EP-1a. These are low NOx burner, previously permitted at 'below 100 MMBtu/hr, uncontrolled'.
-----------------------	---

Heaters-Boilers Emissions

A) Enter information into the yellow boxes.

B) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Heater and Boiler Emission Calculations (fueled by natural gas)				
EPN	4-EP-1b			
Name	Train 4 - HMO Heater			
Heater/Boiler rating (MMBtu/hr):	17.55			
Rating above is (select from list):	below 100 MMBtu/hp-hr, controlled - low NOx burner	(assume uncontrolled, unless specifically stated otherwise)		
Operating hours/year:	8760			
Fuel Heat Value (Btu/SCF):	1020			
Pollutant	Emission Factor (lb/MMCF)	lb/hr	tpy	
VOC	5.5	0.095	0.414	
NOx	50	0.860	3.768	
CO	84	1.445	6.330	
PM ₁₀	7.6	0.131	0.573	
PM _{2.5}	5.7	0.098	0.430	
SO ₂	0.6	0.087	0.383	

If the heater/boiler is fueled by Sour Gas, cannot use emission factors above to calculate SO ₂ emissions, must use SO ₂ mass balance:				
SO ₂ Mass Balance calculation:				
Fuel H ₂ S content (mol %) =	0.0030			
SO ₂ produced (lb/hr) =	0.0873			
SO ₂ produced (tpy) =	0.3825			
	assumptions:			
	SO2 MW	64.06 lb/lb-mole		
	Ideal Gas Law	378.61 SCF/lb-mole		

Enter any notes here:	These are updated emissions from 4-EP-1b. These are low NOx burner, previously permitted at 'below 100 MMBtu/hr, uncontrolled'.
-----------------------	---

Heaters-Boilers HAPs Emissions

Emission Unit EPN	Name	Heater Rating (MMBtu/hr)	Benzene		Toulene		Hexane	
			lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
5-EP-1a	Train 5 - Amine/Glycol Reboiler 1	75	0.0002	0.0007	0.0003	0.0011	0.1324	0.5797
5-EP-1b	Train 5 - Amine/Glycol Reboiler 2	70	0.0001	0.0006	0.0002	0.0010	0.1235	0.5411
5-EP-1c	Cryo Train 5 - Mole Sieve Heater	7.29	0.0000	0.0001	0.0000	0.0001	0.0129	0.0563
5-EP-1d	Cryo Train 5 - HMO Heater	17.55	0.0000	0.0002	0.0001	0.0003	0.0310	0.1357
6-EP-1c	Cryo Train 6 - Mole Sieve Heater	7.29	0.0000	0.0001	0.0000	0.0001	0.0129	0.0563
6-EP-1d	Cryo Train 6 - HMO Heater	17.55	0.0000	0.0002	0.0001	0.0003	0.0310	0.1357
6-EP-1a	Train 6 - Amine/Glycol Reboiler 1	70	0.0001	0.0006	0.0002	0.0010	0.1235	0.5411
6-EP-1b	Train 6 - Amine/Glycol Reboiler 2	70	0.0001	0.0006	0.0002	0.0010	0.1235	0.5411
7-EP-1c	Cryo Train 7 - Mole Sieve Heater	7.29	0.0000	0.0001	0.0000	0.0001	0.0129	0.0563
7-EP-1d	Cryo Train 7 - HMO Heater	17.55	0.0000	0.0002	0.0001	0.0003	0.0310	0.1357
5.5-EP-1a	AGI 2 HMO Heater	70	0.0001	0.0006	0.0002	0.0010	0.1235	0.5411
4-EP-1g	Train 4 - Stabilizer Heater	4.98	0.0000	0.0000	0.0000	0.0001	0.0088	0.0385
Total Emissions			0.0009	0.0039	0.0014	0.0063	0.7580	3.3199

Emission Factors		
	<u>Emission Factors from</u> AP-42 Table 1.4-3 (lb/10 ⁶ scf)	<u>Emission Factors</u> (lb/MMBtu)
Benzene	2.10E-03	2.06E-06
Hexane	1.8	1.76E-03
Pyrene	5.00E-06	4.90E-09
Toulene	3.40E-03	3.33E-06

Tank Emissions - Process Simulator

A) Enter information into the yellow boxes.

B) VOC and H₂S control efficiencies may be entered (if applicable).

C) A reduction for produced water tank emissions calculated as oil/condensate may be entered.

D) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

Analysis of Head Space from Sour Water Tanks

Composition	Mol%	MW	grams per		lb/hr	tpy
			moles of gas	wt%		
Hydrogen Sulfide	0.083%	34.076	0.03	0.05%	0.00	0.01
Nitrogen	4.397%	28.013	1.23	2.07%	0.06	0.28
Carbon Dioxide	0.023%	44.01	0.01	0.02%	0.00	0.00
Methane	4.015%	16.043	0.64	1.08%	0.03	0.15
Ethane	0.570%	30.07	0.17	0.29%	0.01	0.04
Propane	11.837%	44.097	5.22	8.78%	0.27	1.19
Isobutane	12.712%	58.123	7.39	12.43%	0.38	1.68
N-Butane	30.465%	58.123	17.71	29.79%	0.92	4.03
Isopentane	16.224%	72.15	11.71	19.69%	0.61	2.66
N-Pentane	11.506%	72.15	8.30	13.96%	0.43	1.89
Hexanes +	8.168%	86.178	7.04	11.84%	0.37	1.60
VOC Total	90.912%		59.45	96.49%	2.98	13.05
Total	100%			100.00%	3.09	13.52

Uncontrolled Emissions¹

Unit	VOC tpy	Total HAP tpy	Benzene tpy	Toluene tpy	Ethylbenzene tpy	2,2,4-Trimethylpentane tpy	p-Xylene tpy	H2S tpy
4-T-1	13.05	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.006
4-T-2	13.05	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.006

Controlled Emissions²

Unit	VOC tpy	Total HAP tpy	Benzene tpy	Toluene tpy	Ethylbenzene tpy	2,2,4-Trimethylpentane tpy	p-Xylene tpy
Emissions from units 4-T are routed to the flare, unit EP-13. Controlled emissions are represented under unit EP-13.							

Stream Properties					
	Pressurized Inlet	Flashing Losses	Working Losses	Breathing Losses	Total Losses
MV [lb/lbmol]	18.03	40.00	34.08	34.08	
Heating Value [BTU/scf]	-	96.6	182.6	182.6	
Specific Gravity	-	-	-	-	-
Reid Vapor Pressure [psi]	2.48	-	-	-	-
Gas Volumetric Flow [scf/hr]	-	6.18	0.00	13.82	19.99

SHAMROCK GAS ANALYSIS, INC.



LABORATORY REFERENCE NUMBER : **E46489 - FT7374**

LUCID ENERGY

<p>ID: RED HILLS PLANT ACID GAS AREA: NOT/REC METER: SOUR WATER TANKS LEASE: SOUR WATER TANKS OPERATOR: LUCID STATION: RED HILLS PLANT ACID GAS SAMPLE DATE: 5/30/2018 SAMPLE OF: GAS</p>	<p>LINE PRESSURE: 10 PSI LINE TEMPERATURE: 99 F CYLINDER NUMBER: 6341 EFFECTIVE DATE: 6/1/2018 SAMPLED BY: M. BRENNAN ANALYZED BY: BRENNAN ANALYZED DATE: 6/1/2018 SAMPLE TYPE: SPOT</p>
--	---

For: **LUCID ENERGY**
 Attn: **T. KIRK**
288 KINCAID ROAD
ARTESIA, NEW MEXICO 88210

Physical Properties per GPA 2145-09

Calculations per GPA 2172-09

Note: Zero = Less than detection limit

	<u>MOL%</u>	<u>GPM @ 14.73</u>
HYDROGEN SULFIDE	0.083	0.012
NITROGEN	4.397	0.501
CARBON DIOXIDE	0.023	0.004
METHANE	4.015	0.705
ETHANE	0.570	0.158
PROPANE	11.837	3.376
ISOBUTANE	12.712	4.306
N-BUTANE	30.465	9.943
ISOPENTANE	16.224	6.142
N-PENTANE	11.506	4.318
HEXANES PLUS	8.168	3.690
	100.000	33.155

BTU	Vol. Ideal	Vol. Real
	Gas Fuel	Gas Fuel
BTU @ 14.73 PSIA (DRY)	3293.1	3410.0
BTU @ 14.73 PSIA (SAT.)	3235.8	3352.1
Specific Gravity	2.0723	2.1449
Compressibility (Z)	0.9657	

Gasoline Content (Gallons Per Thousand - GPM)

Ethane & Heavier	31.933
Propane & Heavier	31.775
Butane & Heavier	28.399
Pentane & Heavier	14.150
Total 26 psi Reid V.P. Gasoline GPM	19.438

Remarks: Field H2S ppm = 830 (TUTWILER) HEAD SPACE FROM SOUR WATER TANKS
Remarks: NO PREVIOUS BTU AVAILABLE

Tank Emissions - Process Simulator

A) Enter information into the yellow boxes.

B) VOC and H₂S control efficiencies may be entered (if applicable).

C) A reduction for produced water tank emissions calculated as oil/condensate may be entered.

D) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

E) Make sure to answer the control device question.

Process Simulator																							
EPN	Tank Identifier	Throughput (gal/year)	Stream Identification	Turnovers per year	Mixture/Component	RVP (psia)	Temperature (°F)	Emissions Uncontrolled VOC (lb/hr)	Emissions Uncontrolled VOC (ton/yr)	Emissions Uncontrolled Benzene (lb/hr)	Emissions Uncontrolled Benzene (ton/yr)	Emissions Uncontrolled H ₂ S (lb/hr)	Emissions Uncontrolled H ₂ S (ton/yr)	Are tank vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	VOC Control Efficiency (%)	H ₂ S Control Efficiency (%)	Percent Reduction for Produced Water Tank Calc. as Oil/Cond. (%)	VOC Results (lb/hr)	VOC Results (tpy)	Benzene Results (lb/hr)	Benzene Results (tpy)	H ₂ S Results (lb/hr)	H ₂ S Results (tpy)
5-T-1	Stop Tanks	927465	Mol Sieve - Stream	55	Slop	1.04	111.62	0.083	0.36354	0.006	0.02628	0	0	(A) uncontrolled				0.08	0.36	0.01	0.03	0.00	0.00
5-T-2	Stop Tanks	927465	Mol Sieve - Stream	55	Slop	1.04	111.62	0.083	0.36354	0.006	0.02628	0	0	(A) uncontrolled				0.08	0.36	0.01	0.03	0.00	0.00
5-T-3	Stop Tanks	927465	Mol Sieve - Stream	55	Slop	1.04	111.62	0.083	0.36354	0.006	0.02628	0	0	(A) uncontrolled				0.08	0.36	0.01	0.03	0.00	0.00
5-T-4	Stop Tanks	927465	Mol Sieve - Stream	55	Slop	1.04	111.62	0.083	0.36354	0.006	0.02628	0	0	(A) uncontrolled				0.00	0.00	0.00	0.00	0.00	0.00
																		0.00	0.00	0.00	0.00	0.00	0.00
Totals:																		0.33	1.45	0.02	0.11	0.00	0.00

Enter any notes here:

Loading Emissions

A) Enter information into the yellow boxes.

B) VOC and H₂S control and collection efficiencies may be entered (if applicable).

C) The vapor VOC, benzene, and H₂S weight percents may be entered.

D) There are two separate areas below to calculate hourly and annual loading emissions. Then underneath, there is a table summarizing the hourly and annual loading emissions.

E) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

F) If vapor balancing is being performed and the tank is not being controlled, contact TCEQ about the appropriate tank working loss calculation.

G) Make sure to answer the control device question.

EPN	2-LOAD
Identifier	Sour Water Tanks Truck Loading

Truck Hourly Loading Emission Calculations

Using equation $L_v = 12.46 \cdot \text{SPM/T}$ from AP-42, Chapter 5, Section 5.2-4

S =	0.60	Saturation Factor
P =	18.27	True vapor pressure of liquid loaded (psia)
M =	41.52	Molecular Weight of Vapors (lb/lb-mole)
T =	554.67	Temperature of bulk liquid loaded (in degrees Rankine)
Hourly Loading Rate	8000	Gallons Loaded per Hour
L_v =	10.22	Loading Loss (lb VOC released/1000 gal liquid loaded)
	81.79	VOC Uncontrolled Emissions (lb/hr)

Are loading vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(B) cont. by flare/ VC/TO/VRU
---	-------------------------------

Vapor Weight Percents

VOC	96.49	Vapor VOC wt%
benzene	0.00	Vapor Benzene wt%
H ₂ S	0.05	Vapor H ₂ S wt%

Produced Water Reduction

		Percent Reduction for Produced Water Tank Calc. as Oil/Cond. (%)
--	--	--

Uncontrolled Emissions

VOC	78.92	Emissions Uncontrolled VOC (lb/hr)
benzene	0.00	Emissions Uncontrolled Benzene (lb/hr)
H ₂ S	0.04	Emissions Uncontrolled H ₂ S (lb/hr)

Collection Efficiency

	70.00	Collection Efficiency (%)
--	-------	---------------------------

Vapors Uncaptured by Control Device

VOC	23.68	VOC Uncaptured Vapors (lb/hr)
benzene	0.00	benzene Uncaptured Vapors (lb/hr)
H ₂ S	0.01	H ₂ S Uncaptured Vapors (lb/hr)

Vapors Captured by Control Device

VOC	55.25	VOC Captured Vapors (lb/hr)
benzene	0.00	benzene Captured Vapors (lb/hr)
H ₂ S	0.03	H ₂ S Captured Vapors (lb/hr)

Control Efficiency

VOC	95.00	VOC Control Efficiency (%)
H ₂ S	95.00	H ₂ S Control Efficiency (%)

Vapors Uncontrolled by Control Device (Controlled Emissions)

VOC	2.76	VOC Results (lb/hr)
benzene	0.00	Benzene Results (lb/hr)
H ₂ S	0.00	H ₂ S Results (lb/hr)

Enter temperature in Fahrenheit (°F):	Temperature in Rankine (°R):
95	554.67

Enter Barrels of Liquid	Gallons of liquid:
600	25200

Enter gallons per year	Barrels per day:
9198000	600

Enter any notes here:
Updating the percentages used in the previous application.

Truck Annual Loading Emission Calculations

Using equation $L_L = 12.46 \cdot SPM/T$ from AP-42, Chapter 5, Section 5.2-4

S =	0.60	= Saturation Factor
P =	18.27	= True vapor pressure of liquid loaded (psia)
M =	41.52	= Molecular Weight of Vapors (lb/lb-mole)
T =	522.07	= Temperature of bulk liquid loaded (in degrees Rankine)
Annual Loading Rate	9198000	= Gallons Loaded per Year
L _L =	10.86	Loading Loss (lb VOC released/1000 gal liquid loaded)
	49.95	VOC Uncontrolled Emissions (ton/yr)

Vapor Weight Percents

VOC	96.49	Vapor VOC wt%
benzene	0.00	Vapor Benzene wt%
H ₂ S	0.05	Vapor H ₂ S wt%

Produced Water Reduction

		Percent Reduction for Produced Water Tank Calc. as Oil/Cond. (%)
--	--	--

Uncontrolled Emissions

VOC	48.20	Emissions Uncontrolled VOC (ton/yr)
benzene	0.00	Emissions Uncontrolled Benzene (ton/yr)
H ₂ S	0.02	Emissions Uncontrolled H ₂ S (ton/yr)

Collection Efficiency

	70.00	Collection Efficiency (%)
--	-------	---------------------------

Vapors Uncaptured by Control Device

VOC	14.46	VOC Uncaptured Vapors (ton/yr)
benzene	0.00	benzene Uncaptured Vapors (ton/yr)
H ₂ S	0.01	H ₂ S Uncaptured Vapors (ton/yr)

Vapors Captured by Control Device

VOC	33.74	VOC captured Vapors (lb/hr)
benzene	0.00	benzene captured Vapors (lb/hr)
H ₂ S	0.02	H ₂ S captured Vapors (lb/hr)

Control Efficiency

VOC	95.00	VOC Control Efficiency (%)
H ₂ S	95.00	H ₂ S Control Efficiency (%)

Vapors Uncontrolled by Control Device (Controlled Emissions)

VOC	1.69	VOC Results (ton/yr)
benzene	0.00	Benzene Results (ton/yr)
H ₂ S	0.00	H ₂ S Results (ton/yr)

Loading Emissions

	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
VOC	23.68	14.46
benzene	0.00	0.00
H ₂ S	0.01	0.01

0.012269

Enter temperature in Fahrenheit (°F):	Temperature in Rankine (°R):
62.4	522.07

Enter Barrels of Liquid	Gallons of liquid:
600	25200

Enter gallons per year	Barrels per day:
9198000	600

Enter any notes here:

Loading Emissions

A) Enter information into the yellow boxes.

B) VOC and H₂S control and collection efficiencies may be entered (if applicable).

C) The vapor VOC, benzene, and H₂S weight percents may be entered.

D) There are two separate areas below to calculate hourly and annual loading emissions. Then underneath, there is a table summarizing the hourly and annual loading emissions.

E) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).

F) If vapor balancing is being performed and the tank is not being controlled, contact TCEQ about the appropriate tank working loss calculation.

G) Make sure to answer the control device question.

EPN	3-LOAD
Identifier	Condensate Tanks Truck Loading

Truck Hourly Loading Emission Calculations

Using equation $L_v = 12.46 \cdot \text{SPM/T}$ from AP-42, Chapter 5, Section 5.2-4

S =	0.60	Saturation Factor
P =	9.06	True vapor pressure of liquid loaded (psia)
M =	75.03	Molecular Weight of Vapors (lb/lb-mole)
T =	570.88	Temperature of bulk liquid loaded (in degrees Rankine)
Hourly Loading Rate	8000	Gallons Loaded per Hour
L _v =	8.90	Loading Loss (lb VOC released/1000 gal liquid loaded)
	71.22	VOC Uncontrolled Emissions (lb/hr)

Are loading vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(B) cont. by flare/ VC/TO/VRU
---	-------------------------------

Vapor Weight Percents

VOC	100.00	Vapor VOC wt%
benzene	1.49	Vapor Benzene wt%
H ₂ S	0.00	Vapor H ₂ S wt%

Produced Water Reduction

	0.00	Percent Reduction for Produced Water Tank Calc. as Oil/Cond. (%)
--	------	--

Uncontrolled Emissions

VOC	71.22	Emissions Uncontrolled VOC (lb/hr)
benzene	1.06	Emissions Uncontrolled Benzene (lb/hr)
H ₂ S	0.00	Emissions Uncontrolled H ₂ S (lb/hr)

Collection Efficiency

	70.00	Collection Efficiency (%)
--	-------	---------------------------

Vapors Uncaptured by Control Device

VOC	21.37	VOC Uncaptured Vapors (lb/hr)
benzene	0.32	benzene Uncaptured Vapors (lb/hr)
H ₂ S	0.00	H ₂ S Uncaptured Vapors (lb/hr)

Vapors Captured by Control Device

VOC	49.85	VOC Uncaptured Vapors (lb/hr)
benzene	0.74	benzene Uncaptured Vapors (lb/hr)
H ₂ S	0.00	H ₂ S Uncaptured Vapors (lb/hr)

Enter temperature in Fahrenheit (°F):	Temperature in Rankine (°R):
111.21	570.88

Enter Barrels of Liquid	Gallons of liquid:
3129.6	131443.2

Enter gallons per year	Barrels per day:
47976768	3129.6

Enter any notes here:

Truck Annual Loading Emission Calculations		
Using equation $L_L = 12.46 \cdot \text{SPMT}$ from AP-42, Chapter 5, Section 5.2-4		
S =	0.60	= Saturation Factor
P =	4.08	= True vapor pressure of liquid loaded (psia)
M =	75.03	= Molecular Weight of Vapors (lb/lb-mole)
T =	522.07	= Temperature of bulk liquid loaded (in degrees Rankine)
Annual Loading Rate	47976768	= Gallons Loaded per Year
L_L =	4.38	Loading Loss (lb VOC released/1000 gal liquid loaded)
	105.14	VOC Uncontrolled Emissions (ton/yr)
Vapor Weight Percents		
VOC	100.00	Vapor VOC wt%
benzene	1.49	Vapor Benzene wt%
H ₂ S	0.00	Vapor H ₂ S wt%
Produced Water Reduction		
	0.00	Percent Reduction for Produced Water Tank Calc. as Oil/Cond. (%)
Uncontrolled Emissions		
VOC	105.14	Emissions Uncontrolled VOC (ton/yr)
benzene	1.57	Emissions Uncontrolled Benzene (ton/yr)
H ₂ S	0.00	Emissions Uncontrolled H ₂ S (ton/yr)
Collection Efficiency		
	70.00	Collection Efficiency (%)
Vapors Uncaptured by Control Device		
VOC	31.54	VOC Uncaptured Vapors (ton/yr)
benzene	0.47	benzene Uncaptured Vapors (ton/yr)
H ₂ S	0.00	H ₂ S Uncaptured Vapors (ton/yr)
Vapors Captured by Control Device		
VOC	73.59	VOC captured Vapors (lb/hr)
benzene	1.10	benzene captured Vapors (lb/hr)
H ₂ S	0.00	H ₂ S captured Vapors (lb/hr)

Loading Emissions		
	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
VOC	21.37	31.54
benzene	0.32	0.47
H ₂ S	0.00	0.00

Enter temperature in Fahrenheit (°F):	Temperature in Rankine (°R):
62.4	522.07

Enter Barrels of Liquid	Gallons of liquid:
3129.6	131443.2

Enter gallons per year	Barrels per day:
47976768	3129.6

Enter any notes here:
Truck loading will be vented back to the tank which will then vent to the tank combustor.

Loading Emissions

- A) Enter information into the yellow boxes.
- B) VOC and H₂S control and collection efficiencies may be entered (if applicable).
- C) The vapor VOC, benzene, and H₂S weight percents may be entered.
- D) There are two separate areas below to calculate hourly and annual loading emissions. Then underneath, there is a table summarizing the hourly and annual loading emissions.
- E) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
- F) If vapor balancing is being performed and the tank is not being controlled, contact TCEQ about the appropriate tank working loss calculation.
- G) Make sure to answer the control device question.

EPN	4-LOAD
Identifier	Sour Water Tanks Truck Loading

Truck Hourly Loading Emission Calculations

Using equation $L_L = 12.46 \cdot \text{SPM/T}$ from AP-42, Chapter 5, Section 5.2-4

S =	0.60	Saturation Factor
P =	16.49	True vapor pressure of liquid loaded (psia)
M =	40.00	Molecular Weight of Vapors (lb/lb-mole)
T =	570.56	Temperature of bulk liquid loaded (in degrees Rankine)
Hourly Loading Rate	8000	Gallons Loaded per Hour
L _L =	8.64	Loading Loss (lb VOC released/1000 gal liquid loaded)
	69.13	VOC Uncontrolled Emissions (lb/hr)

Are loading vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device? (B) cont. by flare/ VC/TO/VRU

Vapor Weight Percents

VOC	96.49	Vapor VOC wt%
benzene	0.00	Vapor Benzene wt%
H ₂ S	0.05	Vapor H ₂ S wt%

Produced Water Reduction

		Percent Reduction for Produced Water Tank Calc. as Oil/Cond. (%)
--	--	--

Uncontrolled Emissions

VOC	66.70	Emissions Uncontrolled VOC (lb/hr)
benzene	0.00	Emissions Uncontrolled Benzene (lb/hr)
H ₂ S	0.03	Emissions Uncontrolled H ₂ S (lb/hr)

Collection Efficiency

	70.00	Collection Efficiency (%)
--	-------	---------------------------

Vapors Uncaptured by Control Device

VOC	20.01	VOC Uncaptured Vapors (lb/hr)
benzene	0.00	benzene Uncaptured Vapors (lb/hr)
H ₂ S	0.01	H ₂ S Uncaptured Vapors (lb/hr)

Vapors Captured by Control Device

VOC	46.69	VOC Captured Vapors (lb/hr)
benzene	0.00	benzene Captured Vapors (lb/hr)
H ₂ S	0.02	H ₂ S Captured Vapors (lb/hr)

Control Efficiency

VOC		VOC Control Efficiency (%)
H ₂ S		H ₂ S Control Efficiency (%)

Vapors Uncontrolled by Control Device (Controlled Emissions)

VOC	46.69	VOC Results (lb/hr)
benzene	0.00	Benzene Results (lb/hr)
H ₂ S	0.02	H ₂ S Results (lb/hr)

Enter temperature in Fahrenheit (°F):	Temperature in Rankine (°R):
110.89	570.56

Enter Barrels of Liquid	Gallons of liquid:
	0

Enter gallons per year	Barrels per day:
	0

Enter any notes here:

Truck Annual Loading Emission Calculations

Using equation $L_L = 12.46 \cdot \text{SPM/T}$ from AP-42, Chapter 5, Section 5.2-4

S =	0.60	= Saturation Factor
P =	12.18	= True vapor pressure of liquid loaded (psia)
M =	40.00	= Molecular Weight of Vapors (lb/lb-mole)
T =	522.07	= Temperature of bulk liquid loaded (in degrees Rankine)
Annual Loading Rate	1333710	= Gallons Loaded per Year
L _L =	6.98	Loading Loss (lb VOC released/1000 gal liquid loaded)
	4.65	VOC Uncontrolled Emissions (ton/yr)

Vapor Weight Percents

VOC	96.49	Vapor VOC wt%
benzene	0.00	Vapor Benzene wt%
H ₂ S	0.05	Vapor H ₂ S wt%

Produced Water Reduction

		Percent Reduction for Produced Water Tank Calc. as Oil/Cond. (%)
--	--	--

Uncontrolled Emissions

VOC	4.49	Emissions Uncontrolled VOC (ton/yr)
benzene	0.00	Emissions Uncontrolled Benzene (ton/yr)
H ₂ S	0.00	Emissions Uncontrolled H ₂ S (ton/yr)

Collection Efficiency

	70.00	Collection Efficiency (%)
--	-------	---------------------------

Vapors Uncaptured by Control Device

VOC	1.35	VOC Uncaptured Vapors (ton/yr)
benzene	0.00	benzene Uncaptured Vapors (ton/yr)
H ₂ S	0.00	H ₂ S Uncaptured Vapors (ton/yr)

Vapors Captured by Control Device

VOC	3.14	VOC captured Vapors (lb/hr)
benzene	0.00	benzene captured Vapors (lb/hr)
H ₂ S	0.00	H ₂ S captured Vapors (lb/hr)

Control Efficiency

VOC		VOC Control Efficiency (%)
H ₂ S		H ₂ S Control Efficiency (%)

Vapors Uncontrolled by Control Device (Controlled Emissions)

VOC	3.14	VOC Results (ton/yr)
benzene	0.00	Benzene Results (ton/yr)
H ₂ S	0.00	H ₂ S Results (ton/yr)

Loading Emissions

	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
VOC	20.01	1.35
benzene	0.00	0.00
H ₂ S	0.01	0.00

0.009867

Enter temperature in Fahrenheit (°F):	Temperature in Rankine (°R):
62.4	522.07

Enter Barrels of Liquid	Gallons of liquid:
87	3654

Enter gallons per year	Barrels per day:
1333710	87

Enter any notes here:

Loading Emissions

- A) Enter information into the yellow boxes.
- B) VOC and H₂S control and collection efficiencies may be entered (if applicable).
- C) The vapor VOC, benzene, and H₂S weight percents may be entered.
- D) There are two separate areas below to calculate hourly and annual loading emissions. Then underneath, there is a table summarizing the hourly and annual loading emissions.
- E) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
- F) If vapor balancing is being performed and the tank is not being controlled, contact TCEQ about the appropriate tank working loss calculation.
- G) Make sure to answer the control device question.

EPN	5-LOAD
Identifier	Slop Tanks Truck Loading

Truck Hourly Loading Emission Calculations

Using equation $L_v = 12.46 \cdot \text{SPM/T}$ from AP-42, Chapter 5, Section 5.2-4

S =	0.60	Saturation Factor
P =	15.39	True vapor pressure of liquid loaded (psia)
M =	19.56	Molecular Weight of Vapors (lb/lb-mole)
T =	571.29	Temperature of bulk liquid loaded (in degrees Rankine)
Hourly Loading Rate	8000	Gallons Loaded per Hour
L _v =	3.94	Loading Loss (lb VOC released/1000 gal liquid loaded)
	31.52	VOC Uncontrolled Emissions (lb/hr)

Are loading vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(A) uncontrolled
---	------------------

Vapor Weight Percents

VOC	11.16	Vapor VOC wt%
benzene	0.84	Vapor Benzene wt%
H ₂ S	0.00	Vapor H ₂ S wt%

Produced Water Reduction

	0.00	Percent Reduction for Produced Water Tank Calc. as Oil/Cond. (%)
--	------	--

Uncontrolled Emissions

VOC	3.52	Emissions Uncontrolled VOC (lb/hr)
benzene	0.26	Emissions Uncontrolled Benzene (lb/hr)
H ₂ S	0.00	Emissions Uncontrolled H ₂ S (lb/hr)

Control Efficiency

VOC		VOC Control Efficiency (%)
H ₂ S		H ₂ S Control Efficiency (%)

Vapors Uncontrolled by Control Device (Controlled Emissions)

VOC	0.00	VOC Results (lb/hr)
benzene	0.00	Benzene Results (lb/hr)
H ₂ S	0.00	H ₂ S Results (lb/hr)

Enter temperature in Fahrenheit (°F):	Temperature in Rankine (°R):
111.62	571.29

Enter Barrels of Liquid	Gallons of liquid:
242	10164

Enter gallons per year	Barrels per day:
3709860	242

Enter any notes here:

Truck Annual Loading Emission Calculations

Using equation $L_L = 12.46 \cdot SPM/T$ from AP-42, Chapter 5, Section 5.2-4

S =	0.60	= Saturation Factor
P =	11.36	= True vapor pressure of liquid loaded (psia)
M =	19.56	= Molecular Weight of Vapors (lb/lb-mole)
T =	522.07	= Temperature of bulk liquid loaded (in degrees Rankine)
Annual Loading Rate	3709860	= Gallons Loaded per Year
L_L =	3.18	Loading Loss (lb VOC released/1000 gal liquid loaded)
	5.90	VOC Uncontrolled Emissions (ton/yr)

Vapor Weight Percents

VOC	11.16	Vapor VOC wt%
benzene	0.84	Vapor Benzene wt%
H ₂ S	0.00	Vapor H ₂ S wt%

Produced Water Reduction

		Percent Reduction for Produced Water Tank Calc. as Oil/Cond. (%)
--	--	--

Uncontrolled Emissions

VOC	0.66	Emissions Uncontrolled VOC (ton/yr)
benzene	0.05	Emissions Uncontrolled Benzene (ton/yr)
H ₂ S	0.00	Emissions Uncontrolled H ₂ S (ton/yr)

Control Efficiency

VOC		VOC Control Efficiency (%)
H ₂ S		H ₂ S Control Efficiency (%)

Vapors Uncontrolled by Control Device (Controlled Emissions)

VOC	0.00	VOC Results (ton/yr)
benzene	0.00	Benzene Results (ton/yr)
H ₂ S	0.00	H ₂ S Results (ton/yr)

Loading Emissions

	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
VOC	3.52	0.66
benzene	0.26	0.05
H ₂ S	0.00	0.00

Enter temperature in Fahrenheit (°F):	Temperature in Rankine (°R):
62.4	522.07

Enter Barrels of Liquid	Gallons of liquid:
242	10164

Enter gallons per year	Barrels per day:
3709860	242

Enter any notes here:

Glycol Dehydrator Emissions

Calculated Using GRI-GLYCalc or a Process Simulator

- A) Enter information into the yellow boxes.
- B) VOC and H₂S control efficiencies may be entered (if applicable). VOC, benzene, and H₂S regenerator condenser efficiencies may also be entered (if applicable).
- C) There are two separate areas to enter information about the two emissions points, the flash tank and the regenerator. Then underneath, there is a table of the sum of flash tank and regenerator emissions.
- D) The program results and any lab analysis results used as the calculation basis must be provided.
- E) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
- F) Make sure to answer the control device question.

EPN	5-EP-1e
Identifier	Train 5 - Glycol Dehy

<u>Glycol Dehydrator Unit Information</u>	
Are you using GLYCalc or a Process Simulator?	Process Simulator
GLYCalc Calculation Method (if using GLYCalc)	NA
Type of Glycol Used:	TEG
Annual Hours of Operation (hrs/yr):	8760
Dry Gas Flow Rate (MMscf/day)	230.586
Laboratory Wet Gas Analysis Provided? If not, explain why. (Use notes box below if more space needed.)	Yes
Date of Sample:	
Is sample site specific or representative? If representative, please justify. (Use notes box below if more space needed.)	Site specific
At what point in the process was the sample taken?	
Wet Gas Temperature (°F)	120
Wet Gas Pressure (psig)	864.696
Lean Glycol Pump Type	electric
Lean Glycol Pump Make and Model	
Lean Glycol Flow Rate (gpm)	63.2206
Number of Pump Stokes per Minute for the Lean Glycol Pump (pump strokes/min, if applicable)	NA
Flash Tank Temperature (°F)	134.689
Flash Tank Pressure (psig)	60.999951

<u>Flash Tank</u>		
Is there a flash tank? (If no, leave the inputs in this block blank.)	Yes	-
	lb/hr	tpy
Emissions Uncontrolled VOC,(lb/hr, tpy)	112.6996	493.624248
Emissions Uncontrolled Benzene, (lb/hr, tpy)	0.366365	1.6046787
Emissions Uncontrolled H ₂ S, (lb/hr, tpy)	0	0
Are flash tank vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(C) cont. by other control device	-
VOC Control Efficiency (%)	100	-
H ₂ S Control Efficiency (%)	100	-
VOC Results, (lb/hr, tpy)	0	0
Benzene Results, (lb/hr, tpy)	0	0
H ₂ S Results, (lb/hr, tpy)	0	0

<u>Regenerator</u>		
	lb/hr	tpy
Emissions Uncontrolled VOC (lb/hr, tpy)	146.9236	643.525368
Emissions Uncontrolled Benzene, (lb/hr, tpy)	21.0816	92.337408
Emissions Uncontrolled H ₂ S, (lb/hr, tpy)	0	0
Are regenerator vapors controlled by a condenser?	Yes	-
VOC Condenser Efficiency (%) - <i>if applicable</i>	0	-
Benzene Condenser Efficiency (%) - <i>if applicable</i>	0	-
H ₂ S Condenser Efficiency (%) - <i>if applicable</i>	0	-
Are regenerator vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(B) cont. by flare/ VC/TO/VRU	-
VOC Results, (lb/hr, tpy)	146.9236	643.525368
Benzene Results, (lb/hr, tpy)	21.0816	92.337408
H ₂ S Results, (lb/hr, tpy)	0	0

Sum of Flash Tank and Regenerator Results		
	lb/hr	tpy
VOC Results	0	0
Benzene Results	0	0
H₂S Results	0	0

Federal Applicability	
40 CFR Part 63 - Subpart HH	
All area sources, with TEG dehydration units, will have some requirements under the rule. Emission reduction requirements may apply or only recordkeeping requirements may apply.	
Is this subpart applicable?	Yes
If yes, how will compliance be achieved? If no, please explain why.	The permittee shall monitor as required by 40 CFR 63.772(b)(2) to demonstrate facility is exempt from general standards. The permittee shall generate and maintain the

Enter any notes here:
TEG Flash routed back to the process. Regenerator stream is routed to thermal oxidizer, EP-10

Glycol Dehydrator Emissions

Calculated Using GRI-GLYCalc or a Process Simulator

- A) Enter information into the yellow boxes.
- B) VOC and H₂S control efficiencies may be entered (if applicable). VOC, benzene, and H₂S regenerator condenser efficiencies may also be entered (if applicable).
- C) There are two separate areas to enter information about the two emissions points, the flash tank and the regenerator. Then underneath, there is a table of the sum of flash tank and regenerator emissions.
- D) The program results and any lab analysis results used as the calculation basis must be provided.
- E) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
- F) Make sure to answer the control device question.

EPN	6-EP-1e
Identifier	Train 6 - Glycol Dehy

<u>Glycol Dehydrator Unit Information</u>	
Are you using GLYCalc or a Process Simulator?	Process Simulator
GLYCalc Calculation Method (if using GLYCalc)	NA
Type of Glycol Used:	TEG
Annual Hours of Operation (hrs/yr):	8760
Dry Gas Flow Rate (MMscf/day)	230.586
Laboratory Wet Gas Analysis Provided? If not, explain why. (Use notes box below if more space needed.)	Yes
Date of Sample:	
Is sample site specific or representative? If representative, please justify. (Use notes box below if more space needed.)	Site specific
At what point in the process was the sample taken?	
Wet Gas Temperature (°F)	120
Wet Gas Pressure (psig)	864.696
Lean Glycol Pump Type	electric
Lean Glycol Pump Make and Model	
Lean Glycol Flow Rate (gpm)	63.2206
Number of Pump Stokes per Minute for the Lean Glycol Pump (pump strokes/min, if applicable)	NA
Flash Tank Temperature (°F)	134.689
Flash Tank Pressure (psig)	60.999951

<u>Flash Tank</u>		
Is there a flash tank? (If no, leave the inputs in this block blank.)	Yes	-
	lb/hr	tpy
Emissions Uncontrolled VOC,(lb/hr, tpy)	112.6996	493.624248
Emissions Uncontrolled Benzene, (lb/hr, tpy)	0.366365	1.6046787
Emissions Uncontrolled H ₂ S, (lb/hr, tpy)	0	0
Are flash tank vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(C) cont. by other control device	-
VOC Control Efficiency (%)	100	-
H ₂ S Control Efficiency (%)	100	-
VOC Results, (lb/hr, tpy)	0	0
Benzene Results, (lb/hr, tpy)	0	0
H ₂ S Results, (lb/hr, tpy)	0	0

<u>Regenerator</u>		
	lb/hr	tpy
Emissions Uncontrolled VOC (lb/hr, tpy)	146.9236	643.525368
Emissions Uncontrolled Benzene, (lb/hr, tpy)	21.0816	92.337408
Emissions Uncontrolled H ₂ S, (lb/hr, tpy)	0	0
Are regenerator vapors controlled by a condenser?	Yes	-
VOC Condenser Efficiency (%) - <i>if applicable</i>	0	-
Benzene Condenser Efficiency (%) - <i>if applicable</i>	0	-
H ₂ S Condenser Efficiency (%) - <i>if applicable</i>	0	-
Are regenerator vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(B) cont. by flare/ VC/TO/VRU	-
VOC Results, (lb/hr, tpy)	146.9236	643.525368
Benzene Results, (lb/hr, tpy)	21.0816	92.337408
H ₂ S Results, (lb/hr, tpy)	0	0

Sum of Flash Tank and Regenerator Results		
	lb/hr	tpy
VOC Results	0	0
Benzene Results	0	0
H₂S Results	0	0

Federal Applicability	
40 CFR Part 63 - Subpart HH	
All area sources, with TEG dehydration units, will have some requirements under the rule. Emission reduction requirements may apply or only recordkeeping requirements may apply.	
Is this subpart applicable?	Yes
If yes, how will compliance be achieved? If no, please explain why.	The permittee shall monitor as required by 40 CFR 63.772(b)(2) to demonstrate facility is exempt from general standards. The permittee shall generate and maintain the

Enter any notes here:
TEG Flash routed back to the process. Regenerator stream is routed to thermal oxidizer, EP-10

Amine Unit Emissions

Calculated Using AmineCalc or a Process Simulator

- A) Enter information into the yellow boxes.
- B) VOC and H₂S control efficiencies may be entered (if applicable).
- C) There are two separate areas to enter information about the two emissions points, the flash tank and the regenerator. Then underneath, there is a table of the sum of flash tank and regenerator emissions.
- D) The program results and any lab analysis results used as the calculation basis must be provided.
- E) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
- F) Make sure to answer the control device question.

EPN	5-EP-1f
Identifier	Train 5 - Amine

<u>Amine Unit Information</u>	
Are you using AmineCalc or a Process Simulator?	Process Simulator
AmineCalc Model Selection (if using AmineCalc):	NA
Type of Amine Used:	MDEA
Annual Hours of Operation (hrs/yr):	8760
Feed Gas Flow Rate (MMscf/day):	247.294
Laboratory Feed Gas Analysis Provided? If not, explain why. (Use notes box below if more space needed.)	Yes
Date of Sample:	ProMax
Is sample site specific or representative? If representative, please justify. (Use notes box below if more space needed.)	Site Specific
At what point in the process was the sample taken?	
Feed Gas Temperature (°F)	70
Feed Gas Pressure (psia)	914.696
Lean Amine Flow Rate (gpm)	1726.83
Flash Tank Temperature (°F)	169.838
Flash Tank Pressure (psia)	74.6959

<u>Flash Tank</u>		
Is there a flash tank? (If no, leave the inputs in this block blank.)	Yes	-
	lb/hr	tpy
Emissions Uncontrolled VOC,(lb/hr, tpy)	141.3043	618.912834
Emissions Uncontrolled Benzene, (lb/hr, tpy)	1.89568	8.3030784
Emissions Uncontrolled H ₂ S, (lb/hr, tpy)	0.0103932	0.045522216
Are flash tank vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(C) cont. by other control device	-
VOC Control Efficiency (%)	100	-
H ₂ S Control Efficiency (%)	100	-
VOC Results, (lb/hr, tpy)	0	0
Benzene Results, (lb/hr, tpy)	0	0
H ₂ S Results, (lb/hr, tpy)	0	0

<u>Regenerator</u>		
	lb/hr	tpy
Emissions Uncontrolled VOC (lb/hr, tpy)	35.82654	156.9202452
Emissions Uncontrolled Benzene, (lb/hr, tpy)	16.4551	72.073338
Emissions Uncontrolled H ₂ S, (lb/hr, tpy)	1.87409	8.2085142
Are regenerator vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(B) cont. by flare/VC/TO/VRU	-
VOC Results, (lb/hr, tpy)	35.82654	156.9202452
Benzene Results, (lb/hr, tpy)	16.4551	72.073338
H ₂ S Results, (lb/hr, tpy)	1.87409	8.2085142

<u>Sum of Flash Tank and Regenerator Results</u>		
	lb/hr	tpy
VOC Results	0	0
Benzene Results	0	0
H ₂ S Results	0	0

<u>Federal Applicability</u>	
40 CFR Part 60 - Subpart LLL	
Is this subpart applicable?	No
If yes, how will compliance be achieved? If no, please explain why.	The facility is a natural gas processing plant, however, there is not sulfur recovery plant, thus this location does not meet the applicability criteria of 40

Enter any notes here:
Amine flash is routed back to the process and regenerator stream is routed to the thermal oxidizer, EP-10.

Amine Unit Emissions

Calculated Using AmineCalc or a Process Simulator

- A) Enter information into the yellow boxes.
- B) VOC and H₂S control efficiencies may be entered (if applicable).
- C) There are two separate areas to enter information about the two emissions points, the flash tank and the regenerator. Then underneath, there is a table of the sum of flash tank and regenerator emissions.
- D) The program results and any lab analysis results used as the calculation basis must be provided.
- E) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
- F) Make sure to answer the control device question.

EPN	6-EP-1f
Identifier	Train 6 - Amine

<u>Amine Unit Information</u>	
Are you using AmineCalc or a Process Simulator?	Process Simulator
AmineCalc Model Selection (if using AmineCalc):	NA
Type of Amine Used:	MDEA
Annual Hours of Operation (hrs/yr):	8760
Feed Gas Flow Rate (MMscf/day):	247.294
Laboratory Feed Gas Analysis Provided? If not, explain why. (Use notes box below if more space needed.)	Yes
Date of Sample:	ProMax
Is sample site specific or representative? If representative, please justify. (Use notes box below if more space needed.)	Site Specific
At what point in the process was the sample taken?	
Feed Gas Temperature (°F)	70
Feed Gas Pressure (psia)	914.696
Lean Amine Flow Rate (gpm)	1726.83
Flash Tank Temperature (°F)	169.838
Flash Tank Pressure (psia)	74.6959

<u>Flash Tank</u>		
Is there a flash tank? (If no, leave the inputs in this block blank.)	Yes	-
	lb/hr	tpy
Emissions Uncontrolled VOC,(lb/hr, tpy)	141.3043	618.912834
Emissions Uncontrolled Benzene, (lb/hr, tpy)	1.89568	8.3030784
Emissions Uncontrolled H ₂ S, (lb/hr, tpy)	0.0103932	0.045522216
Are flash tank vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(C) cont. by other control device	-
VOC Control Efficiency (%)	100	-
H ₂ S Control Efficiency (%)	100	-
VOC Results, (lb/hr, tpy)	0	0
Benzene Results, (lb/hr, tpy)	0	0
H ₂ S Results, (lb/hr, tpy)	0	0

<u>Regenerator</u>		
	lb/hr	tpy
Emissions Uncontrolled VOC (lb/hr, tpy)	35.82654	156.9202452
Emissions Uncontrolled Benzene, (lb/hr, tpy)	16.4551	72.073338
Emissions Uncontrolled H ₂ S, (lb/hr, tpy)	1.87409	8.2085142
Are regenerator vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(B) cont. by flare/VC/TO/VRU	-
VOC Results, (lb/hr, tpy)	35.82654	156.9202452
Benzene Results, (lb/hr, tpy)	16.4551	72.073338
H ₂ S Results, (lb/hr, tpy)	1.87409	8.2085142

<u>Sum of Flash Tank and Regenerator Results</u>		
	lb/hr	tpy
VOC Results	0	0
Benzene Results	0	0
H ₂ S Results	0	0

<u>Federal Applicability</u>	
40 CFR Part 60 - Subpart LLL	
Is this subpart applicable?	No
If yes, how will compliance be achieved? If no, please explain why.	The facility is a natural gas processing plant, however, there is not sulfur recovery plant, thus this location does not meet the applicability criteria of 40

Enter any notes here:
Amine flash is routed back to the process and regenerator stream is routed to the thermal oxidizer, EP-10.

Flare / Vapor Combustor

- A) Enter information into the blue boxes.
B) See notes/instructions included below.

Unit EPN 5-EP-2
Unit Name Cryo 5 & 6 Flare SSM

Flare EPN: 5-EP-2							
	Gas Stream 1	Gas Stream 2	Gas Stream 3		Gas Stream 1	Gas Stream 2	Gas Stream 3
Emission Unit ID	Sweep Gas	To Mole Sieve Stream		Hourly Gas Routed to Flare (MMBtu/hr)	2.295	12017.60166	
Hourly Gas Stream to Flare (Mscf/hr)	2.25	9607.63		Annual Gas Routed to Flare (MMBtu/yr)	20104.2	144211.22	
Annual Gas Stream to Flare (MMscf/yr)	19.71	115.29		Pilot Gas Routed to Flare (MMBtu/hr)	0.1989	0	
Max. Heat Value of Gas (Btu/scf)	1020	1250.84		Gas MW (lb/lbmol)	16.82	21.23	
Flare operational time (hr/yr)	8760	12		Gas Pressure (psia)	14.7	863.196	
Field Gas Mol Fraction (lbmol H2S/lb-mol)	-	-	-	Gas Temperature (°F)	70	123.308	
Field Gas Sulfur Content (S grains/100scf)	-	-	-	Field Gas H2S Wt.% to Flare (%)	0.0061	0.0000	
Pilot Gas to Flare (Mscf/hr)	0.195			Flare Control Efficiency	98	98	
Max. Heat Value of Pilot Gas (Btu/scf)	1020			Total VOC wt.% to Flare (%)	0.1573	22.6264	
Pilot Gas H2S Wt.% to Flare (%)	0.0061			Source of Flare Emission Factors	TCEQ	TCEQ	
Pilot Gas MW (lb/lbmol)	16.82			Use Highest NO _x & CO Emission Factors From AP-42 or TCEQ	NO	NO	

Flare, Vapor Combustion Devices & Enclosed Devices Emission Factors			
Contaminant	Assist Type	AP-42 Emission Factor (lb/MMBtu)	TCEQ Emission Factors (lb/MMBtu)
NO _x	Steam (Btu/scf >1000)	0.068	0.0485
	Steam (Btu/scf <1000)	0.068	0.068
	Air or Unassisted (Btu/scf >1000)	0.068	0.138
	Air or Unassisted (Btu/scf <1000)	0.068	0.0641
CO	Steam (Btu/scf >1000)	0.31	0.3503
	Steam (Btu/scf <1000)	0.31	0.3465
	Air or Unassisted (Btu/scf >1000)	0.31	0.2755
	Air or Unassisted (Btu/scf <1000)	0.31	0.5496
VOC	Air or Unassisted	0.0054	--

Total Emissions to Flare																
Pollutant	NO _x			CO			VOC			SO ₂			H ₂ S			
	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3	
Gas Stream To Flare																
Uncontrolled (pph)	0.00	0.00	0.00	0.00	0.00	0.00	0.15	121549.60	0.00	0.00	0.00	0.00	0.01	0.00	0.00	
Uncontrolled (tpy)	0.00	0.00	0.00	0.00	0.00	0.00	0.68	729.30	0.00	0.00	0.00	0.00	0.03	0.00	0.00	
Field Gas (pph)	0.32	1658.43	0.00	0.63	3310.85	0.00	0.00	2430.99	0.00	0.01	0.00	0.00	0.00	0.00	0.00	
Field Gas (tpy)	1.39	9.95	0.00	2.77	19.87	0.00	0.01	14.59	0.00	0.00	0.00	0.00	0.001	0.00	0.00	
Pilot Gas (pph)	0.0274	0.0000	0.0000	0.0548	0.0000	0.0000	0.0011	0.0000	0.0000	0.0010	0.0000	0.0000	0.0000	0.0000	0.0000	
Pilot Gas (tpy)	0.1202	0.0000	0.0000	0.2400	0.0000	0.0000	0.0047	0.0000	0.0000	0.0043	0.0000	0.0000	0.0000	0.0000	0.0000	
Subtotal Flare (pph)	0.3442	1658.4290	0.0000	0.6871	3310.8493	0.0000	0.0042	2430.9920	0.0000	0.0122	0.0000	0.0000	0.0001	0.0000	0.0000	
Subtotal Flare (tpy)	1.5074	9.9506	0.0000	3.0094	19.8651	0.0000	0.0182	14.5860	0.0000	0.0043	0.0000	0.0000	0.0006	0.0000	0.0000	
Total Flare (pph)	1658.7732			3311.5363			2430.9962			0.0122			0.0001			
Total Flare (tpy)	11.4580			22.8745			14.6042			0.0043			0.0006			

Notes:
MW of SO₂ = 64.066
MW of H₂S = 34.1

Sample Calculations:

$$NO_x \text{ pph} = \text{Hourly gas routed to the flare} \left(\frac{MMBtu}{hr} \right) \times NO_x \text{ Emission Factor} \left(\frac{lb}{MMBtu} \right)$$

$$NO_x \text{ tpy} = \text{Hourly gas routed to the flare} \left(\frac{MMBtu}{yr} \right) \times NO_x \text{ Emission Factor} \left(\frac{lb}{MMBtu} \right) \times \frac{1}{2000} \left(\frac{ton}{lbs} \right)$$

$$SO_2 \text{ pph} = \frac{\text{Weight \% H}_2\text{S}}{100} \times \frac{1}{385} \left(\frac{lb - mole}{scf} \right) \times MW \text{ of gas} \left(\frac{lb}{lb - mole} \right) \times \text{flowrate of gas} \left(\frac{scf}{hr} \right) \times \frac{MW \text{ of } SO_2}{MW \text{ of } H_2S}$$

$$\text{Residual } H_2S \text{ pph} = \frac{\text{Weight \% H}_2\text{S}}{100} \times \frac{1}{385} \left(\frac{lb - mole}{scf} \right) \times MW \text{ of gas} \left(\frac{lb}{lb - mole} \right) \times \text{flowrate of gas} \left(\frac{scf}{hr} \right) \times \frac{MW \text{ of } SO_2}{MW \text{ of } H_2S} \times \text{Flare efficiency}$$


Lucid Energy Group - Red Hills Gas Processing Plant

Emergency Cryo Flare

Emission Unit: 5-EP-2 and 7-EP-2

Fuel Data

Flare Pilot	195 scf/hr	Max design	
	0.000195 MMscf/hr		
	1020.00 Btu/scf	Pipeline Gas, HHV	
	0.199 MMBtu/hr		
Sweep Gas	54.000 Mscf/day	Design	
	2.2500 Mscf/hr	Mscf/d / 24 hr/day	
	2.25E-03 MMscf/hr	Mscf/hr / 1000	
	1020.00 Btu/scf	Pipeline Gas, HHV	
	2.2950 MMBtu/hr	MMscf/hr * Btu/scf	
Flared Gas - Short Term	9.608 MMscf/hr	Effective hourly flowrate	
	1,251 Btu/scf		
	12,017 MMBtu/hr	Hourly heat rate = Heating value * Effective hourly flow rate.	
	12 hr/yr	Hours of operation	
Flared Gas - Annual	144209.34 MMscf/yr	Estimated Maximum annual SSM flow rate. Not a requested limit; for calculation only.	
Flare Design	1052040.00 lb/hr	Design flowrate	
	21.20 lb/lb-mole	Molecular weight	
	1104.0 Btu/scf	Heating value	
	385.0 scf/lb-mole	Molar volume	
	1000000.0 btu/MMBtu		
	21,092.4 MMBtu/hr	Flare design rate	
	55%	Safety Factor	
	11556.320 MMBtu/hr	Limited Design rate	
Pilot+ Sweep Gas only	16.8	Pilot & Sweep gas molecular weight	Mol. wt. of methane, the dominant species
	1.75E+05 cal/sec	Heat release (q)	MMBtu/hr * 10 ⁶ * 252 cal/Btu ÷ 3600 sec/hr
	1.40E+05	q _n	q _n = q(1-0.048(MW) ^{1/2})
	0.3744 m	Effective stack diameter (D)	D = (10 ⁻⁶ q _n) ^{1/2}
Flared Gas MW	21.2 g/mol	MW flare gas	
	16.8 g/mol	MW assist gas, purge gas	
Flaring Volumes	0.255 MMscf/hr	vol flared gas	
	0.0833 MMscf/hr	vol assist gas	
Flare (SSM)	0.0833 MMscf/hr	vol assist gas	
	0.002445 MMscf/hr	vol pilot + sweep gas	
	15.89 g/mol	vol. weighted % flare gas	
	4.11 g/mol	vol. weighted % assist gas	
	1.21E-01 g/mol	vol. weighted % pilot + sweep gas	
Pilot+Flared Gas+ Assist gas	20.12 g/mol	weighted-averaged Flared gas molecular weight	
	8.09E+08 cal/sec	Heat release (q)	MMBtu/hr * 10 ⁶ * 252 cal/Btu ÷ 3600 sec/hr
	6.35E+08	q _n	q _n = q(1-0.048(MW) ^{1/2})
	25.195 m	Effective stack diameter (D)	D = (10 ⁻⁶ q _n) ^{1/2}



Air Assisted Flare Tip Specification Sheet


Client: Lucid Midstream	Zeeco Ref.: 2019-03373FL-01	Date: 21-May-
Location: Jai, NM	Client Ref.: "Red Hills V"	Rev.: 0

General Information:

Tag No.: FL-5100
 Model: AFDSMJW-20/80 - 26 Type: Air-Assisted
 Length: 10'- 0"
 Weight: 6000 lbs
 No. of Pilots: 3

Design Case:

Governing Case: Cold Case 1
 Molecular weight: 21.2
 L. H. V.: 1,104 BTU/SCF
 Temperature: 9 Deg. F
 Available Static Pressure: 40.0 psig
 Design Flow Rate: 1,052,040 lbs/hr
 Governing Smokeless Case: Case A
 Design Smokeless Rate: 210,408 lbs/hr
 Approximate Exit Velocity: 1194 ft/s
 Mach No.: 1.00
 Approx. Tip Press. Drop: 14.54 psig



(Typical drawing only)

Construction:

Inner Section:	316 SS	Flare Retention Hub:	316 SS
----------------	--------	----------------------	--------

Flare / Vapor Combustor

- A) Enter information into the blue boxes.
B) See notes/instructions included below.

Unit EPN 7-EP-2
Unit Name Cryo 7 Flare SSM

Flare EPN: 7-EP-2							
	Gas Stream 1	Gas Stream 2	Gas Stream 3		Gas Stream 1	Gas Stream 2	Gas Stream 3
Emission Unit ID	Sweep Gas	To Mole Sieve Stream		Hourly Gas Routed to Flare (MMBtu/hr)	2.295	12017.60166	
Hourly Gas Stream to Flare (Mscf/hr)	2.25	9607.63		Annual Gas Routed to Flare (MMBtu/yr)	20104.2	144211.22	
Annual Gas Stream to Flare (MMscf/yr)	19.71	115.29		Pilot Gas Routed to Flare (MMBtu/hr)	0.1989	0	
Max. Heat Value of Gas (Btu/scf)	1020	1250.84		Gas MW (lb/lbmol)	16.82	21.23	
Flare operational time (hr/yr)	8760	12		Gas Pressure (psia)	14.7	863.196	
Field Gas Mol Fraction (lbmol H2S/lb-mol)	-	-	-	Gas Temperature (°F)	70	123.308	
Field Gas Sulfur Content (S grains/100scf)	-	-	-	Field Gas H2S Wt.% to Flare (%)	0.0061	0.0000	
Pilot Gas to Flare (Mscf/hr)	0.195			Flare Control Efficiency	98	98	
Max. Heat Value of Pilot Gas (Btu/scf)	1020			Total VOC wt.% to Flare (%)	0.1573	22.6264	
Pilot Gas H2S Wt.% to Flare (%)	0.0061			Source of Flare Emission Factors	TCEQ	TCEQ	
Pilot Gas MW (lb/lbmol)	16.82			Use Highest NO _x & CO Emission Factors From AP-42 or TCEQ	NO	NO	

Flare, Vapor Combustion Devices & Enclosed Devices Emission Factors			
Contaminant	Assist Type	AP-42 Emission Factor (lb/MMBtu)	TCEQ Emission Factors (lb/MMBtu)
NO _x	Steam (Btu/scf >1000)	0.068	0.0485
	Steam (Btu/scf <1000)	0.068	0.068
	Air or Unassisted (Btu/scf >1000)	0.068	0.138
	Air or Unassisted (Btu/scf <1000)	0.068	0.0641
CO	Steam (Btu/scf >1000)	0.31	0.3503
	Steam (Btu/scf <1000)	0.31	0.3465
	Air or Unassisted (Btu/scf >1000)	0.31	0.2755
	Air or Unassisted (Btu/scf <1000)	0.31	0.5496
VOC	Air or Unassisted	0.0054	--

Total Emissions to Flare																
Pollutant	NO _x			CO			VOC			SO ₂			H ₂ S			
	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3	
Gas Stream To Flare																
Uncontrolled (pph)	0.00	0.00	0.00	0.00	0.00	0.00	0.15	121549.60	0.00	0.00	0.00	0.00	0.01	0.00	0.00	
Uncontrolled (tpy)	0.00	0.00	0.00	0.00	0.00	0.00	0.68	729.30	0.00	0.00	0.00	0.00	0.03	0.00	0.00	
Field Gas (pph)	0.32	1658.43	0.00	0.63	3310.85	0.00	0.00	2430.99	0.00	0.01	0.00	0.00	0.00	0.00	0.00	
Field Gas (tpy)	1.39	9.95	0.00	2.77	19.87	0.00	0.01	14.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Pilot Gas (pph)	0.0274	0.0000	0.0000	0.0548	0.0000	0.0000	0.0011	0.0000	0.0000	0.0010	0.0000	0.0000	0.0000	0.0000	0.0000	
Pilot Gas (tpy)	0.1202	0.0000	0.0000	0.2400	0.0000	0.0000	0.0047	0.0000	0.0000	0.0043	0.0000	0.0000	0.0000	0.0000	0.0000	
Subtotal Flare (pph)	0.3442	1658.4290	0.0000	0.6871	3310.8493	0.0000	0.0042	2430.9920	0.0000	0.0122	0.0000	0.0000	0.0001	0.0000	0.0000	
Subtotal Flare (tpy)	1.5074	9.9506	0.0000	3.0094	19.8651	0.0000	0.0182	14.5860	0.0000	0.0043	0.0000	0.0000	0.0006	0.0000	0.0000	
Total Flare (pph)	1658.7732			3311.5363			2430.9962			0.0122			0.0001			
Total Flare (tpy)	11.4580			22.8745			14.6042			0.0043			0.0006			

Notes:
MW of SO₂ = 64.066
MW of H₂S = 34.1

Sample Calculations:

$$NO_x \text{ pph} = \text{Hourly gas routed to the flare} \left(\frac{MMBtu}{hr} \right) \times NO_x \text{ Emission Factor} \left(\frac{lb}{MMBtu} \right)$$

$$NO_x \text{ tpy} = \text{Hourly gas routed to the flare} \left(\frac{MMBtu}{yr} \right) \times NO_x \text{ Emission Factor} \left(\frac{lb}{MMBtu} \right) \times \frac{1}{2000} \left(\frac{ton}{lbs} \right)$$

$$SO_2 \text{ pph} = \frac{\text{Weight \% H}_2\text{S}}{100} \times \frac{1}{385} \left(\frac{lb - mole}{scf} \right) \times MW \text{ of gas} \left(\frac{lb}{lb - mole} \right) \times \text{flowrate of gas} \left(\frac{scf}{hr} \right) \times \frac{MW \text{ of } SO_2}{MW \text{ of } H_2S}$$

$$\text{Residual H}_2\text{S pph} = \frac{\text{Weight \% H}_2\text{S}}{100} \times \frac{1}{385} \left(\frac{lb - mole}{scf} \right) \times MW \text{ of gas} \left(\frac{lb}{lb - mole} \right) \times \text{flowrate of gas} \left(\frac{scf}{hr} \right) \times \frac{MW \text{ of } SO_2}{MW \text{ of } H_2S} \times \text{Flare efficiency}$$

Flare / Vapor Combustor

- A) Enter information into the blue boxes.
B) See notes/instructions included below.

Unit EPN 5.5-EP-1b
Unit Name AGI 2 Flare SSM

Flare EPN: 5.5-EP-1b							
	Gas Stream 1	Gas Stream 2	Gas Stream 3		Gas Stream 1	Gas Stream 2	Gas Stream 3
Emission Unit ID	Added Fuel Stream	Compressor Stream (900 gpm)	AGI 2 Compressors and VRU Blowdown	Hourly Gas Routed to Flare (MMBtu/hr)	85.00	9.57	0.15
Hourly Gas Stream to Flare (Mscf/hr)	83.33	126.39	1.999	Annual Gas Routed to Flare (MMBtu/yr)	5212.20	1173.34	0.30
Annual Gas Stream to Flare (MMscf/yr)	5.110	15.500	0.004	Pilot Gas Routed to Flare (MMBtu/hr)	0.39	0.00	0.00
Max. Heat Value of Gas (Btu/scf)	1020	75.7	75.7	Gas MW (lb/lbmol)	16.82	40.89	40.89
Flare operational time (hr/yr)	61.32	122.64	2	Gas Pressure (psia)	14.7	24.2	24.2
Field Gas Mol Fraction (lbmol H2S/lb-mol)	-	-	-	Gas Temperature (°F)	70	120	120
Field Gas Sulfur Content (S grains/100scf)	-	-	-	Field Gas H2S Wt.% to Flare (%)	0.0061	10.48	10.48
Pilot Gas to Flare (Mscf/hr)	0.38			Flare Control Efficiency	98	98	98
Max. Heat Value of Pilot Gas (Btu/scf)	1020			Total VOC wt.% to Flare (%)	0.1573	3.1622	3.1622
Pilot Gas H2S Wt.% to Flare (%)	0.0061			Source of Flare Emission Factors	TCEQ	TCEQ	TCEQ
Pilot Gas MW (lb/lbmol)	16.82			Use Highest NO _x & CO Emission Factors From AP-42 or TCEQ	NO	NO	NO

Flare, Vapor Combustion Devices & Enclosed Devices Emission Factors			
Contaminant	Assist Type	AP-42 Emission Factor (lb/MMBtu)	TCEQ Emission Factors (lb/MMBtu)
NO _x	Steam (Btu/scf >1000)	0.068	0.0485
	Steam (Btu/scf <1000)	0.068	0.068
	Air or Unassisted (Btu/scf >1000)	0.068	0.138
	Air or Unassisted (Btu/scf <1000)	0.068	0.0641
CO	Steam (Btu/scf >1000)	0.31	0.3503
	Steam (Btu/scf <1000)	0.31	0.3465
	Air or Unassisted (Btu/scf >1000)	0.31	0.2755
	Air or Unassisted (Btu/scf <1000)	0.31	0.5496
VOC	Air or Unassisted	0.0054	--

Total Emissions to Flare															
Pollutant	NO _x			CO			VOC			SO ₂			H ₂ S		
	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3
Gas Stream To Flare															
Uncontrolled (pph)	0.00	0.00	0.00	0.00	0.00	0.00	5.73	424.46	6.71	0.00	0.00	0.00	0.22	1406.48	22.25
Uncontrolled (tpy)	0.00	0.00	0.00	0.00	0.00	0.00	0.18	26.03	0.01	0.00	0.00	0.00	0.01	86.25	0.02
Field Gas (pph)	11.73	0.61	0.01	23.42	5.26	0.08	0.46	8.49	0.13	0.42	2642.45	41.79	0.00	28.13	0.44
Field Gas (tpy)	0.36	0.04	0.00	0.72	0.32	0.00	0.01	0.52	0.00	0.01	162.03	0.04	0.00	1.72	0.00
Pilot Gas (pph)	0.0535	0.0000	0.0000	0.1068	0.0000	0.0000	0.0021	0.0000	0.0000	0.0019	0.0000	0.0000	0.0000	0.0000	0.0000
Pilot Gas (tpy)	0.2343	0.0000	0.0000	0.4677	0.0000	0.0000	0.0092	0.0000	0.0000	0.0083	0.0000	0.0000	0.0001	0.0000	0.0000
Subtotal Flare (pph)	11.7835	0.6133	0.0097	23.5243	5.2582	0.0832	0.4604	8.4892	0.1343	0.4177	2642.45	41.7948	0.0044	28.1296	0.4449
Subtotal Flare (tpy)	0.5939	0.0376	0.0000	1.1857	0.3224	0.0001	0.0232	0.5206	0.0001	0.0211	162.0350	0.0418	0.0002	1.7249	0.0004
Total Flare (pph)	12.4065			28.8657			9.0839			2684.6612			28.5789		
Total Flare (tpy)	0.6315			1.5082			0.5439			162.0978			1.7256		

Notes: Pilot Gas to Flare (Cell D22) includes Pilot Gas and Sweep Gas.
MW of SO₂ = 64.066
MW of H₂S = 34.1

The acid gas routed to the flare will also be curtailed to half by reducing the inlet flow during startup, maintenance, and shut down. This is achieved by switching to the backup compressor within 30 minutes or by reducing the inlet flow for these periods.

Sample Calculations:

$$NO_x \text{ pph} = \text{Hourly gas routed to the flare} \left(\frac{MMBtu}{hr} \right) \times NO_x \text{ Emission Factor} \left(\frac{lb}{MMBtu} \right)$$

$$NO_x \text{ tpy} = \text{Hourly gas routed to the flare} \left(\frac{MMBtu}{yr} \right) \times NO_x \text{ Emission Factor} \left(\frac{lb}{MMBtu} \right) \times \frac{1}{2000} \left(\frac{ton}{lbs} \right)$$

$$SO_2 \text{ pph} = \frac{\text{Weight \% H}_2\text{S}}{100} \times \frac{1}{385} \left(\frac{lb - mole}{scf} \right) \times MW \text{ of gas} \left(\frac{lb}{lb - mole} \right) \times \text{flowrate of gas} \left(\frac{scf}{hr} \right) \times \frac{MW \text{ of SO}_2}{MW \text{ of H}_2\text{S}}$$

$$\text{Residual H}_2\text{S pph} = \frac{\text{Weight \% H}_2\text{S}}{100} \times \frac{1}{385} \left(\frac{lb - mole}{scf} \right) \times MW \text{ of gas} \left(\frac{lb}{lb - mole} \right) \times \text{flowrate of gas} \left(\frac{scf}{hr} \right) \times \frac{MW \text{ of SO}_2}{MW \text{ of H}_2\text{S}} \times \text{Flare efficiency}$$

Lucid Energy Group - Red Hills Gas Processing Plant

Emergency AGI Flare

Emission Unit: 5.5-EP-1b

Fuel Data

Flare Pilot	150 scf/hr 0.00015 MMscf/hr 1020.00 Btu/scf 0.153 MMBtu/hr	Max design Pipeline Gas, HHV
Sweep Gas	5.520 Mscf/day 0.2300 Mscf/hr 2.30E-04 MMscf/hr 1020.00 Btu/scf 0.2346 MMBtu/hr	Design Mscf/d / 24 hr/day Mscf/hr / 1000 Pipeline Gas, HHV MMscf/hr * Btu/scf
Assist Gas	0.0833 MMscf/hr 1,020.0 Btu/scf	Assist gas volume Assist gas-assumed sweet
Assist gas - Annual	0.0 MMscf/yr	Estimated Maximum annual SSM flow rate.
Flared Gas - Short Term	0.255 MMscf/hr 76 Btu/scf 19 MMBtu/hr 123 hr/yr	Effective hourly flowrate Hourly heat rate = Heating value * Effective hourly flow rate. Hours of operation
Flared Gas - Annual	2,367.38 MMscf/yr	Estimated Maximum annual SSM flow rate. Not a requested limit; for calculation only.
Flare Design	316354.70 lb/hr 25.52 lb/lb-mole 997.0 Btu/scf 385.0 scf/lb-mole 1000000.0 btu/MMBtu 4,758.3 MMBtu/hr 55% 2593.916 MMBtu/hr	Design flowrate Molecular weight Heating value Molar volume Flare design rate Limited Design rate

Pilot+ Sweep Gas only	16.8 2.71E+04 cal/sec 2.18E+04 0.1476 m	Pilot & Sweep gas molecular weight Heat release (q) q _n Effective stack diameter (D)
------------------------------	--	--

Mol. wt. of methane, the dominant species
MMBtu/hr * 10⁶ * 252 cal/Btu ÷ 3600 sec/hr
q_n = q(1-0.048(MW)^{1/2})
D = (10⁶q_n)^{1/2}

Flared Gas MW	40.8 g/mol 16.8 g/mol	MW flare gas MW assist gas, purge gas
----------------------	--------------------------	--

Flaring Volumes	0.255 MMscf/hr 0.0833 MMscf/hr Flare (SSM) 0.0833 MMscf/hr 0.000380 MMscf/hr 30.72 g/mol 4.14 g/mol 1.89E-02 g/mol	vol flared gas vol assist gas vol pilot + sweep gas vol. weighted % flare gas vol. weighted % assist gas vol. weighted % pilot + sweep gas
------------------------	---	---


Pilot+Flared Gas+ Assist gas	34.87 g/mol 1.82E+08 cal/sec 1.30E+08 11.4064 m	weighted-averaged Flared gas molecular weight Heat release (q) q _n Effective stack diameter (D)
-------------------------------------	--	---

MMBtu/hr * 10⁶ * 252 cal/Btu ÷ 3600 sec/hr
q_n = q(1-0.048(MW)^{1/2})
D = (10⁶q_n)^{1/2}

John Zink Company
Flare Design Program 3.02.012 Apr 24th, 2019
Zink File Number: 111272-A Date/Time 05-16-2019/08:05:51
Customer: OPD Engineer: travism
Comment: Amine Cont LV

Tip : Azosin Air Flare
Flow : 316354.7 LBS/HR
MW : 25.52
Tgas : -26 Deg.F
LHV : 997 BTU/SCF
Wind : 30 ft/sec (0 Deg.)
Stack : 120.0 ft

- Notes:
1. Calculated radiation +/- 10%.
2. Transmissivity (70% RH) included.
3. Radiation in BTU/hr-sq.ft.
4. Solar radiation = 300 included.
5. Flame shade shown as : →



Lucid Energy Delaware, LLC
Red Hills Gas Processing Plant

Flare / Vapor Combustor

- A) Enter information into the blue boxes.
B) See notes/instructions included below.

Unit EPN EP-12
Unit Name Condensate Tanks Combustor

Flare EPN: EP-12							
	Gas Stream 1	Gas Stream 2	Gas Stream 3		Gas Stream 1	Gas Stream 2	Gas Stream 3
Emission Unit ID	Condensate Tanks	3-LOAD		Hourly Gas Routed to Flare (MMBtu/hr)	0.08	1.06	
Hourly Gas Stream to Flare (Mscf/hr)	0.02	0.26		Annual Gas Routed to Flare (MMBtu/yr)	725.44	1564.76	
Annual Gas Stream to Flare (MMscf/yr)	0.175	0.38		Pilot Gas Routed to Flare (MMBtu/hr)	0.07	0.00	
Max. Heat Value of Gas (Btu/scf)	4142.72	4142.72		Gas MW (lb/lbmol)	75.03	75.03	
Flare operational time (hr/yr)	8760	5997		Gas Pressure (psia)	11.428	14.7	
Field Gas Mol Fraction (lbmol H2S/lb-mol)	-	-	-	Gas Temperature (°F)	111.21	111.21	
Field Gas Sulfur Content (S grains/100scf)	-	-	-	Field Gas H2S Wt.% to Flare (%)	0.00	0.00	
Pilot Gas to Flare (Mscf/hr)	0.065			Flare Control Efficiency	95	95	
Max. Heat Value of Pilot Gas (Btu/scf)	1020			Total VOC wt.% to Flare (%)	100.00	100.00	
Pilot Gas H2S Wt.% to Flare (%)	0.0061			Source of Flare Emission Factors	TCEQ	TCEQ	
Pilot Gas MW (lb/lbmol)	16.82			Use Highest NO _x & CO Emission Factors From AP-42 or TCEQ	NO	NO	

Flare, Vapor Combustion Devices & Enclosed Devices Emission Factors			
Contaminant	Assist Type	AP-42 Emission Factor (lb/MMBtu)	TCEQ Emission Factors (lb/MMBtu)
NO _x	Steam (Btu/scf >1000)	0.068	0.0485
	Steam (Btu/scf <1000)	0.068	0.068
	Air or Unassisted (Btu/scf >1000)	0.068	0.138
	Air or Unassisted (Btu/scf <1000)	0.068	0.0641
CO	Steam (Btu/scf >1000)	0.31	0.3503
	Steam (Btu/scf <1000)	0.31	0.3465
	Air or Unassisted (Btu/scf >1000)	0.31	0.2755
	Air or Unassisted (Btu/scf <1000)	0.31	0.5496
VOC	Air or Unassisted	0.0054	--

Total Emissions to Flare																
Pollutant	NO _x			CO			VOC			SO ₂			H ₂ S			
	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3	
Gas Stream To Flare																
Uncontrolled (pph)	0.00	0.00	0.00	0.00	0.00	0.00	31.50	49.85	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Uncontrolled (tpy)	0.00	0.00	0.00	0.00	0.00	0.00	137.97	73.61	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Field Gas (pph)	0.01	0.15	0.00	0.02	0.29	0.00	1.58	2.49	0.00	0.000	0.000	0.000	0.00	0.00	0.00	
Field Gas (tpy)	0.05	0.11	0.00	0.10	0.22	0.00	6.90	3.68	0.00	0.000	0.000	0.000	0.00	0.00	0.00	
Pilot Gas (pph)	0.0091	0.0000	0.0000	0.0183	0.0000	0.0000	0.0004	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
Pilot Gas (tpy)	0.0401	0.0000	0.0000	0.0800	0.0000	0.0000	0.0016	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000	
Subtotal Flare (pph)	0.0206	0.1462	0.0000	0.0411	0.2919	0.0000	1.5754	2.4925	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	
Subtotal Flare (tpy)	0.0901	0.1080	0.0000	0.1799	0.2155	0.0000	6.9001	3.6805	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000	
Total Flare (pph)	0.1668			0.3330			4.0679			0.00002			0.00001			
Total Flare (tpy)	0.1981			0.3955			10.5806			0.0001			0.0000			

Notes: VOC Stream 1 input from emissions from tanks (3-T-1 thru 3-T-6) and Stream 2 input from 3-LOAD emissions captured and routed to the combustor.
MW of SO₂ = 64.066
MW of H₂S = 34.1

Sample Calculations:

$$NO_x \text{ pph} = \text{Hourly gas routed to the flare} \left(\frac{MMBtu}{hr} \right) \times NO_x \text{ Emission Factor} \left(\frac{lb}{MMBTu} \right)$$

NO_x tpy

$$= \text{Hourly gas routed to the flare} \left(\frac{MMBtu}{yr} \right) \times NO_x \text{ Emission Factor} \left(\frac{lb}{MMBTu} \right) \times \frac{1}{2000} \left(\frac{ton}{lbs} \right)$$

SO₂ pph

$$= \frac{\text{Weight \% H}_2\text{S}}{100} \times \frac{1}{385} \left(\frac{lb - mole}{scf} \right) \times MW \text{ of gas} \left(\frac{lb}{lb - mole} \right) \times \text{flowrate of gas} \left(\frac{scf}{hr} \right) \times \frac{MW \text{ of SO}_2}{MW \text{ of H}_2\text{S}}$$

Residual H₂S pph

$$= \frac{\text{Weight \% H}_2\text{S}}{100} \times \frac{1}{385} \left(\frac{lb - mole}{scf} \right) \times MW \text{ of gas} \left(\frac{lb}{lb - mole} \right) \times \text{flowrate of gas} \left(\frac{scf}{hr} \right) \times \frac{MW \text{ of SO}_2}{MW \text{ of H}_2\text{S}} \times \text{Flare efficiency}$$

Lucid Energy Group - Red Hills Gas Processing Plant

Emergency Cryo Flare

Emission Unit: 5-EP-2 and 7-EP-2

Fuel Data

<i>Flare Pilot</i>	350 scf/hr	Max design	
	0.00035 MMscf/hr		
	1020.00 Btu/scf	Pipeline Gas, HHV	
	0.357 MMBtu/hr		
<i>Sweep Gas</i>	0.000 Mscf/day	Design	
	0.0000 Mscf/hr	Mscf/d / 24 hr/day	
	0.00E+00 MMscf/hr	Mscf/hr / 1000	
	1020.00 Btu/scf	Pipeline Gas, HHV	
	0.0000 MMBtu/hr	MMscf/hr * Btu/scf	
<i>Flared Gas - Short Term</i>	9.608 MMscf/hr	Effective hourly flowrate	
	3,005 Btu/scf		
	28,871 MMBtu/hr	Hourly heat rate = Heating value * Effective hourly flow rate.	
	12 hr/yr	Hours of operation	
<i>Flared Gas - Annual</i>	346446.45 MMscf/yr	Estimated Maximum annual SSM flow rate. Not a requested limit; for calculation only.	
<i>Flare Design</i>	803.65 scf/hr		
	40.88 lb/lb-mole	Molecular weight	
	149.0 Btu/scf	Heating value	
	385.0 scf/lb-mole	Molar volume	
	1000000.0 btu/MMBtu		
	0.1 MMBtu/hr	Flare design rate	
	50%		
	0.060 MMBtu/hr	Limited Design rate	
<i>Pilot+ Sweep Gas only</i>	16.8	Pilot & Sweep gas molecular weight	Mol. wt. of methane, the dominant species
	2.50E+04 cal/sec	Heat release (q)	MMBtu/hr * 10 ⁶ * 252 cal/Btu ÷ 3600 sec/hr
	2.01E+04	q _n	q _n = q(1-0.048(MW) ^{1/2})
	0.1417 m	Effective stack diameter (D)	D = (10 ⁻⁶ q _n) ^{1/2}
<i>Pilot+Flared Gas+ Assist gas</i>	40.88 g/mol	weighted-averaged Flared gas molecular weight	
	4.19E+03 cal/sec	Heat release (q)	MMBtu/hr * 10 ⁶ * 252 cal/Btu ÷ 3600 sec/hr
	2.90E+03	q _n	q _n = q(1-0.048(MW) ^{1/2})
	0.054 m	Effective stack diameter (D)	D = (10 ⁻⁶ q _n) ^{1/2}

Flare / Vapor Combustor

A) Enter information into the blue boxes.

B) See notes/instructions included below.

Unit EPN EP-13
Unit Name Sour Water Tanks Flare

Flare EPN: EP-13							
	Gas Stream 1	Gas Stream 2	Gas Stream 3		Gas Stream 1	Gas Stream 2	Gas Stream 3
Emission Unit ID	Sour Tanks	4-LOAD		Hourly Gas Routed to Flare (MMBtu/hr)	0.06	1.43	
Hourly Gas Stream to Flare (Mscf/hr)	0.01990	0.43375		Annual Gas Routed to Flare (MMBtu/yr)	523.84	12508.82	
Annual Gas Stream to Flare (MMscf/yr)	0.174	3.800		Pilot Gas Routed to Flare (MMBtu/hr)	0.36	0.00	
Max. Heat Value of Gas (Btu/scf)	3005	3292.1		Gas MW (lb/lbmol)	59.45	59.45	from the head space analysis
Flare operational time (hr/yr)	8760	167		Gas Pressure (psia)	10	10	from the head space analysis
Field Gas Mol Fraction (lbmol H2S/lb-mol)	-	-		Gas Temperature (°F)	99	99	from the head space analysis
Field Gas Sulfur Content (S grains/100scf)	-	-		Field Gas H2S Wt.% to Flare (%)	0.05	0.05	
Pilot Gas to Flare (Mscf/hr)	0.35	0		Flare Control Efficiency	95	95	2295.461566 weighted btu/scf
Max. Heat Value of Pilot Gas (Btu/scf)	1020			Total VOC wt.% to Flare (%)	96.49	96.49	40.88227179 weighted MW
Pilot Gas H2S Wt.% to Flare (%)	0.0061			Source of Flare Emission Factors	TCEQ	TCEQ	
Pilot Gas MW (lb/lbmol)	16.82			Use Highest NO _x & CO Emission Factors From AP-42 or TCEQ	NO	NO	

Flare, Vapor Combustion Devices & Enclosed Devices Emission Factors			
Contaminant	Assist Type	AP-42 Emission Factor (lb/MMBtu)	TCEQ Emission Factors (lb/MMBtu)
NO _x	Steam (Btu/scf >1000)	0.068	0.0485
	Steam (Btu/scf <1000)	0.068	0.068
	Air or Unassisted (Btu/scf >1000)	0.068	0.138
	Air or Unassisted (Btu/scf <1000)	0.068	0.0641
CO	Steam (Btu/scf >1000)	0.31	0.3503
	Steam (Btu/scf <1000)	0.31	0.3465
	Air or Unassisted (Btu/scf >1000)	0.31	0.2755
	Air or Unassisted (Btu/scf <1000)	0.31	0.5496
VOC	Air or Unassisted	0.0054	--

Total Emissions to Flare															
Pollutant	NO _x			CO			VOC			SO ₂			H ₂ S		
	1	2	3	1	2	3	1	2	3	1	2	3	1	2	3
Gas Stream To Flare															
Uncontrolled (pph)	0.00	0.00	0.00	0.00	0.00	0.00	2.98	69.41	0.00	0.0000	0.00	0.00	0.0015	0.0400	0.00
Uncontrolled (tpy)	0.00	0.00	0.00	0.00	0.00	0.00	13.05	4.67	0.00	0.0000	0.00	0.00	0.0064	0.0024	0.00
Field Gas (pph)	0.01	0.09	0.00	0.02	0.78	0.00	0.15	3.47	0.00	0.0027	0.08	0.00	0.0001	0.00	0.00
Field Gas (tpy)	0.04	0.86	0.00	0.07	3.44	0.00	0.65	0.23	0.00	0.0120	0.01	0.00	0.0003	0.00	0.00
Pilot Gas (pph)	0.0493	0.0000	0.0000	0.0984	0.0000	0.0000	0.0019	0.0000	0.0000	0.0017	0.0000	0.0000	0.0000	0.0000	0.0000
Pilot Gas (tpy)	0.2158	0.0000	0.0000	0.4308	0.0000	0.0000	0.0084	0.0000	0.0000	0.0076	0.0000	0.0000	0.0001	0.0000	0.0000
Subtotal Flare (pph)	0.0575	0.0915	0.0000	0.1148	0.7848	0.0000	0.1508	3.4705	0.0000	0.004	0.0752	0.0000	0.0001	0.0020	0.0000
Subtotal Flare (tpy)	0.2519	0.8631	0.0000	0.5029	3.4374	0.0000	0.6607	0.2335	0.0000	0.0197	0.0063	0.0000	0.0004	0.0002	0.0000
Total Flare (pph)	0.1490			0.8996			3.6213			0.0796			0.0021		
Total Flare (tpy)	1.1150			3.9404			0.8942			0.0259			0.0006		

Notes: Pilot Gas to Flare (Cell D22) includes Pilot Gas and Sweep Gas.

MW of SO₂ = 64.066

MW of H₂S = 34.1

Sample Calculations:

$$NO_x \text{ pph} = \text{Hourly gas routed to the flare} \left(\frac{MMBtu}{hr} \right) \times NO_x \text{ Emission Factor} \left(\frac{lb}{MMBtu} \right)$$

NO_x tpy

$$= \text{Hourly gas routed to the flare} \left(\frac{MMBtu}{yr} \right) \times NO_x \text{ Emission Factor} \left(\frac{lb}{MMBtu} \right) \times \frac{1}{2000} \left(\frac{ton}{lb} \right)$$

$$SO_2 \text{ pph} = \frac{\text{Weight \% H}_2\text{S}}{100} \times \frac{1}{385} \left(\frac{lb - mole}{scf} \right) \times MW \text{ of gas} \left(\frac{lb}{lb - mole} \right) \times \text{flowrate of gas} \left(\frac{scf}{hr} \right) \times \frac{MW \text{ of } SO_2}{MW \text{ of H}_2\text{S}}$$

Residual H₂S pph

$$= \frac{\text{Weight \% H}_2\text{S}}{100} \times \frac{1}{385} \left(\frac{lb - mole}{scf} \right) \times MW \text{ of gas} \left(\frac{lb}{lb - mole} \right) \times \text{flowrate of gas} \left(\frac{scf}{hr} \right) \times \frac{MW \text{ of } SO_2}{MW \text{ of H}_2\text{S}} \times \text{Flare efficiency}$$

It is suggested that you link these cells below to the cells in the other tabs of this spreadsheet which contain the calculated uncontrolled emissions for the stream.

Mass Flow Rates of the Vapors Sent to this Control Device, Hourly Basis (lb/hr)													
Stream Sent to Thermal Oxidizer No.	1	2	3	4	5	6	7	8	9	10	11	12	Total
Stream Sent to Thermal Oxidizer Name	pilot(s)	added fuel stream(s)	To Thermal oxidizer stream										
H2S	-	-	3.74818										7.2994
Crude or Condensate VOC	-	-											0
Natural Gas VOC	-	-	365.50028										872.1926
Total VOC	-	-	365.50028										872.1926
benzene	-	-	75.0734										79.3206
Mass Flow Rates of the Vapors Sent to this Control Device, Annual Basis (tpy)													
H2S	-	-	16.08868783										31.33194
Crude or Condensate VOC	-	-											0
Natural Gas VOC	-	-	1568.873402										3743.8
Total VOC	-	-	1568.873402										3743.8
benzene	-	-	322.2450622										340.4757

Controlled Emissions													
Hourly (lb/hr)													
Stream Sent to Thermal Oxidizer No.													Total
Stream Sent to Thermal Oxidizer Name	pilot(s)	added fuel stream(s)	To Thermal oxidizer stream										
NOx	0.10	0.00	16.30	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	16.40
CO	0.08	0.00	9.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.98
PM2.5	0.01	0.00	7.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	7.05
PM10	0.01	0.00	9.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.40
H2S	0.00	0.00	0.07	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.08
SO2	0.00	0.00	0.74	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.74
Crude or Condensate VOC	-	-	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Natural Gas VOC	0.01	0.00	3.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.66
Total VOC	0.01	0.00	3.66	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.66
benzene	0.00	0.00	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.75
Annual (tpy)													
Stream Sent to Thermal Oxidizer No.													Total
Stream Sent to Thermal Oxidizer Name	pilot(s)	added fuel stream(s)	To Thermal oxidizer stream										
NOx	0.00	0.00	69.97	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	69.97
CO	0.00	0.00	42.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	42.49
PM2.5	0.00	0.00	30.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	30.25
PM10	0.00	0.00	40.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	40.33
H2S	0.00	0.00	0.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.32
SO2	0.00	0.00	30.24	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	30.24
Crude or Condensate VOC	-	-	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Natural Gas VOC	0.00	0.00	15.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	15.69
Total VOC	0.00	0.00	15.69	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	15.69
benzene	0.00	0.00	3.22	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.22

Thermal Oxidizer Total Emissions		
	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
Total Crude Oil or Condensate VOC	0.00	0.00
Total Natural Gas VOC	3.66	15.69
Total VOC	3.66	15.69
NOx	16.40	69.97
CO	9.98	42.49
PM2.5	7.05	30.25
PM10	9.40	40.33
H2S	0.08	0.32
SO2	0.74	30.24
benzene	0.75	3.22

Enter any notes here as needed. You must address the following:
 (1) How is this control efficiency justified? Please be specific.
 (2) Explain what happens when this unit is down. Include how long the unit could be down for.

Notes: NOx and CO hourly emission rates from the thermal oxidizer spec sheet

Company Name
 Site Name

Other Emissions

A) Enter information into the yellow boxes.

B) Please provide a separate detailed calculation for these emissions; also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs).

C) Since these emissions fall into the category of "Other", which does not have a pre-made emission estimation sheet with pre-approved methods, the time to review this project cannot be guaranteed to be as quick as if only pre-made sheets had been used.

D) VOC and H₂S control efficiencies may be entered (if applicable).

E) Make sure to answer the control device question.

EPN:	EP-11
Name:	Thermal Oxidizer SSM

Are these vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(A) uncontrolled	
---	------------------	--

<u>Uncontrolled Emissions</u>			
	Hourly Emissions (lb/hr)	Annual Emissions (tpy)	Control Efficiency
Total VOC	365.50	32.02	0
NOx	0.00	0.00	0
CO	0.00	0.00	0
PM2.5	0.00	0.00	0
PM10	0.00	0.00	0
H2S	3.75	0.33	0
SO2	0.00	0.00	0
benzene	75.07	6.58	0
formaldehyde	0.00	0.00	0

<u>Total Emissions (control efficiencies factored in if applicable)</u>		
	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
Total VOC	365.50	32.02
NOx	0.00	0.00
CO	0.00	0.00
PM2.5	0.00	0.00
PM10	0.00	0.00
H2S	3.75	0.33
SO2	0.00	0.00
benzene	75.07	6.58
formaldehyde	0.00	0.00

Flare / Vapor Combustor HAPs

Emission Unit EPN	Name	Flare Efficiency	Hours of Operation (hrs/hr)	Benzene		Toluene		Ethylbenzene		n-Hexane		Xylene		2,2,4-Trimethylpentane	
				lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
5-EP-2	Cryo 5 & 6 Flare SSM	98%	12	3.60	0.022	0.89	0.01	0.04	0.0002	139.59	0.84	0.16	0.001	0.86	0.01
7-EP-2	Cryo 7 Flare SSM	98%	12	3.60	0.022	0.89	0.01	0.04	0.0002	139.59	0.84	0.16	0.001	0.86	0.01
5.5-EP-1b	AGI 2 Flare SSM	98%	66	0.000	0.00	0.000	0.000	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
EP-12	Condensate Tanks Combustor	95%	8760	0.024	0.10	0.000	0.000	0.00	0.00	0.00	0.00	0.00	0.01	0.00	0.01
EP-10	Thermal Oxidizer	99%	8585	0.751	3.22	0.24	1.05	0.01	0.04	0.60	2.58	0.05	0.21	0.006	0.03
EP-11	Thermal Oxidizer SSM	0%	174	75.073	6.54	24.40	2.12	0.99	0.09	60.17	5.24	4.83	0.42	0.003	0.0003
EP-13	Sour Water Tanks Flare	95%	167	0.000	0.00	0.00	0.00	0.00	0.00	0.02	0.00	0.00	0.00	0.000	0.0000
Total				7.22	0.15	1.78	0.01	0.07	0.00	279.18	1.68	0.33	0.01	1.73	0.04

Composition	Mol%	MW1	MW*Mol%	Spec. Volume (scf/lb)	Heating Value (Btu/scf)	Mass Flow (lb/hr)
Carbon Dioxide	80.185%	44.01	35.290	8.623	0.0	10188.0
Nitrogen	0.000%	28.013	0.000	13.547	0.0	0.0
Hydrogen Sulfide	12.571%	34.076	4.284	11.136	637.0	1236.8
Methane	0.091%	16.043	0.015	23.65	1009.7	4.2
Ethane	0.026%	30.07	0.008	12.62	1768.7	2.2
Propane		44.097	0.000	8.606	2517.2	0.0
i-Butane		58.123	0.000	6.529	3252.6	0.0
n-Butane		58.123	0.000	6.529	3262	0.0
i-Pentane		72.15	0.000	5.26	3999.7	0.0
n-Pentane		72.15	0.000	5.26	4008.7	0.0
Hexanes		86.178	0.000	4.4	4756.1	0.0
Heptanes		100.205	0.000	3.787	5502.8	0.0
Benzene		78.114	0.000	4.858	3741.9	0.0
Toluene		92.141	0.000	4.119	4474.8	0.0
Xylene		106.16	0.000	3.574	4957	0.0
Ethylbenzene		106.17	0.000	3.574	4970.6	0.0
Octane		114.23	0.000	3.322	5796.1	0.0
Water	7.101%	18.04	1.281	0.016	0	486241.0
VOC Total	0.0%		0.00			0.0
Total	100%		40.88			11,431.2

Composition	Mass Flow (lb/hr)
N2	16143.9
C1	312132.0
CO2	79.6
C2	87557.7
H2S	0.0
C3	66142.8
iC4	10577.4
nC4	24412.2
iC5	6371.0
nC5	6249.8
C6	6755.2
C7	72.2
C8	22.8
C9	12.7
C10	0.0
Cyclopentane	342.2
Benzene	179.8
Cyclohexane	224.3
Methylcyclo	89.2
2,2,4-Trimet	42.9
Toluene	44.5
Ethylbenzer	1.8
p-Xylene	8.2
H2O	59.0
MDEA	0.0
Piperazine	0.0
TEG	4.2
CHEMOTHERM	0.0

Composition	Mass Flow (lb/hr)
Nitrogen	0.000
Methane	0.000
Carbon Diox	0.000
Ethane	0.000
Propane	0.070
Isobutane	0.362
n-Butane	2.943
Isopentane	6.719
n-Pentane	8.233
Cyclopentan	0.643
2-Methylper	0.000
3-Methylper	0.000
n-Hexane	10.844
Methylcyclo	0.000
Benzene	0.470
Cyclohexane	0.513
2-Methylhex	0.000
Cyclohexane	0.000
3-Methylhex	0.000
n-Heptane	0.169
Methylcyclo	0.215
Toluene	0.139
n-Octane	0.028
Ethylbenzen	0.006
n-Nonane	0.007
n-Decane	0.000
Undecane	0.000
Dodecane	0.000
Water	0.000
Hydrogen Su	0.000
2,2-Dimethyl	0.000
2,2-Dimethyl	0.000
2,3-Dimethyl	0.000
2,2,4-Trimet	0.096
Tridecane	0.000
Tetradecane	0.000
Pentadecane	0.000
Hexadecane	0.000
Heptadecane	0.000
Octadecane	0.000
Nonadecane	0.000
Eicosane	0.000
Heneicosane	0.000
Docosane	0.000
Tricosane	0.000
Tetracosane	0.000
Pentacosane	0.000
Hexacosane	0.000
Heptacosane	0.000
Octacosane	0.000
Nonacosane	0.000
Triacotane	0.000
2,2,4-Trimet	0.000
m-Xylene	0.000
o-Xylene	0.000
1,1-2-Dimeth	0.000
4,4-Dimethyl	0.000
p-Xylene	0.030
TEG	0.000
Piperazine	0.000
MDEA	0.000
O2	0.000

Composition	Mass Flow (lb/hr)
N2	0.24
C1	47.42
CO2	66397.73
C2	34.86
H2S	1.87
C3	36.89
iC4	6.04
nC4	24.97
iC5	10.67
nC5	13.49
C6	26.53
C7	0.52
C8	0.24
C9	0.20
C10	0.00
Cyclopentane	5.13
Benzene	37.54
Cyclohexane	3.55
Methylcyclo	1.58
2,2,4-Trimeth	0.29
Toluene	12.20
Ethylbenzene	0.50
p-Xylene	2.42
H2O	2041.17
MDEA	0.00
Piperazine	0.00
TEG	0.00

Composition	lb/hr
Hydrogen Su	0.00
Nitrogen	0.06
Carbon Diox	0.00
Methane	0.03
Ethane	0.01
Propane	0.27
Isobutane	0.38
N-Butane	0.92
Isopentane	0.61
N-Pentane	0.43
Hexanes +	0.37

Planned MSS Emissions

- A) Enter information into the yellow boxes.
- B) VOC and H₂S control efficiencies may be entered (if applicable).
- C) The vapor VOC, benzene, and H₂S weight percents may be entered. The weight percents from the Analyses tab are displayed below.
- D) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
- E) Make sure to answer the control device question.

EPN	2-EP-1t
Identifier	Train 2 - Blowdown SSM

Describe this MSS event in detail, include specifically what is being done and how it is being done.	Residue compressor blowdown emissions during maintenance activities. This train has 4 compressors, each with 470 acf of venting. 4 compressor blowdown volume = 470 x 4 = 1880 acf
--	--

Venting Emission Calculation

Warning: This calculation should provide a conservatively high (potentially overestimated) result for emissions from venting when only gas is present in a unit. If liquids are present in the unit, this calculation could potentially significantly underestimate emissions because this calculation does not factor in emissions resulting from the evaporation of liquids present in the unit. If liquids are present or if you wish to use another calculation methodology, do not use this calculation tab. Instead, use the calculation tab for "Other" and make sure to provide a separate detailed calculation for these emissions and also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs).

If emissions from this source are uncontrolled:

The formula is set up to do one calculation, which assumes that the entire volume of gas inside the unit is vented from the unit. The calculation of the mass of vented gas is done based on the volume of the unit vented, which is assumed to be saturated with vapor, and the temperature and pressure inside the unit before the venting occurs.

If emissions from this source are controlled:

The formula is set up to do two calculations. To preface the explanation of the two calculations, it is understood that for a release from a pressurized vessel, initial venting due to depressurization could occur rapidly until the vapor inside the vessel is equal to the atmospheric pressure, then further venting of the vapor still left in the vessel at atmospheric conditions could occur at a slower rate. This calculation assumes that any releases at atmospheric pressure cannot be controlled.

In order to move the vapor present in the vessel at atmospheric conditions to a control device, a flare for example, some sort of extra operation is needed such as using air or nitrogen to move the vapor out, and if all of that vapor is routed to the control device, it may be diluted to the point where it would not have a sufficient heating value to combust, and if a supplemental fuel stream is added, there would be additional emissions associated with this.

If you do have a way to move the vapor present in the vessel at atmospheric conditions to a control device, do not use this calculation tab. Instead, use the calculation tab for "Other" and make sure to provide a separate detailed calculation for these emissions and also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs). Also, please describe this MSS event in detail, include specifically what is being done, how it is being done, and how all of the vapor is controlled.

The first calculation of the mass of vented gas, which assumes that the entire volume of gas inside the unit is vented from the unit, is done based on the volume of the unit vented, which is assumed to be saturated with vapor, and the temperature and pressure inside the unit before the venting occurs.

The second calculation is done the same as the first one except using the atmospheric pressure (instead of the pressure inside the unit before the venting occurs) and represents all of the mass vented from the vessel that is present at atmospheric conditions (after the vessel depressurization).

The final result is the first calculation plus the second calculation, with the control efficiency only applied to the first calculation (which uses the pressure inside the unit before venting and represents the entire volume of gas inside the unit being vented).

Actual Volume of the Vented Unit (acf - actual cubic feet)	1880
Pressure of Gas Inside the Unit Before Venting (psig)	241.304051
Final Pressure (psia)	14.7
Pressure of Gas Inside the Unit Before Venting (psia)	256.004051
Temperature of Gas Inside the Unit Before Venting (°F)	100.00
Temperature of Gas Inside the Unit Before Venting (°R)	559.67
Duration of Each Event (hours/event)	1
Frequency of Events (events/year)	8
Venting Gas Molecular Weight (lb/lb-mol)	16.82
VOC wt %	0.157304435
benzene wt%	0
H ₂ S wt%	0.006079097
Are planned MSS vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(A) uncontrolled

Ideal Gas Constant, [(ft³*psia)/(R*lb-mol)]

10.73159

Gas Molecular Weight and Weight Percents From Analyses Tab:

Molecular Weight	22.7523
VOC wt %	21.3005
Benzene wt %	0.0488
H ₂ S wt %	0.0003

Planned MSS Emissions

	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
VOC Results:	2.1201	0.0085
Benzene Results:	0.0000	0.0000
H ₂ S Results:	0.0819	0.0003

Enter any notes here:

Planned MSS Emissions

- A) Enter information into the yellow boxes.
- B) VOC and H₂S control efficiencies may be entered (if applicable).
- C) The vapor VOC, benzene, and H₂S weight percents may be entered. The weight percents from the Analyses tab are displayed below.
- D) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
- E) Make sure to answer the control device question.

EPN	3-EP-1t
Identifier	Train 3 - Blowdown SSM

Describe this MSS event in detail, include specifically what is being done and how it is being done.	Residue compressor blowdown emissions during maintenance activities. This train has 4 compressors, each with 470 acf of venting. 4 compressor blowdown volume = 470 x 4 = 1880 acf
--	--

Venting Emission Calculation

Warning: This calculation should provide a conservatively high (potentially overestimated) result for emissions from venting when only gas is present in a unit. If liquids are present in the unit, this calculation could potentially significantly underestimate emissions because this calculation does not factor in emissions resulting from the evaporation of liquids present in the unit. If liquids are present or if you wish to use another calculation methodology, do not use this calculation tab. Instead, use the calculation tab for "Other" and make sure to provide a separate detailed calculation for these emissions and also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs).

If emissions from this source are uncontrolled:

The formula is set up to do one calculation, which assumes that the entire volume of gas inside the unit is vented from the unit. The calculation of the mass of vented gas is done based on the volume of the unit vented, which is assumed to be saturated with vapor, and the temperature and pressure inside the unit before the venting occurs.

If emissions from this source are controlled:

The formula is set up to do two calculations. To preface the explanation of the two calculations, it is understood that for a release from a pressurized vessel, initial venting due to depressurization could occur rapidly until the vapor inside the vessel is equal to the atmospheric pressure, then further venting of the vapor still left in the vessel at atmospheric conditions could occur at a slower rate. This calculation assumes that any releases at atmospheric pressure cannot be controlled.

In order to move the vapor present in the vessel at atmospheric conditions to a control device, a flare for example, some sort of extra operation is needed such as using air or nitrogen to move the vapor out, and if all of that vapor is routed to the control device, it may be diluted to the point where it would not have a sufficient heating value to combust, and if a supplemental fuel stream is added, there would be additional emissions associated with this.

If you do have a way to move the vapor present in the vessel at atmospheric conditions to a control device, do not use this calculation tab. Instead, use the calculation tab for "Other" and make sure to provide a separate detailed calculation for these emissions and also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs). Also, please describe this MSS event in detail, include specifically what is being done, how it is being done, and how all of the vapor is controlled.

The first calculation of the mass of vented gas, which assumes that the entire volume of gas inside the unit is vented from the unit, is done based on the volume of the unit vented, which is assumed to be saturated with vapor, and the temperature and pressure inside the unit before the venting occurs.

The second calculation is done the same as the first one except using the atmospheric pressure (instead of the pressure inside the unit before the venting occurs) and represents all of the mass vented from the vessel that is present at atmospheric conditions (after the vessel depressurization).

The final result is the first calculation plus the second calculation, with the control efficiency only applied to the first calculation (which uses the pressure inside the unit before venting and represents the entire volume of gas inside the unit being vented).

Actual Volume of the Vented Unit (acf - actual cubic feet)	1880
Pressure of Gas Inside the Unit Before Venting (psig)	241.304051
Final Pressure (psia)	14.7
Pressure of Gas Inside the Unit Before Venting (psia)	256.004051
Temperature of Gas Inside the Unit Before Venting (°F)	100.00
Temperature of Gas Inside the Unit Before Venting (°R)	559.67
Duration of Each Event (hours/event)	1
Frequency of Events (events/year)	8
Venting Gas Molecular Weight (lb/lb-mol)	16.81921558
VOC wt %	0.157304435
benzene wt%	0
H ₂ S wt%	0.006079097
Are planned MSS vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(A) uncontrolled

Ideal Gas Constant, [(ft³*psia)/(R*lb-mol)]

10.73159

Gas Molecular Weight and Weight Percents From Analyses Tab:

Molecular Weight	22.7523
VOC wt %	21.3005
Benzene wt %	0.0488
H ₂ S wt %	0.0003

Planned MSS Emissions

	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
VOC Results:	2.1201	0.0085
Benzene Results:	0.0000	0.0000
H ₂ S Results:	0.0819	0.0003

Enter any notes here:

Planned MSS Emissions

- A) Enter information into the yellow boxes.
- B) VOC and H₂S control efficiencies may be entered (if applicable).
- C) The vapor VOC, benzene, and H₂S weight percents may be entered. The weight percents from the Analyses tab are displayed below.
- D) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
- E) Make sure to answer the control device question.

EPN	4-EP-1t
Identifier	Train 4 - Blowdown SSM

Describe this MSS event in detail, include specifically what is being done and how it is being done.	Residue compressor blowdown emissions during maintenance activities. This train has 4 compressors, each with 470 acf of venting. 4 compressor blowdown volume = 470 x 4 = 1880 acf
--	--

Venting Emission Calculation

Warning: This calculation should provide a conservatively high (potentially overestimated) result for emissions from venting when only gas is present in a unit. If liquids are present in the unit, this calculation could potentially significantly underestimate emissions because this calculation does not factor in emissions resulting from the evaporation of liquids present in the unit. If liquids are present or if you wish to use another calculation methodology, do not use this calculation tab. Instead, use the calculation tab for "Other" and make sure to provide a separate detailed calculation for these emissions and also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs).

If emissions from this source are uncontrolled:

The formula is set up to do one calculation, which assumes that the entire volume of gas inside the unit is vented from the unit. The calculation of the mass of vented gas is done based on the volume of the unit vented, which is assumed to be saturated with vapor, and the temperature and pressure inside the unit before the venting occurs.

If emissions from this source are controlled:

The formula is set up to do two calculations. To preface the explanation of the two calculations, it is understood that for a release from a pressurized vessel, initial venting due to depressurization could occur rapidly until the vapor inside the vessel is equal to the atmospheric pressure, then further venting of the vapor still left in the vessel at atmospheric conditions could occur at a slower rate. This calculation assumes that any releases at atmospheric pressure cannot be controlled.

In order to move the vapor present in the vessel at atmospheric conditions to a control device, a flare for example, some sort of extra operation is needed such as using air or nitrogen to move the vapor out, and if all of that vapor is routed to the control device, it may be diluted to the point where it would not have a sufficient heating value to combust, and if a supplemental fuel stream is added, there would be additional emissions associated with this.

If you do have a way to move the vapor present in the vessel at atmospheric conditions to a control device, do not use this calculation tab. Instead, use the calculation tab for "Other" and make sure to provide a separate detailed calculation for these emissions and also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs). Also, please describe this MSS event in detail, include specifically what is being done, how it is being done, and how all of the vapor is controlled.

The first calculation of the mass of vented gas, which assumes that the entire volume of gas inside the unit is vented from the unit, is done based on the volume of the unit vented, which is assumed to be saturated with vapor, and the temperature and pressure inside the unit before the venting occurs.

The second calculation is done the same as the first one except using the atmospheric pressure (instead of the pressure inside the unit before the venting occurs) and represents all of the mass vented from the vessel that is present at atmospheric conditions (after the vessel depressurization).

The final result is the first calculation plus the second calculation, with the control efficiency only applied to the first calculation (which uses the pressure inside the unit before venting and represents the entire volume of gas inside the unit being vented).

Actual Volume of the Vented Unit (acf - actual cubic feet)	1880
Pressure of Gas Inside the Unit Before Venting (psig)	241.304051
Final Pressure (psia)	14.7
Pressure of Gas Inside the Unit Before Venting (psia)	256.004051
Temperature of Gas Inside the Unit Before Venting (°F)	100.00
Temperature of Gas Inside the Unit Before Venting (°R)	559.67
Duration of Each Event (hours/event)	1
Frequency of Events (events/year)	8
Venting Gas Molecular Weight (lb/lb-mol)	16.81921558
VOC wt %	0.157304435
benzene wt%	0
H ₂ S wt%	0.006079097
Are planned MSS vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(A) uncontrolled

Ideal Gas Constant, [(ft³*psia)/(R*lb-mol)]

10.73159

Gas Molecular Weight and Weight Percents From Analyses Tab:

Molecular Weight	22.7523
VOC wt %	21.3005
Benzene wt %	0.0488
H ₂ S wt %	0.0003

Planned MSS Emissions

	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
VOC Results:	2.1201	0.0085
Benzene Results:	0.0000	0.0000
H ₂ S Results:	0.0819	0.0003

Enter any notes here:

Planned MSS Emissions

- A) Enter information into the yellow boxes.
- B) VOC and H₂S control efficiencies may be entered (if applicable).
- C) The vapor VOC, benzene, and H₂S weight percents may be entered. The weight percents from the Analyses tab are displayed below.
- D) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
- E) Make sure to answer the control device question.

EPN	5-EP-1t
Identifier	Train 5 - Blowdown SSM

Describe this MSS event in detail, include specifically what is being done and how it is being done.	Residue compressor blowdown emissions during maintenance activities. This train has 4 compressors, each with 470 acf of venting. 4 compressor blowdown volume = 470 x 4 = 1880 acf
--	--

Venting Emission Calculation

Warning: This calculation should provide a conservatively high (potentially overestimated) result for emissions from venting when only gas is present in a unit. If liquids are present in the unit, this calculation could potentially significantly underestimate emissions because this calculation does not factor in emissions resulting from the evaporation of liquids present in the unit. If liquids are present or if you wish to use another calculation methodology, do not use this calculation tab. Instead, use the calculation tab for "Other" and make sure to provide a separate detailed calculation for these emissions and also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs).

If emissions from this source are uncontrolled:

The formula is set up to do one calculation, which assumes that the entire volume of gas inside the unit is vented from the unit. The calculation of the mass of vented gas is done based on the volume of the unit vented, which is assumed to be saturated with vapor, and the temperature and pressure inside the unit before the venting occurs.

If emissions from this source are controlled:

The formula is set up to do two calculations. To preface the explanation of the two calculations, it is understood that for a release from a pressurized vessel, initial venting due to depressurization could occur rapidly until the vapor inside the vessel is equal to the atmospheric pressure, then further venting of the vapor still left in the vessel at atmospheric conditions could occur at a slower rate. This calculation assumes that any releases at atmospheric pressure cannot be controlled.

In order to move the vapor present in the vessel at atmospheric conditions to a control device, a flare for example, some sort of extra operation is needed such as using air or nitrogen to move the vapor out, and if all of that vapor is routed to the control device, it may be diluted to the point where it would not have a sufficient heating value to combust, and if a supplemental fuel stream is added, there would be additional emissions associated with this.

If you do have a way to move the vapor present in the vessel at atmospheric conditions to a control device, do not use this calculation tab. Instead, use the calculation tab for "Other" and make sure to provide a separate detailed calculation for these emissions and also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs). Also, please describe this MSS event in detail, include specifically what is being done, how it is being done, and how all of the vapor is controlled.

The first calculation of the mass of vented gas, which assumes that the entire volume of gas inside the unit is vented from the unit, is done based on the volume of the unit vented, which is assumed to be saturated with vapor, and the temperature and pressure inside the unit before the venting occurs.

The second calculation is done the same as the first one except using the atmospheric pressure (instead of the pressure inside the unit before the venting occurs) and represents all of the mass vented from the vessel that is present at atmospheric conditions (after the vessel depressurization).

The final result is the first calculation plus the second calculation, with the control efficiency only applied to the first calculation (which uses the pressure inside the unit before venting and represents the entire volume of gas inside the unit being vented).

Actual Volume of the Vented Unit (acf - actual cubic feet)	1880
Pressure of Gas Inside the Unit Before Venting (psig)	241.304051
Final Pressure (psia)	14.7
Pressure of Gas Inside the Unit Before Venting (psia)	256.004051
Temperature of Gas Inside the Unit Before Venting (°F)	100.00
Temperature of Gas Inside the Unit Before Venting (°R)	559.67
Duration of Each Event (hours/event)	1
Frequency of Events (events/year)	8
Venting Gas Molecular Weight (lb/lb-mol)	16.81921558
VOC wt %	0.157304435
benzene wt%	0
H ₂ S wt%	0.006079097
Are planned MSS vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(A) uncontrolled

Ideal Gas Constant, [(ft³*psia)/(R*lb-mol)]

10.73159

Gas Molecular Weight and Weight Percents From Analyses Tab:

Molecular Weight	22.7523
VOC wt %	21.3005
Benzene wt %	0.0488
H ₂ S wt %	0.0003

Planned MSS Emissions

	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
VOC Results:	2.1201	0.0085
Benzene Results:	0.0000	0.0000
H ₂ S Results:	0.0819	0.0003

Enter any notes here:

Planned MSS Emissions

- A) Enter information into the yellow boxes.
- B) VOC and H₂S control efficiencies may be entered (if applicable).
- C) The vapor VOC, benzene, and H₂S weight percents may be entered. The weight percents from the Analyses tab are displayed below.
- D) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
- E) Make sure to answer the control device question.

EPN	6-EP-1t
Identifier	Train 6 - Blowdown SSM

Describe this MSS event in detail, include specifically what is being done and how it is being done.	Residue compressor blowdown emissions during maintenance activities. This train has 4 compressors, each with 470 acf of venting. 4 compressor blowdown volume = 470 x 4 = 1880 acf
--	--

Venting Emission Calculation

Warning: This calculation should provide a conservatively high (potentially overestimated) result for emissions from venting when only gas is present in a unit. If liquids are present in the unit, this calculation could potentially significantly underestimate emissions because this calculation does not factor in emissions resulting from the evaporation of liquids present in the unit. If liquids are present or if you wish to use another calculation methodology, do not use this calculation tab. Instead, use the calculation tab for "Other" and make sure to provide a separate detailed calculation for these emissions and also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs).

If emissions from this source are uncontrolled:

The formula is set up to do one calculation, which assumes that the entire volume of gas inside the unit is vented from the unit. The calculation of the mass of vented gas is done based on the volume of the unit vented, which is assumed to be saturated with vapor, and the temperature and pressure inside the unit before the venting occurs.

If emissions from this source are controlled:

The formula is set up to do two calculations. To preface the explanation of the two calculations, it is understood that for a release from a pressurized vessel, initial venting due to depressurization could occur rapidly until the vapor inside the vessel is equal to the atmospheric pressure, then further venting of the vapor still left in the vessel at atmospheric conditions could occur at a slower rate. This calculation assumes that any releases at atmospheric pressure cannot be controlled.

In order to move the vapor present in the vessel at atmospheric conditions to a control device, a flare for example, some sort of extra operation is needed such as using air or nitrogen to move the vapor out, and if all of that vapor is routed to the control device, it may be diluted to the point where it would not have a sufficient heating value to combust, and if a supplemental fuel stream is added, there would be additional emissions associated with this.

If you do have a way to move the vapor present in the vessel at atmospheric conditions to a control device, do not use this calculation tab. Instead, use the calculation tab for "Other" and make sure to provide a separate detailed calculation for these emissions and also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs). Also, please describe this MSS event in detail, include specifically what is being done, how it is being done, and how all of the vapor is controlled.

The first calculation of the mass of vented gas, which assumes that the entire volume of gas inside the unit is vented from the unit, is done based on the volume of the unit vented, which is assumed to be saturated with vapor, and the temperature and pressure inside the unit before the venting occurs.

The second calculation is done the same as the first one except using the atmospheric pressure (instead of the pressure inside the unit before the venting occurs) and represents all of the mass vented from the vessel that is present at atmospheric conditions (after the vessel depressurization).

The final result is the first calculation plus the second calculation, with the control efficiency only applied to the first calculation (which uses the pressure inside the unit before venting and represents the entire volume of gas inside the unit being vented).

Actual Volume of the Vented Unit (acf - actual cubic feet)	1880
Pressure of Gas Inside the Unit Before Venting (psig)	241.304051
Final Pressure (psia)	14.7
Pressure of Gas Inside the Unit Before Venting (psia)	256.004051
Temperature of Gas Inside the Unit Before Venting (°F)	100.00
Temperature of Gas Inside the Unit Before Venting (°R)	559.67
Duration of Each Event (hours/event)	1
Frequency of Events (events/year)	8
Venting Gas Molecular Weight (lb/lb-mol)	16.81921558
VOC wt %	0.157304435
benzene wt%	0
H ₂ S wt%	0.006079097
Are planned MSS vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(A) uncontrolled

Ideal Gas Constant, [(ft³*psia)/(R*lb-mol)]

10.73159

Gas Molecular Weight and Weight Percents From Analyses Tab:

Molecular Weight	22.7523
VOC wt %	21.3005
Benzene wt %	0.0488
H ₂ S wt %	0.0003

Planned MSS Emissions

	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
VOC Results:	2.1201	0.0085
Benzene Results:	0.0000	0.0000
H ₂ S Results:	0.0819	0.0003

Enter any notes here:

Planned MSS Emissions

- A) Enter information into the yellow boxes.
- B) VOC and H₂S control efficiencies may be entered (if applicable).
- C) The vapor VOC, benzene, and H₂S weight percents may be entered. The weight percents from the Analyses tab are displayed below.
- D) Use the box provided below for entering any notes necessary (such as the source/justification for any calculation inputs).
- E) Make sure to answer the control device question.

EPN	7-EP-1t
Identifier	Train 7 - Blowdown SSM

Describe this MSS event in detail, include specifically what is being done and how it is being done.	Residue compressor blowdown emissions during maintenance activities. This train has 4 compressors, each with 470 acf of venting. 4 compressor blowdown volume = 470 x 4 = 1880 acf
--	--

Venting Emission Calculation

Warning: This calculation should provide a conservatively high (potentially overestimated) result for emissions from venting when only gas is present in a unit. If liquids are present in the unit, this calculation could potentially significantly underestimate emissions because this calculation does not factor in emissions resulting from the evaporation of liquids present in the unit. If liquids are present or if you wish to use another calculation methodology, do not use this calculation tab. Instead, use the calculation tab for "Other" and make sure to provide a separate detailed calculation for these emissions and also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs).

If emissions from this source are uncontrolled:

The formula is set up to do one calculation, which assumes that the entire volume of gas inside the unit is vented from the unit. The calculation of the mass of vented gas is done based on the volume of the unit vented, which is assumed to be saturated with vapor, and the temperature and pressure inside the unit before the venting occurs.

If emissions from this source are controlled:

The formula is set up to do two calculations. To preface the explanation of the two calculations, it is understood that for a release from a pressurized vessel, initial venting due to depressurization could occur rapidly until the vapor inside the vessel is equal to the atmospheric pressure, then further venting of the vapor still left in the vessel at atmospheric conditions could occur at a slower rate. This calculation assumes that any releases at atmospheric pressure cannot be controlled.

In order to move the vapor present in the vessel at atmospheric conditions to a control device, a flare for example, some sort of extra operation is needed such as using air or nitrogen to move the vapor out, and if all of that vapor is routed to the control device, it may be diluted to the point where it would not have a sufficient heating value to combust, and if a supplemental fuel stream is added, there would be additional emissions associated with this.

If you do have a way to move the vapor present in the vessel at atmospheric conditions to a control device, do not use this calculation tab. Instead, use the calculation tab for "Other" and make sure to provide a separate detailed calculation for these emissions and also include any necessary supplemental information and notes (such as the source/justification for any calculation inputs). Also, please describe this MSS event in detail, include specifically what is being done, how it is being done, and how all of the vapor is controlled.

The first calculation of the mass of vented gas, which assumes that the entire volume of gas inside the unit is vented from the unit, is done based on the volume of the unit vented, which is assumed to be saturated with vapor, and the temperature and pressure inside the unit before the venting occurs.

The second calculation is done the same as the first one except using the atmospheric pressure (instead of the pressure inside the unit before the venting occurs) and represents all of the mass vented from the vessel that is present at atmospheric conditions (after the vessel depressurization).

The final result is the first calculation plus the second calculation, with the control efficiency only applied to the first calculation (which uses the pressure inside the unit before venting and represents the entire volume of gas inside the unit being vented).

Actual Volume of the Vented Unit (acf - actual cubic feet)	1880
Pressure of Gas Inside the Unit Before Venting (psig)	241.304051
Final Pressure (psia)	14.7
Pressure of Gas Inside the Unit Before Venting (psia)	256.004051
Temperature of Gas Inside the Unit Before Venting (°F)	100.00
Temperature of Gas Inside the Unit Before Venting (°R)	559.67
Duration of Each Event (hours/event)	1
Frequency of Events (events/year)	8
Venting Gas Molecular Weight (lb/lb-mol)	16.81921558
VOC wt %	0.157304435
benzene wt%	0
H ₂ S wt%	0.006079097
Are planned MSS vapors (A) uncontrolled; (B) controlled by a flare, vapor combustor, thermal oxidizer, or vapor recovery unit (VRU); or (C) controlled by another type of control device?	(A) uncontrolled

Ideal Gas Constant, [(ft³*psia)/(R*lb-mol)]

10.73159

Gas Molecular Weight and Weight Percents From Analyses Tab:

Molecular Weight	22.7523
VOC wt %	21.3005
Benzene wt %	0.0488
H ₂ S wt %	0.0003

Planned MSS Emissions

	Hourly Emissions (lb/hr)	Annual Emissions (tpy)
VOC Results:	2.1201	0.0085
Benzene Results:	0.0000	0.0000
H ₂ S Results:	0.0819	0.0003

Enter any notes here:

Haul Road Emissions

<u>General Information</u>	
Unit Name:	Haul emissions
Unit EPN:	HAUL1
What kind of device is this? Enter a short description of the device type.	Unpaved haul road emissions from trucking operations for condensate tanks - Exempt under NMAC 20.2.72.202.B.5

Empty vehicle weight (tons)	16.00
Density of liquid loaded (lb/gal)	5.38
Load weight (tons)	20.34
Loaded vehicle (tons)	36.34
Mean vehicle weight (tons)	26.11
Round-trip distance (mile/trip)	0.32
Annual Throughput (bbl/yr)	1143180.00
Trip frequency (trips/hr)	2.00
Trip frequency (trips/yr)	6276.28
Surface silt content (%)	4.80
Annual wet days (days/yr)	70.00
Vehicle miles traveled (mile/hr)	0.60
Control	Base course and watering
Control Efficiency (%)	80%

<u>Controlled Emissions</u>		
<u>Hourly (lb/hr)</u>		
PM ₃₀	PM ₁₀	PM _{2.5}
0.820	0.209	0.021
<u>Annual (tpy)</u>		
1.109	0.283	0.028

Emission Factors and Constants				
Parameter	PM ₃₀	PM ₁₀	PM _{2.5}	
k, lb/VMT	4.90	1.50	0.15	
a, lb/VMT	0.70	0.90	0.90	Table 13.2.2-2, Industrial Roads
b, lb/VMT	0.45	0.45	0.45	
Hourly EF, lb/VMT	6.83	1.74	0.17	
Annual EF, lb/VMT	5.52	1.41	0.14	AP-42 13.2.2, Equation 1a & 2

Empty vehicle weight includes driver and occupants and full fuel load.

Cargo, transported materials, etc. (6.8 lb/gal Oil *7560 gal truck/ 2000lb/ton)

Loaded vehicle weight = Empty + Load Size

Mean Vehicle weight = (Loaded Weight + Empty Weight) / 2

AP-42 Table 13.2.2-1 - Silt Content 4.8 %

AP-42 Figure 13.2.2-1 - Annual wet days

VMT/hr = Vehicle Miles Traveled per hour= Trips per hour * Segment Length


Control Efficiency - NMED Guidance Document - Department Accepted Values For: Aggregate Handling, Storage Pile, and Haul Road Emissions

Table 13.2.2-2, Industrial Roads for values of k, a, and b.

AP-42 13.2.2, Equation 1a & AP-42 13.2.2, Equation 2 for Hourly and Annual EF calculations.

lb/hr = Hourly EF (lb/VMT) * VMT (mile/hr) * (1-control efficiency)

ton/yr =Annual EF (lb/VMT) * VMT (mile/Trip) * Trips per year (Trip/yr) / 2000 (lb/tpy) * (1-control efficiency)



Haul Road Emissions

General Information	
Unit Name:	Haul emissions
Unit EPN:	HAUL2
What kind of device is this? Enter a short description of the device type.	Unpaved haul road emissions from trucking operations for sour water tanks - Exempt under NMAC 20.2.72.202.B.5

Empty vehicle weight (tons)	16.00
Density of liquid loaded (lb/gal)	5.38
Load weight (tons)	20.34
Loaded vehicle (tons)	36.34
Mean vehicle weight (tons)	26.11
Round-trip distance (mile/trip)	0.75
Annual Throughput (bbl/yr)	31755.00
Trip frequency (trips/hr)	2.00
Trip frequency (trips/yr)	174.34
Surface silt content (%)	4.80
Annual wet days (days/yr)	70.00
Vehicle miles traveled (mile/hr)	0.60
Control	Base course and watering
Control Efficiency (%)	80%

Controlled Emissions		
Hourly (lb/hr)		
PM ₃₀	PM ₁₀	PM _{2.5}
0.820	0.209	0.021
Annual (tpy)		
0.072	0.018	0.002

Emission Factors and Constants				
Parameter	PM ₃₀	PM ₁₀	PM _{2.5}	
k, lb/VMT	4.90	1.50	0.15	
a, lb/VMT	0.70	0.90	0.90	Table 13.2.2-2, Industrial Roads
b, lb/VMT	0.45	0.45	0.45	
Hourly EF, lb/VMT	6.83	1.74	0.17	
Annual EF, lb/VMT	5.52	1.41	0.14	AP-42 13.2.2, Equation 1a & 2

Empty vehicle weight includes driver and occupants and full fuel load.

Cargo, transported materials, etc. (6.8 lb/gal Oil *7560 gal truck/ 2000lb/ton)

Loaded vehicle weight = Empty + Load Size

Mean Vehicle weight = (Loaded Weight + Empty Weight) / 2

AP-42 Table 13.2.2-1 - Silt Content 4.8 %

AP-42 Figure 13.2.2-1 - Annual wet days

VMT/hr = Vehicle Miles Traveled per hour= Trips per hour * Segment Length

Control Efficiency - NMED Guidance Document - Department Accepted Values For: Aggregate Handling, Storage Pile, and Haul Road Emissions

Table 13.2.2-2, Industrial Roads for values of k, a, and b.

AP-42 13.2.2, Equation 1a & AP-42 13.2.2, Equation 2 for Hourly and Annual EF calculations.

lb/hr = Hourly EF (lb/VMT) * VMT (mile/hr) * (1-control efficiency)

ton/yr =Annual EF (lb/VMT) * VMT (mile/Trip) * Trips per year (Trip/yr) / 2000 (lb/tpy) * (1-control efficiency)



Haul Road Emissions

<u>General Information</u>	
Unit Name:	Haul emissions
Unit EPN:	HAUL3
What kind of device is this? Enter a short description of the device type.	Unpaved haul road emissions from trucking operations for slop tanks - Exempt under NMAC 20.2.72.202.B.5

Empty vehicle weight (tons)	16.00
Density of liquid loaded (lb/gal)	5.38
Load weight (tons)	20.34
Loaded vehicle (tons)	36.34
Mean vehicle weight (tons)	26.11
Round-trip distance (mile/trip)	1.58
Annual Throughput (bbl/yr)	88330.00
Trip frequency (trips/hr)	2.00
Trip frequency (trips/yr)	484.95
Surface silt content (%)	4.80
Annual wet days (days/yr)	70.00
Vehicle miles traveled (mile/hr)	0.60
Control	Base course and watering
Control Efficiency (%)	80%

<u>Controlled Emissions</u>		
<u>Hourly (lb/hr)</u>		
PM ₃₀	PM ₁₀	PM _{2.5}
0.820	0.209	0.021
<u>Annual (tpy)</u>		
0.423	0.108	0.011

Emission Factors and Constants				
Parameter	PM ₃₀	PM ₁₀	PM _{2.5}	
k, lb/VMT	4.90	1.50	0.15	
a, lb/VMT	0.70	0.90	0.90	Table 13.2.2-2,
b, lb/VMT	0.45	0.45	0.45	Industrial Roads
Hourly EF, lb/VMT	6.83	1.74	0.17	
Annual EF, lb/VMT	5.52	1.41	0.14	AP-42 13.2.2, Equation 1a & 2

Empty vehicle weight includes driver and occupants and full fuel load.

Cargo, transported materials, etc. (6.8 lb/gal Oil *7560 gal truck/ 2000lb/ton)

Loaded vehicle weight = Empty + Load Size

Mean Vehicle weight = (Loaded Weight + Empty Weight) / 2

AP-42 Table 13.2.2-1 - Silt Content 4.8 %

AP-42 Figure 13.2.2-1 - Annual wet days

VMT/hr = Vehicle Miles Traveled per hour= Trips per hour * Segment Length


Control Efficiency - NMED Guidance Document - Department Accepted Values For: Aggregate Handling, Storage Pile, and Haul Road Emissions

Table 13.2.2-2, Industrial Roads for values of k, a, and b.

AP-42 13.2.2, Equation 1a & AP-42 13.2.2, Equation 2 for Hourly and Annual EF calculations.

lb/hr = Hourly EF (lb/VMT) * VMT (mile/hr) * (1-control efficiency)

ton/yr =Annual EF (lb/VMT) * VMT (mile/Trip) * Trips per year (Trip/yr) / 2000 (lb/tpy) * (1-control efficiency)



Default VOC emissions for Miscellaneous MSS activities

Company Name	Lucid Energy Delaware, LLC
Site Name	Red Hills Gas Processing Plant

Source Name	Miscellaneous Startup, Shutdown and Maintenance
EPN	SSM/M

Date of MSS activity	Varies
Default VOC emissions (tpy) associated with miscellaneous MSS activities	0.250
Add default VOC emissions from miscellaneous MSS activities to the emissions summary	No

#	Activity	Description / comments	Default parameters		Equation used		Input parameters		Annual emissions (tpy)	
1	(b)(1) Engine Oil changes / Filter changes The emissions associated with an engine oil/filter change occur during the draining of the used engine oil into oil pan or container.	-Engine has been isolated and blow down occurs prior to oil change. The emissions associated with the blow down [106.359 (b) (8)] need to be accounted for in the oil and gas emission calculation spreadsheet. -Oil is drained into a 4 ft x 4 ft open pan and transferred to a closed container per Best Management Practice (BMP). -Input parameters based on manufacturer specifications of engine oil SAE 10W (a). -Used a 1380 hp Caterpillar G3516B LE engine (b) as basis for calculation. In order to account for emissions from larger horse power engines, the emissions are doubled. An average engine uses 112 gallons of motor oil and manufacturer recommends changing oil every 1000 hrs. We used 10 changes of oil per year as a conservative estimate. -Emission estimates for 1380 hp engine are being doubled to be conservative and to accommodate engines with higher hp.	Temperature (°F)	212	Loading loss L_L (lb/1000 gal)	0.009	Number of engines	41	0.506	
			Vapor pressure (psia)	0.001						
			Saturation factor	1	Loading loss per activity (lb/activity)	0.001				
			Molecular weight (lb/lbmol)	500						
			Motor oil (gal/activity)	112	Evaporation Loss (lb/activity)	1.027				
			U wind speed (m/s)	3.52						
			Vapor pressure P_v (Pa)	10						
			Molecular weight (lb/lbmol)	500						
			Surface Area A_p (m ²) (4ft * 4ft)	1.48						
			Evaporation time t (hrs)	10						
	Number of activities per year (Number of oil changes per engine per year)	12	Total (lbs/yr/engine)	24.678						
	Factor used to account for larger horsepower engines	2								
2	(b)(1) & (b)(4) Changing Engine Rod Packings Emissions from changing of the rod would be from clingage of lubricant in the casing.	-Engine has been isolated and blow down occurs prior to changing rod packing. The emissions associated with the blow down [106.359 (b) (8)] need to be accounted for in the oil and gas emission calculation spreadsheet. -Emissions from clingage are the evaporation of the lubricant adhered to the rod packing casing. -Casing volume for calculations is based on field observation of casing for a 1380hp G3516B LE engine(b). -Input parameters based on material specifications for AP 101(c) grease.	Temperature (°F)	104	Clingage loss (lb/activity)	0.0001	Number of engines	41	2.87189E-05	
			Vapor pressure (psia)	0.001						
			Molecular weight (lb/lb-mole)	500						
			V_v Casing volume (ft ³) (1ft * 3ft)	2.355						
			Ideal gas constant (psia-ft ³ /lb-mol-°R)	10.73						
				Number of activities per year (Number of rod packing changes per year per engine)	12	Total (lbs/yr/engine)				0.0014
3	(b)(3) Changing wet and dry seals Emissions from changing seals would be from clingage of lubricant in the casing.	-Engine has been isolated and blow down occurs prior to changing seals. The emissions associated with the blow down [106.359 (b) (8)] need to be accounted for in the oil and gas emission calculation spreadsheet. -Emissions from clingage are the evaporation of the lubricant adhered to the rod packing casing. -Casing volume for calculations is based on field observation of casing for a 1380 hp Caterpillar G3516B LE engine (b). -Input parameters based on material specifications for AP 101(c) grease.	Temperature (°F)	104	Clingage loss (lb/activity)	0.0001	Number of engines	41	0.000010	
			Vapor pressure of material stored (psia)	0.001						
			Molecular weight (lb/lb-mole)	500						
			V_v Casing volume (ft ³) (1ft * 3ft)	2.355						
			Ideal gas constant (psia-ft ³ /lb-mol-°R)	10.73						
				Number of activities per year (Number of seal changes per year)	4	Total (lbs/yr/engine)				0.0005

4	(b)(2) Glycol dehydration unit Emissions associated with replacement of glycol solution used in dehydration unit. There are two vessels in a dehydration unit: contactor and regenerator.	-Calculations based on physical properties of mono ethylene glycol (MEG)(d) because of its low molecular weight and high vapor pressure which gives the most conservative emissions estimate. -Typically the glycol solution used in dehydration unit is not entirely replaced but it is conservatively assumed that the glycol solution is drained once per year for vessel maintenance. -Per field experience, 4000 gal of glycol solution is used in a large dehydration unit.	Temperature (°F)	68	Loading loss L _L (lb/1000 gal)	0.0015	Number of Dehy units	2	0.000085
			Vapor pressure (psia)	0.001					
			Saturation factor	1	Loading loss per activity (lb/activity)	0.0059			
			Molecular weight (lb/lbmol)	62.07					
			Glycol solution (gal/activity)	4000	Clingage loss (lb/activity)	0.0155			
			Temperature (°F)	68					
			Vapor pressure (psia)	0.001					
			Molecular weight (lb/lb-mole)	62.07					
			V _v Vessel volume (ft ³) (5 ft radii * 30 ft height)	2355					
			Ideal gas constant (psia-ft ³ /lb-mol-°R)	10.73					
Number of activities per year	4	Total (lbs/yr/unit)	0.0854						
5	(b)(2) Amine unit Emissions associated with replacement of solution used in the amine unit. There are two vessels in an amine unit: Contactor and regenerator.	-Calculations based on physical properties of mono ethanol amine (MEA)(e) because of its low molecular weight and high vapor pressure which gives the most conservative emissions estimate. -Typically the solution used in amine unit is not entirely replaced but it is conservatively assumed that the amine solution is drained once per year for vessel maintenance. -Per field experience, 4000 gal of solution is used in a large amine unit.	Temperature (°F)	68	Loading loss L _L (lb/1000 gal)	0.0058	Number of Dehy units	2	0.000336
			Vapor pressure (psia)	0.004					
			Saturation factor	1	Loading loss per activity (lb/activity)	0.0231			
			Molecular weight (lb/lbmol)	61.08					
			Amine solution (gal/activity)	4000	Clingage loss (lb/activity)	0.0609			
			Temperature (°F)	68					
			Vapor pressure (psia)	0.004					
			Molecular weight (lb/lb-mole)	61.08					
			V _v Vessel volume (ft ³) (5 ft radii * 30 ft height)	2355					
			Ideal gas constant (psia-ft ³ /lb-mol-°R)	10.73					
Number of activities per year	4	Total (lbs/yr/unit)	0.3360						
6	(b)(2) Heater Treater	-Calculations based on condensate (RVP 10) because it has higher vapor pressure than crude oil (RVP 5) and results in a more conservative emission estimate. -Emission estimates are based on a large site that typically has 4 heater treaters.	Temperature (°F)	100	Clingage loss (lb/activity)	8.6913	Number of Heater Treaters	11	0.096
			Vapor pressure (psia)	10.5					
			Molecular weight (lb/lb-mole)	66					
			V _v Vessel volume (ft ³) (2ft radii * 10 ft height)	125.6					
			Ideal gas constant (psia-ft ³ /lb-mol-°R)	10.73					
			Number of activities per year	2					
7	(b)(2) Aerosol Lubricants	-45-50% VOC by weight volatilizes. -Material specification per Lubricant MSDS (f). -VOC evaporation is based off standard engineering judgment consistent with product specification. - Standard Industrial Size Cans (oz.) 16			Pounds of emissions per can (lb/can)	0.5	Number of 16 oz cans used	100	0.025
8	(b)(3) Piping Components	-Calculations based on condensate (RVP 10) because it has higher vapor pressure than crude oil (RVP 5) and results in a more conservative emission estimate. -100 foot long pipe sections conservatively assumed for emission calculations.	Temperature (°F)	100	Clingage loss (lb/activity)	5.4321	Number of 100 ft in length of pipes	10	0.027
			Vapor pressure (psia)	10.5					
			Molecular weight (lb/lb-mole)	66					
			V _v Vessel volume (ft ³) (0.5 ft radii * 100 ft height)	78.50					
			Ideal gas constant (psia-ft ³ /lb-mol-°R)	10.73					
			Number of activities per year	1					
9	(b)(3) Pneumatic controllers	Based on field experience and recent site visits to two plants in Central Texas area, changing pneumatic controllers of equipment under pressure requires isolation of pipe section or process equipment and a blow down. There are no emissions associated with changing the controller.							
10	(b)(2) Calibration	-Per Monitoring Division's Laboratory and Quality Assurance Section - One cylinder of pentane or other calibration gas used per year and a typical cylinder contains 100 lbs.	Pounds of pentane in one cylinder (lb)	100	Pounds of pentane in one cylinder (lb/cylinder)	100	Number of cylinders	1	0.050
11	(b)(6)	Safety factor to account for MSS activities with the same character and quantity of emissions as those listed in paragraphs (b) (1) - (5) of §106.359.						1	0.028

	TPY	lbs/hr
Total VOC emissions	0.732	0.167

VOC Type: (pick from list)

Crude Oil or Condensate VOC

Emission Type: (pick from list)

Low Pressure Periodic

Equations used:

1. Loading loss equation: Reference AP-42 Loading equation:

$$L_L = 12.46 \frac{SPM}{T}$$

L_L = Loading loss (lb/1000 gal of liquid loaded)

S = Saturation factor from AP-42, Table 5.2-1

P = True vapor pressure of liquid loaded (psia)

M = Molecular weight of vapors (lb/lb-mol)

T = Temperature of bulk liquid loaded (deg R)

2. Ideal Gas Law: $n = PV/RT$

Total Emissions = $(PV/RT) * M_w * \text{Concentration}$

P = vapor pressure of material stored pressure (psia) at t

V = vessel volume (ft³)

MW = molecular weight (lb/lb-mole)

R = (10.73 psia-ft³/lb-mol-R)

T = 460 + t (deg R)

t = 95° F or actual, whichever is higher

3. Evaporative loss equation: Reference: Ajay Kumar, N.S. Vatcha, and John Schmelzle, "Estimate Emissions from Atmospheric Releases of Hazardous Substances," Environmental Engineering World, November-December 1996.

$$L_{\bar{E}} = 4.14 * 10^{-5} U_{50}^{0.78} P_v M_w^{0.67} A_p^{0.94} t$$

$L_{\bar{E}}$ = Evaporation loss (lb/activity)

U is wind speed in m/s

P_v = VOC vapor pressure, Pa

M_w = VOC vapor molecular weight

A_p = liquid surface area, m²

t = time, hrs

4. Clingage loss equation: AP-42 (2-23) constrained by an upper limit equal to filling loss for IFR with liquid heel.

$$L_{cl, max} = 0.60 (P_v / RT) M_w$$

P = vapor pressure of material stored pressure (psia) at t

V_v = vessel volume (ft³)

M_w = molecular weight (lb/lb-mole)

R = (10.73 psia-ft³/lb-mol-R)

T = 460 + t (deg R)

t = Temperature (R)

References

(a) [Engine Oil SAE 10 W: MSDS](#)

(b) [Caterpillar G3516B LE engine specifications sheet](#)

(c) [AP101 Apeizon grease MSDS](#)

(d) [Mono ethylene glycol \(MEG\) MSDS](#)

(e) [Mono ethanol amine \(MEA\)](#)

(f) [WD-40 Aerosol lubricant MSDS](#)

Section 7

Information Used To Determine Emissions

Information Used to Determine Emissions shall include the following:

- If manufacturer data are used, include specifications for emissions units and control equipment, including control efficiencies specifications and sufficient engineering data for verification of control equipment operation, including design drawings, test reports, and design parameters that affect normal operation.
 - If test data are used, include a copy of the complete test report. If the test data are for an emissions unit other than the one being permitted, the emission units must be identical. Test data may not be used if any difference in operating conditions of the unit being permitted and the unit represented in the test report significantly effect emission rates.
 - If the most current copy of AP-42 is used, reference the section and date located at the bottom of the page. Include a copy of the page containing the emissions factors, and clearly mark the factors used in the calculations.
 - If an older version of AP-42 is used, include a complete copy of the section.
 - If an EPA document or other material is referenced, include a complete copy.
 - Fuel specifications sheet.
 - If computer models are used to estimate emissions, include an input summary (if available) and a detailed report, and a disk containing the input file(s) used to run the model. For tank-flashing emissions, include a discussion of the method used to estimate tank-flashing emissions, relative thresholds (i.e., permit or major source (NSPS, PSD or Title V)), accuracy of the model, the input and output from simulation models and software, all calculations, documentation of any assumptions used, descriptions of sampling methods and conditions, copies of any lab sample analysis.
-

Heaters (Units 5-EP-1c, 5-EP-1d, 6-EP-1c, 6-EP-1d, 7-EP-1c, 7-EP-1d)

- AP-42 Tables 1.4-1 and 1.4-2 from AP-42
- 40 CFR Part 98 methodology
- 40 CFR 98 Tables C-1 and C-2 Emission Factors

Reboilers (Units 4-EP-1d, 4-EP-1e, 4-EP-1h, 5-EP-1a, 5-EP-1b, 6-EP-1a, 6-EP-1b and 5.5-EP-1a)

- AP-42 Tables 1.4-1 and 1.4-2 from AP-42
- Manufacture spec sheet
- 40 CFR Part 98 methodology
- 40 CFR 98 Tables C-1 and C-2 Emission Factors

Amine Vents (Units 4-EP-4, 5-EP-1f, and 6-EP-1f)

- ProMax

Glycol Dehydrators (Units 4-EP-3, 5-EP-1e, and 6-EP-1e)

- ProMax

Thermal Oxidizes (Unit EP-5, EP-6, EP-8 and EP-10)

- AP-42 Tables 1.4-1 and 1.4-2 from AP-42
- Manufacturer's specifications
- 40 CFR Part 98 methodology
- 40 CFR 98 Tables C-1 and C-2 Emission Factors

Flare SSM (Units 5-EP-2 and 7-EP-2), AGI Flare SSM (Unit 5.5-EP-1b) and Sour Water Tanks Flare (EP-13)

- AP-42 Table 13.5-1
- ProMax
- 40 CFR Part 98 methodology

Enclosed Combustion Device (Unit EP-12)

- AP-42 Tables 1.4-1 and 1.4-2 from AP-42
- 40 CFR Part 98 methodology

Condensate Storage Tank (Unit 3-T)

- ProMax

Sour Water Tanks (Unit 4-T)

- Promax

Slop Tanks (Unit 5-T)

- Promax

Loading Emissions (Units 3-Load, 4-Load, and 5-Load)

- ProMax

MSS Blowdowns (Units 2-EP-1t, 3-EP-1t, 4-EP-1t, 5-EP-1t, 6-EP-1t, 7-EP-1t)

- TCEQ spreadsheet

Fugitive Emissions (Unit FUG-1)

- Tables 2-4 and 5-2 of the EPA Protocol for Equipment Leak Emission Estimates, November 1995
- Inlet gas and liquid analyses from ProMax

Haul Road Emissions (Unit HAUL-1)

- Equations 1a and 2 of AP-42 Section 13.2.2 (11/06)
- AP-42 Table 13.2.2-1
- AP-42 Figure 13.2.2-1
- AP-42 Table 13.2.2-2, Industrial Roads
- NMED Guidance Document - Department Accepted Values For: Aggregate Handling, Storage Pile, and Haul Road Emissions
- Google Earth

2019

*Subpart C GHG Emissions
Tier 1*

Facility Wide Subpart C GHG Emissions Calculated Yearly*

Red Hills Gas Processing Plant

Highest Maximum Rated Heat Input Capacity (MMBTUH): 112.00

Weighted Annual Average HHV (BTU/CF): 1,026

Group/Unit ID	Table C-1 Fuel Type	Fuel Use (MCF)	MMBtu/HR	MT CO ₂	MT CH ₄	MT N ₂ O	CH ₄ MT CO ₂ e	N ₂ O MT CO ₂ e	Total CO ₂ e
EP-10	Natural Gas	956,257.3	112.0	52,058.2	0.98	0.098	24.53	29.237	52,112.0
6-EP-1d	Natural Gas	150,723.5	17.5	8,205.3	0.15	0.015	3.87	4.608	8,213.8
5.5-EP-1a	Natural Gas	601,176.5	70.0	32,727.8	0.62	0.062	15.42	18.381	32,761.6
7-EP-1d	Natural Gas	150,723.5	17.5	8,205.3	0.15	0.015	3.87	4.608	8,213.8
7-EP-1c	Natural Gas	62,608.2	7.3	3,408.4	0.06	0.006	1.61	1.914	3,411.9
6-EP-1b	Natural Gas	601,176.5	70.0	32,727.8	0.62	0.062	15.42	18.381	32,761.6
6-EP-1a	Natural Gas	601,176.5	70.0	32,727.8	0.62	0.062	15.42	18.381	32,761.6
6-EP-1c	Natural Gas	62,608.2	7.3	3,408.4	0.06	0.006	1.61	1.914	3,411.9
5-EP-1d	Natural Gas	150,723.5	17.5	8,205.3	0.15	0.015	3.87	4.608	8,213.8
5-EP-1c	Natural Gas	62,608.2	7.3	3,408.4	0.06	0.006	1.61	1.914	3,411.9
5-EP-1b	Natural Gas	601,176.5	70.0	32,727.8	0.62	0.062	15.42	18.381	32,761.6
5-EP-1a	Natural Gas	601,176.5	70.0	32,727.8	0.62	0.062	15.42	18.381	32,761.6
<i>*All Emissions Reported in Metric Tons Per Year</i>		4,602,135.0		250,538.2	4.72	0.472	118.04	140.709	250,797.0

Glycol Dehydrators with throughput greater than or equal to 0.4 MMscfd

Dehydrator's with throughput larger than or equal to 0.4 MMscfd GHG Emissions & Data

Year: 2019

Industry: Onshore Natural Gas Processing

Basin: Permian Basin

County: LEA

State: NM

Formation Type: N/A

Dehydrator's with throughput larger than or equal to 0.4 MMscfd GHG Emissions & Data

Site: Red Hills Gas Processing Plant

Unit ID/#: 5-EP-1e

Feed Natural Gas Flow Rate (MMscfd):	231.2
Feed NG Water Content (lbs/MMSCF):	112.19
Outlet NG Water Content (lbs/MMSCF):	6.1413
Absorbent Circulation Pump Type:	Electric
Dehydrator absorbent Circulation rate (GPM):	55.1804
Type of Absorbent:	Triethylene glycol (TEG)
Use of Stripper Gas (Yes if checked):	<input type="checkbox"/>
Flash Tank Separator (Yes if checked):	<input checked="" type="checkbox"/>
Operating Hours:	8,760.0
Temperature of Wet Natural Gas (°F):	120.0
Pressure of Wet Natural Gas (psig):	851.0
Concentration of CH₄ in Wet Natural Gas:	0.7665
Concentration of CO₂ in Wet Natural Gas:	0.0002
Were any dehydrator emissions vented to a vapor recovery device:	No
Were any dehydrator emissions vented to a flare or regen firebox/tubes:	No
Total CO₂ Emissions from Flaring (mt CO₂):	1,839.3
Total CH₄ Emissions from Flaring (mt CH₄):	0.47
Total N₂O Emissions from Flaring (mt N₂O):	0.003
Were any dehydrator emissions vented to atmosphere:	Yes
Total CO₂ Emissions from Venting (mt CO₂):	0.3
Total CH₄ Emissions from Venting (mt CH₄):	23.3

Dehydrator's with throughput larger than or equal to 0.4 MMscfd GHG Emissions & Data

Unit ID/#: 6-EP-1e

Feed Natural Gas Flow Rate (MMscfd):	231.2	
Feed NG Water Content (lbs/MMSCF):	112.19	
Outlet NG Water Content (lbs/MMSCF):	6.1413	
Absorbent Circulation Pump Type:	Electric	
Dehydrator absorbent Circulation rate (GPM):	55.1804	
Type of Absorbent:	Triethylene glycol (TEG)	
Use of Stripper Gas (Yes if checked):	<input type="checkbox"/>	
Flash Tank Separator (Yes if checked):	<input checked="" type="checkbox"/>	
Operating Hours:	8,760.0	
Temperature of Wet Natural Gas (°F):	120.0	
Pressure of Wet Natural Gas (psig):	851.0	
Concentration of CH₄ in Wet Natural Gas:	0.7665	
Concentration of CO₂ in Wet Natural Gas:	0.0002	
Were any dehydrator emissions vented to a vapor recovery device:		No
Were any dehydrator emissions vented to a flare or regen firebox/tubes:		No
Total CO₂ Emissions from Flaring (mt CO₂):	1,839.3	
Total CH₄ Emissions from Flaring (mt CH₄):	0.47	
Total N₂O Emissions from Flaring (mt N₂O):	0.003	
Were any dehydrator emissions vented to atmosphere:		Yes
Total CO₂ Emissions from Venting (mt CO₂):	0.3	
Total CH₄ Emissions from Venting (mt CH₄):	23.3	

Acid Gas Removal Units: Method 4 Modeling Software

Acid Gas Removal Units Using Modeling Software GHG Emissions & Data

Year: 2019

Industry: Onshore Natural Gas Processing

Basin: Permian Basin

County: LEA

State: NM

Formation Type: N/A

Site: Red Hills Gas Processing Plant

UNIT ID: 5-EP-1f

Total Feed Rate Entering the Unit (MMSCF/YR):	90,262.310
CO₂ transfered out of facility (mt CO₂):	0
Total CO₂ Emissions (mt CO₂):	5276.28591218103
Name of Simulation Software Package Used:	BR&E ProMax
Natural Gas Feed Temperature (°F):	0.0
Natural Gas Feed Pressure (psi):	0.0
Natural Gas Feed Flow Rate (SCF/Min):	0.0
Acid gas content of feed natural gas (mol %):	0.1
Acid gas content of outlet natural gas (mol %):	0.9
Unit operating hours:	8,760.0
Exit Temperature of the Natural Gas (°F):	0.0
Vent Type Information:	Vents To A Flare Or Engine
Solvent Pressure (psi):	0
Solvent Temperature (°F):	0
Solvent Circulation Rate (GPM):	0

Acid Gas Removal Units Using Modeling Software GHG Emissions & Data

UNIT ID: 6-EP-1f

Total Feed Rate Entering the Unit (MMSCF/YR):	90,262.310
CO₂ transfered out of facility (mt CO₂):	0
Total CO₂ Emissions (mt CO₂):	5276.28591218103
Name of Simulation Software Package Used:	BR&E ProMax
Natural Gas Feed Temperature (°F):	0.0
Natural Gas Feed Pressure (psi):	0.0
Natural Gas Feed Flow Rate (SCF/Min):	0.0
Acid gas content of feed natural gas (mol %):	0.1
Acid gas content of outlet natural gas (mol %):	0.9
Unit operating hours:	8,760.0
Exit Temperature of the Natural Gas (°F):	0.0
Vent Type Information:	Vents To A Flare Or Engine
Solvent Pressure (psi):	0
Solvent Temperature (°F):	0
Solvent Circulation Rate (GPM):	0

$$E_{s,CH_4} = V_s * X_{CH_4} * [(1-\eta) * Z_L + Z_U] \quad (\text{Eq. W-19})$$

$$E_{s,CO_2} = V_s * X_{CO_2} + \sum_{j=1}^5 (\eta * V_s * Y_j * R_j * Z_L) \quad (\text{Eq. W-20})$$

Where:

E_{s,CH_4} = Annual CH₄ emissions from flare stack in cubic feet, at standard conditions.

E_{s,CO_2} = Annual CO₂ emissions from flare stack in cubic feet, at standard conditions.

V_s = Volume of gas sent to flare in standard cubic feet, during the year as determined in paragraph (n)(1) of this section.

η = Flare combustion efficiency, expressed as fraction of gas combusted by a burning flare (default is 0.98).

X_{CH_4} = Mole fraction of CH₄ in the feed gas to the flare as determined in paragraph (n)(2) of this section.

X_{CO_2} = Mole fraction of CO₂ in the feed gas to the flare as determined in paragraph (n)(2) of this section.

Z_U = Fraction of the feed gas sent to an un-lit flare determined by engineering estimate and process knowledge based on best available data and operating records.

Z_L = Fraction of the feed gas sent to a burning flare (equal to 1 – Z_U).

Y_j = Mole fraction of hydrocarbon constituents j (such as methane, ethane, propane, butane, and pentanes-plus) in the feed gas to the flare as determined in paragraph (n)(1) of this section.

R_j = Number of carbon atoms in the hydrocarbon constituent j in the feed gas to the flare: 1 for methane, 2 for ethane, 3 for propane, 4 for butane, and 5 for pentanes-plus).

Flare Stack GHG Emissions

Flare Stack GHG Emissions Report

Year: 2019

Industry: Onshore Natural Gas Processing

Basin: Permian Basin

Site: Red Hills Gas Processing Plant

Flare Stack ID: EP-13

Were CEMS used to measure CO₂ emissions for the flare stack:

Does the flare have a continuous flow monitor:

Does the flare have a continuous gas analyzer:

Volume of gas sent to flare (scf/yr): 3,973,972.2

Percent of gas sent to un-lit flare: 0.00

Flare combustion efficiency: 95.00%

Mole Fraction of CH₄ in the feed gas:	0.0402
Mole Fraction of CO₂ in the feed gas:	0.0000
If CEMS were used, CO₂ (mt CO₂):	0.0
CO₂ Emissions (mt CO₂):	932.3
CH₄ Emissions (mt CH₄):	2.92
N₂O Emissions (mt N₂O):	0.002

Flare Stack ID: EP-12

Were CEMS used to measure CO₂ emissions for the flare stack:

Does the flare have a continuous flow monitor:

Does the flare have a continuous gas analyzer:

Volume of gas sent to flare (scf/yr): 1,395,205.0

Percent of gas sent to un-lit flare: 0.00

Flare combustion efficiency: 95.00%

Mole Fraction of CH₄ in the feed gas:	0.0000
Mole Fraction of CO₂ in the feed gas:	0.0000
If CEMS were used, CO₂ (mt CO₂):	0.0
CO₂ Emissions (mt CO₂):	360.3
CH₄ Emissions (mt CH₄):	0.51
N₂O Emissions (mt N₂O):	0.001

Flare Stack GHG Emissions Report

Flare Stack ID: 7-EP-2

Were CEMS used to measure CO₂ emissions for the flare stack:

Does the flare have a continuous flow monitor:

Does the flare have a continuous gas analyzer:

Volume of gas sent to flare (scf/yr): 115,292,998.5

Percent of gas sent to un-lit flare: 0.00

Flare combustion efficiency: 98.00%

Mole Fraction of CH₄ in the feed gas:	0.7685
Mole Fraction of CO₂ in the feed gas:	0.0001
If CEMS were used, CO₂ (mt CO₂):	0.0
CO₂ Emissions (mt CO₂):	7,952.6
CH₄ Emissions (mt CH₄):	34.64
N₂O Emissions (mt N₂O):	0.014

Flare Stack ID: 5-EP-2

Were CEMS used to measure CO₂ emissions for the flare stack:

Does the flare have a continuous flow monitor:

Does the flare have a continuous gas analyzer:

Volume of gas sent to flare (scf/yr): 115,292,998.5

Percent of gas sent to un-lit flare: 0.00

Flare combustion efficiency: 98.00%

Mole Fraction of CH₄ in the feed gas:	0.7685
Mole Fraction of CO₂ in the feed gas:	0.0001
If CEMS were used, CO₂ (mt CO₂):	0.0
CO₂ Emissions (mt CO₂):	7,952.6
CH₄ Emissions (mt CH₄):	34.64
N₂O Emissions (mt N₂O):	0.014

Flare Stack GHG Emissions Report

Flare Stack ID: 5.5-EP-1b

Were CEMS used to measure CO₂ emissions for the flare stack:

Does the flare have a continuous flow monitor:

Does the flare have a continuous gas analyzer:

Volume of gas sent to flare (scf/yr): 17,525,531.8

Percent of gas sent to un-lit flare: 0.00

Flare combustion efficiency: 98.00%

Mole Fraction of CH₄ in the feed gas:	0.0009
Mole Fraction of CO₂ in the feed gas:	0.8019
If CEMS were used, CO₂ (mt CO₂):	0.0
CO₂ Emissions (mt CO₂):	911.7
CH₄ Emissions (mt CH₄):	1.21
N₂O Emissions (mt N₂O):	0.000

$$E_{s,n} = N * \left(V * \left(\frac{(459.67 + T_s) P_s}{(459.67 + T_a) P_a Z_a} \right) - V * C \right) \quad (\text{Eq. W-14A})$$

Where:

$E_{s,n}$ = Annual natural gas emissions at standard conditions from each unique physical volume that is blown down, in cubic feet.

N = Number of occurrences of blowdowns for each unique physical volume in the calendar year.

V = Unique physical volume between isolation valves, in cubic feet, as calculated in paragraph (i)(1) of this section.

C = Purge factor is 1 if the unique physical volume is not purged, or 0 if the unique physical volume is purged using non-GHG gases.

T_s = Temperature at standard conditions (60 °F).

T_a = Temperature at actual conditions in the unique physical volume (°F). For emergency blowdowns at onshore petroleum and natural gas gathering and boosting facilities, engineering estimates based on best available information may be used to determine the temperature.

P_s = Absolute pressure at standard conditions (14.7 psia).

P_a = Absolute pressure at actual conditions in the unique physical volume (psia). For emergency blowdowns at onshore petroleum and natural gas gathering and boosting facilities, engineering estimates based on best available information may be used to determine the pressure.

Z_a = Compressibility factor at actual conditions for natural gas. You may use either a default compressibility factor of 1, or a site-specific compressibility factor based on actual temperature and pressure conditions

Source: 40 CFR 98.233

Blowdown Vent Stacks GHG Emissions

Blowdown Vent Stacks GHG Emissions & Data

Year: 2019

Industry: Onshore Natural Gas Processing

Facility/Pipeline: Red Hills Gas Processing Plant

Blowdown Vent Stack Emissions Type: Calculated by equipment or event type

Equipment Type: All other equipment with a physical volume greater than

Equipment Number: EP-11

Method: W-14A

Was the Volume Purged? : Purged Using non-GHG Gases

For equipment or event type emissions, Total Number of blowdowns: 1

Volume Between Isolation Valves (Cu. Ft.) : 216,608,755

Temperature at Actual Conditions (F) : 119

Pressure at Actual Conditions (psia) : 14

Mol % CH₄ : 0

Mol % CO₂ : 1

Density CO₂ (kg/ft³) : 0.0526

Density CH₄ (kg/ft³) : 0.0192

Purge Factor (C) : 0

Compressibility factor (Za) : 1

Annual CO₂ Emissions (mt CO₂): 9,158.8936109

Annual CH₄ Emissions (mt CH₄): 6.5497862

Blowdown Vent Stacks GHG Emissions & Data

Blowdown Vent Stack Emissions Type: Calculated by equipment or event type

Equipment Type: Compressors

Equipment Number: 7-EP-1t

Method: W-14A

Was the Volume Purged? : Purged Using non-GHG Gases

For equipment or event type emissions, Total Number of blowdowns: 8

Volume Between Isolation Valves (Cu. Ft.) : 1,880

Temperature at Actual Conditions (F) : 100

Pressure at Actual Conditions (psia) : 255

Mol % CH₄ : 1

Mol % CO₂ : 0

Density CO₂ (kg/ft³) : 0.0526

Density CH₄ (kg/ft³) : 0.0192

Purge Factor (C) : 0

Compressibility factor (Za) : 1

Annual CO₂ Emissions (mt CO₂): 0.0012742

Annual CH₄ Emissions (mt CH₄): 4.3744791

Blowdown Vent Stacks GHG Emissions & Data

Blowdown Vent Stack Emissions Type: Calculated by equipment or event type

Equipment Type: Compressors

Equipment Number: 6-EP-1t

Method: W-14A

Was the Volume Purged? : Purged Using non-GHG Gases

For equipment or event type emissions, Total Number of blowdowns: 8

Volume Between Isolation Valves (Cu. Ft.) : 1,880

Temperature at Actual Conditions (F) : 100

Pressure at Actual Conditions (psia) : 255

Mol % CH₄ : 1

Mol % CO₂ : 0

Density CO₂ (kg/ft³) : 0.0526

Density CH₄ (kg/ft³) : 0.0192

Purge Factor (C) : 0

Compressibility factor (Za) : 1

Annual CO₂ Emissions (mt CO₂): 0.0012742

Annual CH₄ Emissions (mt CH₄): 4.3744791

Blowdown Vent Stacks GHG Emissions & Data

Blowdown Vent Stack Emissions Type: Calculated by equipment or event type

Equipment Type: Compressors

Equipment Number: 5-EP-1t

Method: W-14A

Was the Volume Purged? : Purged Using non-GHG Gases

For equipment or event type emissions, Total Number of blowdowns: 8

Volume Between Isolation Valves (Cu. Ft.) : 1,880

Temperature at Actual Conditions (F) : 100

Pressure at Actual Conditions (psia) : 255

Mol % CH₄ : 1

Mol % CO₂ : 0

Density CO₂ (kg/ft³) : 0.0526

Density CH₄ (kg/ft³) : 0.0192

Purge Factor (C) : 0

Compressibility factor (Za) : 1

Annual CO₂ Emissions (mt CO₂): 0.0012742

Annual CH₄ Emissions (mt CH₄): 4.3744791

Blowdown Vent Stacks GHG Emissions & Data

Blowdown Vent Stack Emissions Type: Calculated by equipment or event type

Equipment Type: Compressors

Equipment Number: 4-EP-1t

Method: W-14A

Was the Volume Purged? : Purged Using non-GHG Gases

For equipment or event type emissions, Total Number of blowdowns: 8

Volume Between Isolation Valves (Cu. Ft.) : 1,880

Temperature at Actual Conditions (F) : 100

Pressure at Actual Conditions (psia) : 255

Mol % CH₄ : 1

Mol % CO₂ : 0

Density CO₂ (kg/ft³) : 0.0526

Density CH₄ (kg/ft³) : 0.0192

Purge Factor (C) : 0

Compressibility factor (Za) : 1

Annual CO₂ Emissions (mt CO₂): 0.0012742

Annual CH₄ Emissions (mt CH₄): 4.3744791

Blowdown Vent Stacks GHG Emissions & Data

Blowdown Vent Stack Emissions Type: Calculated by equipment or event type

Equipment Type: Compressors

Equipment Number: 3-EP-1t

Method: W-14A

Was the Volume Purged? : Purged Using non-GHG Gases

For equipment or event type emissions, Total Number of blowdowns: 8

Volume Between Isolation Valves (Cu. Ft.) : 1,880

Temperature at Actual Conditions (F) : 100

Pressure at Actual Conditions (psia) : 255

Mol % CH₄ : 1

Mol % CO₂ : 0

Density CO₂ (kg/ft³) : 0.0526

Density CH₄ (kg/ft³) : 0.0192

Purge Factor (C) : 0

Compressibility factor (Za) : 1

Annual CO₂ Emissions (mt CO₂): 0.0012742

Annual CH₄ Emissions (mt CH₄): 4.3744791

Blowdown Vent Stacks GHG Emissions & Data

Blowdown Vent Stack Emissions Type: Calculated by equipment or event type

Equipment Type: Compressors

Equipment Number: 2-EP-1t

Method: W-14A

Was the Volume Purged? : Purged Using non-GHG Gases

For equipment or event type emissions, Total Number of blowdowns: 8

Volume Between Isolation Valves (Cu. Ft.) : 1,880

Temperature at Actual Conditions (F) : 100

Pressure at Actual Conditions (psia) : 255

Mol % CH₄ : 1

Mol % CO₂ : 0

Density CO₂ (kg/ft³) : 0.0526

Density CH₄ (kg/ft³) : 0.0192

Purge Factor (C) : 0

Compressibility factor (Za) : 1

Annual CO₂ Emissions (mt CO₂): 0.0012742

Annual CH₄ Emissions (mt CH₄): 4.3744791

$$E_{s,p,i} = GHG_i * EF_{s,p} * \sum_{z=1}^{x_p} T_{p,z} \quad (\text{Eq. W-30})$$

Where:

$E_{s,p,i}$ = Annual total volumetric emissions of GHG_i from specific component type “p” (in accordance with paragraphs (q)(1)(i) through (iv) of this section) in standard (“s”) cubic feet, as specified in paragraphs (q)(2)(ii) through (x) of this section.

x_p = Total number of specific component type “p” detected as leaking in any leak survey during the year. A component found leaking in two or more surveys during the year is counted as one leaking component.

$EF_{s,p}$ = Leaker emission factor for specific component types listed in Tables W-1E, W-2, W-3A, W-4A, W-5A, W-6A, and W-7 to this subpart.

GHG_i = For onshore petroleum and natural gas production facilities and onshore petroleum and natural gas gathering and boosting facilities, concentration of GHG_i, CH₄, or CO₂, in produced natural gas as defined in paragraph (u)(2) of this section; for onshore natural gas processing facilities, concentration of GHG_i, CH₄ or CO₂, in the total hydrocarbon of the feed natural gas; for onshore natural gas transmission compression and underground natural gas storage, GHG_i equals 0.975 for CH₄ and 1.1×10^{-2} for CO₂; for LNG storage and LNG import and export equipment, GHG_i equals 1 for CH₄ and 0 for CO₂; and for natural gas distribution, GHG_i equals 1 for CH₄ and 1.1×10^{-2} CO₂.

$T_{p,z}$ = The total time the surveyed component “z,” component type “p,” was assumed to be leaking and operational, in hours. If one leak detection survey is conducted in the calendar year, assume the component was leaking for the entire calendar year. If multiple leak detection surveys are conducted in the calendar year, assume a component found leaking in the first survey was leaking since the beginning of the year until the date of the survey; assume a component found leaking in the last survey of the year was leaking from the preceding survey through the end of the year; assume a component found leaking in a survey between the first and last surveys of the year was leaking since the preceding survey until the date of the survey; and sum times for all leaking periods. For each leaking component, account for time the component was not operational (i.e., not operating under pressure) using an engineering estimate based on best available data.

Equipment Leaks Using Leak Detection Survey Report for Processing Facilities

Equipment Leaks using Leak Detection Surveys for Processing Facility's GHG Emissions Report

Year: 2019

Industry: Onshore Natural Gas Processing

Facility: Red Hills Gas Processing Plant

Number of complete equipment leak surveys performed: 2

Component Type	Total number of leaking components	Average time components assumed to be leaking	CO₂ Emissions (mt CO₂)	CH₄ Emissions (mt CH₄)
Compressor Components, Gas Service - Valve	4,014	5,475.0	1,545.0	7,218.5
Compressor Components, Gas Service - Connector	16,338	5,475.0	2,368.9	11,067.4
Compressor Components, Gas Service - OEL	0	2,190.0	0.0	0.0
Compressor Components, Gas Service - PRV	30	5,475.0	30.9	144.2
Compressor Components, Gas Service - Meter	0	2,190.0	0.0	0.0
Non-Compressor Components, Gas Service - Valve	1,072	5,475.0	178.5	834.0
Non-Compressor Components, Gas Service - Connector	2,290	5,475.0	339.2	1,584.5
Non-Compressor Components, Gas Service - OEL	0	2,190.0	0.0	0.0
Non-Compressor Components, Gas Service - PRV	1	5,475.0	0.1	0.2
Non-Compressor Components, Gas Service - Meter	0	2,190.0	0.0	0.0

Table 13.5-1 (English Units). THC, NO_x AND SOOT EMISSIONS FACTORS FOR FLARE OPERATIONS FOR CERTAIN CHEMICAL MANUFACTURING PROCESSES^a

Pollutant	SCC ^e	Emissions Factor Value	Emissions Factor Units	Grade or Representativeness
THC, elevated flares ^c	30190099; 30119701; 30119705; 30119709; 30119741	0.14 ^{b,f}	lb/10 ⁶ Btu	B
THC, enclosed ground flares ^{g,h} Low Percent Load ⁱ		8.37 ^j or 3.88e-3 ^f	lb/10 ⁶ scf gas burned lb/10 ⁶ Btu heat input	Moderately
THC, enclosed ground flares ^{g,h} Normal to High Percent Load ⁱ		2.56 ^j or 1.20e-3 ^f	lb/10 ⁶ scf gas burned lb/10 ⁶ Btu heat input	Moderately
Nitrogen oxides, elevated flares ^d		0.068 ^{b,k}	lb/10 ⁶ Btu	B
Soot, elevated flares ^d		0 – 274 ^b	µg/L	B

^a All of the emissions factors in this table represent the emissions exiting the flare. Since the flare is not the originating source of the THC emissions, but rather the device controlling these pollutants routed from a process at the facility, the emissions factors are representative of controlled emissions rates for THC. These values are not representative of the uncontrolled THC routed to the flare from the associated process, and as such, they may not be appropriate for estimating the uncontrolled THC emissions or potential to emit from the associated process.

^b Reference 1. Based on tests using crude propylene containing 80% propylene and 20% propane.

^c Measured as methane equivalent. The THC emissions factor may not be appropriate for reporting volatile organic compounds (VOC) emissions when a VOC emissions factor exists.

^d Soot in concentration values: nonsmoking flares, 0 micrograms per liter (µg/L); lightly smoking flares, 40 µg/L; average smoking flares, 177 µg/L; and heavily smoking flares, 274 µg/L.

^e See Table 13.5-4 for a description of these SCCs.

^f Factor developed using the lower (net) heating value of the vent gas.

^g THC measured as propane by US EPA Method 25A.

^h These factors apply to well operated ground flares achieving at least 98% destruction efficiency and operating in compliance with the current General Provisions requirements of 40 CFR Part 60, i.e. >200 btu/scf net heating value in the vent gas and less than the specified maximum exit velocity. The emissions factor data set had an average destruction efficiency of 99.99%. Based on tests using pure propylene fuel. References 12 through 33 and 39 through 45.

ⁱ The dataset for these tests were broken into four different test conditions: ramping back and forth between 0 and 30% of load; ramping back and forth between 30% and 70% of load; ramping back and forth between 70% and 100% of load; and a fixed rate maximum load condition. Analyses determined that only the first condition was statistically different. Low percent load is represented by a unit operating at approximately less than 30% of maximum load.

^j Heat input is an appropriate basis for combustion emissions factor. However, based on available data, heat input data is not always known, but gas flowrate is generally available. Therefore, the emissions factor is presented in two different forms.

^k Factor developed using the higher (gross) heating value of the vent gas.

TABLE 1.4-2. EMISSION FACTORS FOR CRITERIA POLLUTANTS AND GREENHOUSE GASES FROM NATURAL GAS COMBUSTION^a

Pollutant	Emission Factor (lb/10 ⁶ scf)	Emission Factor Rating
CO ₂ ^b	120,000	A
Lead	0.0005	D
N ₂ O (Uncontrolled)	2.2	E
N ₂ O (Controlled-low-NO _x burner)	0.64	E
PM (Total) ^c	7.6	D
PM (Condensable) ^c	5.7	D
PM (Filterable) ^c	1.9	B
SO ₂ ^d	0.6	A
TOC	11	B
Methane	2.3	B
VOC	5.5	C

^a Reference 11. Units are in pounds of pollutant per million standard cubic feet of natural gas fired. Data are for all natural gas combustion sources. To convert from lb/10⁶ scf to kg/10⁶ m³, multiply by 16. To convert from lb/10⁶ scf to lb/MMBtu, divide by 1,020. The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. TOC = Total Organic Compounds.

VOC = Volatile Organic Compounds.

^b Based on approximately 100% conversion of fuel carbon to CO₂. CO₂[lb/10⁶ scf] = (3.67) (CON) (C)(D), where CON = fractional conversion of fuel carbon to CO₂, C = carbon content of fuel by weight (0.76), and D = density of fuel, 4.2x10⁻⁴ lb/10⁶ scf.

^c All PM (total, condensable, and filterable) is assumed to be less than 1.0 micrometer in diameter. Therefore, the PM emission factors presented here may be used to estimate PM₁₀, PM_{2.5} or PM₁ emissions. Total PM is the sum of the filterable PM and condensable PM. Condensable PM is the particulate matter collected using EPA Method 202 (or equivalent). Filterable PM is the particulate matter collected on, or prior to, the filter of an EPA Method 5 (or equivalent) sampling train.

^d Based on 100% conversion of fuel sulfur to SO₂.

Assumes sulfur content is natural gas of 2,000 grains/10⁶ scf. The SO₂ emission factor in this table can be converted to other natural gas sulfur contents by multiplying the SO₂ emission factor by the ratio of the site-specific sulfur content (grains/10⁶ scf) to 2,000 grains/10⁶ scf.

Table 1.4-1. EMISSION FACTORS FOR NITROGEN OXIDES (NO_x) AND CARBON MONOXIDE (CO)
FROM NATURAL GAS COMBUSTION^a

Combustor Type (MMBtu/hr Heat Input) [SCC]	NO _x ^b		CO	
	Emission Factor (lb/10 ⁶ scf)	Emission Factor Rating	Emission Factor (lb/10 ⁶ scf)	Emission Factor Rating
Large Wall-Fired Boilers (>100) [1-01-006-01, 1-02-006-01, 1-03-006-01]				
Uncontrolled (Pre-NSPS) ^c	280	A	84	B
Uncontrolled (Post-NSPS) ^c	190	A	84	B
Controlled - Low NO _x burners	140	A	84	B
Controlled - Flue gas recirculation	100	D	84	B
Small Boilers (<100) [1-01-006-02, 1-02-006-02, 1-03-006-02, 1-03-006-03]				
Uncontrolled	100	B	84	B
Controlled - Low NO _x burners	50	D	84	B
Controlled - Low NO _x burners/Flue gas recirculation	32	C	84	B
Tangential-Fired Boilers (All Sizes) [1-01-006-04]				
Uncontrolled	170	A	24	C
Controlled - Flue gas recirculation	76	D	98	D
Residential Furnaces (<0.3) [No SCC]				
Uncontrolled	94	B	40	B

^a Reference 11. Units are in pounds of pollutant per million standard cubic feet of natural gas fired. To convert from lb/10⁶ scf to kg/10⁶ m³, multiply by 16. Emission factors are based on an average natural gas higher heating value of 1,020 Btu/scf. To convert from lb/10⁶ scf to lb/MMBtu, divide by 1,020. The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. SCC = Source Classification Code. ND = no data. NA = not applicable.

^b Expressed as NO₂. For large and small wall fired boilers with SNCR control, apply a 24 percent reduction to the appropriate NO_x emission factor. For tangential-fired boilers with SNCR control, apply a 13 percent reduction to the appropriate NO_x emission factor.

^c NSPS=New Source Performance Standard as defined in 40 CFR 60 Subparts D and Db. Post-NSPS units are boilers with greater than 250 MMBtu/hr of heat input that commenced construction modification, or reconstruction after August 17, 1971, and units with heat input capacities between 100 and 250 MMBtu/hr that commenced construction modification, or reconstruction after June 19, 1984.

TABLE 1.4-2. EMISSION FACTORS FOR CRITERIA POLLUTANTS AND GREENHOUSE GASES FROM NATURAL GAS COMBUSTION^a

Pollutant	Emission Factor (lb/10 ⁶ scf)	Emission Factor Rating
CO ₂ ^b	120,000	A
Lead	0.0005	D
N ₂ O (Uncontrolled)	2.2	E
N ₂ O (Controlled-low-NO _x burner)	0.64	E
PM (Total) ^c	7.6	D
PM (Condensable) ^c	5.7	D
PM (Filterable) ^c	1.9	B
SO ₂ ^d	0.6	A
TOC	11	B
Methane	2.3	B
VOC	5.5	C

^a Reference 11. Units are in pounds of pollutant per million standard cubic feet of natural gas fired. Data are for all natural gas combustion sources. To convert from lb/10⁶ scf to kg/10⁶ m³, multiply by 16. To convert from lb/10⁶ scf to lb/MMBtu, divide by 1,020. The emission factors in this table may be converted to other natural gas heating values by multiplying the given emission factor by the ratio of the specified heating value to this average heating value. TOC = Total Organic Compounds. VOC = Volatile Organic Compounds.

^b Based on approximately 100% conversion of fuel carbon to CO₂. CO₂[lb/10⁶ scf] = (3.67) (CON) (C)(D), where CON = fractional conversion of fuel carbon to CO₂, C = carbon content of fuel by weight (0.76), and D = density of fuel, 4.2x10⁴ lb/10⁶ scf.

^c All PM (total, condensable, and filterable) is assumed to be less than 1.0 micrometer in diameter. Therefore, the PM emission factors presented here may be used to estimate PM₁₀, PM_{2.5} or PM₁ emissions. Total PM is the sum of the filterable PM and condensable PM. Condensable PM is the particulate matter collected using EPA Method 202 (or equivalent). Filterable PM is the particulate matter collected on, or prior to, the filter of an EPA Method 5 (or equivalent) sampling train.

^d Based on 100% conversion of fuel sulfur to SO₂. Assumes sulfur content is natural gas of 2,000 grains/10⁶ scf. The SO₂ emission factor in this table can be converted to other natural gas sulfur contents by multiplying the SO₂ emission factor by the ratio of the site-specific sulfur content (grains/10⁶ scf) to 2,000 grains/10⁶ scf.

TABLE 1.4-3. EMISSION FACTORS FOR SPECIATED ORGANIC COMPOUNDS FROM
NATURAL GAS COMBUSTION (Continued)

TABLE 1.4-3. EMISSION FACTORS FOR SPECIATED ORGANIC COMPOUNDS FROM
NATURAL GAS COMBUSTION^a

CAS No.	Pollutant	Emission Factor (lb/10 ⁶ scf)	Emission Factor Rating
91-57-6	2-Methylnaphthalene ^{b, c}	2.4E-05	D
56-49-5	3-Methylchloranthrene ^{b, c}	<1.8E-06	E
	7,12-Dimethylbenz(a)anthracene ^{b, c}	<1.6E-05	E
83-32-9	Acenaphthene ^{b, c}	<1.8E-06	E
203-96-8	Acenaphthylene ^{b, c}	<1.8E-06	E
120-12-7	Anthracene ^{b, c}	<2.4E-06	E
56-55-3	Benz(a)anthracene ^{b, c}	<1.8E-06	E
71-43-2	Benzene ^b	2.1E-03	B
50-32-8	Benzo(a)pyrene ^{b, c}	<1.2E-06	E
205-99-2	Benzo(b)fluoranthene ^{b, c}	<1.8E-06	E
191-24-2	Benzo(g,h,i)perylene ^{b, c}	<1.2E-06	E
207-08-9	Benzo(k)fluoranthene ^{b, c}	<1.8E-06	E
106-97-8	Butane	2.1E+00	E
218-01-9	Chrysene ^{b, c}	<1.8E-06	E
53-70-3	Dibenzo(a,h)anthracene ^{b, c}	<1.2E-06	E
25321-22-6	Dichlorobenzene ^b	1.2E-03	E
74-84-0	Ethane	3.1E+00	E
206-44-0	Fluoranthene ^{b, c}	3.0E-06	E
86-73-7	Fluorene ^{b, c}	2.8E-06	E
50-00-0	Formaldehyde ^b	7.5E-02	B
110-54-3	Hexane ^b	1.8E+00	E
193-39-5	Indeno(1,2,3-cd)pyrene ^{b, c}	<1.8E-06	E
91-20-3	Naphthalene ^b	6.1E-04	E
109-66-0	Pentane	2.6E+00	E
85-01-8	Phenanathrene ^{b, c}	1.7E-05	D
74-98-6	Propane	1.6E+00	E

TABLE 1.4-3. EMISSION FACTORS FOR SPECIATED ORGANIC COMPOUNDS FROM
NATURAL GAS COMBUSTION (Continued)

CAS No.	Pollutant	Emission Factor (lb/10 ⁶ scf)	Emission Factor Rating
129-00-0	Pyrene ^{b, c}	5.0E-06	E
108-88-3	Toluene ^b	3.4E-03	C

^a Reference 11. Units are in pounds of pollutant per million standard cubic feet of natural gas fired. Data are for all natural gas combustion sources. To convert from lb/10⁶ scf to kg/10⁶ m³, multiply by 16. To convert from lb/10⁶ scf to lb/MMBtu, divide by 1,020. Emission Factors preceded with a less-than symbol are based on method detection limits.

^b Hazardous Air Pollutant (HAP) as defined by Section 112(b) of the Clean Air Act.

^c HAP because it is Polycyclic Organic Matter (POM). POM is a HAP as defined by Section 112(b) of the Clean Air Act.

^d The sum of individual organic compounds may exceed the VOC and TOC emission factors due to differences in test methods and the availability of test data for each pollutant.

Table 3.2-3. UNCONTROLLED EMISSION FACTORS FOR 4-STROKE RICH-BURN ENGINES^a
(SCC 2-02-002-53)

Pollutant	Emission Factor (lb/MMBtu) ^b (fuel input)	Emission Factor Rating
Criteria Pollutants and Greenhouse Gases		
NO _x ^c 90 - 105% Load	2.21 E+00	A
NO _x ^c <90% Load	2.27 E+00	C
CO ^c 90 - 105% Load	3.72 E+00	A
CO ^c <90% Load	3.51 E+00	C
CO ₂ ^d	1.10 E+02	A
SO ₂ ^e	5.88 E-04	A
TOC ^f	3.58 E-01	C
Methane ^g	2.30 E-01	C
VOC ^h	2.96 E-02	C
PM10 (filterable) ^{i,j}	9.50 E-03	E
PM2.5 (filterable) ^j	9.50 E-03	E
PM Condensable ^k	9.91 E-03	E
Trace Organic Compounds		
1,1,2,2-Tetrachloroethane ^l	2.53 E-05	C
1,1,2-Trichloroethane ^l	<1.53 E-05	E
1,1-Dichloroethane	<1.13 E-05	E
1,2-Dichloroethane	<1.13 E-05	E
1,2-Dichloropropane	<1.30 E-05	E
1,3-Butadiene ^l	6.63 E-04	D
1,3-Dichloropropene ^l	<1.27 E-05	E
Acetaldehyde ^{l,m}	2.79 E-03	C
Acrolein ^{l,m}	2.63 E-03	C
Benzene ^l	1.58 E-03	B
Butyr/isobutyraldehyde	4.86 E-05	D
Carbon Tetrachloride ^l	<1.77 E-05	E

Table 3.2-3. UNCONTROLLED EMISSION FACTORS FOR 4-STROKE RICH-BURN ENGINES
(Concluded)

Pollutant	Emission Factor (lb/MMBtu) ^b (fuel input)	Emission Factor Rating
Chlorobenzene ¹	<1.29 E-05	E
Chloroform ¹	<1.37 E-05	E
Ethane ⁿ	7.04 E-02	C
Ethylbenzene ¹	<2.48 E-05	E
Ethylene Dibromide ¹	<2.13 E-05	E
Formaldehyde ^{1,m}	2.05 E-02	A
Methanol ¹	3.06 E-03	D
Methylene Chloride ¹	4.12 E-05	C
Naphthalene ¹	<9.71 E-05	E
PAH ¹	1.41 E-04	D
Styrene ¹	<1.19 E-05	E
Toluene ¹	5.58 E-04	A
Vinyl Chloride ¹	<7.18 E-06	E
Xylene ¹	1.95 E-04	A

^a Reference 7. Factors represent uncontrolled levels. For NO_x, CO, and PM-10, “uncontrolled” means no combustion or add-on controls; however, the factor may include turbocharged units. For all other pollutants, “uncontrolled” means no oxidation control; the data set may include units with control techniques used for NO_x control, such as PCC and SCR for lean burn engines, and PSC for rich burn engines. Factors are based on large population of engines. Factors are for engines at all loads, except as indicated. SCC = Source Classification Code. TOC = Total Organic Compounds. PM10 = Particulate Matter ≤ 10 microns (μm) aerodynamic diameter. A “<” sign in front of a factor means that the corresponding emission factor is based on one-half of the method detection limit.

^b Emission factors were calculated in units of (lb/MMBtu) based on procedures in EPA Method 19. To convert from (lb/MMBtu) to (lb/10⁶ scf), multiply by the heat content of the fuel. If the heat content is not available, use 1020 Btu/scf. To convert from (lb/MMBtu) to (lb/hp-hr) use the following equation:

$$\text{lb/hp-hr} = (\text{lb/MMBtu}) (\text{heat input, MMBtu/hr}) (1/\text{operating HP, 1/hp})$$

^c Emission tests with unreported load conditions were not included in the data set.

^d Based on 99.5% conversion of the fuel carbon to CO₂. CO₂ [lb/MMBtu] = (3.67)(%CON)(C)(D)(1/h), where %CON = percent conversion of fuel carbon to CO₂,

- C = carbon content of fuel by weight (0.75), D = density of fuel, 4.1 E+04 lb/10⁶ scf, and h = heating value of natural gas (assume 1020 Btu/scf at 60°F).
- ^e Based on 100% conversion of fuel sulfur to SO₂. Assumes sulfur content in natural gas of 2,000 gr/10⁶ scf.
- ^f Emission factor for TOC is based on measured emission levels from 6 source tests.
- ^g Emission factor for methane is determined by subtracting the VOC and ethane emission factors from the TOC emission factor.
- ^h VOC emission factor is based on the sum of the emission factors for all speciated organic compounds. Methane and ethane emissions were not measured for this engine category.
- ⁱ No data were available for uncontrolled engines. PM10 emissions are for engines equipped with a PCC.
- ^j Considered ≤ 1 μm in aerodynamic diameter. Therefore, for filterable PM emissions, PM10(filterable) = PM2.5(filterable).
- ^k No data were available for condensable emissions. The presented emission factor reflects emissions from 4SLB engines.
- ^l Hazardous Air Pollutant as defined by Section 112(b) of the Clean Air Act.
- ^m For rich-burn engines, no interference is suspected in quantifying aldehyde emissions. The presented emission factors are based on FTIR and CARB 430 emissions data measurements.
- ⁿ Ethane emission factor is determined by subtracting the VOC emission factor from the NMHC emission factor.

loading operation, resulting in high levels of vapor generation and loss. If the turbulence is great enough, liquid droplets will be entrained in the vented vapors.

A second method of loading is submerged loading. Two types are the submerged fill pipe method and the bottom loading method. In the submerged fill pipe method, the fill pipe extends almost to the bottom of the cargo tank. In the bottom loading method, a permanent fill pipe is attached to the cargo tank bottom. During most of submerged loading by both methods, the fill pipe opening is below the liquid surface level. Liquid turbulence is controlled significantly during submerged loading, resulting in much lower vapor generation than encountered during splash loading.

The recent loading history of a cargo carrier is just as important a factor in loading losses as the method of loading. If the carrier has carried a nonvolatile liquid such as fuel oil, or has just been cleaned, it will contain vapor-free air. If it has just carried gasoline and has not been vented, the air in the carrier tank will contain volatile organic vapors, which will be expelled during the loading operation along with newly generated vapors.

Cargo carriers are sometimes designated to transport only one product, and in such cases are practicing "dedicated service". Dedicated gasoline cargo tanks return to a loading terminal containing air fully or partially saturated with vapor from the previous load. Cargo tanks may also be "switch loaded" with various products, so that a nonvolatile product being loaded may expel the vapors remaining from a previous load of a volatile product such as gasoline. These circumstances vary with the type of cargo tank and with the ownership of the carrier, the petroleum liquids being transported, geographic location, and season of the year.

One control measure for vapors displaced during liquid loading is called "vapor balance service", in which the cargo tank retrieves the vapors displaced during product unloading at bulk plants or service stations and transports the vapors back to the loading terminal. Figure 5.2-5 shows a tank truck in vapor balance service filling a service station underground tank and taking on displaced gasoline vapors for return to the terminal. A cargo tank returning to a bulk terminal in vapor balance service normally is saturated with organic vapors, and the presence of these vapors at the start of submerged loading of the tanker truck results in greater loading losses than encountered during nonvapor balance, or "normal", service. Vapor balance service is usually not practiced with marine vessels, although some vessels practice emission control by means of vapor transfer within their own cargo tanks during ballasting operations, discussed below.

Emissions from loading petroleum liquid can be estimated (with a probable error of ± 30 percent)⁴ using the following expression:

$$L_L = 12.46 \frac{SPM}{T} \quad (1)$$

where:

L_L = loading loss, pounds per 1000 gallons (lb/10³ gal) of liquid loaded

S = a saturation factor (see Table 5.2-1)

P = true vapor pressure of liquid loaded, pounds per square inch absolute (psia)
(see Section 7.1, "Organic Liquid Storage Tanks")

M = molecular weight of vapors, pounds per pound-mole (lb/lb-mole) (see Section 7.1, "Organic Liquid Storage Tanks")

T = temperature of bulk liquid loaded, °R (°F + 460)

The following empirical expressions may be used to estimate the quantity in pounds (lb) of size-specific particulate emissions from an unpaved road, per vehicle mile traveled (VMT):

For vehicles traveling on unpaved surfaces at industrial sites, emissions are estimated from the following equation:

$$E = k (s/12)^a (W/3)^b \quad (1a)$$

and, for vehicles traveling on publicly accessible roads, dominated by light duty vehicles, emissions may be estimated from the following:

$$E = \frac{k (s/12)^a (S/30)^d}{(M/0.5)^c} - C \quad (1b)$$

where k , a , b , c and d are empirical constants (Reference 6) given below and

- E = size-specific emission factor (lb/VMT)
- s = surface material silt content (%)
- W = mean vehicle weight (tons)
- M = surface material moisture content (%)
- S = mean vehicle speed (mph)
- C = emission factor for 1980's vehicle fleet exhaust, brake wear and tire wear.

The source characteristics s , W and M are referred to as correction parameters for adjusting the emission estimates to local conditions. The metric conversion from lb/VMT to grams (g) per vehicle kilometer traveled (VKT) is as follows:

$$1 \text{ lb/VMT} = 281.9 \text{ g/VKT}$$

The constants for Equations 1a and 1b based on the stated aerodynamic particle sizes are shown in Tables 13.2.2-2 and 13.2.2-4. The PM-2.5 particle size multipliers (k-factors) are taken from Reference 27.

Table 13.2.2-2. CONSTANTS FOR EQUATIONS 1a AND 1b

Constant	Industrial Roads (Equation 1a)			Public Roads (Equation 1b)		
	PM-2.5	PM-10	PM-30*	PM-2.5	PM-10	PM-30*
k (lb/VMT)	0.15	1.5	4.9	0.18	1.8	6.0
a	0.9	0.9	0.7	1	1	1
b	0.45	0.45	0.45	-	-	-
c	-	-	-	0.2	0.2	0.3
d	-	-	-	0.5	0.5	0.3
Quality Rating	B	B	B	B	B	B

*Assumed equivalent to total suspended particulate matter (TSP)

“-“ = not used in the emission factor equation

Table 13.2.2-2 also contains the quality ratings for the various size-specific versions of Equation 1a and 1b. The equation retains the assigned quality rating, if applied within the ranges of source conditions, shown in Table 13.2.2-3, that were tested in developing the equation:

Table 13.2.2-3. RANGE OF SOURCE CONDITIONS USED IN DEVELOPING EQUATION 1a AND 1b

Emission Factor	Surface Silt Content, %	Mean Vehicle Weight		Mean Vehicle Speed		Mean No. of Wheels	Surface Moisture Content, %
		Mg	ton	km/hr	mph		
Industrial Roads (Equation 1a)	1.8-25.2	1.8-260	2-290	8-69	5-43	4-17 ^a	0.03-13
Public Roads (Equation 1b)	1.8-35	1.4-2.7	1.5-3	16-88	10-55	4-4.8	0.03-13

^a See discussion in text.

As noted earlier, the models presented as Equations 1a and 1b were developed from tests of traffic on unpaved surfaces. Unpaved roads have a hard, generally nonporous surface that usually dries quickly after a rainfall or watering, because of traffic-enhanced natural evaporation. (Factors influencing how fast a road dries are discussed in Section 13.2.2.3, below.) The quality ratings given above pertain to the mid-range of the measured source conditions for the equation. A higher mean vehicle weight and a higher than normal traffic rate may be justified when performing a worst-case analysis of emissions from unpaved roads.

The emission factors for the exhaust, brake wear and tire wear of a 1980's vehicle fleet (C) was obtained from EPA's MOBILE6.2 model²³. The emission factor also varies with aerodynamic size range

average uncontrolled conditions (but including natural mitigation) under the simplifying assumption that annual average emissions are inversely proportional to the number of days with measurable (more than 0.254 mm [0.01 inch]) precipitation:

$$E_{\text{ext}} = E [(365 - P)/365] \quad (2)$$

where:

E_{ext} = annual size-specific emission factor extrapolated for natural mitigation, lb/VMT

E = emission factor from Equation 1a or 1b

P = number of days in a year with at least 0.254 mm (0.01 in) of precipitation (see below)

Figure 13.2.2-1 gives the geographical distribution for the mean annual number of “wet” days for the United States.

Equation 2 provides an estimate that accounts for precipitation on an annual average basis for the purpose of inventorying emissions. It should be noted that Equation 2 does not account for differences in the temporal distributions of the rain events, the quantity of rain during any event, or the potential for the rain to evaporate from the road surface. In the event that a finer temporal and spatial resolution is desired for inventories of public unpaved roads, estimates can be based on a more complex set of assumptions. These assumptions include:

1. The moisture content of the road surface material is increased in proportion to the quantity of water added;
2. The moisture content of the road surface material is reduced in proportion to the Class A pan evaporation rate;
3. The moisture content of the road surface material is reduced in proportion to the traffic volume; and
4. The moisture content of the road surface material varies between the extremes observed in the area. The CHIEF Web site (<http://www.epa.gov/ttn/chief/ap42/ch13/related/c13s02-2.html>) has a file which contains a spreadsheet program for calculating emission factors which are temporally and spatially resolved. Information required for use of the spreadsheet program includes monthly Class A pan evaporation values, hourly meteorological data for precipitation, humidity and snow cover, vehicle traffic information, and road surface material information.

It is emphasized that the simple assumption underlying Equation 2 and the more complex set of assumptions underlying the use of the procedure which produces a finer temporal and spatial resolution have not been verified in any rigorous manner. For this reason, the quality ratings for either approach should be downgraded one letter from the rating that would be applied to Equation 1.

13.2.2.3 Controls¹⁸⁻²²

A wide variety of options exist to control emissions from unpaved roads. Options fall into the following three groupings:

1. Vehicle restrictions that limit the speed, weight or number of vehicles on the road;

EMISSIONS FACTORS FOR EQUIPMENT LEAK FUGITIVE COMPONENTS

Technical Disclaimer

This document is intended to help you accurately determine equipment leak fugitive emissions. It does not supersede or replace any state or federal law, rule, or regulation.

This guidance reflects the current understanding of how piping components work and how they generate emissions, how they are monitored or tested, and what data are available for emissions determination, may change over time as we continue our scientific studies and as new information becomes available. We welcome any data, information, or feedback that may improve our understanding of equipment leak fugitive emissions and thereby further improve determinations within the emissions inventory.

The calculation methods represented are intended as an emissions calculation aid; alternate calculation methods may be equally acceptable if they are based upon, and adequately demonstrate, sound engineering assumptions or data. If you have a question regarding the acceptability of a given emissions determination method, contact the Emissions Assessment Section at 512-239-1773.

Introduction

This document provides emission factor guidance for determining equipment leak fugitive emissions from piping components and associated equipment at industrial facilities. It does not address emissions from cooling towers, oil/water separators, material stockpiles, loading operations, or other sources not related to piping components. Use this guidance in conjunction with *2007 Emissions Inventory Guidelines*, Appendix A, Technical Supplement 3: Equipment Leak Fugitives.

Guidance Available in This Document

This document provides appropriate emission factors to be used when determining emissions from piping component fugitives. Specifically, the emission factors included are:

- Correlation equations – synthetic organic chemical manufacturing industry (SOCMI);
- Correlation equations – petroleum industry;
- Average emission factors – SOCMI;
- Average emission factors – oil and gas production;
- Average emission factors – refinery; and
- Average emission factors – petroleum marketing terminal.

Table 4. Average Emission Factors - Petroleum Industry.

Equipment/Service	Petroleum Marketing Terminal ¹	Oil and Gas Production Operations ²				Refinery ³
		Gas	Heavy Oil <20° API	Light Oil >20° API	Water/Light Oil	
Valves		0.00992	0.0000185	0.0055	0.000216	
Gas/Vapor	0.0000287	0.00992				0.059
Light Liquid	0.0000948					0.024
Heavy Liquid	0.0000948					0.000510
Pumps		0.00529	0.0011300	0.02866	0.00005290	
Light Liquid	0.00119					0.251
Heavy Liquid	0.00119					0.046
Flanges/Connectors		0.000860	0.00000086	0.000243	0.00000617	0.000550
Gas/Vapor	0.000092604	0.000860				
Light Liquid	0.00001762					
Heavy Liquid	0.00001720					
Compressors		0.0194	0.0000683	0.0165	0.0309	1.399
Relief Valve Gas/Vapor		0.0194	0.0000683	0.0165	0.0309	0.35
Open-ended Lines ⁴		0.00441	0.0003090	0.00309	0.0006	0.0051
Sampling Connections ⁵						0.033
Connectors		0.000440	0.0000165	0.0004630	0.000243	
Other ⁶		0.0194	0.0000683	0.0165	0.0309	
Gas/Vapor	0.000265					
Light/heavy Liquid	0.000287					
Process Drains		0.0194	0.0000683	0.0165	0.0309	0.07

All factors are in units of (lb/hr)/component.

- Notes:
1. Factors taken from EPA document EPA-453/R-95-017; November, 1995; pp. 2-14.
 2. Factors taken from EPA document EPA-453/R-95-017; November, 1995; pp. 2-15.
 3. Factors taken from EPA document EPA-453/R-95-017; November, 1995; pp. 2-13.
 4. The 28 Series quarterly LDAR programs require open-ended lines to be equipped with a cap, blind flange, plug, or a second valve. If so equipped, open-ended lines may be given a 100% control credit.
 5. Factor for Sampling Connections is in terms of pounds per hour per sample taken.
 6. For Petroleum Marketing Terminals, "Other" includes any component except fittings, pumps, and valves. For Oil & Gas Production Operations, "Other" includes diaphragms, dump arms, hatches, instruments, meters, polished rods, and vents.

SHAMROCK GAS ANALYSIS, INC.



LABORATORY REFERENCE NUMBER : E46489 - FT7374

LUCID ENERGY

ID: RED HILLS PLANT ACID GAS
AREA: NOT/REC
METER: SOUR WATER TANKS
LEASE: SOUR WATER TANKS
OPERATOR: LUCID
STATION: RED HILLS PLANT ACID GAS
SAMPLE DATE: 5/30/2018
SAMPLE OF: GAS

LINE PRESSURE: 10 PSI
LINE TEMPERATURE: 99 F
CYLINDER NUMBER: 6341
EFFECTIVE DATE: 6/1/2018
SAMPLED BY: M. BRENNAN
ANALYZED BY: BRENNAN
ANALYZED DATE: 6/1/2018
SAMPLE TYPE: SPOT

For: LUCID ENERGY
Attn: T. KIRK
288 KINCAID ROAD
ARTESIA, NEW MEXICO 88210

Physical Properties per GPA 2145-09

Calculations per GPA 2172-09

Note: Zero = Less than detection limit

	<u>MOL%</u>	<u>GPM @ 14.73</u>
HYDROGEN SULFIDE	0.083	0.012
NITROGEN	4.397	0.501
CARBON DIOXIDE	0.023	0.004
METHANE	4.015	0.705
ETHANE	0.570	0.158
PROPANE	11.837	3.376
ISOBUTANE	12.712	4.306
N-BUTANE	30.465	9.943
ISOPENTANE	16.224	6.142
N-PENTANE	11.506	4.318
HEXANES PLUS	8.168	3.690
	<u>100.000</u>	<u>33.155</u>

BTU	Vol. Ideal Gas Fuel	Vol. Real Gas Fuel
BTU @ 14.73 PSIA (DRY)	3293.1	3410.0
BTU @ 14.73 PSIA (SAT.)	3235.8	3352.1
Specific Gravity	2.0723	2.1449
Compressibility (Z)	0.9657	

Gasoline Content (Gallons Per Thousand - GPM)

Ethane & Heavier	31.933
Propane & Heavier	31.775
Butane & Heavier	28.399
Pentane & Heavier	14.150
Total 26 psi Reid V.P. Gasoline GPM	19.438

Remarks: Field H2S ppm = 830 (TUTWILER) HEAD SPACE FROM SOUR WATER TANKS
Remarks: NO PREVIOUS BTU AVAILABLE



SUSANA MARTINEZ
GOVERNOR

JOHN A. SANCHEZ
LIEUTENANT GOVERNOR

New Mexico ENVIRONMENT DEPARTMENT

505 Camino de los Marquez, Suite 1
Santa Fe, NM 87505
Phone (505) 476-4300
Fax (505) 476-4375
www.env.nm.gov



BUTCH TONGATE
CABINET SECRETARY-
DESIGATE

JC BORREGO
DEPUTY SECRETARY

DEPARTMENT ACCEPTED VALUES FOR: AGGREGATE HANDLING, STORAGE PILE, and HAUL ROAD EMISSIONS

TO: Applicants and Air Quality Bureau Permitting Staff

SUBJECT: Department accepted default values for percent silt, wind speed, moisture content, and control efficiencies for haul road control measures

This guidance document provides the Department accepted default values for correction parameters in the emission calculation equations for aggregate handling and storage piles emissions in construction permit applications and notices of intent submitted under 20.2.72 and 20.2.73 NMAC; and the Department accepted control efficiencies for haul road control measures for applications submitted under 20.2.72 NMAC.

Aggregate Handling and Storage Pile Emission Calculations

Applicants should calculate the particulate matter emissions from aggregate handling and storage piles using the EPA's AP-42 Chapter 13.2.4.

<http://www3.epa.gov/ttn/chief/ap42/ch13/final/c13s0204.pdf>

Equation 1 from Chapter 13.2.4 requires users to input values for two correction parameters, U and M, where U = mean wind speed and M = material moisture content. Below are the accepted values for U and M:

Default Values for Chapter 13.2.4, Equation 1:

Parameter	Default Value
U = Mean wind speed (miles per hour)	11 mph
M = Material moisture content (% water)	2%

Applicants must receive preapproval from the Department if they wish to assume a higher moisture content and/or a lower wind speed in these calculations. Higher moisture contents may require site specific testing either as a permit condition or submitted with the application. Applicants may assume higher wind speeds and lower percent moisture content in their calculations without prior approval from the Department.

Haul Road Emissions and Control Measure Efficiencies

Applicants should calculate the particulate matter emissions from unpaved haul roads using the EPA's AP-42 Chapter 13.2.2. <http://www3.epa.gov/ttn/chief/ap42/ch13/final/c13s0202.pdf>

Equation 1(a) from Chapter 13.2.2 requires users to input values for two correction parameters, s and W, where s = surface material silt content (%) and W = mean vehicle weight (tons). The applicant should calculate the mean vehicle weight in accordance with the chapter's instructions. Below is the accepted value for the parameter s:

Default Values for Chapter 13.2.2, Equation 1(a):

Parameter	Default Value
s = surface material silt content (%)	4.8%

Applicants may use a higher silt content without prior approval from the Department. Use of a lower silt content requires prior approval from the Department and may require site specific testing in support of the request.

Equation 2 from Chapter 13.2.2 allows users to take credit for the number of days that receive precipitation in excess of 0.01 inches, in the annual emissions calculation, where P = number of days in a year with at least 0.01 inches of precipitation.

Default Values for Chapter 13.2.2, Equation 2:

Parameter	Default Value
P = number of days in a year with at least 0.01 inches of precipitation	70 days

Applications submitted under Part 72 may request to apply control measures to reduce the particulate matter emissions from facility haul roads. Applications submitted under Part 73 may not consider any emission reduction from control measures in the potential emission rate calculation, as registrations issued under Part 73 are not federally enforceable under the Clean Air Act or the New Mexico Air Quality Control Act. In order for those control measures to be federally enforceable, the controls must be a requirement in an air quality permit.

Below are the Department accepted control efficiencies for various haul road control measures:

Haul Road Control Measures and Control Efficiency:

Control Measure	Control Efficiency
None	0%
Base course or watering	60%
Base course and watering	80%
Base course and surfactant	90%
Paved and Swept	95%



Bryan Research & Engineering, LLC

ProMax[®] 5.0

Copyright © 2002-2019 BRE Group, Ltd. All Rights Reserved.

Simulation Report

Project: Lucid RH 5 1800GPM 245MM Rev 2 (06.17.19).pmx

Licensed to Lucid Energy Group II, LLC and Affiliates

Client Name:

Location:

Job:

ProMax Filename: C:\Users\CKassen\Documents\Projects\Red Hills\Red Hills 5-6\Lucid RH 5 1800GPM 245MM Rev 2 (06.17.19).pmx
ProMax Version: 5.0.19050.0

Simulation Initiated: 6/17/2019 6:27:10 AM

Bryan Research & Engineering, LLC

Chemical Engineering Consultants
P.O. Box 4747 Bryan, Texas 77805
Office: (979) 776-5220
FAX: (979) 776-4818
<mailto:sales@bre.com>
<http://www.bre.com/>

Report Navigator can be activated via the ProMax Navigator Toolbar.

An asterisk (*), throughout the report, denotes a user specified value.

A question mark (?) after a value, throughout the report, denotes an extrapolated or approximate value.

Latent Heat Estimates For Stream "7"
 (Energy / Mass Vaporized)

Latent Heat (Method 1) = 553 Btu/lb
 Latent Heat (Method 2) = 609.1 Btu/lb
 Latent Heat (Method 3) = 578.3 Btu/lb
 Latent Heat (Method 4) = 721.6 Btu/lb
 Initial Temperature = 303.9 °F, Mole Frac. Vapor = 0 %
 Final Temperature = 462.6 °F, Mole Frac. Vapor = 100 %
 At Pressure = 50 psig

Latent Heat Estimates For Stream "CoolRich"
 (Energy / Mass Vaporized)

Latent Heat (Method 1) = 430.6 Btu/lb
 Latent Heat (Method 2) = 530.7 Btu/lb
 Latent Heat (Method 3) = 599.3 Btu/lb
 Latent Heat (Method 4) = 757.3 Btu/lb
 Initial Temperature = 242.6 °F, Mole Frac. Vapor = 0 %
 Final Temperature = 485.7 °F, Mole Frac. Vapor = 100 %
 At Pressure = 165 psig

Properties		16
Temperature(Total)		96.789 °F
Pressure(Total)		888 psig
Std Vapor Volumetric Flow (Total)		231.17 MMSCFD
Composition		16
CO2(Partial Molar Volumetric Fraction, Total)		66.828 ppm
H2S(Partial Molar Volumetric Fraction, Total)		0.00032662 ppm


Properties		17
Temperature(Total)		70 °F
Pressure(Total)		900 psig
Std Vapor Volumetric Flow (Total)		245 MMSCFD
Composition		17
CO2(Mole Fraction, Total)		5.6436 %
H2S(Mole Fraction, Total)		1.9907 ppm

Names	Units	Cooler Duty
Energy Rate	MMBtu/h	74.299

Names	Units	Condsr Duty	Reb Duty
Energy Rate	MMBtu/h	34.921	120*

Properties		LeanToBooster
Std Liquid Volumetric Flow (Total)		1800* sghpm
Analysis		LeanToBooster
Total Acid Gas Loading/Mole Amine(Amine Analysis 1, Total)		0.005184

Properties		RichAmine
Temperature(Total)		169.84 °F
Analysis		RichAmine
Total Acid Gas Loading/Mole Amine(Amine Analysis 1, Total)		0.38669



QStream Report


Client Name:		Job:	
Location:			
Flowsheet:	AMINE		

Energy Streams

Energy Stream	Status	Energy Rate	Power	From Block	To Block
Condsr Duty	Solved	3.49209E+07 Btu/h	13724.4 hp	Reflux Condenser	--
Cooler Duty	Solved	7.42994E+07 Btu/h	29200.8 hp	AmineCooler	--
Q-1	Solved	3.29697E+07 Btu/h	12957.6 hp	FAXR-100	--
Q-2	Solved	-10073.0 Btu/h	-3.95885 hp	XCHG-100	--
Q-3	Solved	3.74325E+06 Btu/h	1471.15 hp	--	MSP
Q-4	Solved	205271 Btu/h	80.6747 hp	--	Booster
Q-5	Solved	5534.40 Btu/h	2.17510 hp	--	Reflux Pumps
Q-6	Solved	-1.38335E+07 Btu/h	-5436.79 hp	XCHG-101	--
Q-7	Solved	-367098 Btu/h	-144.275 hp	XCHG-102	--
Q-8	Solved	-118609 Btu/h	-46.6151 hp	XCHG-103	--
Reb Duty	Solved	1.20000E+08* Btu/h	47161.8* hp	--	K-100

Notes:

Basic Glycol Dehydration Unit



PSV 0701 Scenario 19

QStream Report

Client Name:		Job:	
Location:			
Flowsheet:	TEG		

Energy Streams

Energy Stream	Status	Energy Rate	Power	From Block	To Block
Booster Hp	Solved	4302.28 Btu/h	1.69086 hp	--	Booster Pump
Cooler Duty	Solved	2.00183E+06 Btu/h	786.749 hp	Glycol Cooler	--
Q-1	Solved	1.08555E+06 Btu/h	426.637 hp	BTEX Condenser	--
Q-2	Solved	8.53698E+06 Btu/h	3355.16 hp	--	XCHG-101
Q-101	Solved	163838 Btu/h	64.3906 hp	Q-Recycle	Reflux Coil
Reb Duty	Solved	3.08570E+06 Btu/h	1212.73 hp	--	Reboiler
Reflux Duty	Solved	163815 Btu/h	64.3818 hp	Condenser	Q-Recycle
Strip Duty	Solved	0 Btu/h	0 hp	--	XCHG-100
TEG Hp	Solved	117440 Btu/h	46.1556 hp	--	Glycol Pump

Notes:

Warnings Report
Project (Lucid RH 5 1800GPM 245MM Rev 2 (06.17.19).pmx)

ProMax:ProMax!Project!Flowsheets!AMINE!Blocks!XCHG-100!Properties!Pressure Drop

Warning: A negative pressure drop of -95 psi was encountered in block XCHG-100.

ProMax:ProMax!Project!Flowsheets!AMINE!Blocks!XCHG-101!Properties!Pressure Drop

Warning: A negative pressure drop of -95 psi was encountered in block XCHG-101.

ProMax:ProMax!Project!Environments!Dehy

Warning: Calculated stream Heating Values are approximate due to the presence of component(s) with unknown chemical formula: CHEMTHERM 550. These components are: CHEMTHERM 550.
Warning: It is recommended to use a Heat Transfer Fluid property package in a dedicated flowsheet for the following components: CHEMTHERM 550.

ProMax:ProMax!Project!Flowsheets!HT Fluid!Blocks!Pipe Loss!Properties!Pressure Drop

Warning: A negative pressure drop of -5 psi was encountered in block Pipe Loss.

ProMax:ProMax!Project!Flowsheets!AMINE!Blocks!From Amine

Warning: The following components were zeroed out in stream From Amine Plant on flowsheet TEG because they were less than the mole fraction transfer threshold in stream From Amine Plant: H2S, MDEA, Piperazine.

Warning: Cross Flowsheet Connector From Amine is not in mass balance. Check Untransferred Flows in the Composition table on the Streams tab.

ProMax:ProMax!Project!Flowsheets!TEG!Blocks!From Amine

Warning: The following components were zeroed out in stream From Amine Plant on flowsheet TEG because they were less than the mole fraction transfer threshold in stream From Amine Plant: H2S, MDEA, Piperazine.

Warning: Cross Flowsheet Connector From Amine is not in mass balance. Check Untransferred Flows in the Composition table on the Streams tab.

ProMax:ProMax!Project!Flowsheets!AMINE!Blocks!VSSL-100!Sizing Properties

Warning: The specified value of 5 min for Light Liquid Holdup Time cannot be met due to separation or minimum size requirements. Actual value is 626.201 min.

Warning: The specified value of 2.5 min for Light Liquid Surge Time cannot be met due to separation or minimum size requirements. Actual value is 313.1 min.

ProMax:ProMax!Project!Flowsheets!TEG!Blocks!TEG Makeup!Properties!Pressure Drop

Warning: A negative pressure drop of -0.5 psi was encountered in block TEG Makeup

1					
2	Owner:	Lucid	Owner Ref.:	H-101	
3	Purchaser:	Lucid	Purchaser Ref.:	TBD	
4	Manufacturer:	Tulsa Heaters Midstream, LLC	THM Ref.:	P19-0502 /	
5	Service:	Hot Oil Heater	Project:	Acid Gas Expansion	
6	Quantity:	1	Location:	TBD	
7	SHO Duty:	70.00 MMBTU/ hr	SHO Model:	SHO5000	
8	CMS Release:	89.24 MMBTU/ hr	CMS Model:	CMS8500	
9	SHOS Flow:	2,910 USgpm @ 178 ft TDH	SHOS.Model:	N/A	
10					

PROCESS DESIGN CONDITIONS

			Radiant / Convection	Radiant / Convection	Radiant / Convection	Radiant / Convection
14	Heater Section	---				
15	Operating Case	---	Design Case			
16	Service	---	Hot Oil Heater			
17	Heat Absorption (R/C)	MMBTU/ hr	41.64 / 28.36			
18	Process Fluid	---	Chemtherm 550			
19	Process Mass Flow Rate, Total	Lb/ hr	1,200,000			
20	Process Bulk Velocity (calc. R/C)	ft/ s	11 / 11			
21	Process Mass Velocity (calc. R/C)	Lb/ s ft2	554 / 554			
22	Coking Allowance (dP calcs)	in				
23	Pressure Drop, Clean (allow. / calc.)	psi	30 / 31			
24	Pressure Drop, Fouled (allow. / calc.)	psi				
25	Average Heat Flux (allowable)	BTU/ hr ft2	13,000			
26	Average Heat Flux (calculated)	BTU/ hr ft2	14,200			
27	Maximum Heat Flux (allowable)	BTU/ hr ft2				
28	Maximum Heat Flux (calc. R/C)	BTU/ hr ft2	25,900 / 35,120			
29	Fouling Factor, Internal	hr ft2 °F/ BTU	0.002			
30	Corrosion or Erosion Characteristics	---				
31	Max. Film Temperature (allow. / calc.)	°F	640 / 492			
32						
33	Inlet Conditions:					
34	Temperature	°F	280			
35	Pressure	psig	75			
36	Mass Flow Rate, Liquid	Lb/ hr	1,200,000			
37	Mass Flow Rate, Vapor	Lb/ hr	0			
38	Weight Percent, Liquid / Vapor	wt%	100% / 0%			
39	Density, Liquid / Vapor	Lb/ ft3	51.43 / 0.00			
40	Molecular Weight, Liquid / Vapor	Lb/ Lbmole	--- / 0.0			
41	Viscosity, Liquid / Vapor	cp	2.3127 / 0.000			
42	Specific Heat, Liquid / Vapor	BTU/ Lb °F	0.5602 / 0.000			
43	Thermal Conductivity, Liq./Vap.	BTU/hr ft °F	0.0705 / 0.000			
44						
45	Outlet Conditions:					
46	Temperature	°F	380			
47	Pressure	psig	44			
48	Mass Flow Rate, Liquid	Lb/ hr	1,200,000			
49	Mass Flow Rate, Vapor	Lb/ hr	0			
50	Weight Percent, Liquid / Vapor	wt%	100% / 0%			
51	Density, Liquid / Vapor	Lb/ ft3	49.25 / 0.00			
52	Molecular Weight, Liquid / Vapor	Lb/ Lbmole	--- / 0.0			
53	Viscosity, Liquid / Vapor	cp	1.129 / 0.000			
54	Specific Heat, Liquid / Vapor	BTU/ Lb °F	0.609 / 0.000			
55	Thermal Conductivity, Liq./Vap.	BTU/hr ft °F	0.068 / 0.000			
56						

57					
58					
59					
60					
61					
62					
63	A		Issued with Proposal		
64	revision	date	description	by	chk'd appv'd

USA Applications  **SHO = Superior Quality, Flexibility, Dependability & Modularity**

FIRED HEATER DATA SHEET
AMERICAN ENGINEERING SYSTEM of UNITS
P19-0502-HTRds- Pg 1 of 6

This document contains confidential information proprietary to THM. This document shall not be used, reproduced or disclosed without the prior written consent of THM.

COMBUSTION DESIGN CONDITIONS

1									
2									
3	Overall Performance:								
4	Operating Case	---	Design Case						
5	Service	---	Hot Oil Heater						
6	Excess Air	mol%	25.0%						
7	Calculated Heat Release (LHV)	MMBTU/ hr	81.13						
8	Guaranteed Efficiency	HR%	84.3%						
9	Calculated Efficiency	HR%	86.3%						
10	Radiation Loss	HR%	2.00%						
11	Flow Rate, Combustion Gen./ Imp.	Lb/ hr	85,719						
12	Flue Gas Temp. Leaving (R/C)	°F	1,596 / 479						
13	Flue Gas Mass Velocity	Lb/ sec ft2	0.919						

14									
15	Fuel(s) Data:	Gas 1	Gas 2	Gas 3	Design	Burner Design:			
16		Mol.Wt.	Mol.Wt.	Mol.Wt.	Fuel Oil	OEM	---	Callidus Technologies, LLC	
17	LHV	BTU/ scf	898		---	Type	---	Enhanced IFGR	
18	LHV	BTU/ Lb	20,247			Quantities	---	1	ULTRA Low NOx
19	P @ Burner	psig	150			Model No.	---	CUBL-16W-HC-HZ	Cylindrical
20	T @ Burner	°F	100			Windbox	---	yes ...	
21	MW	Lb/ Lbmole	16.82		---	Location	---	EndWall Center ...	Horizontally Fired
22	Flow @ design	lb/hr	4,007			Pilot Design:			
23	Flow @ design	scfh	90,394			Type / Model	---	Self-Inspiring	/ by O.E.M.
24	Atomizing Media		---			Ignition	---	Electric	requires elec.ign.system
25	Atom. Media P & T		---			Heat Release	---	> 350000	BTU/ hr on ... Gas 1

26									
27	Components:					Burner Performance:			
28	N	wt%	---			Minimum Heat Release	MMBTU/ hr	17.85	
29	S	wt%	---			Design Heat Release	MMBTU/ hr	81.13	
30	Ash	wt%	---			Maximum Heat Release	MMBTU/ hr	89.24	
31	Ni	ppm	---			Burner Turndown	Max:Min	5.00	
32	Va	ppm	---			Volumetric Ht. Release	BTU/ hr ft3	10,118	
33	Na	ppm	---			Pressure @ Arch	inH2O	3.40	
34	Fe	ppm	---			Pressure @ Burner	inH2O	17.00	
35						Combustion Air T @ Burner	°F	60	
36	H2	mol%	0.0%		---	Flue Gas T @ Burner	°F	1,400	
37	O2	mol%	0.0%		---				
38	N2 + Ar	mol%	3.3%		---	Guaranteed Emissions:			
39	CO	mol%	0.0%		---	Basis of Guarantee	---	3.0% O2, dry (LHV)	
40	CO2	mol%	0.0%		---	NOx Emissions	Lb/MMBTU	0.040	30 ppm
41	CH4	mol%	94.1%		---	SOx Emissions	Lb/MMBTU	no quote	
42	C2H6	mol%	2.5%		---	CO Emissions	Lb/MMBTU	0.041	50 ppm
43	C2H4	mol%	0.0%		---	VOC Emissions	Lb/MMBTU	0.019	14 ppm
44	C3H8	mol%	0.1%		---	UHC Emissions	Lb/MMBTU	0.007	14 ppm
45	C3H6	mol%	0.0%		---	SPM10 Emissions	Lb/MMBTU	0.013	14 ppm
46	C4H10	mol%	0.0%		---	Noise Emissions	dBA @ 3ft	85	
47	C4H8	mol%	0.0%		---				
48	C5H12	mol%	0.0%		---	Net Flame Clearances:			
49	C5H10	mol%	0.0%		---	Est. Flame Size	approx. 37.5 ft L x 6.5 ft Diameter		
50	C6+	mol%	0.0%		---	Hor Clearance	0 ft NET Tube Clearance		
51	H2S	ppmv	0.0%		---	Vert. Clearance	0 ft NET Tube Clearance		
52	SO2	mol%	0.0%		---	Axial Clearance	3.5 ft NET Refractory Clearance (to Target hot face)		
53	NH3	mol%	0.0%		---				
54	H2O	mol%	0.0%		---	Nominal Flame Clearances:			
55	spare	mol%	0.0%		---	from burner CL ...	Vertical	Horizontal	
56						to Tube CL, API	ft	35.72	23.81
57						to Tube CL, calc.	ft	6.50	6.50
58						to Refrac., calc.	ft	n / a	41.00

59	Blower/Fan Performance:								
60	Volumetric Flow	acfm	20,400						
61	Rated Power	HP	100						
62	Fan Speed	RPM	1,800						
63	Sound Pressure	dBA	< 85						
64	Area Classification	NEC	Class I, Div. II, Groups C&D						

PRESSURE PARTS DESIGN

1				
2				
3	Coil Design:		RADIANT	SHIELD
4	Service		Hot Oil Heater	Hot Oil Heater
5	Design Basis for Tube Temperature		API 530	API 530
6	Design Basis for Tube Wall Thickness		ASME Sec. VIII-1	ASME Sec. VIII-1
7	Design Life	hr	100,000	100,000
8	Design Pressure (elastic / rupture)	psig	150 /	150 /
9	Design Fluid Temperature	°F	380	380
10	Design Temperature Allowance	°F	25	25
11	Design Corrosion Allowance (tubes/fittings)	in	0.063 / 0.063	0.063 / 0.063
12				
13	Maximum Tube Temperature (clean)	°F	517	
14	Maximum Tube Temperature (fouled)	°F	574	492
15	Design Tube Temperature	°F	599	646
16	Inside Film Coefficient	BTU/ hr ft ² °F	253	201
17	Weld Inspection	RT or Other	100 of 10%	100 of 10%
18	Weld Heat Treatment	s.rel., t.stab. or none	None	None
19	Hydrostatic Test Pressure	psig	per API	per API
20				
21	Coil Arrangement:		Horizontal	Horizontal
22	Coil Type	---	Helical	Serpentine
23	Tube Material (pipe or tube spec)	ASTM	SA106GrB	SA106GrB
24	Supplementary Mfg Requirements	ASTM	None	None
25	Tube Outside Diameter	in	6.625	6.625
26	Tube Wall Thickness (aw / mw)	in	0.280 / 0.245	0.280 / 0.245
27	Number of Cells (radiant or convection)	---	1	1
28	Number of Flow Passes (total / cell)	---	3 / 3	3 / 3
29	Number of Tubes per Row (total / cell)	---	4 / 4	4 / 4
30	Overall Tube (1 turn in radiant) Length	ft	40.84	16.04
31	Effective Tube Length / Helix Diameter	ft	40.84 / 13.00	14.46
32	Number of Turns or Tubes (total / pass)		41.4 / 13.8	8.0 / 8.0
33	Total Exposed Surface	ft ²	2,932	201
34	Number of Ext.Surf. Tubes (total / cell)	---	0 / 0.0	0 / 0.0
35	Total Exposed Surface	ft ²	0	9,686
36	Tube Spacing (horiz. / tube centers)	in	9.00 / 11.50	12.00 / 12.00
37	Tube Spacing (horiz. to refractory)	in	9.00	6.00
38	Coil Fluid Volume	USgal	2632	113
39				
40	Coil Fittings:		Hot Oil Heater	Hot Oil Heater
41	Fitting Type	---	SR 90° Elbows	SR 180° U-Bends
42	Fitting Material	ASTM	SA234 WPB	SA234 WPB
43	Supplementary Mfg Requirements	ASTM	None	None
44	Fitting Outside Diameter	in	6.625	6.625
45	Fitting Wall Thickness (aw / mw)	in	0.280 / 0.245	0.280 / 0.245
46	Fitting Location	internal or external	Internal	External
47	Tube Attachment	welded or rolled	Welded	Welded
48				
49	Coil Terminals:		Outlet	Inlet
50	Terminal Type	beveled or flanged	Flanged	Flanged
51	Flange Material	ASTM	SA105	SA105
52	Supplementary Mfg Requirements	ASTM	None	None
53	Flange Size and Rating	NPS/ ASME	6" NPS / 300#	6" NPS / 300#
54	Flange Type	RFWN or RTJ	RFWN	RFWN
55	Location	---	Burner Endwall	Terminal End
56				
57	Extended Surface:		CONVECTION	CONVECTION
58	Service	---	Hot Oil Heater	Hot Oil Heater
59	Fin or Stud Row Number	starting @ bottom	No.1 / No.2-3	No.4 / No.5
60	Ext. Surface Type	seg.fins, solid fins, studs	HF Seg. Fins	HF Seg. Fins
61	Fin/Stud Material	---	C.S. / C.S.	C.S. / C.S.
62	Fin/Stud Height	in	0.50 / 0.50	0.75 / 0.75
63	Fin/Stud Thickness	in	0.11 / 0.11	0.11 / 0.105
64	Fin/Stud Density	fin/ in	3.00 / 5.00	4.00 / 5.00
65				

PRESSURE PARTS DESIGN (continued)

1				
2				
3	Crossovers:		<u>RADIANT</u>	<u>SHIELD</u>
4	Type, location / connections	---	<u>External</u>	<u>/ Flanged</u>
5	Tube / Fittings Material	ASTM	<u>SA106GrB</u>	<u>/ SA234 WPB</u>
6	Tube & Fitting OD / Thickness (aw)	in	<u>6.625</u>	<u>/ 0.280</u>
7				
8	Inlet Manifold(s):	type		<u>Simple LOG</u>
9	Location	---		<u>Top - Term. End</u>
10	Design Basis for Manifold Thickness:	---		<u>ASME B31.3</u>
11	Design Conditions (temp./press.)	°F/ psig		<u>646 / 150</u>
12	Pipe Material	ASTM		<u>SA106GrB</u>
13	Fittings Material	ASTM		<u>SA234 WPB</u>
14	Flange Material / Style	ASTM		<u>SA105 / RFWN</u>
15	Outside Diameters, each Branch	in		<u>16" NPS</u>
16	Wall Thickness(es); aw or mw	in		<u>SCH40 (0.5)</u>
17	End Types (terminal/ dead)	beveled or flanged		<u>Flanged / W.Cap</u>
18	Manifold Terminal Type	NPS/ ASME		<u>16" NPS / 300# Flg</u>
19	Coil Connection Type	extrusion, olet, etc.		<u>Weld-O-Let</u>
20	Coil Terminal Type	NPS/ ASME		<u>6" NPS / 300# Flg</u>
21				
22	Outlet Manifold(s):	type	<u>Simple LOG</u>	
23	Location	---	<u>Burner Endwal</u>	
24	Design Basis for Manifold Thickness:	---	<u>ASME B31.3</u>	
25	Design Conditions (temp./press.)	°F/ psig	<u>599 / 150</u>	
26	Pipe Material	ASTM	<u>SA106GrB</u>	
27	Fittings Material	ASTM	<u>SA234 WPB</u>	
28	Flange Material / Style	ASTM	<u>SA105 / RFWN</u>	
29	Outside Diameters, each Branch	in	<u>16" NPS</u>	
30	Wall Thickness(es); aw or mw	in	<u>SCH40 (0.5)</u>	
31	End Types (terminal/ dead)	beveled or flanged	<u>Flanged / W.Cap</u>	
32	Manifold Terminal Type	NPS/ ASME	<u>16" NPS / 300# Flg</u>	
33	Coil Connection Type	extrusion, olet, etc.	<u>Weld-O-Let</u>	
34	Coil Terminal Type	NPS/ ASME	<u>6" NPS / 300# Flg</u>	
35				

COIL & MANIFOLD SUPPORTS DESIGN

36				
37				
38				
39	Tube Supports:		<u>RADIANT</u>	<u>SHIELD</u>
40	Service		<u>Hot Oil Heater</u>	<u>Hot Oil Heater</u>
41	Location	Top, Bottom, Ends	<u>Bottom</u>	<u>Ends</u>
42	Support Type	casting, tubesht, spring, etc.	<u>SS Pipe Rail</u>	<u>Welded Tbsheets</u>
43	Support Thicknesses	in	<u>SCH40</u>	<u>0.375</u>
44	Support Materials	ASTM	<u>A240 T304</u>	<u>A36 CS</u>
45	Support Temperatures (calc./ design)	°F / °F	<u>1,006 / 1,190</u>	<u>639 / 790</u>
46	TbSht Ferrules Thickness/Materials	in/ ASTM	<u>---</u>	<u>14 ga. / 304 SS</u>
47	Refractory & Anchor Materials & Types		<u>none</u>	<u>per refrac. section</u>
48				
49	Intermediate Guides & Supports:		<u>None</u>	<u>None</u>
50	Location	---		<u>None</u>
51	Guide/ Support Type	casting, spring, etc.		
52	Material	ASTM		
53	Spacing, average	ft		
54				
55	Tube Guides:	Top, Bottom, Ends	<u>None</u>	<u>None</u>
56	Material	ASTM		
57				
58	Manifold Supports:		<u>Outlet Manifold</u>	<u>Intlet Manifold</u>
59	Material	ASTM	<u>A36</u>	<u>N/A</u>
60	Materials Design & Supply	---	<u>by THM</u>	
61	Location	Top, Bottom, Ends	<u>Burner Endwal</u>	
62	Support Type	roller, shoe, spring, etc.	<u>Simple Shelf</u>	
63	Number of Supports	---	<u>One (1)</u>	
64				

CASING / REFRACTORY SYSTEMS DESIGN

1				
2				
3		BURNER	SHIELDED	TARGET
4	Radiant Section Design:	ENDWALL	SIDEWALLS	ENDWALL
5	Total Refractory Thickness	in 6.0	4.0	6.0
6	Hot Face Temperature (design)	°F 2,000	2,000	2,000
7	Hot Face Temperature (calculated)	°F 1,596	1,006	1,596
8	Hot Face Layer	in/ --- 1/ 8# CF Blanket	1/ 8# CF Blanket	1/ 8# CF Blanket
9	Back-Up Layer No.1	in/ --- 1/ 8# CF Blanket	3/ 6# CF Blanket	1/ 8# CF Blanket
10	Back-Up Layer No.2	in/ --- 4/ 6# CF Blanket	None	4/ 6# CF Blanket
11	Foil Vapor Barrier	in/ --- None	None	None
12	Castable Reinforcement (SS Needles)	wt% None	None	None
13	Anchors / Tie Backs:	--- Pins & Clips	Pins & Clips	Pins & Clips
14	Material	--- 310 S.S.	304 S.S.	310 S.S.
15	Attachment	--- Welded	Welded	Welded
16	Casing:			
17	Material	in/ ASTM 0.1875 / A36	0.1875 / A36	0.1875 / A36
18	Internal Coating	--- None	None	None
19	External Temperature, Typical	°F 180	180	180
20	Comments / Clarifications	--- w/ cfb wraps	w/o cfb wraps	w/ cfb wraps
21		SHOP Installed	SHOP Installed	SHOP Installed
22				
23				
24	Convection Section Design	SHIELD	FINNED	TUBESHEETS
25	Total Refractory Thickness	in 3.0	3.0	3.0
26	Hot Face Temperature (design)	°F 2,000	2,000	2,200
27	Hot Face Temperature (calculated)	°F 1,038	1,038	1,038
28	Hot Face Layer	in/ --- 1/ 8# CF Blanket	1/ 8# CF Blanket	3/ Sparlite HS
29	Back-Up Layer No.1	in/ --- 2/ 6# CF Blanket	2/ 6# CF Blanket	None
30	Back-Up Layer No.2	in/ --- None	None	None
31	Foil Vapor Barrier	in/ --- None	None	None
32	Castable Reinforcement (SS Needles)	wt% None	None	None
33	Anchors / Tie Backs:	--- Pins & Clips	Pins & Clips	Bullhorns
34	Material	--- 310 S.S.	304 S.S.	304 S.S.
35	Attachment	--- Welded	Welded	Welded
36	Casing:			
37	Material	in/ ASTM 0.1875 / A36	0.1875 / A36	0.1345 / A36
38	Internal Coating	--- None	None	None
39	External Temperature, Typical	°F 180	180	180
40	Comments / Clarifications	--- Cleaning/Sootblowing lanes: none		Bolted Assembly
41		SHOP Installed	SHOP Installed	SHOP Installed
42				
43				
44	Stack & Uptakes Design:	BREECHING	15° TRANSITION	DISCH. DUCT
45	Quantity	One	One	One
46	Type / Location	--- Full L / Conv	Full L / Conv	Self.Spt/ Grade
47	Length / Metal Outside Diameter (top)	ft/ ft 1.00 / n/a	2.02 / n/a	7 / 4.000
48	Discharge Elev., minimum/ calculated	ft/ ft n/a / n/a	n/a / n/a	20 / 36
49	Total Refractory Thickness	in 3.0	0.0	0.0
50	Hot Face Temperature (design)	°F 2,000		
51	Hot Face Temperature (calculated)	°F 479	479	479
52	Hot Face Layer	in/ --- 1/ 8# CF Blanket	None	None
53	Back-Up Layer No.1	in/ --- 2/ 6# CF Blanket		
54	Castable Reinforcement (SS Needles)	None		
55	Anchors / Tie Backs:	--- Pins & Clips		
56	Material	--- 304 S.S.		
57	Attachment	--- Welded		
58	Casing:			
59	Minimum Thickness/ Material	in/ ASTM 0.1875 / A36	0.1875 / A36	0.1875 / A36
60	Corrosion Allowance	in None	None	None
61	Internal Coating	--- None	None	None
62	External Temperature, Typical	°F 180	479	479
63	Comments / Clarifications	--- SHOP Installed		
64				

MECHANICAL / STRUCTURAL DESIGN BASIS

1					
2					
3	Refractory & Coatings Design:				
4	Refractory Design	Per Std560: 180°F Avg. Casing Temperature @ Ambient Conditions of 0 MPH & 80°F			
5	Refractory Dryout	SHOP dryout = None // FIELD dryout per THM standard.			
6	Coating, Internal	None			
7	Coating, External	Base Coat:	3-4 PPG Dimetcote 9 IOZ Silicate - Flat Green on SP-6		
8		Int. Coat:	None		
9		Top Coat:	1.5-2 PPG Pitt-Therm 97-724 Series Air Dry Silicone - Federal Standard 595B #16132 Gray		
10					
11					
12					
13	Applicable Standards:				
14	API	Std 560 (ISO 13705); Fired Heaters for ...	AISC	Specification for Design, ... Steel for Building:	
15	API	Std 530 (ISO 13704); Calc. of Heater Tube ...	AWS	D 1.1; Structural Welding Code	
16	ASME	B31.3, Chemical Plant and ... Piping	ASTM	tube/ smls pipe/ fitting spec's noted hereir	
17	ASME	Sections I, II, VIII, IX; ASME B&PV Code	ASTM	refractories per C27, C155, C401 & C612	
18	ASME	Section V; Non Destructive Examiner	NFPA	NFPA 70; National Electrical Code	
19					
20	Wind Design:		Seismic Design:		
21	Spec. or Standard	ASCE 7-10	Spec. or Standard	ASCE 7-10	
22	Velocity/ Imp. Factor	100 mph / 1	Risck Cat./Imp. Factor	III / 1.25	
23	Site Exposure	"C"	Ss/S1/Soil Class	0.5 / 0.15 / D	
24	Physical Design:		Site Design Basis:		
25	Plot Limitations	None	Site Elevation	3600 ft AMSL	
26	Tube Limitations	None	Stack Design Temp.	90 °F	
27	Firebox Pressure	Positive; approximately +1.0 inH2O	FG Discharge Elev.	36 ft AG	
28	Ambient Temp's	-20 °F Min/ 60 °F Dsn/ 110 °F Ma>	Area Classification	Class I, Div. II, Groups C&D	
29					

MAJOR SUBSYSTEMS & ACCESSORIES

30					
31					
32					
33	Major Services & Subsystems		Major Accessories:		
34	Process Design	INCLUDED in base pricing	Casing/ Tube Seals	12	TubeSox; Radiant & Conv.
35	Mechanical Design	INCLUDED in base pricing	Observation Doors	2	4 in Dia. w/ H.T. glass
36	Structural Design	INCLUDED in base pricing	Observation Doors	1	4 in Dia. w/ HT glass on Arch
37	Radiant Section	INCLUDED in base pricing	Access Doors	1	Std 24" x 24"
38	Convection Section	INCLUDED in base pricing	Expansion Joints	None	
39	Combustion Mgmt	INCLUDED in base pricing	Ladders & Platforms	Not Included	
40	Burner Piping	INCLUDED in base pricing	L&P Coating	N/A	
41	Forced Draft System	INCLUDED in base pricing			
42					
43	Casing Penetrations		Pressure Part Penetrations		
44	Fbox Purge/ Snuff	None	Coil TSTC's, Radiant	None	
45	CA Temp/Pres	None	Coil TSTC's, Convection	None	
46	FG Temperature	2 1.5"NPS 3000# Coupling	Process TI conn's	3	1.5" NPS 300# RFWN
47	FG Pressure	2 1.5"NPS 3000# Coupling	Process PI conn's	1	1.5" NPS 300# RFWN
48	FG Comp. (Sample)	2 1.5"NPS 3000# Coupling	spare		
49	FG Sample	2 4"NPS 150# RFWN's	spare		
50	O2 Analyzer Port	1 3" NPS 150# RFWN	spare		
51					
52	Dampers				
53		FD Fan (blower) qty = 0	Uptake Ducts	Stack	qty = 0
54	Function	Note:		Note:	
55	Design	Fan inlet damper is inappropriate		Stack Damper (which provides draft	
56	Materials	for forced draft SHO's where O2		control) is inappropriate for forced	
57	Bearings	Control is provided by the CMS O2		draft SHO's where the combustion	
58	Operator	Trim Module which controls the fan		conditions are controlled real-time	
59	Positioner	(blower) motor's VFD/ VSD.		via the CMS.	
60	Instruments				
61	Sootblowers:	Qty. Type Location	FG T Material	Steam T & P	O.E.M. / Ref.
62	Lane 1:	None			
63	Lane 2 :	None			
64					

Fnt
&
Rev

2	Owner: Unknown	Owner Ref.: H-741
3	Purchaser: UOPR	Purchaser Ref.: J463
4	Manufacturer: Tulsa Heaters Midstream, LLC	THM Ref.: MJ17-265
5	Service: Regen Gas Heater	Project: 200 MMscfd Cryo Plant
6	Quantity: 1	Location: Unknown
7	SHO Duty: 7.29 MMBTU/ hr	SHO Model: SHO500
8	CMS Release: 9.20 MMBTU/ hr	CMS Model: CMS1500

PROCESS DESIGN CONDITIONS

		--- Radiant / Convection	Radiant / Convection	
		Over-Design Case	Design Case	
		Regen Gas Heater	Regen Gas Heater	
14	Heater Section	---		
15	Operating Case	---		
16	Service	---		
17	Heat Absorption (R/C)	MMBTU/ hr	4.36 / 2.93	3.52 / 2.08
18	Process Fluid	---	Gas	Gas
19	Process Mass Flow Rate, Total	Lb/ hr	22,924	20,840
20	Process Bulk Velocity (calc. R/C)	ft/ s	42 / 21	39 / 19
21	Process Mass Velocity (calc. R/C)	Lb/ s ft2	80 / 80	73 / 73
22	Coking Allowance (dP calcs)	in		
23	Pressure Drop, Clean (allow. / calc.)	psi	10 / 7	10 / 6
24	Pressure Drop, Fouled (allow. / calc.)	psi		
25	Average Heat Flux (allowable)	BTU/ hr ft2	13,000	13,000
26	Average Heat Flux (calculated)	BTU/ hr ft2	15,410	12,460
27	Maximum Heat Flux (allowable)	BTU/ hr ft2		
28	Maximum Heat Flux (calc. R/C)	BTU/ hr ft2	27,400 / 31,140	22,200 / 23,990
29	Fouling Factor, Internal	hr ft2 °F/ BTU	0.001	0.001
30	Corrosion or Erosion Characteristics	---		
31	Max. Film Temperature (allow. / calc.)	°F	650 / 669	650 / 654
32				
33	Inlet Conditions:			
34	Temperature	°F	75	135
35	Pressure	psig	934	934
36	Mass Flow Rate, Liquid	Lb/ hr	0	0
37	Mass Flow Rate, Vapor	Lb/ hr	22,924	20,840
38	Weight Percent, Liquid / Vapor	wt%	0% / 100%	0% / 100%
39	Density, Liquid / Vapor	Lb/ ft3	0.00 / 3.82	0.00 / 3.82
40	Molecular Weight, Liquid / Vapor	Lb/ Lbmole	--- / 21.6	--- / 21.6
41	Viscosity, Liquid / Vapor	cp	0.0001 / 0.014	0.001 / 0.014
42	Specific Heat, Liquid / Vapor	BTU/ Lb °F	0 / 0.617	0.000 / 0.617
43	Thermal Conductivity, Liq./Vap.	BTU/hr ft °F	0 / 0.023	0.000 / 0.023
44				
45	Outlet Conditions:			
46	Temperature	°F	550	550
47	Pressure	psig	928	929
48	Mass Flow Rate, Liquid	Lb/ hr	0	0
49	Mass Flow Rate, Vapor	Lb/ hr	22,924	20,840
50	Weight Percent, Liquid / Vapor	wt%	0% / 100%	0% / 100%
51	Density, Liquid / Vapor	Lb/ ft3	0.00 / 1.88	0.00 / 1.88
52	Molecular Weight, Liquid / Vapor	Lb/ Lbmole	--- / 21.6	--- / 21.6
53	Viscosity, Liquid / Vapor	cp	0.000 / 0.020	0.0001 / 0.020
54	Specific Heat, Liquid / Vapor	BTU/ Lb °F	0.000 / 0.719	0 / 0.719
55	Thermal Conductivity, Liq./Vap.	BTU/hr ft °F	0.000 / 0.042	0 / 0.042

57					
58					
59					
60					
61					
62	Rev. 1	13-Nov-17	Revised Purchaser Ref. No. per Customer Comments	JDC	JF
63	Rev. 0	19-Aug-17	Issued for Approval	JF	JDC
64	revision	date	description	by	chk'd appv'd

USA Applications



SHO = Superior Quality, Flexibility, Dependability & Modularity

FIRED HEATER DATA SHEET
AMERICAN ENGINEERING SYSTEM of UNITS

MJ17-265-HTRds- Rev. 1 Pg 1 of 6

This document contains confidential information proprietary to THM. This document shall not be used, reproduced or disclosed without the prior written consent of THM.

COMBUSTION DESIGN CONDITIONS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64

Overall Performance:		Over-Design Case	Design Case
Operating Case	---	Regen Gas Heater	Regen Gas Heater
Service	---	Regen Gas Heater	Regen Gas Heater
Excess Air	mol%	15.0%	15.0%
Calculated Heat Release (LHV)	MMBTU/ hr	8.37	6.30
Guaranteed Efficiency	HR%	83.1%	85.0%
Calculated Efficiency	HR%	87.1%	89.0%
Radiation Loss	HR%	3.00%	3.00%
Flow Rate, Combustion Gen./ Imp.	Lb/ hr	8,145	6,130
Flue Gas Temp. Leaving (R/C)	°F	1,649 / 447	1,526 / 377
Flue Gas Mass Velocity	Lb/ sec ft2	0.260	0.196

Fuel(s) Data:		Gas 1	Burner Design:
		Mol.Wt.	OEM --- Callidus Technologies, LLC
LHV	BTU/ scf	976	Type --- Enhanced IFGR ULTRA Low NOx
LHV	BTU/ Lb	20,426	Quantities --- 1 Burner
P @ Burner	psig	75	Model No. --- CUBL-3W Cylindrical
T @ Burner	°F	100	Windbox --- yes ...
MW	Lb/ Lbmole	18.13	Location --- EndWall Center ... Horizontally Fired
m @ ??? °F	cp	---	Pilot Design:
m @ ??? °F	cp	---	Type / Model Self-Inspiring / by O.E.M.
Atomizing Media	---	---	Ignition --- Electric requires elec.ign.system
Atom. Media P & T	---	---	Heat Release -- > 90000 BTU/ hr on ... Gas 1

Components:		Burner Performance:	
N	wt%	---	Minimum Heat Release MMBTU/ hr 1.84
S	wt%	---	Design Heat Release MMBTU/ hr 8.37
Ash	wt%	---	Maximum Heat Release MMBTU/ hr 9.20
Ni	ppm	---	Burner Turndown Max/Min 5.00
Va	ppm	---	Volumetric Ht. Release BTU/ hr ft3 17,106
Na	ppm	---	Pressure @ Arch inH2O 0.50
Fe	ppm	---	Pressure @ Burner inH2O 7.64
			Combustion Air T @ Burner °F 60
H2	mol%	0.0%	Flue Gas T @ Burner °F 1,450
O2	mol%	0.0%	
N2 + Ar	mol%	1.0%	

		Guaranteed Emissions:	
CO	mol%	0.0%	Basis of Guarantee --- 3.0% O2, dry (LHV)
CO2	mol%	1.0%	NOx Emissions Lb/MMBTU 0.053 40 ppm
CH4	mol%	88.0%	SOx Emissions Lb/MMBTU no quote
C2H6	mol%	8.0%	CO Emissions Lb/MMBTU 0.041 50 ppm
C2H4	mol%	0.0%	VOC Emissions Lb/MMBTU 0.019 15 ppm
C3H8	mol%	2.0%	UHC Emissions Lb/MMBTU 0.007 15 ppm
C3H6	mol%	0.0%	SPM10 Emissions Lb/MMBTU 0.014 16 ppm
C4H10	mol%	0.0%	Noise Emissions dBA @ 3ft 85
C4H8	mol%	0.0%	
C5H12	mol%	0.0%	

		Net Flame Clearances:	
		Est. Flame Size	approx. 10.9 ft L x 2.5 ft Diameter
		Hor Clearance	0.75 ft NET Tube Clearance
		Vert. Clearance	0.75 ft NET Tube Clearance
		Axial Clearance	-1.77 ft NET Refractory Clearance (to Arch hot face)

		Nominal Flame Clearances:		
		from burner CL ...	Vertical	Horizontal
		to Tube CL, API	ft 5.70	3.80
		to Tube CL, calc.	ft 3.25	3.25
		to Refrac., calc.	ft n/a	9.17

Blower/Fan Performance:	
Volumetric Flow	acfm 1,800
Rated Power	HP 10
Fan Speed	RPM 3,600
Sound Pressure	dBA < 85
Area Classification	NEC Unclassified

PRESSURE PARTS DESIGN

1					
2					
3	Coil Design:		RADIANT	SHIELD	CONVECTION
4	Service		Regen Gas Heater	Regen Gas Heater	Regen Gas Heater
5	Design Basis for Tube Temperature		API 530	API 530	API 530
6	Design Basis for Tube Wall Thickness		ASME Sec. VIII-1	ASME Sec. VIII-1	ASME Sec. VIII-1
7	Design Life	hr	100,000	100,000	100,000
8	Design Pressure (elastic / rupture)	psig	1,095 /	1,095 /	1,095 /
9	Design Fluid Temperature	°F	550	550	550
10	Design Temperature Allowance	°F	29	29	29
11	Design Corrosion Allowance (tubes/fittings)	in	0.0625 / 0.0625	0.0625 / 0.0625	0.0625 / 0.0625
12					
13	Maximum Tube Temperature (clean)	°F	702		
14	Maximum Tube Temperature (fouled)	°F	734	372	475
15	Design Tube Temperature	°F	763	650	650
16	Inside Film Coefficient	BTU/ hr ft ² °F	271	233	233
17	Weld Inspection	RT or Other	100 of 100%	100 of 100%	100 of 100%
18	Weld Heat Treatment	s.rel., t.stab. or none	None	None	None
19	Hydrostatic Test Pressure	psig	per API	per API	per API
20					
21	Coil Arrangement:		Horizontal	Horizontal	Horizontal
22	Coil Type	---	Helical	Serpentine	Serpentine
23	Tube Material (pipe or tube spec)	ASTM	SA106GrB	SA106GrB	SA106GrB
24	Supplementary Mfg Requirements	ASTM	None	None	None
25	Tube Outside Diameter	in	4.500	4.500	4.500
26	Tube Wall Thickness (aw / mw)	in	0.337 / 0.295	0.337 / 0.295	0.337 / 0.295
27	Number of Cells (radiant or convection)	---	1	1	1
28	Number of Flow Passes (total / cell)	---	1 / 1	1 / 1	1 / 1
29	Number of Tubes per Row (total / cell)	---	4 / 4	4 / 4	4 / 4
30	Overall Tube (1 turn in radiant) Length	ft	20.42	9.04	9.04
31	Effective Tube Length / Helix Diameter	ft	20.42 / 6.50	7.46	7.46
32	Number of Turns or Tubes (total / pass)		11.8 / 11.8	4.0 / 4.0	0.0 / 0.0
33	Total Exposed Surface	ft ²	283	35	0
34	Number of Ext.Surf. Tubes (total / cell)	---	0 / 0.0	0 / 0.0	12 / 12.0
35	Total Exposed Surface	ft ²	0	0	1,309
36	Tube Spacing (horiz. / tube centers)	in	--- / 8.00	8.00 / 8.00	8.00 / 8.00
37	Tube Spacing (horiz. to refractory)	in	6.00	4.00	4.00
38					
39	Coil Fittings:		Regen Gas Heater	Regen Gas Heater	Regen Gas Heater
40	Fitting Type	---	SR 90° Elbows	SR 180° U-Bends	SR 180° U-Bends
41	Fitting Material	ASTM	SA234 WPB	SA234 WPB	SA234 WPB
42	Supplementary Mfg Requirements	ASTM	None	None	None
43	Fitting Outside Diameter	in	4.500	4.500	4.500
44	Fitting Wall Thickness (aw / mw)	in	0.337 / 0.295	0.337 / 0.295	0.337 / 0.295
45	Fitting Location	internal or external	Internal	External	External
46	Tube Attachment	welded or rolled	Welded	Welded	Welded
47					
48	Coil Terminals:		Outlet		Inlet
49	Terminal Type	beveled or flanged	Flanged		Flanged
50	Flange Material	ASTM	SA105		SA105
51	Supplementary Mfg Requirements	ASTM	None		None
52	Flange Size and Rating	NPS / ASME	4" NPS / 900#		4" NPS / 900#
53	Flange Type	RFWN or RTJ	RFWN		RFWN
54	Location	---	Burner Endwall		Terminal End
55					
56	Extended Surface:			CONVECTION	CONVECTION
57	Service	---		Regen Gas Heater	Regen Gas Heater
58	Fin or Stud Row Number	starting @ bottom		No.1 / No.2-3	
59	Ext. Surface Type	seg.fins, solid fins, studs		HF Seg. Fins	
60	Fin/Stud Material	---		C.S. / C.S.	
61	Fin/Stud Height	in		1.00 / 1.00	
62	Fin/Stud Thickness	in		0.06 / 0.06	
63	Fin/Stud Density	fin/ in		4.00 / 5.00	
64					

1
2 PRESSURE PARTS DESIGN (continued)

3	Crossovers:		RADIANT	SHIELD	CONVECTION
4	Type, location / connections	---	External	/ Flanged	None
5	Tube / Fittings Material	ASTM	SA106GrB	/ SA234 WPB	
6	Tube & Fitting OD / Thickness (aw)	in	4.500	/ 0.337	
7					
8	Inlet Manifold(s):	type			N/A
9	Location	---			
10	Design Basis for Manifold Thickness	---			
11	Design Conditions (temp./press.)	°F/ psig			
12	Pipe Material	ASTM			
13	Fittings Material	ASTM			
14	Flange Material / Style	ASTM			
15	Outside Diameters, each Branch	in			
16	Wall Thickness(es); aw or mw	in			
17	End Types (terminal/ dead)	beveled or flanged			
18	Manifold Terminal Type	NPS/ ASME			
19	Coil Connection Type	extrusion, olet, etc.			
20	Coil Terminal Type	NPS/ ASME			
21					
22	Outlet Manifold(s):	type	N/A		
23	Location	---			
24	Design Basis for Manifold Thickness	---			
25	Design Conditions (temp./press.)	°F/ psig			
26	Pipe Material	ASTM			
27	Fittings Material	ASTM			
28	Flange Material / Style	ASTM			
29	Outside Diameters, each Branch	in			
30	Wall Thickness(es); aw or mw	in			
31	End Types (terminal/ dead)	beveled or flanged			
32	Manifold Terminal Type	NPS/ ASME			
33	Coil Connection Type	extrusion, olet, etc.			
34	Coil Terminal Type	NPS/ ASME			
35					

36
37 COIL & MANIFOLD SUPPORTS DESIGN

39	Tube Supports:		RADIANT	SHIELD	CONVECTION
40	Service		Regen Gas Heater	Regen Gas Heater	Regen Gas Heater
41	Location	Top, Bottom, Ends	Bottom	Ends	Ends
42	Support Type	casting, tubesht, spring, etc.	SS Pipe Rail	Welded Tbsheets	Welded Tbsheets
43	Support Thicknesses	in	SCH40	0.375	0.375
44	Support Materials	ASTM	A240 T304	A36 CS	A36 CS
45	Support Temperatures (calc./ design)	°F / °F	1,130 / 1,310	612 / 770	612 / 770
46	TbSht Ferrules Thickness/Materials	in/ ASTM	---	14 ga. / 304 SS	14 ga. / 304 SS
47	Refractory & Anchor Materials & Types		none	per refrac. section	per refrac. section
48					
49	Intermediate Guides & Supports:		None	None	None
50	Location	---			
51	Guide/ Support Type	casting, spring, etc.			
52	Material	ASTM			
53	Spacing, average	ft			
54					
55	Tube Guides:	Top, Bottom, Ends	None	None	None
56	Material	ASTM			
57					
58	Manifold Supports:		Outlet Manifold		Intlet Manifold
59	Material	ASTM	A36		N/A
60	Materials Design & Supply	---	by THM		
61	Location	Top, Bottom, Ends			
62	Support Type	roller, shoe, spring, etc.	Simple Shelf		
63	Number of Supports	---	One (1)		
64					

CASING / REFRACTORY SYSTEMS DESIGN

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64

Radiant Section Design:		BURNER ENDWALL	SHIELDED SIDEWALLS	ARCH ENDWALL
Total Refractory Thickness	in	5.0	3.0	5.0
Hot Face Temperature (design)	°F	2,000	2,000	2,000
Hot Face Temperature (calculated)	°F	1,649	1,130	1,649
Hot Face Layer	in/ ---	1/ 8# CF Blanket	1/ 8# CF Blanket	1/ 8# CF Blanket
Back-Up Layer No.1	in/ ---	1/ 8# CF Blanket	2/ 6# CF Blanket	1/ 8# CF Blanket
Back-Up Layer No.2	in/ ---	3/ 6# CF Blanket	None	3/ 6# CF Blanket
Foil Vapor Barrier	in/ ---	None	None	None
Castable Reinforcement (SS Needles)	wt%	None	None	None
Anchors / Tie Backs:	---	Pins & Clips	Pins & Clips	Pins & Clips
Material	---	310 S.S.	304 S.S.	310 S.S.
Attachment	---	Welded	Welded	Welded
Casing:				
Material	in/ ASTM	0.1875 / A36	0.1345 / A36	0.1875 / A36
Internal Coating	---	None	None	None
External Temperature, Typical	°F	180	180	180
Comments / Clarifications	---	w/ cfb wraps SHOP Installed	w/o cfb wraps SHOP Installed	w/ cfb wraps SHOP Installed

Convection Section Design:		SIDEWALLS		ENDWALLS	
		SHIELD	FINNED	TUBESHEETS	HEADER BOXES
Total Refractory Thickness	in	3.0	3.0	3.0	2.0
Hot Face Temperature (design)	°F	2,000	2,000	2,200	2,000
Hot Face Temperature (calculated)	°F	1,048	1,048	1,048	766
Hot Face Layer	in/ ---	1/ 8# CF Blanket	1/ 8# CF Blanket	3/ Sparlite HS	1/ 8# CF Blanket
Back-Up Layer No.1	in/ ---	2/ 6# CF Blanket	2/ 6# CF Blanket	None	1/ 8# CF Blanket
Back-Up Layer No.2	in/ ---	None	None	None	None
Foil Vapor Barrier	in/ ---	None	None	None	None
Castable Reinforcement (SS Needles)	wt%	None	None	None	None
Anchors / Tie Backs:	---	Pins & Clips	Pins & Clips	Bullhorns	Pins & Clips
Material	---	310 S.S.	304 S.S.	304 S.S.	304 S.S.
Attachment	---	Welded	Welded	Welded	Welded
Casing:					
Material	in/ ASTM	0.1345 / A36	0.1345 / A36		0.1345 / A36
Internal Coating	---	None	None	None	None
External Temperature, Typical	°F	180	180		180
Comments / Clarifications	---	Cleaning/Sootblowing lanes: none SHOP Installed	SHOP Installed	SHOP Installed	Bolted Assembly SHOP Installed

Stack & Uptakes Design:		FLUE GAS DUCTS		DISCH. DUCT	
		15° TRANSITION		One	
Quantity		One		One	
Type / Location		Full L / Conv		Self.Spt/ Grade	
Length / Metal Outside Diameter (top)	ft/ ft	1.08	n/ a	7	1.333
Discharge Elev., minimum/ calculated	ft/ ft	n/ a	n/ a	20	20
Total Refractory Thickness	in	0.0		0.0	
Hot Face Temperature (design)	°F				
Hot Face Temperature (calculated)	°F	447		447	
Hot Face Layer	in/ ---	None		None	
Back-Up Layer No.1	in/ ---				
Castable Reinforcement (SS Needles)					
Anchors / Tie Backs:	---				
Material	---				
Attachment	---				
Casing:					
Minimum Thickness/ Material	in/ ASTM		0.1345 / A36	0.1345 / A36	
Corrosion Allowance	in		None	None	
Internal Coating	---		None	None	
External Temperature, Typical	°F		447	447	
Comments / Clarifications	---				

MECHANICAL / STRUCTURAL DESIGN BASIS

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64

Refractory & Coatings Design:	Per Std560: 180°F Avg. Casing Temperature @ Ambient Conditions of 0 MPH & 80°F		
Refractory Design	SHOP dryout = None // FIELD dryout is NOT required with the use of TC's AHR additive to Castable.		
Refractory Dryout	None		
Coating, Internal	None		
Coating, External	Base Coat:	3 mils dft IOZ (InOrganic Zinc) on SP-6 Surface	
	Int. Coat:	None	
	Top Coat:	None	

Applicable Standards:			
API	Std 560 (ISO 13705); Fired Heaters for ...	AISC	Specification for Design, ... Steel for Buildings
API	Std 530 (ISO 13704); Calc. of Heater Tube ...	AWS	D 1.1; Structural Welding Code
ASME	B31.3, Chemical Plant and ... Piping	ASTM	tube/ smls pipe/ fitting spec's noted herein
ASME	Sections I, II, VIII, IX; ASME B&PV Code	ASTM	refractories per C27, C155, C401 & C612
ASME	Section V; Non Destructive Examination	NFPA	NFPA 70; National Electrical Code

Wind Design:		Seismic Design:	
Spec. or Standard	ASCE 7-10	Spec. or Standard	ASCE 7-10
Velocity/ Imp. Factor	120 mph / 1	Risck Cat./Imp. Factor	III / 1.25
Site Exposure	"C"		
Physical Design:		Site Design Basis:	
Plot Limitations	None	Site Elevation	750 ft AMSL
Tube Limitations	None	Stack Design Temp.	90 °F
Firebox Pressure	Positive; approximately +1.0 inH2O	FG Discharge Elev.	20 ft AG
Ambient Temp's	-20 °F Min/ 60 °F Dsn/ 110 °F Max	Area Classification	Unclassified

MAJOR SUBSYSTEMS & ACCESSORIES

Major Services & Subsystems		Major Accessories:	
Process Design	INCLUDED in base pricing	Casing/ Tube Seals	4 TubeSox; Radiant & Conv.
Mechanical Design	INCLUDED in base pricing	Observation Doors	2 4 in Dia. w/ H.T. glass
Structural Design	INCLUDED in base pricing	Observation Doors	1 4 in Dia. w/ HT glass on Arch
Radiant Section	INCLUDED in base pricing	Access Doors	1 Std 24" x 24"
Convection Section	INCLUDED in base pricing	Expansion Joints	None
Combustion Mgmt	INCLUDED in base pricing	Ladders & Platforms	Not Included
Burner Piping	INCLUDED in base pricing	L&P Coating	N/A
Forced Draft System	INCLUDED in base pricing		
Casing Penetrations		Pressure Part Penetrations	
Fbox Purge/ Snuff	None	Coil TSTC's, Radiant	None
CA Temp/Pres	None	Coil TSTC's, Convection	None
FG Temperature	2 1.5"NPS 3000# Coupling	Process TI conn's	3 1.5" NPS 900# RFWN
FG Pressure	2 1.5"NPS 3000# Coupling	Process PI conn's	1 1.5" NPS 900# RFWN
FG Comp. (Sample)	2 1.5"NPS 3000# Coupling	spare	
FG Sample	2 4"NPS 150# RFWN's	spare	
O2 Analyzer Port	None	spare	

Dampers					
Function	FD Fan (blower)	qty = 0	Uptake Ducts	Stack	qty = 0
Design	Note: Fan inlet damper is inappropriate for forced draft SHO's where O2 Control is provided by the CMS O2			Note: Stack Damper (which provides draft control) is inappropriate for forced draft SHO's where the combustion conditions are controlled real-time via the CMS.	
Operator	Trim Module which controls the fan (blower) motor's VFD/ VSD.				
Sootblowers:	Qty.	Type	Location	FG T	Material
Lane 1:	None				Steam T & P O.E.M. / Ref.
Lane 2:	None				

1	Owner:	Unknown	Owner Ref.:	H-741	Fnt &
2	Purchaser:	UOPR	Purch. Ref.:	J463	Rev
3	Manufacturer:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-265	
4	SHO Model:	SHO500	Location:	Unknown	

ASME SECTION VIII - DIVISION 1 CALCULATIONS for RADIANT COIL

Formulas:

$t_s = \frac{(P \times R_i)}{(S \times J_E - 0.6 \times P)}$ Circumferential Stress	or $\frac{(P \times R_i)}{(2 \times S \times J_E + 0.4 \times P)}$ Longitudinal Stress	or $\frac{(P \times R_o)}{(S \times J_E + 0.4 \times P)}$ Circumferential Stress
---	--	--

where:		units	comments:
t _s	Required / Minimum Stress Thickness	in	Excludes corrosion and/or erosion allowances
P	Design Pressure, per PO / Contract	psig	Per PO / Contract
R _o / R _i	Outside / Inside Radius of Tube	in	Calculated values for New Condition
S	Design (Max. Allowable) Stress @ T	psi	Per UG-23 / ASME Section II, Part D, Subpart 1
J _E	Joint Efficiency, per UW-12	%	TABLE UW-12; 100% seamless pipe/tube = 1.00

Radiant Coil Design Basis:	units	Variable Values	Comments
Design Pressure, P	psig	1,095	Design Pressure is per PO / Contract.
Design Temperatures, T.Dmax / T.Dmin.	°F	763 / -20	T.Dmax per THM calcs / T.Dmin per PO / Contract
Design Allowances, Corrosion/ Erosion	in	0.0625 / 0.000	Allowances (both CA & EA) are per PO / Contract
Design Stress @ Design Temp, S	psi	12,413	Design Stress @ T.Dmax
Pipe/Tube Outside Diameter	in	4.500	
Pipe/Tube Material Standard	ASME	SA106GrB	Max. Allowable Nonconcentricity, per ASTM: 12.50%
Pipe/Tube Type	welded or seamless	Seamless	
Butt Weld Inspection	RT or Other	100 of 100%	
Tube Schedule / New Avg. Wall	ASTM	SCH 80 / 0.337	Tube Inside Radius (R _i), New = 1.913
Actual Minimum Thickness, t _{new} / t _{EOL}	in	0.295 / 0.232	t _{EOL} = End of Life Thickness = t _{new} - (CA + EA)

UG-27 Calculations:	units	Variable Values	Comments
Circumferential Stress Calculations	---	1.00	Per UW-12, Longitudinal J _E of seamless pipe is 100%
UG-27(c) (1) Minimum Thickness, t _s	in	0.178	UG-27(c) (1)&(2) Thickness Check: 0.18 = OK!!
UG-27(c) (1) Surplus Wall Thickness	in	0.054	UG-27(c) (1) Pressure Limit Check: 4,779 = OK!!
UG-27(c) (1) Acceptability	---	Acceptable!	Acceptable if t _{EOL} > t _s (ie, Surplus Thickness > 0.000)
Longitudinal Stress Calculations	---	0.85	Per UW-12, Circumferential J _E of butt-welds is 85%
UG-27(c) (2) Minimum Thickness, t _s	in	0.097	UG-27(c) (2) Pressure Limit Check: 13,189 = OK!!
UG-27(c) (2) Surplus Wall Thickness	in	0.135	
UG-27(c) (2) Acceptability	---	Acceptable!	Acceptable if t _{EOL} > t _s (ie, Surplus Thickness > 0.000)

Appendix 1, Para.1-1 Calculations:	units	Variable Values	Comments
Circumferential Stress Calculations	---		Per UW-12, Longitudinal J _E of seamless pipe is 100%
Appendix 1 (1-1) (1) Min. Thickness, t _s	in		
Appendix 1 (1-1) (1) Surplus Thickness	in		
Appendix 1 (1-1) (1) Acceptability	---		Acceptable if t _{EOL} > t _s (ie, Surplus Thickness > 0.000)

- Footnotes / Clarifications:**
- a) Fluxed coil (inside casing) & XOvers are per ASME Section VIII -Div.1; unfluxed manifolds are per ASME B31.3.
 - b) This design is per the 2015 Edition of Section VIII - Division 1 (UG-27 basis; not Appendix 1).
 - c) These calculations are "preliminary" until accepted by the Coil Manufacturer; whom provides the code stamp on the coil.
 - d) The different Design Temp's of Radiant and Convection coils reflect the heater's large process temp rise.
 - e) Per UG-11 & UG-44, the Pressure-Temperature ratings of standard components shall be per noted ASME/ANSI Stds.
 - f) Per UG-44, fittings per B16.9 & B16.11 shall be calculated as for straight seamless pipe per Section VIII - Division 1.
 - g) Per UCS-66, charpy impact testing for this coil is not mandatory (ref. FIG UCS-66, Curve B).
 - h) Work this data sheet with Heater Datasheets and General Arrangement Drawings (latest versions).
 - i) Mandatory Appendix 1 provides supplemental design formulas that MAY be substituted for UG-27(c) formulas.
 - j) spare

63					
64					
65					
66	1	13-Nov-17	Revised Purch. Ref. No. per Customer	JDC	JDF
67	0	19-Aug-17	Issued for Approval	JF	JDC
68	rev.	date	description	by	app'v'd

CONFIDENTIAL
PROPERTY of ...
TULSA HEATERS MIDSTREAM LLC

project reference: American Engineering Standard (AES) Units

COIL UNDER INTERNAL PRESSURE
ASME SECTION VIII - DIVISION 1 CALCS

FLUXED HEATER COIL
MJ17-265-COIL.VIIIids-Rev. 1 **Pg 1 of 2**

www.tulsaheatersmidstream.com u 74119 u Tulsa, OK 74119 u TULSA HEATERS MIDSTREAM LLC u 1215 S. Boulder Ste 1040 u (918) 392-8000(vce) u info@tulsaheatersmidstream.com

1	Owner:	Unknown	Owner Ref.:	H-741	Flnt
2	Purchaser:	UOPR	Purch. Ref.:	J463	&
3	Manufacturer:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-265	Rev
4	SHO Model:	SHO500	Location:	Unknown	

ASME SECTION VIII - DIVISION 1 CALCULATIONS for CONVECTION COIL

Formulas:

t.s =	$\frac{(P \times R_i)}{(S \times J_E - 0.6 \times P)}$	or	$\frac{(P \times R_i)}{(2 \times S \times J_E + 0.4 \times P)}$	or	$\frac{(P \times R_o)}{(S \times J_E + 0.4 \times P)}$
	Circumferential Stress		Longitudinal Stress		Circumferential Stress

where:

t.s	Required / Minimum Stress Thickness	in	Excludes corrosion and/or erosion allowances
P	Design Pressure, per PO / Contract	psig	Per PO / Contract
Ro / Ri	Outside / Inside Radius of Tube	in	Calculated values for New Condition
S	Design (Max. Allowable) Stress @ T	psi	Per UG-23 / ASME Section II, Part D, Subpart 1
JE	Joint Efficiency, per UW-12	%	TABLE UW-12; 100% seamless pipe/tube = 1.00

	units	Variable Values	Comments
23 Convection Coil Design Basis:			
24 Design Pressure, P	psig	1,095	Design Pressure is per PO / Contract.
25 Design Temperatures, T.Dmax. / T.Dmin.	"F	650 / -20	T.Dmax per THM calcs / T.Dmin per PO / Contract
26 Design Allowances, Corrosion / Erosion	in	0.0625 / 0.000	Allowances (both CA & EA) are per PO / Contract.
27 Design Stress @ Design Temp, S	psi	17,100	Design Stress @ T.Dmax
28 Pipe/Tube Outside Diameter	in	4.500	
29 Pipe/Tube Material Standard	ASME	SA106GrB	Max. Allowable Nonconcentricity, per ASTM: 12.50%
30 Pipe/Tube Type	welded or seamless	Seamless	
31 Butt Weld Inspection	RT or Other	100 of 100%	
32 Tube Schedule / New Avg. Wall	ASTM	SCH 80 / 0.337	Tube Inside Radius (R.i), New = 1.913
33 Actual Minimum Thickness, t.new / t.EOL	in	0.295 / 0.232	t.EOL = End of Life Thickness = t.new - (CA + EA)

UG-27 Calculations:

36 Circumferential Stress Calculations	---	1.00	Per UW-12, Longitudinal JE of seamless pipe is 100%
37 UG-27(c) (1) Minimum Thickness, t.s	in	0.127	UG-27(c) (1)&(2) Thickness Check: 0.18 = OK!!
38 UG-27(c) (1) Surplus Wall Thickness	in	0.105	UG-27(c) (1) Pressure Limit Check: 6,584 = OK!!
39 UG-27(c) (1) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)
40 Longitudinal Stress Calculations	---	0.85	Per UW-12, Circumferential JE of butt-welds is 85%
41 UG-27(c) (2) Minimum Thickness, t.s	in	0.071	UG-27(c) (2) Pressure Limit Check: 18,169 = OK!!
42 UG-27(c) (2) Surplus Wall Thickness	in	0.161	
43 UG-27(c) (2) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Appendix 1, Para.1-1 Calculations:

46 Circumferential Stress Calculations:	---		Per UW-12, Longitudinal JE of seamless pipe is 100%
47 Appendix 1 (1-1) (1) Min. Thickness, t.s	in		
48 Appendix 1 (1-1) (1) Surplus Thickness	in		
49 Appendix 1 (1-1) (1) Acceptability	---		Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Footnotes / Clarifications:

a) Fluxed coil (inside casing) & XOvers are per ASME Section VIII -Div.1; unfluxed manifolds are per ASME B31.3.

b) This design is per the 2015 Edition of Section VIII - Division 1 (UG-27 basis; not Appendix 1).

c) These calculations are "preliminary" until accepted by the Coil Manufacturer; whom provides the code stamp on the coil.

d) The different Design Temp's of Radiant and Convection coils reflect the heater's large process temp rise.

e) Per UG-11 & UG-44, the Pressure-Temperature ratings of standard components shall be per noted ASME/ANSI Stds.

f) Per UG-44, fittings per B16.9 & B16.11 shall be calculated as for straight seamless pipe per Section VIII - Division 1.

g) Per UCS-66, charpy impact testing for this coil is not mandatory (ref. FIG UCS-66, Curve B).

h) Mandatory Appendix 1 provides supplemental design formulas that MAY be substituted for UG-27(c) formulas.

i) These calculations are for the Convection Coil and for the Crossovers (between radiant and convection modules).

j) spare

63					
64					
65					
66	1	13-Nov-17	Revised Purch. Ref. No. per Customer	JDC	JDF
67	0	19-Aug-17	Issued for Approval	JF	JDC
68	rev.	date	description	by	app'v'd



CONFIDENTIAL
PROPERTY of ...
TULSA HEATERS MIDSTREAM LLC

project reference: American Engineering Standard (AES) Units

COIL UNDER INTERNAL PRESSURE

ASME SECTION VIII - DIVISION 1 CALCS

FLUXED HEATER COIL

MJ17-265-COIL.VIIIids-Rev. 1 **Pg 2 of 2**

www.tulsaheatersmidstream.com u Tulsa, OK 74119 u Boulder Ste 1040 u TULSA HEATERS MIDSTREAM LLC u (918) 392-8000(vce) u info@tulsaheatersmidstream.com

1							
2	Owner:	Unknown	Owner Ref.:	H-741			Ftnt
3	Purchaser:	UOPR	Purch. Ref.:	J463			&
4	Heater Mfr:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-265			Rev
5	Burner OEM:	Callidus Technologies, LLC	OEM Ref.:	9020143			
6	SHO Model:	SHO500	Service:	Regen Gas Heater			
7	CMS Model:	CMS1500	Location:	Unknown @ 750 ft elevation			
8							

9

10 **GENERAL DESIGN CONDITIONS**

11

12 **General Application:**

13	Service	---	Regen Gas Heater	Regen Gas Heater
14	Operating Case	---	Over-Design Case	Design Case
15	Burner Type		Enhanced IFGR	Enhanced IFGR
16	Burner Quantity	---	1	1
17	Model & Size:	---	CUBL-3W	CUBL-3W
18	Flame Shape	cylindrical or flat	Cylindrical	Cylindrical
19	Applicable Fuel(s)	---	Fuel Gases pg. 2	Fuel Gases pg. 2
20	Location(s) / Firing Direction		Endwall Center	Endwall Center
21	Firing Orientation		Horizontal	Horizontal
22	BridgeWall Temperature, calc.	°F	1,649	1,526

23

24 **Heat Release Performance:**

		MMBTU/hr	MMBTU/hr
25	Operating Case	---	Over-Design Case
26	Max. Heat Release, per Burner	LHV Basis	9.20
27	Design Heat Release, per Burner	LHV Basis	8.37
28	Min. Heat Release, per Burner	LHV Basis	1.84
29	Turndown, minimum/ actual	max / min	5.00 / 5.00

30

31

32

Radiant Dimensions:		comments	ft / (in)	Flame Dimensions:		ft / (in)
34	Casing Width / Height, Casing	face - face	8.00 / (96)	Burner CL elev., approx.	AG	4.50 / (54)
35	Casing Length, Casing to Casing	face - face	10.00 / (120)	Flame Length, calc.	@ design HR	10.9 / (131)
36	Helical Coil CenterLine Diameter	CL - CL	6.50 / (78)	Flame Dia., calc.	@ design HR	2.50 / (30)
37	Helical Coil Inside Diameter	face - face	6.13 / (74)			
38	Serpentine Coil CtrLine Dimensions	W / H		Actual Clearances		ft / (in)
39	Serpentine Coil Inside Dimensions	face - face		Burner - tube (tangential)	CL / Net	3.25 / (39)
40	Firebox Length, Refractory Faces	face - face	9.17 / (110)			

41

42 **Combustion Air (CA) Basis - All Fuel(s):**

43	CA Temperature, min.	-20 °F	FG Draft, at Bridgwall	0.50 inH2O	(positive)
44	CA Temperature, design	60 °F	CA Pressure, at Burner	7.64 inH2O	(positive)
45	CA Temperature, max.	110 °F	CA Pressure Drop, Design	7.10 inH2O	
46	CA Pressure, Ambient	14.30 psia	CA Pressure Drop, Actual	t.b.q. inH2O	
47	CA Humidity, Design	50% %RH			


48

49 **Emissions -**

		---	Gaseous Fuel(s):	Liquid Fuel(s):	no
50	Design/ Guaranteed Emissions:	basis	3.0% O2, dry (LHV)		
51	NOx Emissions	LHV Basis	0.053 Lb/MMBTU		
52	SOx Emissions	LHV Basis	no quote Lb/MMBTU		
53	CO Emissions	LHV Basis	0.041 Lb/MMBTU		
54	VOC Emissions	LHV Basis	0.019 Lb/MMBTU		
55	UHC Emissions	LHV Basis	0.007 Lb/MMBTU		
56	SPM10 Emissions	LHV Basis	0.014 Lb/MMBTU		
57	Noise Emissions	---	85 dBA @		

58

59					
60					
61					
62	Rev. 1	13-Nov-17	Revised Purchaser Ref. No. per Customer Comments	JDC	JF
63	Rev. 0	19-Aug-17	Issued for Approval	JF	JDC
64	revision	date	description	by	chk'd
					app'v'd

	BURNER DATA SHEET AES SYSTEMS of UNITS	
	MJ17-265-BRNRds-Rev. 1	Page 1 of 3

SHO = Superior Quality, Flexibility, Dependability & Modularity

This document contains confidential information, which is proprietary to THM. This document shall not be used, reproduced or disclosed without the prior written consent of THM.

GASEOUS FUEL(S) & PRODUCTS OF COMBUSTION

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64

Fuel Gas Basis:	---	Gas 1	Mol.Wt.		
Operating Mode	---	Over-Design Case			
Temperature, at Burner	°F	100			
Pressure, at Burner (available)	psig	75			
LHV (net HV), mass basis	AES units	20,426	BTU/ Lbm		
LHV (net HV), volume basis	AES units	976	BTU/ scf		
HHV (gross HV), mass basis	AES units	22,613	BTU/ Lbr		
HHV (gross HV), volume basis	AES units	1,080	BTU/ scf		
Molecular Weight (mass)	all units	18.13	x/ x mole		

Fuel Gas Composition(s):	symbol	MW	Gas 1	Mol.Wt.		
	H2	2.02	0.00%	mole %		
	O2	32.00	0.00%	mole %		
	N2 + Ar	28.15	1.00%	mole %		
	CO	28.01	0.00%	mole %		
	CO2	44.01	1.00%	mole %		
	CH4	16.04	88.00%	mole %		
	C2H6	30.07	8.00%	mole %		
	C2H4	28.05	0.00%	mole %		
	C3H8	44.10	2.00%	mole %		
	C3H6	42.08	0.00%	mole %		
	C4H10	58.12	0.00%	mole %		
	C4H8	56.11	0.00%	mole %		
	C5H12	72.15	0.00%	mole %		
	C5H10	70.13	0.00%	mole %		
	C6+	86.18	0.00%	mole %		
	H2S	34.08	0.00%	mole %		
	SO2	64.06	0.00%	mole %		
	NH3	17.09	0.00%	mole %		
	H2O	18.02	0.00%	mole %		
	spare		0.00%	mole %		

Products of Combustion @ Design:		Gas 1	Mol.Wt.	
Excess Air Concentration	mole%	15%	mole%	
Temperature, PoC at Bridgewall	°F	1,649		
Temperature, PoC at Burner	°F	1,450		
Temperature, PoC Acid Dew Point	°F	151		

Combustion Mass Balances:		MW	<< ----- mass balance by TULSA HEATERS MIDSTREAM LLC ----- >>	
Fuel Flow Rates	mass in		Lbm/ hr	
Comb. Air Flow Rates	mass in	28.96	410	
POC Mass Flow Rates (wet)	mass out	27.89	7,735	
POC Mass Flow Rates (dry)	mass out	29.91	8,145	
POC Component Flow Rates ...	O2	32.00	7,251	
	N2 + Ar	28.15	233	
	CO2	44.01	5,915	
	H2O	18.02	1,102	
			894	
			<< ----- vapor / solid concentrations are in ppmvd / ppmvd, resp. ----- >>	
	NOx	46.01	0.45	40 ppm
	SOx	64.06	0.00	0 ppm
	CO	28.01	0.34	50 ppm
	VOC	44.10	0.16	15 ppm
	UHC	16.04	0.06	15 ppm
	SPM		0.12	16 ppm

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64

ADDITIONAL REQUIREMENTS

QA Requirements:

Performance Test @ shop --- Not Required
 CFD Model of Firebox --- None
 CFM of CA Ducting --- None
 Mill Certs, fuel wetted parts --- Not Required
 PMI, fuel wetted parts --- Not Required

Fuel Wetted Components:

Oil Gun Model --- None
 Gun Tip / Atomizer Mat'ls ASTM None / None
 Gas Risers Material ASTM t.b.d.
 Gas Manifolds Mat'l ASTM Carbon Steel

Burner Pilot:

model by O.E.M.
 Type --- Self-Inspiring
 Heat Release BTU/ hr > 90,000
 Ignition Method man.or elec. Electric
 Pilot Fuel Gas --- Gas 1 Mol.Wt.
 Pilot Detection type or none None
 Fuel P, avail. @ pilot psig 10 (5 -15 is OK)

Connections:

Primary Fuel Gas sz & spec by OEM & 150# A105 RF
 Secondary Fuel Gas sz & spec None
 Fuel Oil sz & spec None
 Atomizing Media sz & spec None
 Pilot Gas sz & spec by OEM & 150# A105 RF
 Detector, Main Flame sz & spec None
 Detector, Pilot Flame sz & spec by OEM - UV Scanner Mount
 Sight Ports sz & spec None

Windbox or Plenum:

Individual windbox yes or no yes
 Material Description th x ASTM 12 ga. x A36
 Common Plenum Depth ft. none
 Refractory Description th x type 1.00 in x Min.Wool
 Refractory Anchors ASTM C.S. Expanded Metal
 Register Type none
 Register Material ASTM C.S.
 Leakage, guaranteed wt% < 5.0 % of Max HR Flow
 Actuation man., pneu.or elec. manual

APPLICABLE SPECIFICATIONS & STANDARDS

TULSA HEATERS MIDSTREAM LLC Specifications:

- a) Burner scope ...
 - 1) Pilot w/ Electric Ignition - Ignition Transformer is by others (CMS Supplier)
 - 2) UV Scanner is by others. Swivel scanner mount (by burner supplier) aimed at pilot and main flame when pilot off.
 - 3) Sight port(s) for viewing pilot and main flames.
- b) Burner shall have 5:1 turndown; this capability shall NOT compromise flame size or performance.
- c) External Coatings shall be as follows:

Prime:	3 mils dft IOZ (InOrganic Zinc) on SP-6 Surface
Intermediate:	None
Finish:	None
- d) Burner is mounted and fired horizontally. Tile to be shop mounted in 304 SS case.
- e) Even though job location/elevation is different, burner to be sized to range from sea level to 3500 ft and worst case air delta P reported.

1	Owner:	Unknown	Owner Ref.:	H-741	Fnt
2	Purchaser:	UOPR	Purch. Ref.:	J463	&
3	Heater OEM:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-265	Rev
4	CMS OEM:	International Custom Controls	CMS Model:	CMS1500	
5					
6					
7					
8	System Overview:				
9	Design Philosophy	Meet or Exceed NFPA 85 with packaged Combustion Management System			
10	Heater DHR	Heater Design Heat Release = 9 MMBTU/hr (LHV); ref. Burner Data Sheets for fuel composition			
11	CMS DHR	CMS Design Heat Release = 15 MMBTU/hr (LHV); ref. Burner Data Sheets for fuel composition			
12	No. of Burners	One Callidus CUBL-3W Burner per heater			
13					
14	THM Specs	Provided datasheets	Ambient P, Design	750 ft AMSL =	14.30 psia
15	THM P&ID	CMS1500 P&ID	Ambient T Range	-20 °F Minimum to 110 °F Maximum	
16	Area Classification	Unclassified	Noise Limit	85 dBA @ 3 ft	
17	Supply Power	120V / 1 ph / 60 Hz	Ind. Standard(s)	B31.3, NFPA 70 (NEC), NFPA 85	
18	Supply Air	80 psig	Customer Specs	None	
19					
20	Subsystem Design:				
21	Main Gas Train ³	Double Block & Bleed SDVs with ZSC's	Dsn P	Dsn T	NPS
22	Pilot Gas Train	Double Block & Bleed SDVs	150 psig	150°F	1-1/2"
23	Instrument Air Hdr		150 psig	150°F	1/2"
24	Main Oil Train	None	125 psig	150°F	1"
25	Atom. Media Train	None			
26	Local Panel (LCP)	NEMA 4 Enclosure for Controls, HMI, Pushbuttons & Lights			
27	Other Panel(s)	NEMA 7 Enclosure with 6kV Ignition Transformer & 7mm HiV IGN Cable			
28	Other Panel(s)	None			
29	Forced Draft Sys.	One FD Fan ¹ ; a) unlined ducting, b) CA controlled by			
30					
31	Minimum Pre-Purge Interlocks:			Minimum Purge Interlocks:	
32	✓ Manual ESD Switch (pushbutton)	✓ Gas Supply Low Pressure		✓ Minimum CA Flow	
33	✓ SDVs FailSafe Positions	✓ Gas to Burner High Pressure			
34	✓ Stack High Temperature	- Firebox High Pressure			
35	✓ Process High Temperature	- Oil Supply Low Pressure			
36		- Atom.Media Low Pressure			
37	Gas / Oil Trains Overview:		Local Panel Components Overview:		
38	✓ Pilot Double Block & Bleed SDVs	✓ Slate Control Package			
39	✓ Gas Train Dbl Block & Bleed SDVs	✓ Touchscreen HMI			
40	✓ Inlet Header Isolation Valve	- Remote Control Panel			
41	✓ Inlet Header Sediment Trap w/ Cap	- Field Wiring schematic to connect LCP to J/B			
42	✓ Inlet Header Gas Strainer	- LCP Weather/Sun Shield			
43	✓ Inlet Header Pressure Regulator				
44	- Inlet Header Relief Valve	Supporting Components:			
45	- Oil Train Dbl Block & Bleed SDVs	✓ Pilot Flame UV Detector			
46	- Atom.Media dP Controls	- Main Flame UV Detector			
47	- Gas/Oil Flow Element	✓ CA Ducting to Burner(s)			
48	- Coarse Air Flow Element	✓ Flex Hoses at Brnr Terminals			
49	- Misc. Fire PCV in Parallel w/ TCV	- Individual Burner SDVs			
50		✓ Fuel Train Only (no skid)			
51					
52					
53					
54	NOTES:				
55	1. Forced draft fan supplied by THM				
56	2. Process Pressure Gauge to be designed for 0-1095 psig				
57	3. ZSC's only on block valves, not bleed.				
58	4. Piping 2" and below to use threaded fittings, except end connections.				
59	5. FAT required				
60					
61					
62	1	13-Nov-17	Rev'd Purch. Ref. No.	JDC	JF
63	0	19-Aug-17	Issued for Approval	JF	JDC
64	rev.	date	description	by	app'd
COMBUSTION MANAGEMENT SYSTEM				CMS1500 DATA SHEET	
15 MMBTU/hr RATED HEAT RELEASE				MJ17-265-CMS1500ds- Rev. 1	
This document contains confidential and proprietary information, and IT SHALL NOT be used, reproduced or disclosed without the prior written consent of THM.					



Process Interlocks:

	units	Tag No.	Factory Setting		Design Conditions		Comments
			Low	High	Min.	Design	
Process Flow	MLb/hr	FALL-300	7.6	None	20.8	116.2	---
		Action:	S/D @ minimum flow to avoid "short circuiting" one or more coil passes				
Process Temperature	°F	TSHH-202	None	600	---	550	600
		Action:	S/L @ maximum fluid temperature to avoid "overheating" the coil				

Heater Interlocks:

Stack Temperature	°F	TSHH-201	None	700	377	483	---
		Action:	S/D @ 700 F, which is indicative of an "out-of-control" fire in the heater				

CMS Interlocks:

FG Train Pressure	psig	PSLL-101	10	None	---	---	150
		Action:	S/D @ 10 psig, which is indicative of "inadequate" fuel gas supply				
FG Train Pressure	psig	PSHH-103	None	35	---	---	150
		Action:	S/D @ 35 psig, which is indicative of a "failure" of PCV-100 &/or FG supply				

FD Fan Interlocks:

FD Fan (blower) SP	inH2O	PSLL-107	0.20	None	0.46	7.6	11.4
FD Fan (blower) FDF shutdown:	5.0	Action:	S/D @ 0.2 inH2O, which is indicative of a FD Fan (blower) "failure".				

Other permissives/interlocks in BMS Operations Manual (block valves, FCV, and flame signal).

CMS CONTROL COMPONENTS

	units	Tag No.	Factory Setting		Design Conditions		Comments
			Low	High	Min.	Design	
Remote T Setpoint	°F	TY-700	0	999	---	550	600
		Action:	4 -20 mA input corresponds to a temperature setpoint range of 0 -999 °F				
Process Temperature	°F	TT-203	0	999	---	550	600
		Action:	4 -20 mA output corresponds to a process temperature range of 0 -999 °F				
Main Gas Regulator	psig	PCV-100	---	---	---	35	150
Pilot Gas Regulator	psig	PCV-105	---	---	---	10	150
Inst. Air Regulator	psig	PCV-107	---	---	---	80	150

CUSTOMER CONNECTIONS (TO DCS)

The following signals are sent to the customer's DCS from the control panel:

- Remote ESD
- Heater Run
- Low Process Flow
- High Stack Temperature
- High Process Temperature
- Burner Status

1					
2	Owner:	Unknown	Heater Ref.:	H-741	
3	Purchaser:	UOPR	Purch. Ref.:	J463	Flnt
4	Heater Mfrg:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-265	&
5	Location:	Unknown	FD OEM Ref.:	340802	Rev
6	FD Fan OEM:	Chicago Blower	FD Item No.:	BL-741	
7					

8

9 **General Application:**

10 FD Fan(s) Design Basis mass.flow.% 115% of Design MASS Flows per API Standard 560

11 Location(s) --- @ Grade, adjacent to Burner Endwall (incorporated into Combustion Skid)

12 Area Classification NEC Unclassified

13

14 **AES Units**

		Heater Design	FD Test Block
15 Process Design Conditions:			
16 Mass Flow Rate/ % Htr Design	Lb/hr / kg/ hr	7,736 / 100%	8,900 / 115%
17 Volumetric Flow/ % Htr Design	acfm / am3/ hr	1,800 / 100%	2,200 / 122%
18 Density, @ Suction	as noted	0.074 Lb/ ft3	0.068 Lb/ ft3
19 Design Allowances, Temp./ SP	°F / °C	--- / ---	130 °F / 149%
20 Temperature @ Min / Suction / Design	°F / °C	-20 / 60 / 110	
21 Static Pressure @ Suction	as ntoed	-0.2 inH2O	-0.2 inH2O
22 Site Elevation/ Atm. P	as ntoed	750 ftAMSL	14.30 psia
23 Static Pressure Rise (min./ guar.)	inH2O	7.6 / 7.6	11.4 / 11.4
24 Fan Speed (allowable/ actual)	RPM	3,600 / 3,525	3,600 / 3,525
25 Sound Pressure (allowable/ guar.)	dBA	< 85 / < 85	< 85 / < 85
26 Relative Humidity	%	50%	

27

28 **Fan Mechanical Design:** tag // OEM **BL-741 // CHICAGO BLOWER Corp.**

29 OEM Reference CMS // FD Fan International Custom Controls // 340802

30 OEM Model &/or Type-Size per OEM D/36A (SQAD)

31 Arrangement --- Arrangement 4 (direct drive)

32 Brake Power, Design/ Test Block (calc.) HP 10.0 / 10.0

33 Temperature, Mechanical Design °F 135 °F Mechanical Design

34 Casing Description / Materials --- "Square" pattern / CS

35 Rotor Description / Materials --- Airfoil Blades / CS

36 Shaft Description / Materials --- None - Arrangement 4

37 Bearings Description / Materials --- None - Arrangement 4

38 Noise Abatement Provisions / SPL --- 85 dBA

39 External Coatings / Surface Prep. --- OEM's Std Multiple Coat System

40 Purchase Specifications --- OEM's Std Industrial Quality Design

41

42 **Fan Control Design:** tag // OEM **VSD-741 / by OTHERS**

43 VFD Description --- by Others / Owner

44 VFD Rating ---

45 Damper Actuator Description ---

46 Damper Actuator Operation ---

47

48 **Fan Motor Design:** tag // OEM **BM-741 / TECO-WESTINGHOUSE**

49 OEM Model &/or Type-Size --- Catalog EP0102 / AEHH8N

50 VFD Service / speed range --- YES / 3 - 60 Hz or 180 - 3,600 rpm

51 Motor Type / Frame Size --- NEMA TEFC / 215T

52 Rated Power w/ SF @ Speed NEMA 10 HP w/ 1.15 SF @ 40°C

53 Nameplate Input Power V/ Hz/ ph 460V / 60 Hz / 3 ph


54 Typical Performance --- 89.5- 91.0 % FL Effy @ 89.5 % FL PF

55 Insulation Description --- Class F / B Rise

56 External Coatings & Surface Prep. --- OEM's Std Multiple Coat System

57 Purchase Specifications --- None

59					
60					
61					
62	Rev. 1	13-Nov-17	Revised Purchaser Ref. No. per Customer Comments	JDC	JF
63	Rev. 0	19-Aug-17	Issued for Approval	JF	JDC
65	revision	date	description	by	chk'd appv'd

 <p>USA Applications SHO = Superior Quality, Flexibility, Dependability & Modularity</p>	FD FAN DATA SHEET AES & cgs or SI SYSTEMS of UNITS MJ17-265-FDFANds-Rev. 1	Page 1 of 1
	<small>this document contains confidential information, which is proprietary to THM. This document shall not be used, reproduced or disclosed without the prior written consent of THM</small>	

Flnt
&
Rev

1	Owner:	Unknown	Owner Ref.:	H-781
2	Purchaser:	UOPR	Purchaser Ref.:	J463
3	Manufacturer:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-266
4	Service:	Heat Medium Heater	Project:	200 MMscfd Cryo Plant
5	Quantity:	1	Location:	Unknown
6	SHO Duty:	17.55 MMBTU/ hr	SHO Model:	SHO1750
7	CMS Release:	22.30 MMBTU/ hr	CMS Model:	CMS2500
8	SHOS Flow:	650 USgpm @ 137 ft TDH	SHOS.Model:	SHOS660
9				

PROCESS DESIGN CONDITIONS

		--- Radiant / Convection	Radiant / Convection		
14	Heater Section	---			
15	Operating Case	---	Over-Design Case	Design Case	
16	Service	---	Heat Medium Hea	Heat Medium Hea	
17	Heat Absorption (R/C)	MMBTU/ hr	11.82 / 5.72	10.88 / 5.07	
18	Process Fluid	---	Therminol 55	Therminol 55	
19	Process Mass Flow Rate, Total	Lb/ hr	267,775	267,775	
20	Process Bulk Velocity (calc. R/C)	ft/ s	9 / 8	9 / 8	
21	Process Mass Velocity (calc. R/C)	Lb/ s ft2	421 / 421	421 / 421	
22	Coking Allowance (dP calcs)	in			
23	Pressure Drop, Clean (allow. / calc.)	psi	20 / 21	20 / 21	
24	Pressure Drop, Fouled (allow. / calc.)	psi			
25	Average Heat Flux (allowable)	BTU/ hr ft2	13,000	13,000	
26	Average Heat Flux (calculated)	BTU/ hr ft2	11,560	10,640	
27	Maximum Heat Flux (allowable)	BTU/ hr ft2			
28	Maximum Heat Flux (calc. R/C)	BTU/ hr ft2	20,600 / 32,070	18,900 / 29,070	
29	Fouling Factor, Internal	hr ft2 °F/ BTU	0.002	0.002	
30	Corrosion or Erosion Characteristics	---			
31	Max. Film Temperature (allow. / calc.)	°F	650 / 423	650 / 413	
32					
33	Inlet Conditions:				
34	Temperature	°F	195	195	
35	Pressure	psig	60	60	
36	Mass Flow Rate, Liquid	Lb/ hr	267,775	267,775	
37	Mass Flow Rate, Vapor	Lb/ hr	0	0	
38	Weight Percent, Liquid / Vapor	wt%	100% / 0%	100% / 0%	
39	Density, Liquid / Vapor	Lb/ ft3	51.30 / 0.00	51.30 / 0.00	
40	Molecular Weight, Liquid / Vapor	Lb/ Lbmole	--- / 0.0	--- / 0.0	
41	Viscosity, Liquid / Vapor	cp	3.3101 / 0.000	3.310 / 0.000	
42	Specific Heat, Liquid / Vapor	BTU/ Lb °F	0.518 / 0.000	0.518 / 0.000	
43	Thermal Conductivity, Liq./Vap.	BTU/hr ft °F	0.0693 / 0.000	0.069 / 0.000	
44					
45	Outlet Conditions:				
46	Temperature	°F	305	305	
47	Pressure	psig	41	41	
48	Mass Flow Rate, Liquid	Lb/ hr	267,775	267,775	
49	Mass Flow Rate, Vapor	Lb/ hr	0	0	
50	Weight Percent, Liquid / Vapor	wt%	100% / 0%	100% / 0%	
51	Density, Liquid / Vapor	Lb/ ft3	49.00 / 0.00	49.00 / 0.00	
52	Molecular Weight, Liquid / Vapor	Lb/ Lbmole	--- / 0.0	--- / 0.0	
53	Viscosity, Liquid / Vapor	cp	1.311 / 0.000	1.311 / 0.000	
54	Specific Heat, Liquid / Vapor	BTU/ Lb °F	0.565 / 0.000	0.565 / 0.000	
55	Thermal Conductivity, Liq./Vap.	BTU/hr ft °F	0.066 / 0.000	0.0656 / 0.000	
56					

57					
58					
59					
60					
61					
62	Rev. 1	13-Nov-17	Revised Purchaser Ref. No. per Customer Comments	JDC	JF
63	Rev. 0	19-Aug-17	Issued for Approval	JF	JDC
64	revision	date	description	by	chk'd appv'd



USA Applications
SHO = Superior Quality, Flexibility, Dependability & Modularity

FIRED HEATER DATA SHEET
AMERICAN ENGINEERING SYSTEM of UNITS

MJ17-266-HTRds- Rev. 1 Pg 1 of 6

This document contains confidential information proprietary to THM. This document shall not be used, reproduced or disclosed without the prior written consent of THM.

COMBUSTION DESIGN CONDITIONS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64

Overall Performance:

Operating Case	---	Over-Design Case	Design Case	
Service	---	Heat Medium Hea	Heat Medium Hea	
Excess Air	mol%	15.0%	15.0%	
Calculated Heat Release (LHV)	MMBTU/ hr	20.28	18.22	
Guaranteed Efficiency	HR%	84.5%	85.6%	
Calculated Efficiency	HR%	86.5%	87.6%	
Radiation Loss	HR%	3.00%	3.00%	
Flow Rate, Combustion Gen./ Imp.	Lb/ hr	19,739	17,736	
Flue Gas Temp. Leaving (R/C)	°F	1,452 / 468	1,402 / 429	
Flue Gas Mass Velocity	Lb/ sec ft2	0.472	0.424	

Fuel(s) Data:

Gas 1		
Mol.Wt.	976	
LHV BTU/ scf	20,426	
LHV BTU/ Lb	75	
P @ Burner psig	100	
T @ Burner °F	18.13	
MW Lb/ Lbmole	---	
m @ ??? °F cp	---	
m @ ??? °F cp	---	
Atomizing Media	---	
Atom. Media P & T	---	

Burner Design:

OEM	---	Callidus Technologies, LLC
Type	---	Enhanced IFGR ULTRA Low NOx
Quantities	---	1 Burner
Model No.	---	CUBL-5W Cylindrical
Windbox	---	yes ...
Location	---	EndWall Center ... Horizontally Fired
Pilot Design:		
Type / Model	Self-Inspiring	/ by O.E.M.
Ignition	---	Electric requires elec.ign.system
Heat Release	> 90000	BTU/ hr on ... Gas 1

Components:

N	wt%	---
S	wt%	---
Ash	wt%	---
Ni	ppm	---
Va	ppm	---
Na	ppm	---
Fe	ppm	---
H2	mol%	0.0%
O2	mol%	0.0%
N2 + Ar	mol%	1.0%
CO	mol%	0.0%
CO2	mol%	1.0%
CH4	mol%	88.0%
C2H6	mol%	8.0%
C2H4	mol%	0.0%
C3H8	mol%	2.0%
C3H6	mol%	0.0%
C4H10	mol%	0.0%
C4H8	mol%	0.0%
C5H12	mol%	0.0%
C5H10	mol%	0.0%
C6+	mol%	0.0%
H2S	ppmv	0.0%
SO2	mol%	0.0%
NH3	mol%	0.0%
H2O	mol%	0.0%
spare	mol%	0.0%

Burner Performance:

Minimum Heat Release	MMBTU/ hr	4.46
Design Heat Release	MMBTU/ hr	20.28
Maximum Heat Release	MMBTU/ hr	22.30
Burner Turndown	Max/Min	5.00
Volumetric Ht. Release	BTU/ hr ft3	10,034
Pressure @ Arch	inH2O	0.60
Pressure @ Burner	inH2O	7.75
Combustion Air T @ Burner	°F	60
Flue Gas T @ Burner	°F	1,260

Guaranteed Emissions:

Basis of Guarantee	---	3.0% O2, dry (LHV)
NOx Emissions	Lb/MMBTU	0.053 40 ppm
SOx Emissions	Lb/MMBTU	no quote
CO Emissions	Lb/MMBTU	0.041 50 ppm
VOC Emissions	Lb/MMBTU	0.019 15 ppm
UHC Emissions	Lb/MMBTU	0.007 15 ppm
SPM10 Emissions	Lb/MMBTU	0.014 16 ppm
Noise Emissions	dBA @ 3ft	85

Net Flame Clearances:

Est. Flame Size	approx. 19.7 ft L x 3.5 ft Diameter	
Hor Clearance	1 ft NET Tube Clearance	
Vert. Clearance	1 ft NET Tube Clearance	
Axial Clearance	1.45 ft NET Refractory Clearance (to Arch hot face)	

Nominal Flame Clearances:

from burner CL ...	Vertical	Horizontal
to Tube CL, API	ft 10.61	7.08
to Tube CL, calc.	ft 4.50	4.50
to Refrac., calc.	ft n / a	21.17

Blower/Fan Performance:

Volumetric Flow	acfm	4,300
Rated Power	HP	15
Fan Speed	RPM	3,600
Sound Pressure	dBA	< 85
Area Classification	NEC	Unclassified

PRESSURE PARTS DESIGN

1					
2					
3	Coil Design:		<u>RADIANT</u>	<u>SHIELD</u>	<u>CONVECTION</u>
4	Service		Heat Medium Hea	Heat Medium Hea	Heat Medium Heater
5	Design Basis for Tube Temperature		API 530	API 530	API 530
6	Design Basis for Tube Wall Thickness		ASME Sec. VIII-1	ASME Sec. VIII-1	ASME Sec. VIII-1
7	Design Life	hr	100,000	100,000	100,000
8	Design Pressure (elastic / rupture)	psig	150 /	150 /	150 /
9	Design Fluid Temperature	°F	305	305	305
10	Design Temperature Allowance	°F	29	29	29
11	Design Corrosion Allowance (tubes/fittings)	in	0.063 / 0.063	0.063 / 0.063	0.063 / 0.063
12					
13	Maximum Tube Temperature (clean)	°F	440		
14	Maximum Tube Temperature (fouled)	°F	486	389	582
15	Design Tube Temperature	°F	515	611	611
16	Inside Film Coefficient	BTU/ hr ft ² °F	195	141	141
17	Weld Inspection	RT or Other	100 of 100%	100 of 100%	100 of 100%
18	Weld Heat Treatment	s.rel., t.stab. or none	None	None	None
19	Hydrostatic Test Pressure	psig	per API	per API	per API
20					
21	Coil Arrangement:		Horizontal	Horizontal	Horizontal
22	Coil Type	---	Helical	Serpentine	Serpentine
23	Tube Material (pipe or tube spec)	ASTM	SA106GrB	SA106GrB	SA106GrB
24	Supplementary Mfg Requirements	ASTM	None	None	None
25	Tube Outside Diameter	in	4.500	4.500	4.500
26	Tube Wall Thickness (aw / mw)	in	0.237 / 0.207	0.237 / 0.207	0.237 / 0.207
27	Number of Cells (radiant or convection)	---	1	1	1
28	Number of Flow Passes (total / cell)	---	2 / 2	2 / 2	2 / 2
29	Number of Tubes per Row (total / cell)	---	4 / 4	4 / 4	4 / 4
30	Overall Tube (1 turn in radiant) Length	ft	28.27	11.54	11.54
31	Effective Tube Length / Helix Diameter	ft	28.27 / 9.00	9.96	9.96
32	Number of Turns or Tubes (total / pass)	---	30.7 / 15.3	4.0 / 4.0	0.0 / 0.0
33	Total Exposed Surface	ft ²	1,023	47	0
34	Number of Ext.Surf. Tubes (total / cell)	---	0 / 0.0	0 / 0.0	20 / 20.0
35	Total Exposed Surface	ft ²	0	0	2,940
36	Tube Spacing (horiz. / tube centers)	in	--- / 8.00	8.00 / 8.00	8.00 / 8.00
37	Tube Spacing (horiz. to refractory)	in	6.00	4.00	4.00
38					
39	Coil Fittings:		Heat Medium Hea	Heat Medium Hea	Heat Medium Heater
40	Fitting Type	---	SR 90° Elbows	SR 180° U-Bends	SR 180° U-Bends
41	Fitting Material	ASTM	SA234 WPB	SA234 WPB	SA234 WPB
42	Supplementary Mfg Requirements	ASTM	None	None	None
43	Fitting Outside Diameter	in	4.500	4.500	4.500
44	Fitting Wall Thickness (aw / mw)	in	0.237 / 0.207	0.237 / 0.207	0.237 / 0.207
45	Fitting Location	internal or external	Internal	External	External
46	Tube Attachment	welded or rolled	Welded	Welded	Welded
47					
48	Coil Terminals:		Outlet		Inlet
49	Terminal Type	beveled or flanged	Flanged		Flanged
50	Flange Material	ASTM	SA105		SA105
51	Supplementary Mfg Requirements	ASTM	None		None
52	Flange Size and Rating	NPS/ ASME	4" NPS / 300#		4" NPS / 300#
53	Flange Type	RFWN or RTJ	RFWN		RFWN
54	Location	---	Burner Endwall		Terminal End
55					
56	Extended Surface:			<u>CONVECTION</u>	<u>CONVECTION</u>
57	Service	---		Heat Medium Hea	Heat Medium Heater
58	Fin or Stud Row Number	starting @ bottom		No.1 / No.2-3	No.4-5 /
59	Ext. Surface Type	seg.fins, solid fins, studs		HF Seg. Fins	HF Seg. Fins
60	Fin/Stud Material	---		C.S. / C.S.	C.S. /
61	Fin/Stud Height	in		0.75 / 1.00	1.00 /
62	Fin/Stud Thickness	in		0.06 / 0.06	0.06 /
63	Fin/Stud Density	fin/ in		5.00 / 5.00	5.00 /
64					

1
2 PRESSURE PARTS DESIGN (continued)

3	Crossovers:		RADIANT	SHIELD	CONVECTION
4	Type, location / connections	---	External	Flanged	None
5	Tube / Fittings Material	ASTM	SA106GrB	SA234 WPB	
6	Tube & Fitting OD / Thickness (aw)	in	4.500	0.237	
7					
8	Inlet Manifold(s):	type			Simple LOG
9	Location	---			Top - Term. End
10	Design Basis for Manifold Thickness	---			ASME B31.3
11	Design Conditions (temp./press.)	°F/ psig			611 / 150
12	Pipe Material	ASTM			SA106GrB
13	Fittings Material	ASTM			SA234 WPB
14	Flange Material / Style	ASTM			SA105 / RFWN
15	Outside Diameters, each Branch	in			8" NPS
16	Wall Thickness(es); aw or mw	in			SCH40 (0.322)
17	End Types (terminal/ dead)	beveled or flanged			Flanged / W.Cap
18	Manifold Terminal Type	NPS/ ASME			8" NPS / 300# Flg
19	Coil Connection Type	extrusion, olet, etc.			Weld-O-Let
20	Coil Terminal Type	NPS/ ASME			4" NPS / 300# Flg
21					
22	Outlet Manifold(s):	type	Simple LOG		
23	Location	---	Burner Endwall		
24	Design Basis for Manifold Thickness	---	ASME B31.3		
25	Design Conditions (temp./press.)	°F/ psig	515 / 150		
26	Pipe Material	ASTM	SA106GrB		
27	Fittings Material	ASTM	SA234 WPB		
28	Flange Material / Style	ASTM	SA105 / RFWN		
29	Outside Diameters, each Branch	in	8" NPS		
30	Wall Thickness(es); aw or mw	in	SCH40 (0.322)		
31	End Types (terminal/ dead)	beveled or flanged	Flanged / W.Cap		
32	Manifold Terminal Type	NPS/ ASME	8" NPS / 300# Flg		
33	Coil Connection Type	extrusion, olet, etc.	Weld-O-Let		
34	Coil Terminal Type	NPS/ ASME	4" NPS / 300# Flg		
35					

36
37 COIL & MANIFOLD SUPPORTS DESIGN

39	Tube Supports:		RADIANT	SHIELD	CONVECTION
40	Service		Heat Medium Heater	Heat Medium Heater	Heat Medium Heater
41	Location	Top, Bottom, Ends	Bottom	Ends	Ends
42	Support Type	casting, tubesht, spring, etc.	SS Pipe Rail	Welded Tbsheets	Welded Tbsheets
43	Support Thicknesses	in	SCH40	0.375	0.375
44	Support Materials	ASTM	A240 T304	A36 CS	A36 CS
45	Support Temperatures (calc./ design)	°F / °F	840 / 1,030	536 / 690	536 / 690
46	TbSht Ferrules Thickness/Materials	in/ ASTM	---	14 ga. / 304 SS	14 ga. / 304 SS
47	Refractory & Anchor Materials & Types		none	per refrac. section	per refrac. section
48					
49	Intermediate Guides & Supports:		None	None	None
50	Location	---			
51	Guide/ Support Type	casting, spring, etc.			
52	Material	ASTM			
53	Spacing, average	ft			
54					
55	Tube Guides:	Top, Bottom, Ends	None	None	None
56	Material	ASTM			
57					
58	Manifold Supports:		Outlet Manifold		Inlet Manifold
59	Material	ASTM	A36		N/A
60	Materials Design & Supply	---	by THM		
61	Location	Top, Bottom, Ends	Burner Endwall		
62	Support Type	roller, shoe, spring, etc.	Simple Shelf		
63	Number of Supports	---	One (1)		
64					

CASING / REFRACTORY SYSTEMS DESIGN

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64

RADIANT SECTION DESIGN:		BURNER ENDWALL	SHIELDED SIDEWALLS	ARCH ENDWALL
Total Refractory Thickness	in	5.0	3.0	5.0
Hot Face Temperature (design)	°F	2,000	2,000	2,000
Hot Face Temperature (calculated)	°F	1,452	840	1,452
Hot Face Layer	in/---	1/ 8# CF Blanket	1/ 8# CF Blanket	1/ 8# CF Blanket
Back-Up Layer No.1	in/---	1/ 8# CF Blanket	2/ 6# CF Blanket	1/ 8# CF Blanket
Back-Up Layer No.2	in/---	3/ 6# CF Blanket	None	3/ 6# CF Blanket
Foil Vapor Barrier	in/---	None	None	None
Castable Reinforcement (SS Needles)	wt%	None	None	None
Anchors / Tie Backs:	---	Pins & Clips	Pins & Clips	Pins & Clips
Material	---	310 S.S.	304 S.S.	310 S.S.
Attachment	---	Welded	Welded	Welded
Casing:				
Material	in/ ASTM	0.1875 / A36	0.1345 / A36	0.1875 / A36
Internal Coating	---	None	None	None
External Temperature, Typical	°F	180	180	180
Comments / Clarifications	---	w/ cfb wraps SHOP Installed	w/o cfb wraps SHOP Installed	w/ cfb wraps SHOP Installed

CONVECTION SECTION DESIGN:		SIDEWALLS		ENDWALLS	
		SHIELD	FINNED	TUBESHEETS	HEADER BOXES
Total Refractory Thickness	in	3.0	3.0	3.0	2.0
Hot Face Temperature (design)	°F	2,000	2,000	2,200	2,000
Hot Face Temperature (calculated)	°F	960	960	960	650
Hot Face Layer	in/---	1/ 8# CF Blanket	1/ 8# CF Blanket	3/ Sparlite HS	1/ 8# CF Blanket
Back-Up Layer No.1	in/---	2/ 6# CF Blanket	2/ 6# CF Blanket	None	1/ 8# CF Blanket
Back-Up Layer No.2	in/---	None	None	None	None
Foil Vapor Barrier	in/---	None	None	None	None
Castable Reinforcement (SS Needles)	wt%	None	None	None	None
Anchors / Tie Backs:	---	Pins & Clips	Pins & Clips	Bullhorns	Pins & Clips
Material	---	310 S.S.	304 S.S.	304 S.S.	304 S.S.
Attachment	---	Welded	Welded	Welded	Welded
Casing:					
Material	in/ ASTM	0.1345 / A36	0.1345 / A36		0.1345 / A36
Internal Coating	---	None	None	None	None
External Temperature, Typical	°F	180	180		180
Comments / Clarifications	---	SHOP Installed	Cleaning/Sootblowing lanes: none SHOP Installed	SHOP Installed	Bolted Assembly SHOP Installed

STACK & UPTAKES DESIGN:		FLUE GAS DUCTS		DISCH. DUCT	
		15° TRANSITION			
Quantity		One		One	
Type / Location	---	Full L / Conv		Self.Spt/ Grade	
Length / Metal Outside Diameter (top)	ft/ ft	1.41 / n/ a		7 / 2.333	
Discharge Elev., minimum/ calculated	ft/ ft	n/ a / n/ a		20 / 24	
Total Refractory Thickness	in	0.0		0.0	
Hot Face Temperature (design)	°F				
Hot Face Temperature (calculated)	°F	468		468	
Hot Face Layer	in/---	None		None	
Back-Up Layer No.1	in/---				
Castable Reinforcement (SS Needles)					
Anchors / Tie Backs:	---				
Material	---				
Attachment	---				
Casing:					
Minimum Thickness/ Material	in/ ASTM	0.1345 / A36		0.1345 / A36	
Corrosion Allowance	in	None		None	
Internal Coating	---	None		None	
External Temperature, Typical	°F	468		468	
Comments / Clarifications	---				

MECHANICAL / STRUCTURAL DESIGN BASIS

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64

Refractory & Coatings Design:			
Refractory Design	Per Std560: 180°F Avg. Casing Temperature @ Ambient Conditions of 0 MPH & 80°F		
Refractory Dryout	SHOP dryout = None // FIELD dryout is NOT required with the use of TC's AHR additive to Castable.		
Coating, Internal	None		
Coating, External	Base Coat:	3 mils dft IOZ (InOrganic Zinc) on SP-6 Surface	
	Int. Coat:	None	
	Top Coat:	None	

Applicable Standards:			
API	Std 560 (ISO 13705); Fired Heaters for ...	AISC	Specification for Design, ... Steel for Buildings
API	Std 530 (ISO 13704); Calc. of Heater Tube ...	AWS	D 1.1; Structural Welding Code
ASME	B31.3, Chemical Plant and ... Piping	ASTM	tube/ smls pipe/ fitting spec's noted herein
ASME	Sections I, II, VIII, IX; ASME B&PV Code	ASTM	refractories per C27, C155, C401 & C612
ASME	Section V; Non Destructive Examination	NFPA	NFPA 70; National Electrical Code

Wind Design:		Seismic Design:	
Spec. or Standard	ASCE 7-10	Spec. or Standard	ASCE 7-10
Velocity/ Imp. Factor	120 mph / 1	Risk Cat./Imp. Factor	III / 1.25
Site Exposure	"C"		
Physical Design:		Site Design Basis:	
Plot Limitations	None	Site Elevation	750 ft AMSL
Tube Limitations	None	Stack Design Temp.	90 °F
Firebox Pressure	Positive; approximately +1.0 inH2O	FG Discharge Elev.	24 ft AG
Ambient Temp's	-20 °F Min/ 60 °F Dsn/ 110 °F Max	Area Classification	Unclassified

MAJOR SUBSYSTEMS & ACCESSORIES

Major Services & Subsystems		Major Accessories:	
Process Design	INCLUDED in base pricing	Casing/ Tube Seals	8 TubeSox; Radiant & Conv.
Mechanical Design	INCLUDED in base pricing	Observation Doors	2 4 in Dia. w/ H.T. glass
Structural Design	INCLUDED in base pricing	Observation Doors	1 4 in Dia. w/ HT glass on Arch
Radiant Section	INCLUDED in base pricing	Access Doors	1 Std 24" x 24"
Convection Section	INCLUDED in base pricing	Expansion Joints	None
Combustion Mgmt	INCLUDED in base pricing	Ladders & Platforms	Not Included
Burner Piping	INCLUDED in base pricing	L&P Coating	N/A
Forced Draft System	INCLUDED in base pricing		
Casing Penetrations		Pressure Part Penetrations	
Fbox Purge/ Snuff	None	Coil TSTC's, Radiant	None
CA Temp/Pres	None	Coil TSTC's, Convection	None
FG Temperature	2 1.5"NPS 3000# Coupling	Process TI conn's	3 1.5" NPS 300# RFWN
FG Pressure	2 1.5"NPS 3000# Coupling	Process PI conn's	1 1.5" NPS 300# RFWN
FG Comp. (Sample)	2 1.5"NPS 3000# Coupling	spare	
FG Sample	2 4"NPS 150# RFWN's	spare	
O2 Analyzer Port	None	spare	

Dampers			
Function	FD Fan (blower) qty = 0	Uptake Ducts	Stack qty = 0
Design	Note: Fan inlet damper is inappropriate for forced draft SHO's where O2 Control is provided by the CMS O2		Note: Stack Damper (which provides draft control) is inappropriate for forced draft SHO's where the combustion conditions are controlled real-time via the CMS.
Materials	Trim Module which controls the fan (blower) motor's VFD/ VSD.		
Bearings			
Operator			
Positioner			
Instruments			
Sootblowers:	Qty.	Type	Location
Lane 1:	None		
Lane 2:	None		

1	Owner:	Unknown	Owner Ref.:	H-781	Ftnt
2	Purchaser:	UOPR	Purch. Ref.:	J463	&
3	Manufacturer:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-266	Rev
4	SHO Model:	SHO1750	Location:	Unknown	

ASME SECTION VIII - DIVISION 1 CALCULATIONS for RADIANT COIL

Formulas:

$t_s =$	$\frac{(P \times R_i)}{(S \times J_E - 0.6 \times P)}$	or	$\frac{(P \times R_i)}{(2 \times S \times J_E + 0.4 \times P)}$	or	$\frac{(P \times R_o)}{(S \times J_E + 0.4 \times P)}$
	Circumferential Stress		Longitudinal Stress		Circumferential Stress

where:

t_s	Required / Minimum Stress Thickness	units	in	comments:	Excludes corrosion and/or erosion allowances
P	Design Pressure, per PO / Contract	psig			Per PO / Contract
R_o / R_i	Outside / Inside Radius of Tube	in			Calculated values for New Condition
S	Design (Max. Allowable) Stress @ T	psi			Per UG-23 / ASME Section II, Part D, Subpart 1
J_E	Joint Efficiency, per UW-12	%			TABLE UW-12; 100% seamless pipe/tube = 1.00

	units	Variable Values	Comments
23 Radiant Coil Design Basis:			
24 Design Pressure, P	psig	150	Design Pressure is per PO / Contract.
25 Design Temperatures, T.Dmax. / T.Dmin.	°F	515 / -20	T.Dmax per THM calcs / T.Dmin per PO / Contract
26 Design Allowances, Corrosion/ Erosion	in	0.063 / 0.000	Allowances (both CA & EA) are per PO / Contract
27 Design Stress @ Design Temp, S	psi	17,100	Design Stress @ T.Dmax
28 Pipe/Tube Outside Diameter	in	4.500	
29 Pipe/Tube Material Standard	ASME	SA106GrB	Max. Allowable Nonconcentricity, per ASTM: 12.50%
30 Pipe/Tube Type	welded or seamless	Seamless	
31 Butt Weld Inspection	RT or Other	100 of 100%	
32 Tube Schedule / New Avg. Wall	ASTM	SCH 40 / 0.237	Tube Inside Radius (R.i), New = 2.013
33 Actual Minimum Thickness, t.new / t.EOL	in	0.207 / 0.145	t.EOL = End of Life Thickness = t.new - (CA + EA)

UG-27 Calculations:	units	Variable Values	Comments
35 Circumferential Stress Calculations	---	1.00	Per UW-12, Longitudinal J_E of seamless pipe is 100%
36 UG-27(c) (1) Minimum Thickness, t.s	in	0.018	UG-27(c) (1)&(2) Thickness Check: 0.12 = OK!!
37 UG-27(c) (1) Surplus Wall Thickness	in	0.127	UG-27(c) (1) Pressure Limit Check: 6,584 = OK!!
38 UG-27(c) (1) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)
39 Longitudinal Stress Calculations	---	0.85	Per UW-12, Circumferential J_E of butt-welds is 85%
40 UG-27(c) (2) Minimum Thickness, t.s	in	0.010	UG-27(c) (2) Pressure Limit Check: 18,169 = OK!!
41 UG-27(c) (2) Surplus Wall Thickness	in	0.135	
42 UG-27(c) (2) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Appendix 1, Para.1-1 Calculations:	units	Variable Values	Comments
45 Circumferential Stress Calculations	---		Per UW-12, Longitudinal J_E of seamless pipe is 100%
46 Appendix 1 (1-1) (1) Min. Thickness, t.s	in		
47 Appendix 1 (1-1) (1) Surplus Thickness	in		
48 Appendix 1 (1-1) (1) Acceptability	---		Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

- Footnotes / Clarifications:**
- a) Fluxed coil (inside casing) & XOvers are per ASME Section VIII -Div.1; unfluxed manifolds are per ASME B31.3.
 - b) This design is per the 2015 Edition of Section VIII - Division 1 (UG-27 basis; not Appendix 1).
 - c) These calculations are "preliminary" until accepted by the Coil Manufacturer; whom provides the code stamp on the coil.
 - d) The different Design Temp's of Radiant and Convection coils reflect the heater's large process temp rise.
 - e) Per UG-11 & UG-44, the Pressure-Temperature ratings of standard components shall be per noted ASME/ANSI Stds.
 - f) Per UG-44, fittings per B16.9 & B16.11 shall be calculated as for straight seamless pipe per Section VIII - Division 1.
 - g) Per UCS-66, charpy impact testing for this coil is not mandatory (ref. FIG UCS-66, Curve B).
 - h) Work this data sheet with Heater Datasheets and General Arrangement Drawings (latest versions).
 - i) Mandatory Appendix 1 provides supplemental design formulas that MAY be substituted for UG-27(c) formulas.
 - j) spare

63				
64				
65				
66	1	13-Nov-17	Revised Purch. Ref. No. per Customer	JDC JDF
67	0	19-Aug-17	Issued for Approval	JF JDC
68	rev.	date	description	by app'v'd



CONFIDENTIAL
PROPERTY of ...
TULSA HEATERS MIDSTREAM LLC

project reference: American Engineering Standard (AES) Units

COIL UNDER INTERNAL PRESSURE	FLUXED HEATER COIL
ASME SECTION VIII - DIVISION 1 CALCS	MJ17-266-COIL.VIIIids-Rev. 1
	Pg 1 of 2

www.tulsaheatersmidstream.com u (918) 392-8000(vce) u TULSA HEATERS MIDSTREAM LLC u 1215 S. Boulder Ste 1040 u Tulsa, OK 74119 u

1	Owner:	Unknown	Owner Ref.:	H-781	Ftnt
2	Purchaser:	UOPR	Purch. Ref.:	J463	&
3	Manufacturer:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-266	Rev
4	SHO Model:	SHO1750	Location:	Unknown	

ASME SECTION VIII - DIVISION 1 CALCULATIONS for CONVECTION COIL

Formulas:

$t.s = \frac{(P \times R_i)}{(S \times J.E - 0.6 \times P)}$ Circumferential Stress	or	$\frac{(P \times R_i)}{(2 \times S \times J.E + 0.4 \times P)}$ Longitudinal Stress	or	$\frac{(P \times R_o)}{(S \times J.E + 0.4 \times P)}$ Circumferential Stress
---	----	---	----	---

where:

t.s	Required / Minimum Stress Thickness	in	Excludes corrosion and/or erosion allowances
P	Design Pressure, per PO / Contract	psig	Per PO / Contract
R _o / R _i	Outside / Inside Radius of Tube	in	Calculated values for New Condition
S	Design (Max. Allowable) Stress @ T	psi	Per UG-23 / ASME Section II, Part D, Subpart 1
J.E	Joint Efficiency, per UW-12	%	TABLE UW-12; 100% seamless pipe/tube = 1.00


Convection Coil Design Basis:	units	Variable Values	Comments
Design Pressure, P	psig	150	Design Pressure is per PO / Contract.
Design Temperatures, T.Dmax./ T.Dmin.	"F	611 / -20	T.Dmax per THM calcs / T.Dmin per PO / Contract
Design Allowances, Corrosion/ Erosion	in	0.063 / 0.000	Allowances (both CA & EA) are per PO / Contract.
Design Stress @ Design Temp, S	psi	17,100	Design Stress @ T.Dmax
Pipe/Tube Outside Diameter	in	4.500	
Pipe/Tube Material Standard	ASME	SA106GrB	Max. Allowable Nonconcentricity, per ASTM: 12.50%
Pipe/Tube Type	welded or seamless	Seamless	
Butt Weld Inspection	RT or Other	100 of 100%	
Tube Schedule / New Avg.Wall	ASTM	SCH 40 / 0.237	Tube Inside Radius (R _i), New = 2.013
Actual Minimum Thickness, t.new / t.EOL	in	0.207 / 0.145	t.EOL = End of Life Thickness = t.new - (CA + EA)

UG-27 Calculations:	---	Value	Comments
Circumferential Stress Calculations	---	1.00	Per UW-12, Longitudinal JE of seamless pipe is 100%
UG-27(c) (1) Minimum Thickness, t.s	in	0.018	UG-27(c) (1)&(2) Thickness Check: 0.12 = OK!!
UG-27(c) (1) Surplus Wall Thickness	in	0.127	UG-27(c) (1) Pressure Limit Check: 6,584 = OK!!
UG-27(c) (1) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)
Longitudinal Stress Calculations	---	0.85	Per UW-12, Circumferential JE of butt-welds is 85%
UG-27(c) (2) Minimum Thickness, t.s	in	0.010	UG-27(c) (2) Pressure Limit Check: 18,169 = OK!!
UG-27(c) (2) Surplus Wall Thickness	in	0.135	
UG-27(c) (2) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Appendix 1, Para.1-1 Calculations:	---	Value	Comments
Circumferential Stress Calculations:	---		Per UW-12, Longitudinal JE of seamless pipe is 100%
Appendix 1 (1-1) (1) Min. Thickness, t.s	in		
Appendix 1 (1-1) (1) Surplus Thickness	in		
Appendix 1 (1-1) (1) Acceptability	---		Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Footnotes / Clarifications:

- Fluxed coil (inside casing) & XOvers are per ASME Section VIII -Div.1; unfluxed manifolds are per ASME B31.3.
- This design is per the 2015 Edition of Section VIII - Division 1 (UG-27 basis; not Appendix 1).
- These calculations are "preliminary" until accepted by the Coil Manufacturer; whom provides the code stamp on the coil.
- The different Design Temp's of Radiant and Convection coils reflect the heater's large process temp rise.
- Per UG-11 & UG-44, the Pressure-Temperature ratings of standard components shall be per noted ASME/ANSI Stds.
- Per UG-44, fittings per B16.9 & B16.11 shall be calculated as for straight seamless pipe per Section VIII - Division 1.
- Per UCS-66, charpy impact testing for this coil is not mandatory (ref. FIG UCS-66, Curve B).
- Mandatory Appendix 1 provides supplemental design formulas that MAY be substituted for UG-27(c) formulas.
- These calculations are for the Convection Coil and for the Crossovers (between radiant and convection modules).
- spare

<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td>1</td> <td>13-Nov-17</td> <td>Revised Purch. Ref. No. per Customer</td> <td>JDC</td> <td>JDF</td> </tr> <tr> <td>0</td> <td>19-Aug-17</td> <td>Issued for Approval</td> <td>JF</td> <td>JDC</td> </tr> <tr> <td>rev.</td> <td>date</td> <td>description</td> <td>by</td> <td>app'v'd</td> </tr> </table> <p align="center">COIL UNDER INTERNAL PRESSURE ASME SECTION VIII - DIVISION 1 CALCS</p>	1	13-Nov-17	Revised Purch. Ref. No. per Customer	JDC	JDF	0	19-Aug-17	Issued for Approval	JF	JDC	rev.	date	description	by	app'v'd	 <p>CONFIDENTIAL PROPERTY of ... TULSA HEATERS MIDSTREAM LLC</p> <p>project reference: American Engineering Standard (AES) Units</p> <p>FLUXED HEATER COIL MJ17-266-COIL.VIIIids-Rev. 1 Pg 2 of 2</p>
1	13-Nov-17	Revised Purch. Ref. No. per Customer	JDC	JDF												
0	19-Aug-17	Issued for Approval	JF	JDC												
rev.	date	description	by	app'v'd												

info@tulsaheatersmidstream.com u (918) 392-8000(vce) u TULSA HEATERS MIDSTREAM LLC u 1215 S. Boulder Ste 1040 u Tulsa, OK 74119 u www.tulsaheatersmidstream.com

1							
2	Owner:	Unknown	Owner Ref.:	H-781			Frnt
3	Purchaser:	UOPR	Purch. Ref.:	J463			&
4	Heater Mfgr:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-266			Rev
5	Burner OEM:	Callidus Technologies, LLC	OEM Ref.:	9020130			
6	SHO Model:	SHO1750	Service:	Heat Medium Heater			
7	CMS Model:	CMS2500	Location:	Unknown @ 750 ft elevation			
8							

GENERAL DESIGN CONDITIONS

12	General Application:			
13	Service	---	Heat Medium Heater	Heat Medium Heater
14	Operating Case	---	Over-Design Case	Design Case
15	Burner Type		Enhanced IFGR	Enhanced IFGR
16	Burner Quantity	---	1	1
17	Model & Size:	---	CUBL-5W	CUBL-5W
18	Flame Shape	cylindrical or flat	Cylindrical	Cylindrical
19	Applicable Fuel(s)	---	Fuel Gases pg. 2	Fuel Gases pg. 2
20	Location(s) / Firing Direction		Endwall Center	Endwall Center
21	Firing Orientation		Horizontal	Horizontal
22	BridgeWall Temperature, calc.	°F	1,452	1,402


24	Heat Release Performance:			
25	Operating Case	---	Over-Design Case	Design Case
26	Max. Heat Release, per Burner	LHV Basis	22.30	20.04
27	Design Heat Release, per Burner	LHV Basis	20.28	18.22
28	Min. Heat Release, per Burner	LHV Basis	4.46	4.46
29	Turndown, minimum/ actual	max / min	5.00 / 5.00	5.00 / 5.00

33	Radiant Dimensions:		comments	ft / (in)	Flame Dimensions:		ft / (in)
34	Casing Width / Height, Casing	face - face		10.50 / (126)	Burner CL elev., approx.	AG	5.75 / (69)
35	Casing Length, Casing to Casing	face - face		22.00 / (264)	Flame Length, calc.	@ design HR	19.7 / (237)
36	Helical Coil CenterLine Diameter	CL - CL		9.00 / (108)	Flame Dia., calc.	@ design HR	3.50 / (42)
37	Helical Coil Inside Diameter	face - face		8.63 / (104)			
38	Serpentine Coil CtrLine Dimensions	W / H			Actual Clearances		ft / (in)
39	Serpentine Coil Inside Dimensions	face - face			Burner - tube (tangential)	CL / Net	4.50 / (54)
40	Firebox Length, Refractory Faces	face - face		21.17 / (254)			

42	Combustion Air (CA) Basis - All Fuel(s):			
43	CA Temperature, min.	-20 °F	FG Draft, at Bridgewall	0.60 inH2O (positive)
44	CA Temperature, design	60 °F	CA Pressure, at Burner	7.75 inH2O (positive)
45	CA Temperature, max.	110 °F	CA Pressure Drop, Design	7.10 inH2O
46	CA Pressure, Ambient	14.30 psia	CA Pressure Drop, Actual	t.b.q. inH2O
47	CA Humidity, Design	50% %RH		

49	Emissions -		---	Gaseous Fuel(s):	Liquid Fuel(s):	no
50	Design/ Guaranteed Emissions:	basis		3.0% O2, dry (LHV)		
51	NOx Emissions	LHV Basis	0.053	Lb/MMBTU		
52	SOx Emissions	LHV Basis	no quote	Lb/MMBTU		
53	CO Emissions	LHV Basis	0.041	Lb/MMBTU		
54	VOC Emissions	LHV Basis	0.019	Lb/MMBTU		
55	UHC Emissions	LHV Basis	0.007	Lb/MMBTU		
56	SPM10 Emissions	LHV Basis	0.014	Lb/MMBTU		
57	Noise Emissions	---	85	dBA @		

59						
60						
61						
62	Rev. 1	13-Nov-17	Revised Purchaser Ref. No. per Customer Comments	JDC	JF	
63	Rev. 0	19-Aug-17	Issued for Approval	JF	JDC	
64	revision	date	description	by	chk'd	appv'd

	BURNER DATA SHEET AES SYSTEMS of UNITS	
	MJ17-266-BRNRds-Rev. 1	Page 1 of 3

SHO = Superior Quality, Flexibility, Dependability & Modularity

This document contains confidential information, which is proprietary to THM. This document shall not be used, reproduced or disclosed without the prior written consent of THM.

GASEOUS FUEL(S) & PRODUCTS OF COMBUSTION

1					
2					
3	Fuel Gas Basis:	---	Gas 1	Mol.Wt.	
4	Operating Mode	---	Over-Design Case		
5	Temperature, at Burner	°F	100		
6	Pressure, at Burner (available)	psig	75		
7					
8	LHV (net HV), mass basis	AES units	20,426	BTU/ Lbm	
9	LHV (net HV), volume basis	AES units	976	BTU/ scf	
10					
11	HHV (gross HV), mass basis	AES units	22,613	BTU/ Lbr	
12	HHV (gross HV), volume basis	AES units	1,080	BTU/ scf	
13	Molecular Weight (mass)	all units	18.13	x/ x mole	
14					
15					
16					
17					
18					

19	Fuel Gas Composition(s):	symbol	MW	Gas 1	Mol.Wt.		
20		H2	2.02	0.00%	mole %		
21		O2	32.00	0.00%	mole %		
22		N2 + Ar	28.15	1.00%	mole %		
23		CO	28.01	0.00%	mole %		
24		CO2	44.01	1.00%	mole %		
25		CH4	16.04	88.00%	mole %		
26		C2H6	30.07	8.00%	mole %		
27		C2H4	28.05	0.00%	mole %		
28		C3H8	44.10	2.00%	mole %		
29		C3H6	42.08	0.00%	mole %		
30		C4H10	58.12	0.00%	mole %		
31		C4H8	56.11	0.00%	mole %		
32		C5H12	72.15	0.00%	mole %		
33		C5H10	70.13	0.00%	mole %		
34		C6+	86.18	0.00%	mole %		
35		H2S	34.08	0.00%	mole %		
36		SO2	64.06	0.00%	mole %		
37		NH3	17.09	0.00%	mole %		
38		H2O	18.02	0.00%	mole %		
39		spare		0.00%	mole %		
40							

41	Products of Combustion @ Design:		Gas 1	Mol.Wt.	
42	Excess Air Concentration	mole%	15%	mole%	
43	Temperature, PoC at Bridgewall	°F	1,452		
44	Temperature, PoC at Burner	°F	1,260		
45	Temperature, PoC Acid Dew Point	°F	151		
46					

47			<< ----- mass balance by TULSA HEATERS MIDSTREAM LLC ----- >>			
48	Combustion Mass Balances:	MW	Lbm/ hr			
49	Fuel Flow Rates	mass in	993			
50	Comb. Air Flow Rates	mass in	28.96	18,747		
51	POC Mass Flow Rates (wet)	mass out	27.89	19,739		
52	POC Mass Flow Rates (dry)	mass out	29.91	17,573		
53	POC Component Flow Rates ...	O2	32.00	564		
54		N2 + Ar	28.15	14,335		
55		CO2	44.01	2,671		
56		H2O	18.02	2,166		
57			<< ----- vapor / solid concentrations are in ppmvd / ppmd, resp. ----- >>			
58		NOx	46.01	1.08	40 ppm	
59		SOx	64.06	0.00	0 ppm	
60		CO	28.01	0.82	50 ppm	
61		VOC	44.10	0.39	15 ppm	
62		UHC	16.04	0.14	15 ppm	
63		SPM		0.28	16 ppm	
64						

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64

ADDITIONAL REQUIREMENTS

QA Requirements:

Performance Test @ shop --- Not Required
 CFD Model of Firebox --- None
 CFM of CA Ducting --- None
 Mill Certs, fuel wetted parts --- Not Required
 PMI, fuel wetted parts --- Not Required

Fuel Wetted Components:

Oil Gun Model --- None
 Gun Tip / Atomizer Mat'ls ASTM None / None
 Gas Risers Material ASTM t.b.d.
 Gas Manifolds Mat'l ASTM Carbon Steel

Burner Pilot:

model by O.E.M.
 Type --- Self-Inspiring
 Heat Release BTU/hr > 90,000
 Ignition Method man.or elec. Electric
 Pilot Fuel Gas --- Gas 1 Mol.Wt.
 Pilot Detection type or none None
 Fuel P, avail. @ pilot psig 10 (5 -15 is OK)

Connections:

Primary Fuel Gas sz & spec by OEM & 150# A105 RF
 Secondary Fuel Gas sz & spec None
 Fuel Oil sz & spec None
 Atomizing Media sz & spec None
 Pilot Gas sz & spec by OEM & 150# A105 RF
 Detector, Main Flame sz & spec None
 Detector, Pilot Flame sz & spec by OEM - UV Scanner Mount
 Sight Ports sz & spec None

Windbox or Plenum:

Individual windbox yes or no yes
 Material Description th x ASTM 12 ga. x A36
 Common Plenum Depth ft. none
 Refractory Description th x type 1.00 in x Min.Wool
 Refractory Anchors ASTM C.S. Expanded Metal
 Register Type none
 Register Material ASTM C.S.
 Leakage, guaranteed wt% < 5.0 % of Max HR Flow
 Actuation man., pneu.or elec. manual

APPLICABLE SPECIFICATIONS & STANDARDS

TULSA HEATERS MIDSTREAM LLC Specifications:

- a) Burner scope ...
 - 1) Pilot w/ Electric Ignition - Ignition Transformer is by others (CMS Supplier)
 - 2) UV Scanner is by others. Swivel scanner mount (by burner supplier) aimed at pilot and main flame when pilot off.
 - 3) Sight port(s) for viewing pilot and main flames.
- b) Burner shall have 5:1 turndown; this capability shall NOT compromise flame size or performance.
- c) External Coatings shall be as follows:

Prime:	3 mils dft IOZ (InOrganic Zinc) on SP-6 Surface
Intermediate:	None
Finish:	None
- d) Burner is mounted and fired horizontally. Tile to be shop mounted in 304 SS case.
- e) Even though job location/elevation is different, burner to be sized to range from sea level to 3500 ft and worst case air delta P reported.

1	Owner:	Unknown	Owner Ref.:	H-781	Fnt
2	Purchaser:	UOPR	Purch. Ref.:	J463	&
3	Heater OEM:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-266	Rev
4	CMS OEM:	International Custom Controls	CMS Model:	CMS2500	
5					
6					
7					
8	System Overview:				
9	Design Philosophy	Meet or Exceed NFPA 85 with packaged Combustion Management System			
10	Heater DHR	Heater Design Heat Release = 22 MMBTU/hr (LHV); ref. Burner Data Sheets for fuel composition			
11	CMS DHR	CMS Design Heat Release = 25 MMBTU/hr (LHV); ref. Burner Data Sheets for fuel composition			
12	No. of Burners	One Callidus CUBL-5W Burner per heater			
13					
14	THM Specs	Provided datasheets	Ambient P, Design	750 ft AMSL =	14.30 psia
15	THM P&ID	CMS2500 P&ID	Ambient T Range	-20 °F Minimum to 110 °F Maximum	
16	Area Classification	Unclassified	Noise Limit	85 dBA @ 3 ft	
17	Supply Power	120V / 1 ph / 60 Hz	Ind. Standard(s)	B31.3, NFPA 70 (NEC), NFPA 85	
18	Supply Air	80 psig	Customer Specs	None	
19					
20	Subsystem Design:				
21	Main Gas Train ³	Double Block & Bleed SDVs with ZSC's	Dsn P	Dsn T	NPS
22	Pilot Gas Train	Double Block & Bleed SDVs	150 psig	150°F	2"
23	Instrument Air Hdr		150 psig	150°F	1/2"
24	Main Oil Train	None	125 psig	150°F	1"
25	Atom. Media Train	None			
26	Local Panel (LCP)	NEMA 4 Enclosure for Controls, HMI, Pushbuttons & Lights			Z-Purge: No
27	Other Panel(s)	NEMA 7 Enclosure with 6kV Ignition Transformer & 7mm HiV IGN Cable			
28	Other Panel(s)	None			
29	Forced Draft Sys.	One FD Fan ¹ ; a) unlined ducting, b) CA controlled by	Damper		
30	Minimum Pre-Purge Interlocks:			Minimum Purge Interlocks:	
31	✓ Manual ESD Switch (pushbutton)	✓ Gas Supply Low Pressure		✓ Minimum CA Flow	
32	✓ SDVs FailSafe Positions	✓ Gas to Burner High Pressure			
33	✓ Stack High Temperature	- Firebox High Pressure			
34	✓ Process High Temperature	- Oil Supply Low Pressure			
35		- Atom. Media Low Pressure			
36					
37	Gas / Oil Trains Overview:		Local Panel Components Overview:		
38	✓ Pilot Double Block & Bleed SDVs		✓ Slate Control Package		
39	✓ Gas Train Dbl Block & Bleed SDVs		✓ Touchscreen HMI		
40	✓ Inlet Header Isolation Valve		- Remote Control Panel		
41	✓ Inlet Header Sediment Trap w/ Cap		- Field Wiring schematic to connect LCP to JIB		
42	✓ Inlet Header Gas Strainer		- LCP Weather/Sun Shield		
43	✓ Inlet Header Pressure Regulator				
44	- Inlet Header Relief Valve		Supporting Components:		
45	- Oil Train Dbl Block & Bleed SDVs		✓ Pilot Flame UV Detector	- O2 Analyzer	
46	- Atom. Media dP Controls		- Main Flame UV Detector	✓ Process TC (control loop)	
47	- Gas/ Oil Flow Element		✓ CA Ducting to Burner(s)	✓ Process TC (shutdown)	
48	- Comb. Air Flow Element		✓ Flex Hoses at Brnr Terminals	✓ Process Pressure Gauge ²	
49	- Min. Flow PCV in Parallel w/ TCV		- Individual Burner SDVs	✓ Stack TC	
50			✓ Fuel Train Only (no skid)	- Process Coil Relief	
51					
52					
53					
54	NOTES:				
55	1. Forced draft fan supplied by THM				
56	2. Process Pressure Gauge to be designed for 0-150 psig				
57	3. ZSC's only on block valves, not bleed.				
58	4. Piping 2" and below to use threaded fittings, except end connections.				
59	5. FAT required				
60					
61					
62	1	13-Nov-17	Rev'd Purch. Ref. No.	JDC	JF
63	0	19-Aug-17	Issued for Approval	JF	JDC
64	rev.	date	description	by	appv'd
COMBUSTION MANAGEMENT SYSTEM				CMS2500 DATA SHEET	
25 MMBTU/hr RATED HEAT RELEASE				MJ17-266-CMS2500ds- Rev. 1	
This document contains confidential and proprietary information, and IT SHALL NOT be used, reproduced or disclosed without the prior written consent of THM.					



Purch. Ref.: H-781

THM Ref.: MJ17-266

Process Interlocks:

	units	Tag No.	Factory Settings		Design Conditions		Comments
			Low	High	Min.	Design	
Process Flow	MLb/hr	FALL-300	105.1	None	116.2	267.8	---
		Action:	S/D @ minimum flow to avoid "short circuiting" one or more coil passes				
Process Temperature	°F	TSHH-202	None	355	---	305	355
		Action:	S/D @ maximum fluid temperature to avoid "overheating" the coil				

Heater Interlocks:

Stack Temperature	°F	TSHH-201	None	700	429	483	---
		Action:	S/D @ 700 F, which is indicative of an "out-of-control" fire in the heater				

CMS Interlocks:

FG Train Pressure	psig	PSLL-101	10	None	---	---	150
		Action:	S/D @ 10 psig, which is indicative of "inadequate" fuel gas supply				
FG Train Pressure	psig	PSHH-103	None	35	---	---	150
		Action:	S/D @ 35 psig, which is indicative of a "failure" of PCV-100 &/or FG supply				

FD Fan Interlocks:

FD Fan (blower) SP	inH2O	PSLL-107	0.20	None	0.47	7.8	11.8
FD Fan turndown:	5.0	Action:	S/D @ 0.2 inH2O, which is indicative of a FD Fan (blower) "failure".				

Other permissives/interlocks in BMS Operations Manual (block valves, FCV, and flame signal).

CMS CONTROL COMPONENTS

	units	Tag No.	Factory Settings		Design Conditions		Comments
			Low	High	Min.	Design	
Remote T Setpoint	°F	TY-700	0	999	---	305	355
		Action:	4 -20 mA input corresponds to a temperature setpoint range of 0 -999 °F				
Process Temperature	°F	TT-203	0	999	---	305	355
		Action:	4 -20 mA output corresponds to a process temperature range of 0 -999 °F				
Main Gas Regulator	psig	PCV-100	---	---	---	35	150
Pilot Gas Regulator	psig	PCV-105	---	---	---	10	150
Inst. Air Regulator	psig	PCV-107	---	---	---	80	150

CUSTOMER CONNECTIONS (TO DCS)

The following signals are sent to the customer's DCS from the control panel:

- Remote ESD
- Heater Run
- Low Process Flow
- High Stack Temperature
- High Process Temperature
- Burner Status

1	2	Owner: Unknown	Heater Ref.:	H-781	
	3	Purchaser: UOPR	Purch. Ref.:	J463	
	4	Heater Mfg: Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-266	Ftnt
	5	Location: Unknown	FDF OEM Ref.:	340829	&
	6	FD Fan OEM: Chicago Blower	FDF Item No.:	BL-781	Rev

9 **General Application:**

10 FD Fan(s) Design Basis mass.flow.% 115% of Design MASS Flows per API Standard 560

11 Location(s) --- @ Grade, adjacent to Burner Endwall (incorporated into Combustion Skid)

12 Area Classification NEC Unclassified

14 **AES Units**

	Heater Design	FDF Test Block
15 Process Design Conditions:		
16 Mass Flow Rate/ % Htr Design Lb/hr / kg/ hr	18,747 / 100%	21,560 / 115%
17 Volumetric Flow/ % Htr Design acfm / am3/ hr	4,300 / 100%	5,300 / 123%
18 Density, @ Suction as noted	0.074 Lb/ ft3	0.068 Lb/ ft3
19 Design Allowances, Temp./ SP °F / °C	--- / ---	130 °F / 152%
20 Temperature @ Min / Suction / Design °F / °C	-20 / 60	110
21 Static Pressure @ Suction as ntoed	-0.2 inH2O	-0.2 inH2O
22 Site Elevation/ Atm. P as ntoed	750 ftAMSL	14.30 psia
23 Static Pressure Rise (min./ guar.) inH2O	7.8 / 7.8	11.8 / 11.8
24 Fan Speed (allowable/ actual) RPM	3,600 / 3,525	3,600 / 3,525
25 Sound Pressure (allowable/ guar.) dBA	< 85 / < 85	< 85 / < 85
26 Relative Humidity %	50%	

27

28 **Fan Mechanical Design:** tag // OEM **BL-781 // CHICAGO BLOWER Corp.**

29 OEM Reference CMS // FD Fan International Custom Controls // 340829

30 OEM Model &/or Type-Size per OEM D/36A (SQAD)

31 Arrangement --- Arrangement 4 (direct drive)

32 Brake Power, Design/ Test Block (calc.) HP 15.0 / 20.0

33 Temperature, Mechanical Design °F 135 °F Mechanical Design

34 Casing Description / Materials --- "Square" pattern / CS

35 Rotor Description / Materials --- Airfoil Blades / CS

36 Shaft Description / Materials --- None - Arrangement 4

37 Bearings Description / Materials --- None - Arrangement 4

38 Noise Abatement Provisions / SPL --- 85 dBA

39 External Coatings / Surface Prep. --- OEM's Std Multiple Coat System

40 Purchase Specifications --- OEM's Std Industrial Quality Design

41

42 **Fan Control Design:** tag // OEM **VSD-781 / by OTHERS**

43 VFD Description --- by Others / Owner

44 VFD Rating ---

45 Damper Actuator Description ---

46 Damper Actuator Operation ---

47

48 **Fan Motor Design:** tag // OEM **BM-781 / TECO-WESTINGHOUSE**

49 OEM Model &/or Type-Size --- Catalog EP0202 / AEHH8N

50 VFD Service / speed range --- YES / 3 - 60 Hz or 180 - 3,600 rpm

51 Motor Type / Frame Size --- NEMA TEFC / 256T

52 Rated Power w/ SF @ Speed NEMA 20 HP w/ 1.15 SF @ 40°C

53 Nameplate Input Power V/ Hz/ ph 460V / 60 Hz / 3 ph


54 Typical Performance --- 91.0- 92.4 % FL Effy @ 92.5 % FL PF

55 Insulation Description --- Class F / B Rise

56 External Coatings & Surface Prep. --- OEM's Std Multiple Coat System

57 Purchase Specifications --- None

59					
60					
61					
62	Rev. 1	13-Nov-17	Revised Purchaser Ref. No. per Customer Comments	JDC	JF
63	Rev. 0	19-Aug-17	Issued for Approval	JF	JDC
65	revision	date	description	by	chk'd appv'd


 <p>USA Applications</p> <p>SHO = Superior Quality, Flexibility, Dependability & Modularity</p>	<p>FD FAN DATA SHEET</p> <p>AES & cgs or SI SYSTEMS of UNITS</p> <p>MJ17-266-FDFANds-Rev. 1</p>	<p>Page 1 of 1</p>
	<p><small>this document contains confidential information, which is proprietary to THM. This document shall not be used, reproduced or disclosed without the prior written consent of THM</small></p>	

Eclipse Winnox

Burners

Model WX0850

Version 2

Parameter		Specifications	
Blower Type		Packaged Blower	Remote Blower
Maximum Input, Btu/h (kW)¹	Chamber Pressure "w.c. (mbar)	Nominal (60Hz)	Pressure at Air Inlet 1.5 psig (100 mbar)
<i>For chamber pressures outside the given range or for varying chamber pressure conditions, contact Eclipse, Inc.</i>	-5.0 (-12.5)	9,700,000 (2840)	13,600,000 (3985)
	-3.0 (-7.5)	9,200,000 (2694)	13,200,000 (3868)
	0.0	8,500,000 (2490)	12,500,000 (3660)
	1.0 (2.5)	8,200,000 (2416)	12,200,000 (3575)
	2.0 (5.0)	7,980,000 (2337)	12,000,000 (3516)
Minimum Input, Btu/h (kW)	Natural Gas	500,000 (146)	500,000 (146)
<i>For lower inputs, contact Eclipse, Inc.</i>	Propane, Butane	600,000 (175)	600,000 (175)
Main Gas Inlet Pressure, "w.c. (mbar)²	Maximum	82 (207)	110 (273)
<i>Fuel pressure at ratio regulator inlet</i>	Minimum	27.7 (69)	55.4 (138)
Maximum Chamber Temperature, °F (°C)		Standard combustion tube: 1300 (704) High temperature combustion tube: 1400 (760) Refractory plug: 1800 (982) ³	
High Fire Visible Flame Length, inches (mm)	Alloy Tube	Flame is inside tube at all times.	
<i>Measured from the outlet end of the combustor</i>			
% Excess Air at High Fire		40% - 70%	
Piping		NPT or BSP/DN Flange connections available.	
Flame Detection		Flame rod or UV scanner.	
Fuels⁴		Natural gas, Propane, Butane	
<i>For any other mixed gas, contact Eclipse, Inc.</i>			
Blower Motor Power, Hp		15	-
Weight, lbs (kg)⁵		1435 (651)	1135 (515)
Approvals			

¹ Maximum inputs for packaged blower versions are given for the standard combustion air blower without an inlet air filter.

² For proper performance, this pressure must be kept constant across the burner operating range.

³ See page 3 of this datasheet and the "Refractory Plug" section of Installation Guide 111.

⁴ See Design Guide 111 for more information about typical fuel composition and properties.



⁵ All weights are approximate.

- All inputs are based on gross calorific values and standard conditions: one atmosphere, 70°F (21°C).

- All information is based on laboratory testing. Different chamber size and conditions will affect data.

- Eclipse reserves the right to change the construction and/or configurations of our products at any time without being obliged to adjust earlier supplies accordingly.

Performance Graphs



Fuel/Input Measurement

System design must include fuel flow measurement upstream of the burner. Eclipse recommends its 12-5 FOM (Fuel Orifice Meter) assembly number 302050-5 for natural gas. See Bulletin 930 for details.

Secondary By-Pass Fuel Setting:

Fuel	ΔP "w.c. (mbar)*
Natural Gas	4.0 (10.0)
Propane	4.0 (10.0)
Butane	4.0 (10.0)

*Measured between Tap "E" and the chamber @ low fire.

NOTE: Input at low fire changes with ratio regulator adjustment.


NO_x emission data is given for:

- Ambient combustion air (~70°F, 21°C)
- Less than 1000°F (540°C) firing chamber
- Minimal process air velocity
- Low fire input adjusted to 500,000 BTU/hr (88 kW)
- Neutral chamber pressure

Emissions are influenced by:

- Chamber conditions
- Fuel type
- Firing rate
- Ratio regulator adjustments
- Combustion air temperature
- Excess air

CO emission is largely influenced by chamber conditions. Contact your local Eclipse representative for an estimate of CO emission on your application.





Burner Data Sheet

FBC CONTRACT NUMBER:	15018
PURCHASER:	Heatec
PURCHASE ORDER NUMBER:	T3174F
USER:	UOP Russell
LOCATION:	Unknown
SCOPE OF EQUIPMENT:	1-WB-16-SG Low Nox "Bare" Package Burner for firing NG in a Heatec horizontally fired heater. Same as Faber 15010 & Heatec 14-148
NUMBER OF UNITS:	1
INSURANCE:	NFPA 87, IRI, FM
SPECIFICATION:	Faber Burner Company Proposal #7415106-1 dated April 21, 2015
PROJECT ENGINEER:	KRP
REVISION:	00
REVISION DATE:	
DATE ISSUED:	4/30/2015

JOB SPECIFICATIONS:

A. PROCESS HEATER DATA

MANUFACTURER:	HEATEC
MODEL:	8010-40D
FURNACE DIMENSIONS:	70" Dia x 237" L
HEAT INPUT:	23.65 MMBTU/HR AT 100% MCR
FLUID TEMPERATURE:	305 °F
FURNACE PRESSURE:	1.00 INWC WITHOUT FGR

B. SITE CONDITIONS:

ELEVATION:	1,300	FASL
LOCATION:	UNKNOWN	
TYPE:	OUTDOOR	
MAXIMUM AMBIENT TEMPERATURE:	110	°F
ELECTRICAL NEMA RATING:	4	
AREA CLASSIFICATION:	NOT CLASSIFIED	

C. UTILITIES:

FAN / INPUT POWER:	480 VOLTS, 3 PHASE, 60 HZ. 27 FLA REQUIRED.
CONTROL / INSTRUMENT POWER:	120 VOLTS, 1 PHASE, 60 HERTZ

D. CONTROL DATA:

BURNER MANAGEMENT SYSTEM PROVIDED BY:	OTHERS
BURNER MANAGEMENT SYSTEM:	FIREYE
COMBUSTION CONTROL SYSTEM PROVIDED BY:	OTHERS
COMBUSTION CONTROL SYSTEM:	UNKNOWN
TYPE OF CONTROL:	PARALLEL POSITIONING
NOTES:	HEATEC TO PROVIDE WEY-5000 ACTUATORS FOR MOUNTING

E. FORCED DRAFT FAN DESIGN DATA:

MAXIMUM COMBUSTION AIR REQUIRED:	6,625	ACFM	22,845 LB/HR
COMBUSTION AIR TEMPERATURE:	110	°F	
MAXIMUM FD FAN OUTLET PRESSURE:	7.0	INWC	

F. BURNER DATA

MAXIMUM BURNER PRESSURE DROP:	3.3	INWC	
TOTAL STACK GAS FLOW AT MCL - NATURAL GAS:	5,085	ACFM	23,930 LB/HR

G. MAIN GAS DATA:

MAIN GAS TYPE:	NATURAL GAS		
HEATING VALUE:	1,000	BTU/SCF	
SPECIFIC GRAVITY (AIR = 1.00):	0.60		
GAS TEMPERATURE:	60	°F	
ALL VALUES BELOW ARE AT MCR			
DESIGN HEAT INPUT:	23.65	MMBTU/HR	
GAS FLOW RATE:	23,650	SCFH	
DESIGN EXCESS AIR TO BURNER:	32	%	
FRESH AIR TO BURNER:	22,845	LB/HR	
DESIGN TURNDOWN:	7:1		
BURNER DRAFT LOSS:	3.3	INWC	
PRESSURE AT BURNER:	MAIN	4.8 PSIG	
	STAGED	6.0 PSIG	
SUPPLY PRESSURE REGULATED BY:	OTHERS		
GAS PRESSURE AVAILABLE:	20.0	PSIG	

H. GAS COMPOSITION:

	% BY VOLUME
METHANE	90.00
ETHANE	5.00
CARBON DIOXIDE	0.00
NITROGEN	5.00

I. PILOT GAS FUEL DATA:

PRIMARY PILOT FUEL:	NATURAL GAS	
HEAT INPUT:	0.63	MMBTU/HR
FUEL FLOW:	630	SCFH
PRESSURE AT IGNITOR:	1.0	PSIG
SUPPLY PRESSURE REGULATED BY:	OTHERS	
SUPPLY PRESSURE TO PILOT:	1-2	PSIG

J. EMISSION GUARANTEES:

NOT TO EXCEED:

NATURAL GAS:

NOX

40

PPM

0.048

LB/MMBTU

CO

50

PPM

0.037

LB/MMBTU

EMISSION TEST CONDITIONS

FOR A VALID GUARANTEE TEST, THE FOLLOWING CONDITIONS MUST BE MET:

1. Emission guarantees are based upon the data in the design conditions above and are for the firing of natural gas only.
2. Guarantees are from 25% to 100% heater MCR (maximum continuous rating) only.
3. Heater meets (min.) construction requirements for furnace sidewall integrity and seals at the drums and front wall. CO emission stated above is provided furnace leakage (bypassing of flue gas) does not contribute more than .015 lb/MMBTU to the total CO emissions.
4. Emission guarantees exclude background emissions present in the air or fuel used for combustion.
5. Samples for VOC test will be taken at the rear of the furnace only.
6. FABER field service must do the initial burner adjustments and must be present during testing for optimization of the equipment supplied.
7. Emission testing must be conducted within the warranty period. Upon obtaining the guaranteed emissions, as described above, the equipment shall be considered accepted.

K. LIMIT SWITCH SETPOINTS:

		TRIP SETPOINT		DIRECTION
FDP	FAN DIFFERENTIAL PRESSURE	FIELD SET		DECREASING
HSP	HIGH SUCTION PRESSURE	FIELD SET		INCREASING
LFA	LOW FIRE AIR	7	%	FIELD SET AS REQ'D
LFG-1	LOW FIRE MAIN GAS	10	%	FIELD SET AS REQ'D
LFG-2	LOW FIRE STAGED GAS	10	%	FIELD SET AS REQ'D

L. TORQUE REQUIREMENTS

GVA-1	MAIN GAS VALVE ACTUATOR	20 in-lb
GVA-2	STAGED GAS VALVE ACTUATOR	65 in-lb
ADA	AIR DAMPER ACTUATOR	241 in-lb

M. PAINTING SPECIFICATION:

PREPARATION:

EXTERNAL STEEL	SSPC-SP3
PIPING / FITTINGS	SSPC-SP1
ELECTRICAL PANELS	MANUFACTURER'S STANDARD
INSTRUMENTS	MANUFACTURER'S STANDARD
CONDUIT	MANUFACTURER'S STANDARD

PRIMER AND PAINT:

ALL UNPRIMED COMPONENTS ARE PRIMED WITH (1) ONE COAT OF PRIMER.
ALL UNPAINTED COMPONENTS ARE PAINTED WITH (2) TWO COATS OF STEEL-IT
STEEL-IT IS INDUSTRIAL GRADE STAINLESS STEEL IMPREGNATED URETHANE BASED PAINT.

N. SPECIFICATION FOR PIPING AND FITTINGS:

WELDING: STANDARD

MAIN GAS TRAIN: SCHEDULE 40 ASTM A 106 GRADE B PIPE WITH CLASS 3000 FITTINGS.
PILOT GAS TRAIN: 1/2" NPT STAINLESS STEEL FLEX HOSE
SWITCHES AND GAUGES: 3/8" STAINLESS STEEL TUBING WITH STAINLESS STEEL TUBE FITTINGS.

O. SUBMITTAL DOCUMENTATION

DOCUMENT FORMAT:	ELECTRONIC
NUMBER OF DRAWING SETS:	1
NUMBER OF DATA SHEETS:	1
MECHANICAL BILL OF MATERIAL:	1
FAN CURVE:	1
MOTOR DATA SHEETS:	1
DWG DRAWINGS ON THE WEBSITE:	1
STEP FILE ON THE WEBSITE:	1
NOTES: FOR INFORMATION ONLY. RELEASE WITH ORDER. SAME AS FABER 15010	

P. AS-BUILT DOCUMENTATION

DOCUMENT FORMAT:	HARDCOPY AND ELECTRONIC
NUMBER OF DRAWING SETS:	2
NUMBER OF DATA SHEETS:	2
NUMBER OF O&M MANUALS:	2
DRAWING SIZE:	B
MECHANICAL BILL OF MATERIAL:	2
DWG DRAWINGS ON THE WEBSITE:	1
STEP FILE ON THE WEBSITE:	1
CD:	1

Q. JOB DRAWINGS

BURNER GENERAL ARRANGEMENT:	25-01-01-01
BURNER THROAT INSTALLATION DETAIL:	25-01-01-10
PIPING SCHEMATIC:	25-60-01-01

1				
2	Owner:	Unknown	Owner Ref.:	H-741
3	Purchaser:	UOPR	Purchaser Ref.:	J463
4	Manufacturer:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-265
5	Service:	Regen Gas Heater	Project:	200 MMscfd Cryo Plant
6	Quantity:	1	Location:	Unknown
7	SHO Duty:	7.29 MMBTU/ hr	SHO Model:	SHO500
8	CMS Release:	9.20 MMBTU/ hr	CMS Model:	CMS1500
9				
10				

PROCESS DESIGN CONDITIONS

14	Heater Section	---	Radiant / Convection	Radiant / Convection		
15	Operating Case	---	Over-Design Case	Design Case		
16	Service	---	Regen Gas Heater	Regen Gas Heater		
17	Heat Absorption (R/C)	MMBTU/ hr	4.36 / 2.93	3.52 / 2.08		
18	Process Fluid	---	Gas	Gas		
19	Process Mass Flow Rate, Total	Lb/ hr	22,924	20,840		
20	Process Bulk Velocity (calc. R/C)	ft/ s	42 / 21	39 / 19		
21	Process Mass Velocity (calc. R/C)	Lb/ s ft2	80 / 80	73 / 73		
22	Coking Allowance (dP calcs)	in				
23	Pressure Drop, Clean (allow. / calc.)	psi	10 / 7	10 / 6		
24	Pressure Drop, Fouled (allow. / calc.)	psi				
25	Average Heat Flux (allowable)	BTU/ hr ft2	13,000	13,000		
26	Average Heat Flux (calculated)	BTU/ hr ft2	15,410	12,460		
27	Maximum Heat Flux (allowable)	BTU/ hr ft2				
28	Maximum Heat Flux (calc. R/C)	BTU/ hr ft2	27,400 / 31,140	22,200 / 23,990		
29	Fouling Factor, Internal	hr ft2 °F/ BTU	0.001	0.001		
30	Corrosion or Erosion Characteristics	---				
31	Max. Film Temperature (allow. / calc.)	°F	650 / 669	650 / 654		
32						
33	Inlet Conditions:					
34	Temperature	°F	75	135		
35	Pressure	psig	934	934		
36	Mass Flow Rate, Liquid	Lb/ hr	0	0		
37	Mass Flow Rate, Vapor	Lb/ hr	22,924	20,840		
38	Weight Percent, Liquid / Vapor	wt%	0% / 100%	0% / 100%		
39	Density, Liquid / Vapor	Lb/ ft3	0.00 / 3.82	0.00 / 3.82		
40	Molecular Weight, Liquid / Vapor	Lb/ Lbmole	--- / 21.6	--- / 21.6		
41	Viscosity, Liquid / Vapor	cp	0.0001 / 0.014	0.001 / 0.014		
42	Specific Heat, Liquid / Vapor	BTU/ Lb °F	0 / 0.617	0.000 / 0.617		
43	Thermal Conductivity, Liq./Vap.	BTU/hr ft °F	0 / 0.023	0.000 / 0.023		
44						
45	Outlet Conditions:					
46	Temperature	°F	550	550		
47	Pressure	psig	928	929		
48	Mass Flow Rate, Liquid	Lb/ hr	0	0		
49	Mass Flow Rate, Vapor	Lb/ hr	22,924	20,840		
50	Weight Percent, Liquid / Vapor	wt%	0% / 100%	0% / 100%		
51	Density, Liquid / Vapor	Lb/ ft3	0.00 / 1.88	0.00 / 1.88		
52	Molecular Weight, Liquid / Vapor	Lb/ Lbmole	--- / 21.6	--- / 21.6		
53	Viscosity, Liquid / Vapor	cp	0.000 / 0.020	0.0001 / 0.020		
54	Specific Heat, Liquid / Vapor	BTU/ Lb °F	0.000 / 0.719	0 / 0.719		
55	Thermal Conductivity, Liq./Vap.	BTU/hr ft °F	0.000 / 0.042	0 / 0.042		
56						

57					
58					
59					
60					
61					
62	Rev. 1	13-Nov-17	Revised Purchaser Ref. No. per Customer Comments	JDC	JF
63	Rev. 0	19-Aug-17	Issued for Approval	JF	JDC
64	revision	date	description	by	chk'd app'v'd



USA Applications

SHO = Superior Quality, Flexibility, Dependability & Modularity

FIRED HEATER DATA SHEET
AMERICAN ENGINEERING SYSTEM of UNITS

MJ17-265-HTRds- Rev. 1 Pg 1 of 6

This document contains confidential information proprietary to THM. This document shall not be used, reproduced or disclosed without the prior written consent of THM.

COMBUSTION DESIGN CONDITIONS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64

Overall Performance:				
Operating Case	---	Over-Design Case	Design Case	
Service	---	Regen Gas Heater	Regen Gas Heater	
Excess Air	mol%	15.0%	15.0%	
Calculated Heat Release (LHV)	MMBTU/ hr	8.37	6.30	
Guaranteed Efficiency	HR%	83.1%	85.0%	
Calculated Efficiency	HR%	87.1%	89.0%	
Radiation Loss	HR%	3.00%	3.00%	
Flow Rate, Combustion Gen./ Imp.	Lb/ hr	8,145	6,130	
Flue Gas Temp. Leaving (R/C)	°F	1,649 / 447	1,526 / 377	
Flue Gas Mass Velocity	Lb/ sec ft2	0.260	0.196	

Fuel(s) Data:	Gas 1	Burner Design:	
	Mol.Wt.	OEM	--- Callidus Technologies, LLC
LHV	BTU/ scf	Type	--- Enhanced IFGR ULTRA Low NOx
LHV	BTU/ Lb	Quantities	--- 1 Burner
P @ Burner	psig	Model No.	--- CUBL-3W Cylindrical
T @ Burner	°F	Windbox	--- yes ...
MW	Lb/ Lbmole	Location	--- EndWall Center ... Horizontally Fired
m @ ??? °F	cp	Pilot Design:	
m @ ??? °F	cp	Type / Model	Self-Inspiring / by O.E.M.
Atomizing Media	---	Ignition	--- Electric requires elec.ign.system
Atom. Media P & T	---	Heat Release	> 90000 BTU/ hr on ... Gas 1

Components:		Burner Performance:	
N	wt%	Minimum Heat Release	MMBTU/ hr 1.84
S	wt%	Design Heat Release	MMBTU/ hr 8.37
Ash	wt%	Maximum Heat Release	MMBTU/ hr 9.20
Ni	ppm	Burner Turndown	Max:Min 5.00
Va	ppm	Volumetric Ht. Release	BTU/ hr ft3 17,106
Na	ppm	Pressure @ Arch	inH2O 0.50
Fe	ppm	Pressure @ Burner	inH2O 7.64
		Combustion Air T @ Burner	°F 60
		Flue Gas T @ Burner	°F 1,450

		Guaranteed Emissions:	
H2	mol%	Basis of Guarantee	--- 3.0% O2, dry (LHV)
O2	mol%	NOx Emissions	Lb/MMBTU 0.053 40 ppm
N2 + Ar	mol%	SOx Emissions	Lb/MMBTU no quote
CO	mol%	CO Emissions	Lb/MMBTU 0.041 50 ppm
CO2	mol%	VOC Emissions	Lb/MMBTU 0.019 15 ppm
CH4	mol%	UHC Emissions	Lb/MMBTU 0.007 15 ppm
C2H6	mol%	SPM10 Emissions	Lb/MMBTU 0.014 16 ppm
C2H4	mol%	Noise Emissions	dBA @ 3ft 85
C3H8	mol%		
C3H6	mol%		
C4H10	mol%		
C4H8	mol%		
C5H12	mol%		

		Net Flame Clearances:	
C5H10	mol%	Est. Flame Size	approx. 10.9 ft L x 2.5 ft Diameter
C6+	mol%	Hor Clearance	0.75 ft NET Tube Clearance
H2S	ppmv	Vert. Clearance	0.75 ft NET Tube Clearance
SO2	mol%	Axial Clearance	-1.77 ft NET Refractory Clearance (to Arch hot face)
NH3	mol%		
H2O	mol%		

		Nominal Flame Clearances:	
spare	mol%	from burner CL ...	Vertical Horizontal
		to Tube CL, API	ft 5.70 3.80
		to Tube CL, calc.	ft 3.25 3.25
		to Refrac., calc.	ft n / a 9.17

Blower/Fan Performance:		
Volumetric Flow	acfm	1,800
Rated Power	HP	10
Fan Speed	RPM	3,600
Sound Pressure	dBA	< 85
Area Classification	NEC	Unclassified

PRESSURE PARTS DESIGN

1				
2				
3	Coil Design:		<u>RADIANT</u>	<u>SHIELD</u>
4	Service		<u>Regen Gas Heater</u>	<u>Regen Gas Heater</u>
5	Design Basis for Tube Temperature		<u>API 530</u>	<u>API 530</u>
6	Design Basis for Tube Wall Thickness		<u>ASME Sec. VIII-1</u>	<u>ASME Sec. VIII-1</u>
7	Design Life	hr	<u>100,000</u>	<u>100,000</u>
8	Design Pressure (elastic / rupture)	psig	<u>1,095 /</u>	<u>1,095 /</u>
9	Design Fluid Temperature	°F	<u>550</u>	<u>550</u>
10	Design Temperature Allowance	°F	<u>29</u>	<u>29</u>
11	Design Corrosion Allowance (tubes/fittings)	in	<u>0.0625 / 0.0625</u>	<u>0.0625 / 0.0625</u>
12				
13	Maximum Tube Temperature (clean)	°F	<u>702</u>	
14	Maximum Tube Temperature (fouled)	°F	<u>734</u>	<u>475</u>
15	Design Tube Temperature	°F	<u>763</u>	<u>650</u>
16	Inside Film Coefficient	BTU/ hr ft ² °F	<u>271</u>	<u>233</u>
17	Weld Inspection	RT or Other	<u>100 of 100%</u>	<u>100 of 100%</u>
18	Weld Heat Treatment	s.rel., t.stab. or none	<u>None</u>	<u>None</u>
19	Hydrostatic Test Pressure	psig	<u>per API</u>	<u>per API</u>
20				
21	Coil Arrangement:		<u>Horizontal</u>	<u>Horizontal</u>
22	Coil Type	---	<u>Helical</u>	<u>Serpentine</u>
23	Tube Material (pipe or tube spec)	ASTM	<u>SA106GrB</u>	<u>SA106GrB</u>
24	Supplementary Mfg Requirements	ASTM	<u>None</u>	<u>None</u>
25	Tube Outside Diameter	in	<u>4.500</u>	<u>4.500</u>
26	Tube Wall Thickness (aw / mw)	in	<u>0.337 / 0.295</u>	<u>0.337 / 0.295</u>
27	Number of Cells (radiant or convection)	---	<u>1</u>	<u>1</u>
28	Number of Flow Passes (total / cell)	---	<u>1 / 1</u>	<u>1 / 1</u>
29	Number of Tubes per Row (total / cell)	---	<u>4 / 4</u>	<u>4 / 4</u>
30	Overall Tube (1 turn in radiant) Length	ft	<u>20.42</u>	<u>9.04</u>
31	Effective Tube Length / Helix Diameter	ft	<u>20.42 / 6.50</u>	<u>7.46</u>
32	Number of Turns or Tubes (total / pass)		<u>11.8 / 11.8</u>	<u>4.0 / 4.0</u>
33	Total Exposed Surface	ft ²	<u>283</u>	<u>0</u>
34	Number of Ext.Surf. Tubes (total / cell)	---	<u>0 / 0.0</u>	<u>0 / 0.0</u>
35	Total Exposed Surface	ft ²	<u>0</u>	<u>1,309</u>
36	Tube Spacing (horiz. / tube centers)	in	<u>--- / 8.00</u>	<u>8.00 / 8.00</u>
37	Tube Spacing (horiz. to refractory)	in	<u>6.00</u>	<u>4.00</u>
38				
39	Coil Fittings:		<u>Regen Gas Heater</u>	<u>Regen Gas Heater</u>
40	Fitting Type	---	<u>SR 90° Elbows</u>	<u>SR 180° U-Bends</u>
41	Fitting Material	ASTM	<u>SA234 WPB</u>	<u>SA234 WPB</u>
42	Supplementary Mfg Requirements	ASTM	<u>None</u>	<u>None</u>
43	Fitting Outside Diameter	in	<u>4.500</u>	<u>4.500</u>
44	Fitting Wall Thickness (aw / mw)	in	<u>0.337 / 0.295</u>	<u>0.337 / 0.295</u>
45	Fitting Location	internal or external	<u>Internal</u>	<u>External</u>
46	Tube Attachment	welded or rolled	<u>Welded</u>	<u>Welded</u>
47				
48	Coil Terminals:		<u>Outlet</u>	<u>Inlet</u>
49	Terminal Type	beveled or flanged	<u>Flanged</u>	<u>Flanged</u>
50	Flange Material	ASTM	<u>SA105</u>	<u>SA105</u>
51	Supplementary Mfg Requirements	ASTM	<u>None</u>	<u>None</u>
52	Flange Size and Rating	NPS/ ASME	<u>4" NPS / 900#</u>	<u>4" NPS / 900#</u>
53	Flange Type	RFWN or RTJ	<u>RFWN</u>	<u>RFWN</u>
54	Location	---	<u>Burner Endwall</u>	<u>Terminal End</u>
55				
56	Extended Surface:		<u>CONVECTION</u>	<u>CONVECTION</u>
57	Service	---	<u>Regen Gas Heater</u>	<u>Regen Gas Heater</u>
58	Fin or Stud Row Number	starting @ bottom	<u>No.1 / No.2-3</u>	
59	Ext. Surface Type	seg.fins, solid fins, studs	<u>HF Seg. Fins</u>	
60	Fin/Stud Material	---	<u>C.S. / C.S.</u>	
61	Fin/Stud Height	in	<u>1.00 / 1.00</u>	
62	Fin/Stud Thickness	in	<u>0.06 / 0.06</u>	
63	Fin/Stud Density	fin/ in	<u>4.00 / 5.00</u>	
64				

PRESSURE PARTS DESIGN (continued)

1				
2				
3	Crossovers:		<u>RADIANT</u>	<u>SHIELD</u>
4	Type, location / connections	---	<u>External</u>	<u>Flanged</u>
5	Tube / Fittings Material	ASTM	<u>SA106GrB</u>	<u>SA234 WPB</u>
6	Tube & Fitting OD / Thickness (aw)	in	<u>4.500</u>	<u>0.337</u>
7				
8	Inlet Manifold(s):	type		<u>N/A</u>
9	Location	---		
10	Design Basis for Manifold Thickness	---		
11	Design Conditions (temp./press.)	°F/ psig		
12	Pipe Material	ASTM		
13	Fittings Material	ASTM		
14	Flange Material / Style	ASTM		
15	Outside Diameters, each Branch	in		
16	Wall Thickness(es); aw or mw	in		
17	End Types (terminal/ dead)	beveled or flanged		
18	Manifold Terminal Type	NPS/ ASME		
19	Coil Connection Type	extrusion, olet, etc.		
20	Coil Terminal Type	NPS/ ASME		
21				
22	Outlet Manifold(s):	type	<u>N/A</u>	
23	Location	---		
24	Design Basis for Manifold Thickness	---		
25	Design Conditions (temp./press.)	°F/ psig		
26	Pipe Material	ASTM		
27	Fittings Material	ASTM		
28	Flange Material / Style	ASTM		
29	Outside Diameters, each Branch	in		
30	Wall Thickness(es); aw or mw	in		
31	End Types (terminal/ dead)	beveled or flanged		
32	Manifold Terminal Type	NPS/ ASME		
33	Coil Connection Type	extrusion, olet, etc.		
34	Coil Terminal Type	NPS/ ASME		
35				

COIL & MANIFOLD SUPPORTS DESIGN

36				
37				
38				
39	Tube Supports:		<u>RADIANT</u>	<u>SHIELD</u>
40	Service		<u>Regen Gas Heater</u>	<u>Regen Gas Heater</u>
41	Location	Top, Bottom, Ends	<u>Bottom</u>	<u>Ends</u>
42	Support Type	casting, tubesht, spring, etc.	<u>SS Pipe Rail</u>	<u>Welded Tbsheets</u>
43	Support Thicknesses	in	<u>SCH40</u>	<u>0.375</u>
44	Support Materials	ASTM	<u>A240 T304</u>	<u>A36 CS</u>
45	Support Temperatures (calc./ design)	°F / °F	<u>1,130 / 1,310</u>	<u>612 / 770</u>
46	TbSht Ferrules Thickness/Materials	in/ ASTM	<u>---</u>	<u>14 ga. / 304 SS</u>
47	Refractory & Anchor Materials & Types		<u>none</u>	<u>per refrac. section</u>
48				
49	Intermediate Guides & Supports:		<u>None</u>	<u>None</u>
50	Location	---		
51	Guide/ Support Type	casting, spring, etc.		
52	Material	ASTM		
53	Spacing, average	ft		
54				
55	Tube Guides:	Top, Bottom, Ends	<u>None</u>	<u>None</u>
56	Material	ASTM		
57				
58	Manifold Supports:		<u>Outlet Manifold</u>	<u>Intlet Manifold</u>
59	Material	ASTM	<u>A36</u>	<u>N/A</u>
60	Materials Design & Supply	---	<u>by THM</u>	
61	Location	Top, Bottom, Ends		
62	Support Type	roller, shoe, spring, etc.	<u>Simple Shelf</u>	
63	Number of Supports	---	<u>One (1)</u>	
64				

CASING / REFRACTORY SYSTEMS DESIGN

1				
2				
3				
4	Radiant Section Design:	BURNER	SHIELDED	ARCH
5	Total Refractory Thickness	ENDWALL	SIDEWALLS	ENDWALL
6	Hot Face Temperature (design)	in 5.0	3.0	5.0
7	Hot Face Temperature (calculated)	°F 2,000	2,000	2,000
8	Hot Face Layer	°F 1,649	1,130	1,649
9	Back-Up Layer No.1	in/ --- 1/ 8# CF Blanket	1/ 8# CF Blanket	1/ 8# CF Blanket
10	Back-Up Layer No.2	in/ --- 1/ 8# CF Blanket	2/ 6# CF Blanket	1/ 8# CF Blanket
11	Foil Vapor Barrier	in/ --- 3/ 6# CF Blanket	None	3/ 6# CF Blanket
12	Castable Reinforcement (SS Needles)	in/ --- None	None	None
13	Anchors / Tie Backs:	wt% None	None	None
14	Material	--- Pins & Clips	Pins & Clips	Pins & Clips
15	Attachment	--- 310 S.S.	304 S.S.	310 S.S.
16	Casing:	--- Welded	Welded	Welded
17	Material	in/ ASTM 0.1875 / A36	0.1345 / A36	0.1875 / A36
18	Internal Coating	--- None	None	None
19	External Temperature, Typical	°F 180	180	180
20	Comments / Clarifications	--- w/ cfb wraps	w/o cfb wraps	w/ cfb wraps
21		SHOP Installed	SHOP Installed	SHOP Installed
22				
23		SIDEWALLS	ENDWALLS	
24	Convection Section Design:	SHIELD	FINNED	TUBESHEETS
25	Total Refractory Thickness	in 3.0	3.0	3.0
26	Hot Face Temperature (design)	°F 2,000	2,000	2,200
27	Hot Face Temperature (calculated)	°F 1,048	1,048	1,048
28	Hot Face Layer	in/ --- 1/ 8# CF Blanket	1/ 8# CF Blanket	3/ Sparlite HS
29	Back-Up Layer No.1	in/ --- 2/ 6# CF Blanket	2/ 6# CF Blanket	None
30	Back-Up Layer No.2	in/ --- None	None	None
31	Foil Vapor Barrier	in/ --- None	None	None
32	Castable Reinforcement (SS Needles)	wt% None	None	None
33	Anchors / Tie Backs:	--- Pins & Clips	Pins & Clips	Bullhorns
34	Material	--- 310 S.S.	304 S.S.	304 S.S.
35	Attachment	--- Welded	Welded	Welded
36	Casing:			
37	Material	in/ ASTM 0.1345 / A36	0.1345 / A36	0.1345 / A36
38	Internal Coating	--- None	None	None
39	External Temperature, Typical	°F 180	180	180
40	Comments / Clarifications	--- Cleaning/Sootblowing lanes: none		Bolted Assembly
41		SHOP Installed	SHOP Installed	SHOP Installed
42				
43		FLUE GAS DUCTS		
44	Stack & Uptakes Design:	15° TRANSITION	DISCH. DUCT	
45	Quantity	One	One	
46	Type / Location	--- Full L / Conv	Self.Spt / Grade	
47	Length / Metal Outside Diameter (top)	ft/ ft 1.08 / n/a	7 / 1.333	
48	Discharge Elev., minimum/ calculated	ft/ ft n/a / n/a	20 / 20	
49	Total Refractory Thickness	in 0.0	0.0	
50	Hot Face Temperature (design)	°F		
51	Hot Face Temperature (calculated)	°F	447	447
52	Hot Face Layer	in/ --- None	None	
53	Back-Up Layer No.1	in/ ---		
54	Castable Reinforcement (SS Needles)			
55	Anchors / Tie Backs:	---		
56	Material	---		
57	Attachment	---		
58	Casing:			
59	Minimum Thickness/ Material	in/ ASTM 0.1345 / A36	0.1345 / A36	
60	Corrosion Allowance	in None	None	
61	Internal Coating	--- None	None	
62	External Temperature, Typical	°F 447	447	
63	Comments / Clarifications	---		
64				

MECHANICAL / STRUCTURAL DESIGN BASIS

1	
2	
3	Refractory & Coatings Design:
4	Refractory Design <u>Per Std560: 180°F Avg. Casing Temperature @ Ambient Conditions of 0 MPH & 80°F</u>
5	Refractory Dryout <u>SHOP dryout = None // FIELD dryout is NOT required with the use of TC's AHR additive to Castable.</u>
6	Coating, Internal <u>None</u>
7	Coating, External <u>Base Coat: 3 mils dft IOZ (InOrganic Zinc) on SP-6 Surface</u>
8	<u>Int. Coat: None</u>
9	<u>Top Coat: None</u>
10	
11	
12	
13	Applicable Standards:
14	API <u>Std 560 (ISO 13705); Fired Heaters for ...</u> AISC <u>Specification for Design, ... Steel for Buildings</u>
15	API <u>Std 530 (ISO 13704); Calc. of Heater Tube ...</u> AWS <u>D 1.1; Structural Welding Code</u>
16	ASME <u>B31.3, Chemical Plant and ... Piping</u> ASTM <u>tube/ smls pipe/ fitting spec's noted herein</u>
17	ASME <u>Sections I, II, VIII, IX; ASME B&PV Code</u> ASTM <u>refractories per C27, C155, C401 & C612</u>
18	ASME <u>Section V; Non Destructive Examination</u> NFPA <u>NFPA 70; National Electrical Code</u>
19	
20	Wind Design:
21	Spec. or Standard <u>ASCE 7-10</u>
22	Velocity/ Imp. Factor <u>120 mph / 1</u>
23	Site Exposure <u>"C"</u>
24	Physical Design:
25	Plot Limitations <u>None</u>
26	Tube Limitations <u>None</u>
27	Firebox Pressure <u>Positive; approximately +1.0 inH2O</u>
28	Ambient Temp's <u>-20 °F Min/ 60 °F Dsn/ 110 °F Max</u>
29	
30	
31	
32	
33	
34	
35	
36	
37	
38	
39	
40	
41	
42	
43	
44	
45	
46	
47	
48	
49	
50	
51	
52	
53	
54	
55	
56	
57	
58	
59	
60	
61	
62	
63	
64	

MAJOR SUBSYSTEMS & ACCESSORIES

33	Major Services & Subsystems	Major Accessories:
34	Process Design <u>INCLUDED in base pricing</u>	Casing/ Tube Seals <u>4 TubeSox; Radiant & Conv.</u>
35	Mechanical Design <u>INCLUDED in base pricing</u>	Observation Doors <u>2 4 in Dia. w/ H.T. glass</u>
36	Structural Design <u>INCLUDED in base pricing</u>	Observation Doors <u>1 4 in Dia. w/ HT glass on Arch</u>
37	Radiant Section <u>INCLUDED in base pricing</u>	Access Doors <u>1 Std 24" x 24"</u>
38	Convection Section <u>INCLUDED in base pricing</u>	Expansion Joints <u>None</u>
39	Combustion Mgmt <u>INCLUDED in base pricing</u>	Ladders & Platforms <u>Not Included</u>
40	Burner Piping <u>INCLUDED in base pricing</u>	L&P Coating <u>N/A</u>
41	Forced Draft System <u>INCLUDED in base pricing</u>	
42		
43	Casing Penetrations	Pressure Part Penetrations
44	Fbox Purge/ Snuff <u>None</u>	Coil TSTC's, Radiant <u>None</u>
45	CA Temp/Pres <u>None</u>	Coil TSTC's, Convection <u>None</u>
46	FG Temperature <u>2 1.5"NPS 3000# Coupling</u>	Process TI conn's <u>3 1.5" NPS 900# RFWN</u>
47	FG Pressure <u>2 1.5"NPS 3000# Coupling</u>	Process PI conn's <u>1 1.5" NPS 900# RFWN</u>
48	FG Comp. (Sample) <u>2 1.5"NPS 3000# Coupling</u>	spare _____
49	FG Sample <u>2 4"NPS 150# RFWN's</u>	spare _____
50	O2 Analyzer Port <u>None</u>	spare _____
51		
52	Dampers	
53	FD Fan (blower) <u>qty = 0</u>	Uptake Ducts <u>Stack qty = 0</u>
54	Note: _____	Note: _____
55	Design <u>Fan inlet damper is inappropriate</u>	Stack Damper (which provides draft
56	Materials <u>for forced draft SHO's where O2</u>	control) is inappropriate for forced
57	Bearings <u>Control is provided by the CMS O2</u>	draft SHO's where the combustion
58	Operator <u>Trim Module which controls the fan</u>	conditions are controlled real-time
59	Positioner <u>(blower) motor's VFD/ VSD.</u>	via the CMS.
60	Instruments	
61	Sootblowers: Qty. Type Location FG T Material Steam T & P O.E.M. / Ref.	
62	Lane 1: <u>None</u>	
63	Lane 2 : <u>None</u>	
64		

1	Owner:	Unknown	Owner Ref.:	H-741	Ftnt
2	Purchaser:	UOPR	Purch. Ref.:	J463	&
3	Manufacturer:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-265	Rev
4	SHO Model:	SHO500	Location:	Unknown	

ASME SECTION VIII - DIVISION 1 CALCULATIONS for RADIANT COIL

Formulas:

$t.s = \frac{(P \times R_i)}{(S \times JE - 0.6 \times P)}$ Circumferential Stress	or	$\frac{(P \times R_i)}{(2 \times S \times JE + 0.4 \times P)}$ Longitudinal Stress	or	$\frac{(P \times R_o)}{(S \times JE + 0.4 \times P)}$ Circumferential Stress
--	----	--	----	--

where:

t.s	Required / Minimum Stress Thickness	in	Excludes corrosion and/or erosion allowances
P	Design Pressure, per PO / Contract	psig	Per PO / Contract
Ro / Ri	Outside / Inside Radius of Tube	in	Calculated values for New Condition
S	Design (Max. Allowable) Stress @ T	psi	Per UG-23 / ASME Section II, Part D, Subpart 1
JE	Joint Efficiency, per UW-12	%	TABLE UW-12; 100% seamless pipe/tube = 1.00

	units	Variable Values	Comments
Design Pressure, P	psig	1,095	Design Pressure is per PO / Contract.
Design Temperatures, T.Dmax / T.Dmin.	°F	763 / -20	T.Dmax per THM calcs / T.Dmin per PO / Contract
Design Allowances, Corrosion/ Erosion	in	0.0625 / 0.000	Allowances (both CA & EA) are per PO / Contract
Design Stress @ Design Temp, S	psi	12,413	Design Stress @ T.Dmax
Pipe/Tube Outside Diameter	in	4.500	
Pipe/Tube Material Standard	ASME	SA106GrB	Max. Allowable Nonconcentricity, per ASTM: 12.50%
Pipe/Tube Type	welded or seamless	Seamless	
Butt Weld Inspection	RT or Other	100 of 100%	
Tube Schedule / New Avg.Wall	ASTM	SCH 80 / 0.337	Tube Inside Radius (R.i), New = 1.913
Actual Minimum Thickness, t.new / t.EOL	in	0.295 / 0.232	t.EOL = End of Life Thickness = t.new - (CA + EA)

UG-27 Calculations:

Circumferential Stress Calculations	---	1.00	Per UW-12, Longitudinal JE of seamless pipe is 100%
UG-27(c) (1) Minimum Thickness, t.s	in	0.178	UG-27(c) (1)&(2) Thickness Check: 0.18 = OK!!
UG-27(c) (1) Surplus Wall Thickness	in	0.054	UG-27(c) (1) Pressure Limit Check: 4,779 = OK!!
UG-27(c) (1) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)
Longitudinal Stress Calculations	---	0.85	Per UW-12, Circumferential JE of butt-welds is 85%
UG-27(c) (2) Minimum Thickness, t.s	in	0.097	UG-27(c) (2) Pressure Limit Check: 13,189 = OK!!
UG-27(c) (2) Surplus Wall Thickness	in	0.135	
UG-27(c) (2) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Appendix 1, Para.1-1 Calculations:

Circumferential Stress Calculations	---		Per UW-12, Longitudinal JE of seamless pipe is 100%
Appendix 1 (1-1) (1) Min. Thickness, t.s	in		
Appendix 1 (1-1) (1) Surplus Thickness	in		
Appendix 1 (1-1) (1) Acceptability	---		Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Footnotes / Clarifications:

a) Fluxed coil (inside casing) & XOvers are per ASME Section VIII -Div.1; unfluxed manifolds are per ASME B31.3.

b) This design is per the 2015 Edition of Section VIII - Division 1 (UG-27 basis; not Appendix 1).

c) These calculations are "preliminary" until accepted by the Coil Manufacturer; whom provides the code stamp on the coil.

d) The different Design Temp's of Radiant and Convection coils reflect the heater's large process temp rise.

e) Per UG-11 & UG-44, the Pressure-Temperature ratings of standard components shall be per noted ASME/ANSI Stds.

f) Per UG-44, fittings per B16.9 & B16.11 shall be calculated as for straight seamless pipe per Section VIII - Division 1.

g) Per UCS-66, charpy impact testing for this coil is not mandatory (ref. FIG UCS-66, Curve B).


h) Work this data sheet with Heater Datasheets and General Arrangement Drawings (latest versions).

i) Mandatory Appendix 1 provides supplemental design formulas that MAY be substituted for UG-27(c) formulas.

j) spare

rev.	date	description	by	appv'd
1	13-Nov-17	Revised Purch. Ref. No. per Customer	JDC	JDF
0	19-Aug-17	Issued for Approval	JF	JDC

**COIL UNDER INTERNAL PRESSURE
ASME SECTION VIII - DIVISION 1 CALCS**



CONFIDENTIAL
PROPERTY of ...
TULSA HEATERS MIDSTREAM LLC

project reference: American Engineering Standard (AES) Units

FLUXED HEATER COIL

MJ17-265-COIL.VIIIds-Rev. 1 **Pg 1 of 2**

info@tulsaheatersmidstream.com u (918) 392 -8000(vce) u TULSA HEATERS MIDSTREAM LLC u 1215 S. Boulder Ste 1040 u Tulsa, OK 74119 u www.tulsaheatersmidstream.com

1	Owner:	Unknown	Owner Ref.:	H-741	Ftnt
2	Purchaser:	UOPR	Purch. Ref.:	J463	&
3	Manufacturer:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-265	Rev
4	SHO Model:	SHO500	Location:	Unknown	

ASME SECTION VIII - DIVISION 1 CALCULATIONS for CONVECTION COIL

Formulas:

$t.s = \frac{(P \times R_i)}{(S \times J_E - 0.6 \times P)}$ <p align="center">Circumferential Stress</p>	or	$\frac{(P \times R_i)}{(2 \times S \times J_E + 0.4 \times P)}$ <p align="center">Longitudinal Stress</p>	or	$\frac{(P \times R_o)}{(S \times J_E + 0.4 \times P)}$ <p align="center">Circumferential Stress</p>
---	----	---	----	---

where:		units	comments:
t.s	Required / Minimum Stress Thickness	in	Excludes corrosion and/or erosion allowances
P	Design Pressure, per PO / Contract	psig	Per PO / Contract
Ro / Ri	Outside / Inside Radius of Tube	in	Calculated values for New Condition
S	Design (Max. Allowable) Stress @ T	psi	Per UG-23 / ASME Section II, Part D, Subpart 1
JE	Joint Efficiency, per UW-12	%	TABLE UW-12; 100% seamless pipe/tube = 1.00

Convection Coil Design Basis:

	units	Variable Values	Comments
Design Pressure, P	psig	1,095	Design Pressure is per PO / Contract.
Design Temperatures, T.Dmax. / T.Dmin.	°F	650 / -20	T.Dmax per THM calcs / T.Dmin per PO / Contract
Design Allowances, Corrosion/ Erosion	in	0.0625 / 0.000	Allowances (both CA & EA) are per PO / Contract.
Design Stress @ Design Temp, S	psi	17,100	Design Stress @ T.Dmax
Pipe/Tube Outside Diameter	in	4.500	
Pipe/Tube Material Standard	ASME	SA106GrB	Max. Allowable Nonconcentricity, per ASTM: 12.50%
Pipe/Tube Type	welded or seamless	Seamless	
Butt Weld Inspection	RT or Other	100 of 100%	
Tube Schedule / New Avg.Wall	ASTM	SCH 80 / 0.337	Tube Inside Radius (R.i), New = 1.913
Actual Minimum Thickness, t.new / t.EOL	in	0.295 / 0.232	t.EOL = End of Life Thickness = t.new - (CA + EA)

UG-27 Calculations:

Circumferential Stress Calculations	---	1.00	Per UW-12, Longitudinal JE of seamless pipe is 100%
UG-27(c) (1) Minimum Thickness, t.s	in	0.127	UG-27(c) (1)&(2) Thickness Check: 0.18 = OK!!
UG-27(c) (1) Surplus Wall Thickness	in	0.105	UG-27(c) (1) Pressure Limit Check: 6,584 = OK!!
UG-27(c) (1) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)
Longitudinal Stress Calculations	---	0.85	Per UW-12, Circumferential JE of butt-welds is 85%
UG-27(c) (2) Minimum Thickness, t.s	in	0.071	UG-27(c) (2) Pressure Limit Check: 18,169 = OK!!
UG-27(c) (2) Surplus Wall Thickness	in	0.161	
UG-27(c) (2) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Appendix 1, Para.1-1 Calculations:

Circumferential Stress Calculations:	---		Per UW-12, Longitudinal JE of seamless pipe is 100%
Appendix 1 (1-1) (1) Min. Thickness, t.s	in		
Appendix 1 (1-1) (1) Surplus Thickness	in		
Appendix 1 (1-1) (1) Acceptability	---		Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Footnotes / Clarifications:

- a) Fluxed coil (inside casing) & XOvers are per ASME Section VIII -Div.1; unfluxed manifolds are per ASME B31.3.
- b) This design is per the 2015 Edition of Section VIII - Division 1 (UG-27 basis; not Appendix 1).
- c) These calculations are "preliminary" until accepted by the Coil Manufacturer; whom provides the code stamp on the coil.
- d) The different Design Temp's of Radiant and Convection coils reflect the heater's large process temp rise.
- e) Per UG-11 & UG-44, the Pressure-Temperature ratings of standard components shall be per noted ASME/ANSI Stds.
- f) Per UG-44, fittings per B16.9 & B16.11 shall be calculated as for straight seamless pipe per Section VIII - Division 1.
- g) Per UCS-66, charpy impact testing for this coil is not mandatory (ref. FIG UCS-66, Curve B).
- h) Mandatory Appendix 1 provides supplemental design formulas that MAY be substituted for UG-27(c) formulas.
- i) These calculations are for the Convection Coil and for the Crossovers (between radiant and convection modules).
- j) spare

rev.	date	description	by	app'vd
1	13-Nov-17	Revised Purch. Ref. No. per Customer	JDC	JDF
0	19-Aug-17	Issued for Approval	JF	JDC



CONFIDENTIAL
PROPERTY of ...
TULSA HEATERS MIDSTREAM LLC

project reference: American Engineering Standard (AES) Units

**COIL UNDER INTERNAL PRESSURE
ASME SECTION VIII - DIVISION 1 CALCS**

**FLUXED HEATER COIL
MJ17-265-COIL.VIIIids-Rev. 1 Pg 2 of 2**

info@tulsaheatersmidstream.com u (918) 392-8000(vce) u TULSA HEATERS MIDSTREAM LLC u 1215 S. Boulder Ste 1040 u Tulsa, OK 74119 u www.tulsaheatersmidstream.com

Ftnt
&
Rev

Owner:	Unknown	Owner Ref.:	H-741
Purchaser:	UOPR	Purch. Ref.:	J463
Heater Mfgr:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-265
Burner OEM:	Callidus Technologies, LLC	OEM Ref.:	9020143
SHO Model:	SHO500	Service:	Regen Gas Heater
CMS Model:	CMS1500	Location:	Unknown @ 750 ft elevation

GENERAL DESIGN CONDITIONS

General Application:

Service	---	Regen Gas Heater	Regen Gas Heater
Operating Case	---	Over-Design Case	Design Case
Burner Type		Enhanced IFGR	Enhanced IFGR
Burner Quantity	---	1	1
Model & Size:	---	CUBL-3W	CUBL-3W
Flame Shape	cylindrical or flat	Cylindrical	Cylindrical
Applicable Fuel(s)	---	Fuel Gases pg. 2	Fuel Gases pg. 2
Location(s) / Firing Direction		Endwall Center	Endwall Center
Firing Orientation		Horizontal	Horizontal
BridgeWall Temperature, calc.	°F	1,649	1,526

Heat Release Performance:

		MMBTU/hr	MMBTU/hr
Operating Case	---	Over-Design Case	Design Case
Max. Heat Release, per Burner	LHV Basis	9.20	6.93
Design Heat Release, per Burner	LHV Basis	8.37	6.30
Min. Heat Release, per Burner	LHV Basis	1.84	1.84
Turndown, minimum/ actual	max / min	5.00 / 5.00	5.00 / 5.00

Radiant Dimensions:

	comments	ft / (in)
Casing Width / Height, Casing	face - face	8.00 / (96)
Casing Length, Casing to Casing	face - face	10.00 / (120)
Helical Coil CenterLine Diameter	CL - CL	6.50 / (78)
Helical Coil Inside Diameter	face - face	6.13 / (74)
Serpentine Coil CtrLine Dimensions	W / H	
Serpentine Coil Inside Dimensions	face - face	
Firebox Length, Refractory Faces	face - face	9.17 / (110)

Flame Dimensions:

		ft / (in)
Burner CL elev., approx.	AG	4.50 / (54)
Flame Length, calc.	@ design HR	10.9 / (131)
Flame Dia., calc.	@ design HR	2.50 / (30)

Actual Clearances

		ft / (in)
Burner - tube (tangential)	CL / Net	3.25 / (39)

Combustion Air (CA) Basis - All Fuel(s):

CA Temperature, min.	-20 °F	FG Draft, at Bridgewall	0.50 inH2O (positive)
CA Temperature, design	60 °F	CA Pressure, at Burner	7.64 inH2O (positive)
CA Temperature, max.	110 °F	CA Pressure Drop, Design	7.10 inH2O
CA Pressure, Ambient	14.30 psia	CA Pressure Drop, Actual	t.b.q. inH2O
CA Humidity, Design	50% %RH		

Emissions -

Design/ Guaranteed Emissions:	basis	Gaseous Fuel(s):	Liquid Fuel(s):
		3.0% O2, dry (LHV)	no
NOx Emissions	LHV Basis	0.053 Lb/MMBTU	
SOx Emissions	LHV Basis	no quote Lb/MMBTU	
CO Emissions	LHV Basis	0.041 Lb/MMBTU	
VOC Emissions	LHV Basis	0.019 Lb/MMBTU	
UHC Emissions	LHV Basis	0.007 Lb/MMBTU	
SPM10 Emissions	LHV Basis	0.014 Lb/MMBTU	
Noise Emissions	---	85 dBA @	

59					
60					
61					
62	Rev. 1	13-Nov-17	Revised Purchaser Ref. No. per Customer Comments	JDC	JF
63	Rev. 0	19-Aug-17	Issued for Approval	JF	JDC
64	revision	date	description	by	chk'd appv'd



BURNER DATA SHEET
AES SYSTEMS of UNITS

Owner Ref.: **H-741**

THM Ref.: **MJ17-265**

Ftnt
&
Rev

GASEOUS FUEL(S) & PRODUCTS OF COMBUSTION

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42
- 43
- 44
- 45
- 46
- 47
- 48
- 49
- 50
- 51
- 52
- 53
- 54
- 55
- 56
- 57
- 58
- 59
- 60
- 61
- 62
- 63
- 64

Fuel Gas Basis:	---	Gas 1	Mol.Wt.			
Operating Mode	---	Over-Design Case				
Temperature, at Burner	°F	100				
Pressure, at Burner (available)	psig	75				
LHV (net HV), mass basis	AES units	20,426	BTU/ Lbm			
LHV (net HV), volume basis	AES units	976	BTU/ scf			
HHV (gross HV), mass basis	AES units	22,613	BTU/ Lbr			
HHV (gross HV), volume basis	AES units	1,080	BTU/ scf			
Molecular Weight (mass)	all units	18.13	x/ x mole			

Fuel Gas Composition(s):	symbol	MW	Gas 1	Mol.Wt.			
	H2	2.02	0.00%	mole %			
	O2	32.00	0.00%	mole %			
	N2 + Ar	28.15	1.00%	mole %			
	CO	28.01	0.00%	mole %			
	CO2	44.01	1.00%	mole %			
	CH4	16.04	88.00%	mole %			
	C2H6	30.07	8.00%	mole %			
	C2H4	28.05	0.00%	mole %			
	C3H8	44.10	2.00%	mole %			
	C3H6	42.08	0.00%	mole %			
	C4H10	58.12	0.00%	mole %			
	C4H8	56.11	0.00%	mole %			
	C5H12	72.15	0.00%	mole %			
	C5H10	70.13	0.00%	mole %			
	C6+	86.18	0.00%	mole %			
	H2S	34.08	0.00%	mole %			
	SO2	64.06	0.00%	mole %			
	NH3	17.09	0.00%	mole %			
	H2O	18.02	0.00%	mole %			
	spare		0.00%	mole %			

Products of Combustion @ Design:		Gas 1	Mol.Wt.			
Excess Air Concentration	mole%	15%	mole%			
Temperature, PoC at Bridgeway	°F	1,649				
Temperature, PoC at Burner	°F	1,450				
Temperature, PoC Acid Dew Point	°F	151				

			<< ----- mass balance by TULSA HEATERS MIDSTREAM LLC ----- >>			
Combustion Mass Balances:		MW	Lbm/ hr			
Fuel Flow Rates	mass in		410			
Comb. Air Flow Rates	mass in	28.96	7,736			
POC Mass Flow Rates (wet)	mass out	27.89	8,145			
POC Mass Flow Rates (dry)	mass out	29.91	7,251			
POC Component Flow Rates ...	O2	32.00	233			
	N2 + Ar	28.15	5,915			
	CO2	44.01	1,102			
	H2O	18.02	894			
			<< ----- vapor / solid concentrations are in ppmvd / ppm, resp. ----- >>			
	NOx	46.01	0.45	40 ppm		
	SOx	64.06	0.00	0 ppm		
	CO	28.01	0.34	50 ppm		
	VOC	44.10	0.16	15 ppm		
	UHC	16.04	0.06	15 ppm		
	SPM		0.12	16 ppm		

ADDITIONAL REQUIREMENTS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64

QA Requirements:

Performance Test @ shop --- Not Required
 CFD Model of Firebox --- None
 CFM of CA Ducting --- None
 Mill Certs, fuel wetted parts --- Not Required
 PMI, fuel wetted parts --- Not Required

Fuel Wetted Components:

Oil Gun Model --- None
 Gun Tip / Atomizer Mat'ls ASTM None / None
 Gas Risers Material ASTM t.b.d.
 Gas Manifolds Mat'l ASTM Carbon Steel

Burner Pilot:

model by O.E.M.
 Type --- Self-Inspiring
 Heat Release BTU/hr > 90,000
 Ignition Method man.or elec. Electric
 Pilot Fuel Gas --- Gas 1 Mol.Wt.
 Pilot Detection type or none None
 Fuel P, avail. @ pilot psig 10 (5 -15 is OK)

Connections:

Primary Fuel Gas sz & spec by OEM & 150# A105 RF
 Secondary Fuel Gas sz & spec None
 Fuel Oil sz & spec None
 Atomizing Media sz & spec None
 Pilot Gas sz & spec by OEM & 150# A105 RF
 Detector, Main Flame sz & spec None
 Detector, Pilot Flame sz & spec by OEM - UV Scanner Mount
 Sight Ports sz & spec None

Windbox or Plenum:

Individual windbox yes or no yes
 Material Description th x ASTM 12 ga. x A36
 Common Plenum Depth ft. none
 Refractory Description th x type 1.00 in x Min.Wool
 Refractory Anchors ASTM C.S. Expanded Metal
 Register Type none
 Register Material ASTM C.S.
 Leakage, guaranteed wt% < 5.0 % of Max HR Flow
 Actuation man., pneu.or elec. manual

APPLICABLE SPECIFICATIONS & STANDARDS

TULSA HEATERS MIDSTREAM LLC Specifications:

- a) Burner scope ...
 - 1) Pilot w/ Electric Ignition - Ignition Transformer is by others (CMS Supplier)
 - 2) UV Scanner is by others. Swivel scanner mount (by burner supplier) aimed at pilot and main flame when pilot off.
 - 3) Sight port(s) for viewing pilot and main flames.
- b) Burner shall have 5:1 turndown; this capability shall NOT compromise flame size or performance.
- c) External Coatings shall be as follows:

Prime:	3 mils dft IOZ (InOrganic Zinc) on SP-6 Surface
Intermediate:	None
Finish:	None
- d) Burner is mounted and fired horizontally. Tile to be shop mounted in 304 SS case.
- e) Even though job location/elevation is different, burner to be sized to range from sea level to 3500 ft and worst case air delta P reported.

1	Owner:	Unknown	Owner Ref.:	H-741	Ftnt
2	Purchaser:	UOPR	Purch. Ref.:	J463	&
3	Heater OEM:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-265	Rev
4	CMS OEM:	International Custom Controls	CMS Model:	CMS1500	
5					

6					
7					
8	System Overview:				
9	Design Philosophy	Meet or Exceed NFPA 85 with packaged Combustion Management System			
10	Heater DHR	Heater Design Heat Release = 9 MMBTU/hr (LHV); ref. Burner Data Sheets for fuel composition			
11	CMS DHR	CMS Design Heat Release = 15 MMBTU/hr (LHV); ref. Burner Data Sheets for fuel composition			
12	No. of Burners	One Callidus CUBL-3W Burner per heater			
13					
14	THM Specs	Provided datasheets	Ambient P, Design	750 ft AMSL =	14.30 psia
15	THM P&ID	CMS1500 P&ID	Ambient T Range	-20 °F Minimum to 110 °F Maximum	
16	Area Classification	Unclassified	Noise Limit	85 dBA @ 3 ft	
17	Supply Power	120V / 1 ph / 60 Hz	Ind. Standard(s)	B31.3, NFPA 70 (NEC), NFPA 85	
18	Supply Air	80 psig	Customer Specs	None	
19					

20	Subsystem Design:		Dsn P	Dsn T	NPS	Dsn V	End Con.⁴
21	Main Gas Train ³	Double Block & Bleed SDVs with ZSC's	150 psig	150°F	1-1/2"	67	150# RF
22	Pilot Gas Train	Double Block & Bleed SDVs	150 psig	150°F	1/2"	11	150# RF
23	Instrument Air Hdr		125 psig	150°F	1"	---	150# RF
24	Main Oil Train	None					
25	Atom. Media Train	None					
26	Local Panel (LCP)	NEMA 4 Enclosure for Controls, HMI, Pushbuttons & Lights				Z-Purge: No	
27	Other Panel(s)	NEMA 7 Enclosure with 6kV Ignition Transformer & 7mm HiV IGN Cable					
28	Other Panel(s)	None					
29	Forced Draft Sys.	One FD Fan ¹ ; a) unlined ducting, b) CA controlled by	Damper				

30	Minimum Pre-Purge Interlocks:		Minimum Purge Interlocks:
31	✓ Manual ESD Switch (pushbutton)	✓ Gas Supply Low Pressure	✓ Minimum CA Flow
32	✓ SDVs FailSafe Positions	✓ Gas to Burner High Pressure	
33	✓ Stack High Temperature	- Firebox High Pressure	
34	✓ Process High Temperature	- Oil Supply Low Pressure	
35		- Atom.Media Low Pressure	

37	Gas / Oil Trains Overview:	Local Panel Components Overview:
38	✓ Pilot Double Block & Bleed SDVs	✓ Slate Control Package
39	✓ Gas Train Dbl Block & Bleed SDVs	✓ Touchscreen HMI
40	✓ Inlet Header Isolation Valve	- Remote Control Panel
41	✓ Inlet Header Sediment Trap w/ Cap	- Field Wiring schematic to connect LCP to J/B
42	✓ Inlet Header Gas Strainer	- LCP Weather/Sun Shield
43	✓ Inlet Header Pressure Regulator	
44	- Inlet Header Relief Valve	

45	- Oil Train Dbl Block & Bleed SDVs	Supporting Components:
46	- Atom.Media dP Controls	✓ Pilot Flame UV Detector
47	- Gas/ Oil Flow Element	- Main Flame UV Detector
48	- Comb. Air Flow Element	✓ CA Ducting to Burner(s)
49	- Min. Fire PCV in Parallel w/ TCV	✓ Flex Hoses at Brnr Terminals
50		- Individual Burner SDVs
51		✓ Fuel Train Only (no skid)
52		- O2 Analyzer
53		✓ Process TC (control loop)
54		✓ Process TC (shutdown)
55		✓ Process Pressure Gauge ²
56		✓ Stack TC
57		- Process Coil Relief

54 NOTES:

55 1. Forced draft fan supplied by THM

56 2. Process Pressure Gauge to be designed for 0-1095 psig

57 3. ZSC's only on block valves, not bleed.

58 4. Piping 2" and below to use threaded fittings, except end connections.

59 5. FAT required

60					
61					
62	1	13-Nov-17	Rev'd Purch. Ref. No.	JDC	JF
63	0	19-Aug-17	Issued for Approval	JF	JDC
64	rev.	date	description	by	app'v'd



COMBUSTION MANAGEMENT SYSTEM

15 MMBTU/hr RATED HEAT RELEASE

This document contains confidential and proprietary information, and IT SHALL NOT be used, reproduced or disclosed without the prior written consent of THM.

CMS1500 DATA SHEET

MJ17-265-CMS1500ds- Rev. 1

Pg 1 of 2

Purch. Ref.: **H-741**

THM Ref.: **MJ17-265**

Process Interlocks:

	units	Tag No.	Factory Settings		Design Conditions		Comments
			Low	High	Min.	Design	
Process Flow	MLb/hr	FALL-300	7.6	None	20.8	116.2	---
		Action:	S/D @ minimum flow to avoid "short circuiting" one or more coil passes				
Process Temperature	°F	TSHH-202	None	600	---	550	600
		Action:	S/D @ maximum fluid temperature to avoid "overheating" the coil				

Heater Interlocks:

Stack Temperature	°F	TSHH-201	None	700	377	483	---
		Action:	S/D @ 700 F, which is indicative of an "out-of-control" fire in the heater				

CMS Interlocks:

FG Train Pressure	psig	PSLL-101	10	None	---	---	150
		Action:	S/D @ 10 psig, which is indicative of "inadequate" fuel gas supply				

FG Train Pressure	psig	PSHH-103	None	35	---	---	150
		Action:	S/D @ 35 psig, which is indicative of a "failure" of PCV-100 &/or FG supply				

FD Fan Interlocks:

FD Fan (blower) SP	inH2O	PSLL-107	0.20	None	0.46	7.6	11.4
FD Fan (blower) FDF shutdown:	5.0	Action:	S/D @ 0.2 inH2O, which is indicative of a FD Fan (blower) "failure".				

Other permissives/interlocks in BMS Operations Manual (block valves, FCV, and flame signal).

CMS CONTROL COMPONENTS

	units	Tag No.	Factory Settings		Design Conditions		Comments
			Low	High	Min.	Design	
Remote T Setpoint	°F	TY-700	0	999	---	550	600
		Action:	4 -20 mA input corresponds to a temperature setpoint range of 0 -999 °F				
Process Temperature	°F	TT-203	0	999	---	550	600
		Action:	4 -20 mA output corresponds to a process temperature range of 0 -999 °F				
Main Gas Regulator	psig	PCV-100	---	---	---	35	150
Pilot Gas Regulator	psig	PCV-105	---	---	---	10	150
Inst. Air Regulator	psig	PCV-107	---	---	---	80	150

CUSTOMER CONNECTIONS (TO DCS)

The following signals are sent to the customer's DCS from the control panel:

- Remote ESD
- Heater Run
- Low Process Flow
- High Stack Temperature
- High Process Temperature
- Burner Status

Fnt
&
Rev

1					
2	Owner:	Unknown	Heater Ref.:	H-741	
3	Purchaser:	UOPR	Purch. Ref.:	J463	
4	Heater Mfg:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-265	
5	Location:	Unknown	DFD OEM Ref.:	340802	
6	FD Fan OEM:	Chicago Blower	DFD Item No.:	BL-741	

9	General Application:				
10	FD Fan(s) Design Basis	mass.flow.%	115% of Design MASS Flows per API Standard 560		
11	Location(s)	---	@ Grade, adjacent to Burner Endwall (incorporated into Combustion Skid)		
12	Area Classification	NEC	Unclassified		


14	AES Units				
15	Process Design Conditions:		Heater Design	DFD Test Block	
16	Mass Flow Rate/ % Htr Design	Lb/hr / kg/ hr	7,736 / 100%	8,900 / 115%	
17	Volumetric Flow/ % Htr Design	acfm / am3/ hr	1,800 / 100%	2,200 / 122%	
18	Density, @ Suction	as noted	0.074 Lb/ ft3	0.068 Lb/ ft3	
19	Design Allowances, Temp./ SP	°F / °C	--- / ---	130 °F / 149%	
20	Temperature @ Min / Suction / Design	°F / °C	-20 / 60	/ 110	
21	Static Pressure @ Suction	as ntoed	-0.2 inH2O	-0.2 inH2O	
22	Site Elevation/ Atm. P	as ntoed	750 ftAMSL	14.30 psia	
23	Static Pressure Rise (min./ guar.)	inH2O	7.6 / 7.6	11.4 / 11.4	
24	Fan Speed (allowable/ actual)	RPM	3,600 / 3,525	3,600 / 3,525	
25	Sound Pressure (allowable/ guar.)	dBA	< 85 / < 85	< 85 / < 85	
26	Relative Humidity	%	50%		

28	Fan Mechanical Design:	tag // OEM	BL-741 // CHICAGO BLOWER Corp.		
29	OEM Reference	CMS // FD Fan	International Custom Controls // 340802		
30	OEM Model &/or Type-Size	per OEM	D/36A (SQAD)		
31	Arrangement	---	Arrangement 4 (direct drive)		
32	Brake Power, Design/ Test Block (calc.)	HP	10.0	/ 10.0	
33	Temperature, Mechanical Design	°F	135	°F Mechanical Design	
34	Casing Description / Materials	---	"Square" pattern / CS		
35	Rotor Description / Materials	---	Airfoil Blades / CS		
36	Shaft Description / Materials	---	None - Arrangement 4		
37	Bearings Description / Materials	---	None - Arrangement 4		
38	Noise Abatement Provisions / SPL	---	85 dBA		
39	External Coatings / Surface Prep.	---	OEM's Std Multiple Coat System		
40	Purchase Specifications	---	OEM's Std Industrial Quality Design		

42	Fan Control Design:	tag // OEM	VSD-741 / by OTHERS		
43	VFD Description	---	by Others / Owner		
44	VFD Rating	---	---		
45	Damper Actuator Description	---	---		
46	Damper Actuator Operation	---	---		

48	Fan Motor Design:	tag // OEM	BM-741 / TECO-WESTINGHOUSE		
49	OEM Model &/or Type-Size	---	Catalog EP0102 / AEHH8N		
50	VFD Service / speed range	---	YES / 3 - 60 Hz or 180 - 3,600 rpm		
51	Motor Type / Frame Size	---	NEMA TEFC / 215T		
52	Rated Power w/ SF @ Speed	NEMA	10	HP w/ 1.15 SF @ 40°C	
53	Nameplate Input Power	V/ Hz/ ph	460V	/ 60 Hz / 3 ph	
54	Typical Performance	---	89.5- 91.0 % FL Effy @ 89.5 % FL PF		
55	Insulation Description	---	Class F / B Rise		
56	External Coatings & Surface Prep.	---	OEM's Std Multiple Coat System		
57	Purchase Specifications	---	None		

59					
60					
61					
62	Rev. 1	13-Nov-17	Revised Purchaser Ref. No. per Customer Comments	JDC	JF
63	Rev. 0	19-Aug-17	Issued for Approval	JF	JDC
65	revision	date	description	by	chk'd appv'd

 <p>USA Applications SHO = Superior Quality, Flexibility, Dependability & Modularity</p>	FD FAN DATA SHEET AES & cgs or SI SYSTEMS of UNITS	
	MJ17-265-DFDANds-Rev. 1	Page 1 of 1

his document contains confidential information, which is proprietary to THM. This document shall not be used, reproduced or disclosed without the prior written consent of THM

COMBUSTION DESIGN CONDITIONS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64

Overall Performance:

		Over-Design Case	Design Case		
Operating Case	---	Over-Design Case	Design Case		
Service	---	Heat Medium Heat	Heat Medium Heat		
Excess Air	mol%	15.0%	15.0%		
Calculated Heat Release (LHV)	MMBTU/ hr	20.28	18.22		
Guaranteed Efficiency	HR%	84.5%	85.6%		
Calculated Efficiency	HR%	86.5%	87.6%		
Radiation Loss	HR%	3.00%	3.00%		
Flow Rate, Combustion Gen./ Imp.	Lb/ hr	19,739	17,736		
Flue Gas Temp. Leaving (R/C)	°F	1,452 / 468	1,402 / 429		
Flue Gas Mass Velocity	Lb/ sec ft2	0.472	0.424		

Fuel(s) Data:

Gas 1	Mol.Wt.			
LHV	BTU/ scf	976		
LHV	BTU/ Lb	20,426		
P @ Burner	psig	75		
T @ Burner	°F	100		
MW	Lb/ Lbmole	18.13		
m @ ??? °F	cp	---		
m @ ??? °F	cp	---		
Atomizing Media	---			
Atom. Media P & T	---			

Burner Design:

OEM	---	Callidus Technologies, LLC
Type	---	Enhanced IFGR ULTRA Low NOx
Quantities	---	1 Burner
Model No.	---	CUBL-5W Cylindrical
Windbox	---	yes ...
Location	---	EndWall Center ... Horizontally Fired
Pilot Design:		
Type / Model	Self-Inspiring /	by O.E.M.
Ignition	---	Electric requires elec.ign.system
Heat Release	> 90000	BTU/ hr on ... Gas 1

Components:

N	wt%	---		
S	wt%	---		
Ash	wt%	---		
Ni	ppm	---		
Va	ppm	---		
Na	ppm	---		
Fe	ppm	---		
H2	mol%	0.0%		
O2	mol%	0.0%		
N2 + Ar	mol%	1.0%		
CO	mol%	0.0%		
CO2	mol%	1.0%		
CH4	mol%	88.0%		
C2H6	mol%	8.0%		
C2H4	mol%	0.0%		
C3H8	mol%	2.0%		
C3H6	mol%	0.0%		
C4H10	mol%	0.0%		
C4H8	mol%	0.0%		
C5H12	mol%	0.0%		
C5H10	mol%	0.0%		
C6+	mol%	0.0%		
H2S	ppmv	0.0%		
SO2	mol%	0.0%		
NH3	mol%	0.0%		
H2O	mol%	0.0%		
spare	mol%	0.0%		

Burner Performance:

Minimum Heat Release	MMBTU/ hr	4.46
Design Heat Release	MMBTU/ hr	20.28
Maximum Heat Release	MMBTU/ hr	22.30
Burner Turndown	Max:Min	5.00
Volumetric Ht. Release	BTU/ hr ft3	10,034
Pressure @ Arch	inH2O	0.60
Pressure @ Burner	inH2O	7.75
Combustion Air T @ Burner	°F	60
Flue Gas T @ Burner	°F	1,260

Guaranteed Emissions:

Basis of Guarantee	---	3.0% O2, dry (LHV)
NOx Emissions	Lb/MMBTU	0.053 40 ppm
SOx Emissions	Lb/MMBTU	no quote
CO Emissions	Lb/MMBTU	0.041 50 ppm
VOC Emissions	Lb/MMBTU	0.019 15 ppm
UHC Emissions	Lb/MMBTU	0.007 15 ppm
SPM10 Emissions	Lb/MMBTU	0.014 16 ppm
Noise Emissions	dBA @ 3ft	85

Net Flame Clearances:

Est. Flame Size	approx. 19.7 ft L x 3.5 ft Diameter	
Hor Clearance	1 ft NET Tube Clearance	
Vert. Clearance	1 ft NET Tube Clearance	
Axial Clearance	1.45 ft NET Refractory Clearance (to Arch hot face)	

Nominal Flame Clearances:

from burner CL ...	Vertical	Horizontal
to Tube CL, API	ft 10.61	7.08
to Tube CL, calc.	ft 4.50	4.50
to Refrac., calc.	ft n / a	21.17

Blower/Fan Performance:

Volumetric Flow	acfm	4,300
Rated Power	HP	15
Fan Speed	RPM	3,600
Sound Pressure	dBA	< 85
Area Classification	NEC	Unclassified

PRESSURE PARTS DESIGN

1					
2					
3	Coil Design:		<u>RADIANT</u>	<u>SHIELD</u>	<u>CONVECTION</u>
4	Service		Heat Medium Heat	Heat Medium Heat	Heat Medium Heater
5	Design Basis for Tube Temperature		API 530	API 530	API 530
6	Design Basis for Tube Wall Thickness		ASME Sec. VIII-1	ASME Sec. VIII-1	ASME Sec. VIII-1
7	Design Life	hr	100,000	100,000	100,000
8	Design Pressure (elastic / rupture)	psig	150 /	150 /	150 /
9	Design Fluid Temperature	°F	305	305	305
10	Design Temperature Allowance	°F	29	29	29
11	Design Corrosion Allowance (tubes/fittings)	in	0.063 / 0.063	0.063 / 0.063	0.063 / 0.063
12					
13	Maximum Tube Temperature (clean)	°F	440		
14	Maximum Tube Temperature (fouled)	°F	486	389	582
15	Design Tube Temperature	°F	515	611	611
16	Inside Film Coefficient	BTU/ hr ft ² °F	195	141	141
17	Weld Inspection	RT or Other	100 of 100%	100 of 100%	100 of 100%
18	Weld Heat Treatment	s.rel., t.stab. or none	None	None	None
19	Hydrostatic Test Pressure	psig	per API	per API	per API
20					
21	Coil Arrangement:		Horizontal	Horizontal	Horizontal
22	Coil Type	---	Helical	Serpentine	Serpentine
23	Tube Material (pipe or tube spec)	ASTM	SA106GrB	SA106GrB	SA106GrB
24	Supplementary Mfg Requirements	ASTM	None	None	None
25	Tube Outside Diameter	in	4.500	4.500	4.500
26	Tube Wall Thickness (aw / mw)	in	0.237 / 0.207	0.237 / 0.207	0.237 / 0.207
27	Number of Cells (radiant or convection)	---	1	1	1
28	Number of Flow Passes (total / cell)	---	2 / 2	2 / 2	2 / 2
29	Number of Tubes per Row (total / cell)	---		4 / 4	4 / 4
30	Overall Tube (1 turn in radiant) Length	ft	28.27	11.54	11.54
31	Effective Tube Length / Helix Diameter	ft	28.27 / 9.00	9.96	9.96
32	Number of Turns or Tubes (total / pass)		30.7 / 15.3	4.0 / 4.0	0.0 / 0.0
33	Total Exposed Surface	ft ²	1,023	47	0
34	Number of Ext.Surf. Tubes (total / cell)	---	0 / 0.0	0 / 0.0	20 / 20.0
35	Total Exposed Surface	ft ²	0	0	2,940
36	Tube Spacing (horiz. / tube centers)	in	--- / 8.00	8.00 / 8.00	8.00 / 8.00
37	Tube Spacing (horiz. to refractory)	in	6.00	4.00	4.00
38					
39	Coil Fittings:		Heat Medium Heat	Heat Medium Heat	Heat Medium Heater
40	Fitting Type	---	SR 90° Elbows	SR 180° U-Bends	SR 180° U-Bends
41	Fitting Material	ASTM	SA234 WPB	SA234 WPB	SA234 WPB
42	Supplementary Mfg Requirements	ASTM	None	None	None
43	Fitting Outside Diameter	in	4.500	4.500	4.500
44	Fitting Wall Thickness (aw / mw)	in	0.237 / 0.207	0.237 / 0.207	0.237 / 0.207
45	Fitting Location	internal or external	Internal	External	External
46	Tube Attachment	welded or rolled	Welded	Welded	Welded
47					
48	Coil Terminals:		Outlet		Inlet
49	Terminal Type	beveled or flanged	Flanged		Flanged
50	Flange Material	ASTM	SA105		SA105
51	Supplementary Mfg Requirements	ASTM	None		None
52	Flange Size and Rating	NPS/ ASME	4" NPS / 300#		4" NPS / 300#
53	Flange Type	RFWN or RTJ	RFWN		RFWN
54	Location	---	Burner Endwall		Terminal End
55					
56	Extended Surface:			<u>CONVECTION</u>	<u>CONVECTION</u>
57	Service	---		Heat Medium Heat	Heat Medium Heater
58	Fin or Stud Row Number	starting @ bottom		No.1 / No.2-3	No.4-5 /
59	Ext. Surface Type	seg.fins, solid fins, studs		HF Seg. Fins	HF Seg. Fins
60	Fin/Stud Material	---		C.S. / C.S.	C.S. /
61	Fin/Stud Height	in		0.75 / 1.00	1.00 /
62	Fin/Stud Thickness	in		0.06 / 0.06	0.06 /
63	Fin/Stud Density	fin/ in		5.00 / 5.00	5.00 /
64					

PRESSURE PARTS DESIGN (continued)

1				
2				
3	Crossovers:		<u>RADIANT</u>	<u>SHIELD</u>
4	Type, location / connections	---	<u>External</u>	<u>Flanged</u>
5	Tube / Fittings Material	ASTM	<u>SA106GrB</u>	<u>SA234 WPB</u>
6	Tube & Fitting OD / Thickness (aw)	in	<u>4.500</u>	<u>0.237</u>
7				
8	Inlet Manifold(s):	type		<u>Simple LOG</u>
9	Location	---		<u>Top - Term. End</u>
10	Design Basis for Manifold Thickness	---		<u>ASME B31.3</u>
11	Design Conditions (temp./press.)	°F/ psig		<u>611 / 150</u>
12	Pipe Material	ASTM		<u>SA106GrB</u>
13	Fittings Material	ASTM		<u>SA234 WPB</u>
14	Flange Material / Style	ASTM		<u>SA105 / RFWN</u>
15	Outside Diameters, each Branch	in		<u>8" NPS</u>
16	Wall Thickness(es); aw or mw	in		<u>SCH40 (0.322)</u>
17	End Types (terminal/ dead)	beveled or flanged		<u>Flanged / W.Cap</u>
18	Manifold Terminal Type	NPS/ ASME		<u>8" NPS / 300# Flg</u>
19	Coil Connection Type	extrusion, olet, etc.		<u>Weld-O-Let</u>
20	Coil Terminal Type	NPS/ ASME		<u>4" NPS / 300# Flg</u>
21				
22	Outlet Manifold(s):	type	<u>Simple LOG</u>	
23	Location	---	<u>Burner Endwall</u>	
24	Design Basis for Manifold Thickness	---	<u>ASME B31.3</u>	
25	Design Conditions (temp./press.)	°F/ psig	<u>515 / 150</u>	
26	Pipe Material	ASTM	<u>SA106GrB</u>	
27	Fittings Material	ASTM	<u>SA234 WPB</u>	
28	Flange Material / Style	ASTM	<u>SA105 / RFWN</u>	
29	Outside Diameters, each Branch	in	<u>8" NPS</u>	
30	Wall Thickness(es); aw or mw	in	<u>SCH40 (0.322)</u>	
31	End Types (terminal/ dead)	beveled or flanged	<u>Flanged / W.Cap</u>	
32	Manifold Terminal Type	NPS/ ASME	<u>8" NPS / 300# Flg</u>	
33	Coil Connection Type	extrusion, olet, etc.	<u>Weld-O-Let</u>	
34	Coil Terminal Type	NPS/ ASME	<u>4" NPS / 300# Flg</u>	
35				

COIL & MANIFOLD SUPPORTS DESIGN

36				
37				
38				
39	Tube Supports:		<u>RADIANT</u>	<u>SHIELD</u>
40	Service		<u>Heat Medium Heat</u>	<u>Heat Medium Heat</u>
41	Location	Top, Bottom, Ends	<u>Bottom</u>	<u>Ends</u>
42	Support Type	casting, tubesht, spring, etc.	<u>SS Pipe Rail</u>	<u>Welded Tbsheets</u>
43	Support Thicknesses	in	<u>SCH40</u>	<u>0.375</u>
44	Support Materials	ASTM	<u>A240 T304</u>	<u>A36 CS</u>
45	Support Temperatures (calc./ design)	°F / °F	<u>840 / 1,030</u>	<u>536 / 690</u>
46	TbSht Ferrules Thickness/Materials	in/ ASTM	<u>---</u>	<u>14 ga. / 304 SS</u>
47	Refractory & Anchor Materials & Types		<u>none</u>	<u>per refrac. section</u>
48				
49	Intermediate Guides & Supports:		<u>None</u>	<u>None</u>
50	Location	---		<u>None</u>
51	Guide/ Support Type	casting, spring, etc.		
52	Material	ASTM		
53	Spacing, average	ft		
54				
55	Tube Guides:	Top, Bottom, Ends	<u>None</u>	<u>None</u>
56	Material	ASTM		
57				
58	Manifold Supports:		<u>Outlet Manifold</u>	<u>Intlet Manifold</u>
59	Material	ASTM	<u>A36</u>	<u>N/A</u>
60	Materials Design & Supply	---	<u>by THM</u>	
61	Location	Top, Bottom, Ends	<u>Burner Endwall</u>	
62	Support Type	roller, shoe, spring, etc.	<u>Simple Shelf</u>	
63	Number of Supports	---	<u>One (1)</u>	
64				

CASING / REFRACTORY SYSTEMS DESIGN

1				
2				
3				
4	Radiant Section Design:	BURNER	SHIELDED	ARCH
5	Total Refractory Thickness	ENDWALL	SIDEWALLS	ENDWALL
6	Hot Face Temperature (design)	in 5.0	3.0	5.0
7	Hot Face Temperature (calculated)	°F 2,000	2,000	2,000
8	Hot Face Layer	°F 1,452	840	1,452
9	Back-Up Layer No.1	in/ --- 1/ 8# CF Blanket	1/ 8# CF Blanket	1/ 8# CF Blanket
10	Back-Up Layer No.2	in/ --- 1/ 8# CF Blanket	2/ 6# CF Blanket	1/ 8# CF Blanket
11	Foil Vapor Barrier	in/ --- 3/ 6# CF Blanket	None	3/ 6# CF Blanket
12	Castable Reinforcement (SS Needles)	in/ --- None	None	None
13	Anchors / Tie Backs:	wt% None	None	None
14	Material	--- Pins & Clips	Pins & Clips	Pins & Clips
15	Attachment	--- 310 S.S.	304 S.S.	310 S.S.
16	Casing:	--- Welded	Welded	Welded
17	Material	in/ ASTM 0.1875 / A36	0.1345 / A36	0.1875 / A36
18	Internal Coating	--- None	None	None
19	External Temperature, Typical	°F 180	180	180
20	Comments / Clarifications	--- w/ cfb wraps	w/o cfb wraps	w/ cfb wraps
21		SHOP Installed	SHOP Installed	SHOP Installed
22				
23		SIDEWALLS	ENDWALLS	
24	Convection Section Design:	SHIELD	FINNED	TUBESHEETS
25	Total Refractory Thickness	in 3.0	3.0	3.0
26	Hot Face Temperature (design)	°F 2,000	2,000	2,200
27	Hot Face Temperature (calculated)	°F 960	960	960
28	Hot Face Layer	in/ --- 1/ 8# CF Blanket	1/ 8# CF Blanket	3/ Sparlite HS
29	Back-Up Layer No.1	in/ --- 2/ 6# CF Blanket	2/ 6# CF Blanket	None
30	Back-Up Layer No.2	in/ --- None	None	None
31	Foil Vapor Barrier	in/ --- None	None	None
32	Castable Reinforcement (SS Needles)	wt% None	None	None
33	Anchors / Tie Backs:	--- Pins & Clips	Pins & Clips	Bullhorns
34	Material	--- 310 S.S.	304 S.S.	304 S.S.
35	Attachment	--- Welded	Welded	Welded
36	Casing:			
37	Material	in/ ASTM 0.1345 / A36	0.1345 / A36	0.1345 / A36
38	Internal Coating	--- None	None	None
39	External Temperature, Typical	°F 180	180	180
40	Comments / Clarifications	--- Cleaning/Sootblowing lanes: none		Bolted Assembly
41		SHOP Installed	SHOP Installed	SHOP Installed
42				
43		FLUE GAS DUCTS		
44	Stack & Uptakes Design:	15° TRANSITION	DISCH. DUCT	
45	Quantity	One	One	
46	Type / Location	--- Full L / Conv	Self.Spt / Grade	
47	Length / Metal Outside Diameter (top)	ft/ ft 1.41 / n/a	7 / 2.333	
48	Discharge Elev., minimum/ calculated	ft/ ft n/a / n/a	20 / 24	
49	Total Refractory Thickness	in 0.0	0.0	
50	Hot Face Temperature (design)	°F		
51	Hot Face Temperature (calculated)	°F	468	468
52	Hot Face Layer	in/ --- None	None	
53	Back-Up Layer No.1	in/ ---		
54	Castable Reinforcement (SS Needles)			
55	Anchors / Tie Backs:	---		
56	Material	---		
57	Attachment	---		
58	Casing:			
59	Minimum Thickness/ Material	in/ ASTM 0.1345 / A36	0.1345 / A36	
60	Corrosion Allowance	in None	None	
61	Internal Coating	--- None	None	
62	External Temperature, Typical	°F 468	468	
63	Comments / Clarifications	---		
64				

MECHANICAL / STRUCTURAL DESIGN BASIS

1	
2	
3	Refractory & Coatings Design:
4	Refractory Design <u>Per Std560: 180°F Avg. Casing Temperature @ Ambient Conditions of 0 MPH & 80°F</u>
5	Refractory Dryout <u>SHOP dryout = None // FIELD dryout is NOT required with the use of TC's AHR additive to Castable.</u>
6	Coating, Internal <u>None</u>
7	Coating, External <u>Base Coat: 3 mils dft IOZ (InOrganic Zinc) on SP-6 Surface</u>
8	<u>Int. Coat: None</u>
9	<u>Top Coat: None</u>
10	
11	
12	
13	Applicable Standards:
14	API <u>Std 560 (ISO 13705); Fired Heaters for ...</u> AISC <u>Specification for Design, ... Steel for Buildings</u>
15	API <u>Std 530 (ISO 13704); Calc. of Heater Tube ...</u> AWS <u>D 1.1; Structural Welding Code</u>
16	ASME <u>B31.3, Chemical Plant and ... Piping</u> ASTM <u>tube/ smls pipe/ fitting spec's noted herein</u>
17	ASME <u>Sections I, II, VIII, IX; ASME B&PV Code</u> ASTM <u>refractories per C27, C155, C401 & C612</u>
18	ASME <u>Section V; Non Destructive Examination</u> NFPA <u>NFPA 70; National Electrical Code</u>
19	
20	Wind Design:
21	Spec. or Standard <u>ASCE 7-10</u>
22	Velocity/ Imp. Factor <u>120 mph / 1</u>
23	Site Exposure <u>"C"</u>
24	Physical Design:
25	Plot Limitations <u>None</u>
26	Tube Limitations <u>None</u>
27	Firebox Pressure <u>Positive; approximately +1.0 inH2O</u>
28	Ambient Temp's <u>-20 °F Min/ 60 °F Dsn/ 110 °F Max</u>
29	
30	
31	
32	
33	
34	
35	
36	
37	
38	
39	
40	
41	
42	
43	
44	
45	
46	
47	
48	
49	
50	
51	
52	
53	
54	
55	
56	
57	
58	
59	
60	
61	
62	
63	
64	

MAJOR SUBSYSTEMS & ACCESSORIES

33	Major Services & Subsystems	Major Accessories:
34	Process Design <u>INCLUDED in base pricing</u>	Casing/ Tube Seals <u>8 TubeSox; Radiant & Conv.</u>
35	Mechanical Design <u>INCLUDED in base pricing</u>	Observation Doors <u>2 4 in Dia. w/ H.T. glass</u>
36	Structural Design <u>INCLUDED in base pricing</u>	Observation Doors <u>1 4 in Dia. w/ HT glass on Arch</u>
37	Radiant Section <u>INCLUDED in base pricing</u>	Access Doors <u>1 Std 24" x 24"</u>
38	Convection Section <u>INCLUDED in base pricing</u>	Expansion Joints <u>None</u>
39	Combustion Mgmt <u>INCLUDED in base pricing</u>	Ladders & Platforms <u>Not Included</u>
40	Burner Piping <u>INCLUDED in base pricing</u>	L&P Coating <u>N/A</u>
41	Forced Draft System <u>INCLUDED in base pricing</u>	
42		
43	Casing Penetrations	Pressure Part Penetrations
44	Fbox Purge/ Snuff <u>None</u>	Coil TSTC's, Radiant <u>None</u>
45	CA Temp/Pres <u>None</u>	Coil TSTC's, Convection <u>None</u>
46	FG Temperature <u>2 1.5"NPS 3000# Coupling</u>	Process TI conn's <u>3 1.5" NPS 300# RFWN</u>
47	FG Pressure <u>2 1.5"NPS 3000# Coupling</u>	Process PI conn's <u>1 1.5" NPS 300# RFWN</u>
48	FG Comp. (Sample) <u>2 1.5"NPS 3000# Coupling</u>	spare _____
49	FG Sample <u>2 4"NPS 150# RFWN's</u>	spare _____
50	O2 Analyzer Port <u>None</u>	spare _____
51		
52	Dampers	
53	FD Fan (blower) <u>qty = 0</u>	Uptake Ducts <u>Stack qty = 0</u>
54	Note: _____	Note: _____
55	Design <u>Fan inlet damper is inappropriate</u>	Stack Damper (which provides draft
56	Materials <u>for forced draft SHO's where O2</u>	control) is inappropriate for forced
57	Bearings <u>Control is provided by the CMS O2</u>	draft SHO's where the combustion
58	Operator <u>Trim Module which controls the fan</u>	conditions are controlled real-time
59	Positioner <u>(blower) motor's VFD/ VSD.</u>	via the CMS.
60	Instruments	
61	Sootblowers: <u>Qty. Type Location FG T Material Steam T & P O.E.M. / Ref.</u>	
62	Lane 1: <u>None</u>	
63	Lane 2 : <u>None</u>	
64		

1	Owner:	Unknown	Owner Ref.:	H-781	Ftnt
2	Purchaser:	UOPR	Purch. Ref.:	J463	&
3	Manufacturer:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-266	Rev
4	SHO Model:	SHO1750	Location:	Unknown	

ASME SECTION VIII - DIVISION 1 CALCULATIONS for RADIANT COIL

Formulas:

$t.s = \frac{(P \times R_i)}{(S \times J_E - 0.6 \times P)}$ Circumferential Stress	or	$\frac{(P \times R_i)}{(2 \times S \times J_E + 0.4 \times P)}$ Longitudinal Stress	or	$\frac{(P \times R_o)}{(S \times J_E + 0.4 \times P)}$ Circumferential Stress
---	----	---	----	---

where:

t.s	Required / Minimum Stress Thickness	in	Excludes corrosion and/or erosion allowances
P	Design Pressure, per PO / Contract	psig	Per PO / Contract
Ro / Ri	Outside / Inside Radius of Tube	in	Calculated values for New Condition
S	Design (Max. Allowable) Stress @ T	psi	Per UG-23 / ASME Section II, Part D, Subpart 1
JE	Joint Efficiency, per UW-12	%	TABLE UW-12; 100% seamless pipe/tube = 1.00

	units	Variable Values	Comments
Design Pressure, P	psig	150	Design Pressure is per PO / Contract.
Design Temperatures, T.Dmax / T.Dmin.	°F	515 / -20	T.Dmax per THM calcs / T.Dmin per PO / Contract
Design Allowances, Corrosion/ Erosion	in	0.063 / 0.000	Allowances (both CA & EA) are per PO / Contract
Design Stress @ Design Temp, S	psi	17,100	Design Stress @ T.Dmax
Pipe/Tube Outside Diameter	in	4.500	
Pipe/Tube Material Standard	ASME	SA106GrB	Max. Allowable Nonconcentricity, per ASTM: 12.50%
Pipe/Tube Type	welded or seamless	Seamless	
Butt Weld Inspection	RT or Other	100 of 100%	
Tube Schedule / New Avg.Wall	ASTM	SCH 40 / 0.237	Tube Inside Radius (R.i), New = 2.013
Actual Minimum Thickness, t.new / t.EOL	in	0.207 / 0.145	t.EOL = End of Life Thickness = t.new - (CA + EA)

UG-27 Calculations:

Circumferential Stress Calculations	---	1.00	Per UW-12, Longitudinal JE of seamless pipe is 100%
UG-27(c) (1) Minimum Thickness, t.s	in	0.018	UG-27(c) (1)&(2) Thickness Check: 0.12 = OK!!
UG-27(c) (1) Surplus Wall Thickness	in	0.127	UG-27(c) (1) Pressure Limit Check: 6,584 = OK!!
UG-27(c) (1) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)
Longitudinal Stress Calculations	---	0.85	Per UW-12, Circumferential JE of butt-welds is 85%
UG-27(c) (2) Minimum Thickness, t.s	in	0.010	UG-27(c) (2) Pressure Limit Check: 18,169 = OK!!
UG-27(c) (2) Surplus Wall Thickness	in	0.135	
UG-27(c) (2) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Appendix 1, Para.1-1 Calculations:


Circumferential Stress Calculations	---		Per UW-12, Longitudinal JE of seamless pipe is 100%
Appendix 1 (1-1) (1) Min. Thickness, t.s	in		
Appendix 1 (1-1) (1) Surplus Thickness	in		
Appendix 1 (1-1) (1) Acceptability	---		Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Footnotes / Clarifications:

- Fluxed coil (inside casing) & XOvers are per ASME Section VIII -Div.1; unfluxed manifolds are per ASME B31.3.
- This design is per the 2015 Edition of Section VIII - Division 1 (UG-27 basis; not Appendix 1).
- These calculations are "preliminary" until accepted by the Coil Manufacturer; whom provides the code stamp on the coil.
- The different Design Temp's of Radiant and Convection coils reflect the heater's large process temp rise.
- Per UG-11 & UG-44, the Pressure-Temperature ratings of standard components shall be per noted ASME/ANSI Stds.
- Per UG-44, fittings per B16.9 & B16.11 shall be calculated as for straight seamless pipe per Section VIII - Division 1.
- Per UCS-66, charpy impact testing for this coil is not mandatory (ref. FIG UCS-66, Curve B).
- Work this data sheet with Heater Datasheets and General Arrangement Drawings (latest versions).
- Mandatory Appendix 1 provides supplemental design formulas that MAY be substituted for UG-27(c) formulas.
- spare

rev.	date	description	by	appv'd
1	13-Nov-17	Revised Purch. Ref. No. per Customer	JDC	JDF
0	19-Aug-17	Issued for Approval	JF	JDC

**COIL UNDER INTERNAL PRESSURE
ASME SECTION VIII - DIVISION 1 CALCS**



CONFIDENTIAL
PROPERTY of ...
TULSA HEATERS MIDSTREAM LLC

project reference: American Engineering Standard (AES) Units

FLUXED HEATER COIL

MJ17-266-COIL.VIIIds-Rev. 1 **Pg 1 of 2**

info@tulsaheatersmidstream.com u (918) 392 -8000(vce) u TULSA HEATERS MIDSTREAM LLC u 1215 S. Boulder Ste 1040 u Tulsa, OK 74119 u www.tulsaheatersmidstream.com

1	Owner:	Unknown	Owner Ref.:	H-781	Ftnt
2	Purchaser:	UOPR	Purch. Ref.:	J463	&
3	Manufacturer:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-266	Rev
4	SHO Model:	SHO1750	Location:	Unknown	

ASME SECTION VIII - DIVISION 1 CALCULATIONS for CONVECTION COIL

Formulas:

$t.s = \frac{(P \times R_i)}{(S \times J_E - 0.6 \times P)}$ <p align="center">Circumferential Stress</p>	or	$\frac{(P \times R_i)}{(2 \times S \times J_E + 0.4 \times P)}$ <p align="center">Longitudinal Stress</p>	or	$\frac{(P \times R_o)}{(S \times J_E + 0.4 \times P)}$ <p align="center">Circumferential Stress</p>
---	----	---	----	---

where:		units	comments:
t.s	Required / Minimum Stress Thickness	in	Excludes corrosion and/or erosion allowances
P	Design Pressure, per PO / Contract	psig	Per PO / Contract
Ro / Ri	Outside / Inside Radius of Tube	in	Calculated values for New Condition
S	Design (Max. Allowable) Stress @ T	psi	Per UG-23 / ASME Section II, Part D, Subpart 1
JE	Joint Efficiency, per UW-12	%	TABLE UW-12; 100% seamless pipe/tube = 1.00

Convection Coil Design Basis:

	units	Variable Values	Comments
Design Pressure, P	psig	150	Design Pressure is per PO / Contract.
Design Temperatures, T.Dmax. / T.Dmin.	°F	611 / -20	T.Dmax per THM calcs / T.Dmin per PO / Contract
Design Allowances, Corrosion/ Erosion	in	0.063 / 0.000	Allowances (both CA & EA) are per PO / Contract.
Design Stress @ Design Temp, S	psi	17,100	Design Stress @ T.Dmax
Pipe/Tube Outside Diameter	in	4.500	
Pipe/Tube Material Standard	ASME	SA106GrB	Max. Allowable Nonconcentricity, per ASTM: 12.50%
Pipe/Tube Type	welded or seamless	Seamless	
Butt Weld Inspection	RT or Other	100 of 100%	
Tube Schedule / New Avg.Wall	ASTM	SCH 40 / 0.237	Tube Inside Radius (R.i), New = 2.013
Actual Minimum Thickness, t.new / t.EOL	in	0.207 / 0.145	t.EOL = End of Life Thickness = t.new - (CA + EA)

UG-27 Calculations:

Circumferential Stress Calculations	---	1.00	Per UW-12, Longitudinal JE of seamless pipe is 100%
UG-27(c) (1) Minimum Thickness, t.s	in	0.018	UG-27(c) (1)&(2) Thickness Check: 0.12 = OK!!
UG-27(c) (1) Surplus Wall Thickness	in	0.127	UG-27(c) (1) Pressure Limit Check: 6,584 = OK!!
UG-27(c) (1) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)
Longitudinal Stress Calculations	---	0.85	Per UW-12, Circumferential JE of butt-welds is 85%
UG-27(c) (2) Minimum Thickness, t.s	in	0.010	UG-27(c) (2) Pressure Limit Check: 18,169 = OK!!
UG-27(c) (2) Surplus Wall Thickness	in	0.135	
UG-27(c) (2) Acceptability	---	Acceptable!	Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Appendix 1, Para.1-1 Calculations:

Circumferential Stress Calculations:	---		Per UW-12, Longitudinal JE of seamless pipe is 100%
Appendix 1 (1-1) (1) Min. Thickness, t.s	in		
Appendix 1 (1-1) (1) Surplus Thickness	in		
Appendix 1 (1-1) (1) Acceptability	---		Acceptable if t.EOL > t.s (ie, Surplus Thickness > 0.000)

Footnotes / Clarifications:

- a) Fluxed coil (inside casing) & XOvers are per ASME Section VIII -Div.1; unfluxed manifolds are per ASME B31.3.
- b) This design is per the 2015 Edition of Section VIII - Division 1 (UG-27 basis; not Appendix 1).
- c) These calculations are "preliminary" until accepted by the Coil Manufacturer; whom provides the code stamp on the coil.
- d) The different Design Temp's of Radiant and Convection coils reflect the heater's large process temp rise.
- e) Per UG-11 & UG-44, the Pressure-Temperature ratings of standard components shall be per noted ASME/ANSI Stds.
- f) Per UG-44, fittings per B16.9 & B16.11 shall be calculated as for straight seamless pipe per Section VIII - Division 1.
- g) Per UCS-66, charpy impact testing for this coil is not mandatory (ref. FIG UCS-66, Curve B).
- h) Mandatory Appendix 1 provides supplemental design formulas that MAY be substituted for UG-27(c) formulas.
- i) These calculations are for the Convection Coil and for the Crossovers (between radiant and convection modules).
- j) spare

rev.	date	description	by	app'vd
1	13-Nov-17	Revised Purch. Ref. No. per Customer	JDC	JDF
0	19-Aug-17	Issued for Approval	JF	JDC



CONFIDENTIAL
PROPERTY of ...
TULSA HEATERS MIDSTREAM LLC

project reference: American Engineering Standard (AES) Units

**COIL UNDER INTERNAL PRESSURE
ASME SECTION VIII - DIVISION 1 CALCS**

**FLUXED HEATER COIL
MJ17-266-COIL.VIIIids-Rev. 1 Pg 2 of 2**

Ftnt
&
Rev

1					
2	Owner:	Unknown	Owner Ref.:	H-781	
3	Purchaser:	UOPR	Purch. Ref.:	J463	
4	Heater Mfg:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-266	
5	Burner OEM:	Callidus Technologies, LLC	OEM Ref.:	9020130	
6	SHO Model:	SHO1750	Service:	Heat Medium Heater	
7	CMS Model:	CMS2500	Location:	Unknown @ 750 ft elevation	
8					

GENERAL DESIGN CONDITIONS

General Application:

13	Service	---	<u>Heat Medium Heater</u>	<u>Heat Medium Heater</u>
14	Operating Case	---	<u>Over-Design Case</u>	<u>Design Case</u>
15	Burner Type		<u>Enhanced IFGR</u>	<u>Enhanced IFGR</u>
16	Burner Quantity	---	<u>1</u>	<u>1</u>
17	Model & Size:	---	<u>CUBL-5W</u>	<u>CUBL-5W</u>
18	Flame Shape	cylindrical or flat	<u>Cylindrical</u>	<u>Cylindrical</u>
19	Applicable Fuel(s)	---	<u>Fuel Gases pg. 2</u>	<u>Fuel Gases pg. 2</u>
20	Location(s) / Firing Direction		<u>Endwall Center</u>	<u>Endwall Center</u>
21	Firing Orientation		<u>Horizontal</u>	<u>Horizontal</u>
22	BridgeWall Temperature, calc.	°F	<u>1,452</u>	<u>1,402</u>

Heat Release Performance:

24			<u>MMBTU/hr</u>	<u>MMBTU/hr</u>
25	Operating Case	---	<u>Over-Design Case</u>	<u>Design Case</u>
26	Max. Heat Release, per Burner	LHV Basis	<u>22.30</u>	<u>20.04</u>
27	Design Heat Release, per Burner	LHV Basis	<u>20.28</u>	<u>18.22</u>
28	Min. Heat Release, per Burner	LHV Basis	<u>4.46</u>	<u>4.46</u>
29	Turndown, minimum/ actual	max / min	<u>5.00 / 5.00</u>	<u>5.00 / 5.00</u>

Radiant Dimensions:

33	Casing Width / Height, Casing	face - face	<u>10.50 / (126)</u>
35	Casing Length, Casing to Casing	face - face	<u>22.00 / (264)</u>
36	Helical Coil CenterLine Diameter	CL - CL	<u>9.00 / (108)</u>
37	Helical Coil Inside Diameter	face - face	<u>8.63 / (104)</u>
38	Serpentine Coil CtrLine Dimensions	W / H	
39	Serpentine Coil Inside Dimensions	face - face	
40	Firebox Length, Refractory Faces	face - face	<u>21.17 / (254)</u>

Flame Dimensions:

Burner CL elev., approx.	AG	<u>5.75 / (69)</u>
Flame Length, calc.	@ design HR	<u>19.7 / (237)</u>
Flame Dia., calc.	@ design HR	<u>3.50 / (42)</u>

Actual Clearances

Burner - tube (tangential)	CL / Net	<u>4.50 / (54)</u>
----------------------------	----------	--------------------

Combustion Air (CA) Basis - All Fuel(s):

43	CA Temperature, min.	<u>-20 °F</u>	FG Draft, at Bridgewall	<u>0.60 inH2O</u>	(positive)
44	CA Temperature, design	<u>60 °F</u>	CA Pressure, at Burner	<u>7.75 inH2O</u>	(positive)
45	CA Temperature, max.	<u>110 °F</u>	CA Pressure Drop, Design	<u>7.10 inH2O</u>	
46	CA Pressure, Ambient	<u>14.30 psia</u>	CA Pressure Drop, Actual	<u>t.b.q. inH2O</u>	
47	CA Humidity, Design	<u>50% %RH</u>			

Emissions -

49	Design/ Guaranteed Emissions:	---	Gaseous Fuel(s):	<u>3.0% O2, dry (LHV)</u>	Liquid Fuel(s):	<u>no</u>
51	NOx Emissions	LHV Basis	<u>0.053</u>	<u>Lb/MMBTU</u>		
52	SOx Emissions	LHV Basis	<u>no quote</u>	<u>Lb/MMBTU</u>		
53	CO Emissions	LHV Basis	<u>0.041</u>	<u>Lb/MMBTU</u>		
54	VOC Emissions	LHV Basis	<u>0.019</u>	<u>Lb/MMBTU</u>		
55	UHC Emissions	LHV Basis	<u>0.007</u>	<u>Lb/MMBTU</u>		
56	SPM10 Emissions	LHV Basis	<u>0.014</u>	<u>Lb/MMBTU</u>		
57	Noise Emissions	---	<u>85</u>	<u>dBA @</u>		

59					
60					
61					
62	Rev. 1	13-Nov-17	Revised Purchaser Ref. No. per Customer Comments	JDC	JF
63	Rev. 0	19-Aug-17	Issued for Approval	JF	JDC
64	revision	date	description	by	chk'd
					appv'd



BURNER DATA SHEET
AES SYSTEMS of UNITS

MJ17-266-BRNRds-Rev. 1

Owner Ref.: **H-781**

THM Ref.: **MJ17-266**

Ftnt
&
Rev

GASEOUS FUEL(S) & PRODUCTS OF COMBUSTION

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64

Fuel Gas Basis:	---	Gas 1	Mol.Wt.			
Operating Mode	---	Over-Design Case				
Temperature, at Burner	°F	100				
Pressure, at Burner (available)	psig	75				
LHV (net HV), mass basis	AES units	20,426	BTU/ Lbm			
LHV (net HV), volume basis	AES units	976	BTU/ scf			
HHV (gross HV), mass basis	AES units	22,613	BTU/ Lbr			
HHV (gross HV), volume basis	AES units	1,080	BTU/ scf			
Molecular Weight (mass)	all units	18.13	x/ x mole			

Fuel Gas Composition(s):	symbol	MW	Gas 1	Mol.Wt.			
	H2	2.02	0.00%	mole %			
	O2	32.00	0.00%	mole %			
	N2 + Ar	28.15	1.00%	mole %			
	CO	28.01	0.00%	mole %			
	CO2	44.01	1.00%	mole %			
	CH4	16.04	88.00%	mole %			
	C2H6	30.07	8.00%	mole %			
	C2H4	28.05	0.00%	mole %			
	C3H8	44.10	2.00%	mole %			
	C3H6	42.08	0.00%	mole %			
	C4H10	58.12	0.00%	mole %			
	C4H8	56.11	0.00%	mole %			
	C5H12	72.15	0.00%	mole %			
	C5H10	70.13	0.00%	mole %			
	C6+	86.18	0.00%	mole %			
	H2S	34.08	0.00%	mole %			
	SO2	64.06	0.00%	mole %			
	NH3	17.09	0.00%	mole %			
	H2O	18.02	0.00%	mole %			
	spare		0.00%	mole %			

Products of Combustion @ Design:		Gas 1	Mol.Wt.			
Excess Air Concentration	mole%	15%	mole%			
Temperature, PoC at Bridgeway	°F	1,452				
Temperature, PoC at Burner	°F	1,260				
Temperature, PoC Acid Dew Point	°F	151				

			<< ----- mass balance by TULSA HEATERS MIDSTREAM LLC ----- >>			
Combustion Mass Balances:		MW	Lbm/ hr			
Fuel Flow Rates	mass in		993			
Comb. Air Flow Rates	mass in	28.96	18,747			
POC Mass Flow Rates (wet)	mass out	27.89	19,739			
POC Mass Flow Rates (dry)	mass out	29.91	17,573			
POC Component Flow Rates ...	O2	32.00	564			
	N2 + Ar	28.15	14,335			
	CO2	44.01	2,671			
	H2O	18.02	2,166			
			<< ----- vapor / solid concentrations are in ppmvd / ppm, resp. ----- >>			
	NOx	46.01	1.08	40 ppm		
	SOx	64.06	0.00	0 ppm		
	CO	28.01	0.82	50 ppm		
	VOC	44.10	0.39	15 ppm		
	UHC	16.04	0.14	15 ppm		
	SPM		0.28	16 ppm		

ADDITIONAL REQUIREMENTS

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64

QA Requirements:

Performance Test @ shop --- Not Required
 CFD Model of Firebox --- None
 CFM of CA Ducting --- None
 Mill Certs, fuel wetted parts --- Not Required
 PMI, fuel wetted parts --- Not Required

Fuel Wetted Components:

Oil Gun Model --- None
 Gun Tip / Atomizer Mat'ls ASTM None / None
 Gas Risers Material ASTM t.b.d.
 Gas Manifolds Mat'l ASTM Carbon Steel

Burner Pilot:

model by O.E.M.
 Type --- Self-Inspiring
 Heat Release BTU/ hr > 90,000
 Ignition Method man.or elec. Electric
 Pilot Fuel Gas --- Gas 1 Mol.Wt.
 Pilot Detection type or none None
 Fuel P, avail. @ pilot psig 10 (5 -15 is OK)

Connections:

Primary Fuel Gas sz & spec by OEM & 150# A105 RF
 Secondary Fuel Gas sz & spec None
 Fuel Oil sz & spec None
 Atomizing Media sz & spec None
 Pilot Gas sz & spec by OEM & 150# A105 RF
 Detector, Main Flame sz & spec None
 Detector, Pilot Flame sz & spec by OEM - UV Scanner Mount
 Sight Ports sz & spec None

Windbox or Plenum:

Individual windbox yes or no yes
 Material Description th x ASTM 12 ga. x A36
 Common Plenum Depth ft. none
 Refractory Description th x type 1.00 in x Min.Wool
 Refractory Anchors ASTM C.S. Expanded Metal
 Register Type none
 Register Material ASTM C.S.
 Leakage, guaranteed wt% < 5.0 % of Max HR Flow
 Actuation man., pneu.or elec. manual

APPLICABLE SPECIFICATIONS & STANDARDS

TULSA HEATERS MIDSTREAM LLC Specifications:

- a) Burner scope ...
 - 1) Pilot w/ Electric Ignition - Ignition Transformer is by others (CMS Supplier)
 - 2) UV Scanner is by others. Swivel scanner mount (by burner supplier) aimed at pilot and main flame when pilot off.
 - 3) Sight port(s) for viewing pilot and main flames.
- b) Burner shall have 5:1 turndown; this capability shall NOT compromise flame size or performance.
- c) External Coatings shall be as follows:

Prime:	3 mils dft IOZ (InOrganic Zinc) on SP-6 Surface
Intermediate:	None
Finish:	None
- d) Burner is mounted and fired horizontally. Tile to be shop mounted in 304 SS case.
- e) Even though job location/elevation is different, burner to be sized to range from sea level to 3500 ft and worst case air delta P reported.

1	Owner:	Unknown	Owner Ref.:	H-781	Ftnt
2	Purchaser:	UOPR	Purch. Ref.:	J463	&
3	Heater OEM:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-266	Rev
4	CMS OEM:	International Custom Controls	CMS Model:	CMS2500	

6					
7					
8	System Overview:				
9	Design Philosophy	Meet or Exceed NFPA 85 with packaged Combustion Management System			
10	Heater DHR	Heater Design Heat Release = 22 MMBTU/hr (LHV); ref. Burner Data Sheets for fuel composition			
11	CMS DHR	CMS Design Heat Release = 25 MMBTU/hr (LHV); ref. Burner Data Sheets for fuel composition			
12	No. of Burners	One Callidus CUBL-5W Burner per heater			
13					
14	THM Specs	Provided datasheets	Ambient P, Design	750 ft AMSL =	14.30 psia
15	THM P&ID	CMS2500 P&ID	Ambient T Range	-20 °F Minimum to 110 °F Maximum	
16	Area Classification	Unclassified	Noise Limit	85 dBA @ 3 ft	
17	Supply Power	120V / 1 ph / 60 Hz	Ind. Standard(s)	B31.3, NFPA 70 (NEC), NFPA 85	
18	Supply Air	80 psig	Customer Specs	None	

19							
20	Subsystem Design:		Dsn P	Dsn T	NPS	Dsn V	End Con.⁴
21	Main Gas Train ³	Double Block & Bleed SDVs with ZSC's	150 psig	150°F	2"	67	150# RF
22	Pilot Gas Train	Double Block & Bleed SDVs	150 psig	150°F	1/2"	11	150# RF
23	Instrument Air Hdr		125 psig	150°F	1"	---	150# RF
24	Main Oil Train	None					
25	Atom. Media Train	None					
26	Local Panel (LCP)	NEMA 4 Enclosure for Controls, HMI, Pushbuttons & Lights				Z-Purge:	No
27	Other Panel(s)	NEMA 7 Enclosure with 6kV Ignition Transformer & 7mm HiV IGN Cable					
28	Other Panel(s)	None					
28	Forced Draft Sys.	One FD Fan ¹ ; a) unlined ducting, b) CA controlled by	Damper				

30	Minimum Pre-Purge Interlocks:		Minimum Purge Interlocks:
31	✓ Manual ESD Switch (pushbutton)	✓ Gas Supply Low Pressure	✓ Minimum CA Flow
32	✓ SDVs FailSafe Positions	✓ Gas to Burner High Pressure	
33	✓ Stack High Temperature	- Firebox High Pressure	
34	✓ Process High Temperature	- Oil Supply Low Pressure	
35		- Atom.Media Low Pressure	

37	Gas / Oil Trains Overview:	Local Panel Components Overview:
38	✓ Pilot Double Block & Bleed SDVs	✓ Slate Control Package
39	✓ Gas Train Dbl Block & Bleed SDVs	✓ Touchscreen HMI
40	✓ Inlet Header Isolation Valve	- Remote Control Panel
41	✓ Inlet Header Sediment Trap w/ Cap	- Field Wiring schematic to connect LCP to J/B
42	✓ Inlet Header Gas Strainer	- LCP Weather/Sun Shield
43	✓ Inlet Header Pressure Regulator	
44	- Inlet Header Relief Valve	

45	- Oil Train Dbl Block & Bleed SDVs	Supporting Components:
46	- Atom.Media dP Controls	✓ Pilot Flame UV Detector
47	- Gas/ Oil Flow Element	- Main Flame UV Detector
48	- Comb. Air Flow Element	✓ CA Ducting to Burner(s)
49	- Min. Fire PCV in Parallel w/ TCV	✓ Flex Hoses at Brnr Terminals
50		- Individual Burner SDVs
51		✓ Fuel Train Only (no skid)
52		- O2 Analyzer
53		✓ Process TC (control loop)
54		✓ Process TC (shutdown)
55		✓ Process Pressure Gauge ²
56		✓ Stack TC
57		- Process Coil Relief

- NOTES:
1. Forced draft fan supplied by THM
 2. Process Pressure Gauge to be designed for 0-150 psig
 3. ZSC's only on block valves, not bleed.
 4. Piping 2" and below to use threaded fittings, except end connections.
 5. FAT required

60					
61					
62	1	13-Nov-17	Rev'd Purch. Ref. No.	JDC	JF
63	0	19-Aug-17	Issued for Approval	JF	JDC
64	rev.	date	description	by	app'v'd



COMBUSTION MANAGEMENT SYSTEM
25 MMBTU/hr RATED HEAT RELEASE

CMS2500 DATA SHEET
MJ17-266-CMS2500ds- Rev. 1

Purch. Ref.: **H-781**

THM Ref.: **MJ17-266**

Process Interlocks:

	units	Tag No.	Factory Settings		Design Conditions		Comments
			Low	High	Min.	Design	
Process Flow	MLb/hr	FALL-300	105.1	None	116.2	267.8	---
		Action:	S/D @ minimum flow to avoid "short circuiting" one or more coil passes				
Process Temperature	°F	TSHH-202	None	355	---	305	355
		Action:	S/D @ maximum fluid temperature to avoid "overheating" the coil				

Heater Interlocks:

Stack Temperature	°F	TSHH-201	None	700	429	483	---
		Action:	S/D @ 700 F, which is indicative of an "out-of-control" fire in the heater				

CMS Interlocks:

FG Train Pressure	psig	PSLL-101	10	None	---	---	150
		Action:	S/D @ 10 psig, which is indicative of "inadequate" fuel gas supply				

FG Train Pressure	psig	PSHH-103	None	35	---	---	150
		Action:	S/D @ 35 psig, which is indicative of a "failure" of PCV-100 &/or FG supply				

FD Fan Interlocks:

FD Fan (blower) SP	inH2O	PSLL-107	0.20	None	0.47	7.8	11.8
FD Fan (blower) FDF shutdown:	5.0	Action:	S/D @ 0.2 inH2O, which is indicative of a FD Fan (blower) "failure".				

Other permissives/interlocks in BMS Operations Manual (block valves, FCV, and flame signal).

CMS CONTROL COMPONENTS

	units	Tag No.	Factory Settings		Design Conditions		Comments
			Low	High	Min.	Design	
Remote T Setpoint	°F	TY-700	0	999	---	305	355
		Action:	4 -20 mA input corresponds to a temperature setpoint range of 0 -999 °F				
Process Temperature	°F	TT-203	0	999	---	305	355
		Action:	4 -20 mA output corresponds to a process temperature range of 0 -999 °F				
Main Gas Regulator	psig	PCV-100	---	---	---	35	150
Pilot Gas Regulator	psig	PCV-105	---	---	---	10	150
Inst. Air Regulator	psig	PCV-107	---	---	---	80	150

CUSTOMER CONNECTIONS (TO DCS)

The following signals are sent to the customer's DCS from the control panel:

- Remote ESD
- Heater Run
- Low Process Flow
- High Stack Temperature
- High Process Temperature
- Burner Status

Fnt
&
Rev

1					
2	Owner:	Unknown	Heater Ref.:	H-781	
3	Purchaser:	UOPR	Purch. Ref.:	J463	
4	Heater Mfg:	Tulsa Heaters Midstream, LLC	THM Ref.:	MJ17-266	
5	Location:	Unknown	FD OEM Ref.:	340829	
6	FD Fan OEM:	Chicago Blower	FD Item No.:	BL-781	

9	General Application:				
10	FD Fan(s) Design Basis	mass.flow.%	115% of Design MASS Flows per API Standard 560		
11	Location(s)	---	@ Grade, adjacent to Burner Endwall (incorporated into Combustion Skid)		
12	Area Classification	NEC	Unclassified		


14	AES Units				
15	Process Design Conditions:				
16	Mass Flow Rate/ % Htr Design	Lb/hr / kg/ hr	18,747 / 100%	21,560 / 115%	
17	Volumetric Flow/ % Htr Design	acfm / am3/ hr	4,300 / 100%	5,300 / 123%	
18	Density, @ Suction	as noted	0.074 Lb/ ft3	0.068 Lb/ ft3	
19	Design Allowances, Temp./ SP	°F / °C	---	130 °F / 152%	
20	Temperature @ Min / Suction / Design	°F / °C	-20 / 60 / 110		
21	Static Pressure @ Suction	as ntoed	-0.2 inH2O	-0.2 inH2O	
22	Site Elevation/ Atm. P	as ntoed	750 ftAMSL	14.30 psia	
23	Static Pressure Rise (min./ guar.)	inH2O	7.8 / 7.8	11.8 / 11.8	
24	Fan Speed (allowable/ actual)	RPM	3,600 / 3,525	3,600 / 3,525	
25	Sound Pressure (allowable/ guar.)	dBA	< 85 / < 85	< 85 / < 85	
26	Relative Humidity	%	50%		

28	Fan Mechanical Design:	tag // OEM	BL-781 // CHICAGO BLOWER Corp.		
29	OEM Reference	CMS // FD Fan	International Custom Controls // 340829		
30	OEM Model &/or Type-Size	per OEM	D/36A (SQAD)		
31	Arrangement	---	Arrangement 4 (direct drive)		
32	Brake Power, Design/ Test Block (calc.)	HP	15.0	/ 20.0	
33	Temperature, Mechanical Design	°F	135 °F Mechanical Design		
34	Casing Description / Materials	---	"Square" pattern / CS		
35	Rotor Description / Materials	---	Airfoil Blades / CS		
36	Shaft Description / Materials	---	None - Arrangement 4		
37	Bearings Description / Materials	---	None - Arrangement 4		
38	Noise Abatement Provisions / SPL	---	85 dBA		
39	External Coatings / Surface Prep.	---	OEM's Std Multiple Coat System		
40	Purchase Specifications	---	OEM's Std Industrial Quality Design		

42	Fan Control Design:	tag // OEM	VSD-781 / by OTHERS		
43	VFD Description	---	by Others / Owner		
44	VFD Rating	---			
45	Damper Actuator Description	---			
46	Damper Actuator Operation	---			

48	Fan Motor Design:	tag // OEM	BM-781 / TECO-WESTINGHOUSE		
49	OEM Model &/or Type-Size	---	Catalog EP0202 / AEHH8N		
50	VFD Service / speed range	---	YES / 3 - 60 Hz or 180 - 3,600 rpm		
51	Motor Type / Frame Size	---	NEMA TEFC / 256T		
52	Rated Power w/ SF @ Speed	NEMA	20	HP w/ 1.15 SF @ 40°C	
53	Nameplate Input Power	V/ Hz/ ph	460V / 60 Hz / 3 ph		
54	Typical Performance	---	91.0- 92.4 % FL Effy @ 92.5 % FL PF		
55	Insulation Description	---	Class F / B Rise		
56	External Coatings & Surface Prep.	---	OEM's Std Multiple Coat System		
57	Purchase Specifications	---	None		

59					
60					
61					
62	Rev. 1	13-Nov-17	Revised Purchaser Ref. No. per Customer Comments	JDC	JF
63	Rev. 0	19-Aug-17	Issued for Approval	JF	JDC
65	revision	date	description	by	chk'd appv'd


 <p>USA Applications SHO = Superior Quality, Flexibility, Dependability & Modularity</p>	FD FAN DATA SHEET AES & cgs or SI SYSTEMS of UNITS	
	MJ17-266-FDFANds-Rev. 1	Page 1 of 1

his document contains confidential information, which is proprietary to THM. This document shall not be used, reproduced or disclosed without the prior written consent of THM


LUCID GAS PLANT – TANKS LOSSES

- FEED TO SLOP TANKS COMPOSITION taken from Excel file "Lucid RH5 Mol Sieve 245MM (04.24.19)" Stream 16, provided by client.
- FEED TO CONDENSATE TANKS COMPOSITION taken from Excel file "Lucid Expansion 10K – Stabilizer Sweet-Sour Feed (05.3.19)", stream "Storage" provided by client.
- FEED TO SOUR WATER TANKS COMPOSITION taken from Excel file "Lucid AGI-Sour Water (05.3.19)", stream "Sour Water " provided by client.
- SOURCES: e-mail by Chris Kassen <CKassen@lucid-energy.com> on Friday, May 3, 2019 12:49 PM


CONDENSATE TANKS



SLOP TANKS



SOUR WATER TANKS



Project Information	
File Name	LUCID
Company	
City	
State	
Equation of State	Peng-Robinson
Description	

Separator Information	
Separator Name	2 x 500bbls Sour Water Tanks
Separator Inlet Stream	AGI SOUR WATER
Separator Inlet Pressure [psia]	14.70
Separator Inlet Temperature [°F]	120.00
Separator Outlet Pressure [psia]	13.28
Separator Outlet Temperature [°F]	80.76

Tank Specifications	
Tank Losses Stencil Name	Tank-1
Tank Losses Stencil Reference Stream	AGI SOUR WATER
Number of Tanks	2
Shell Height [ft]	16
Diameter [ft]	15.5
Maximum Fill Percent [%]	100
Average Fill Percent [%]	50
Total Tank Volume [bbl]	537.7
Is Tank Heated?	

Paint Characteristics	
Shell Color	Tan
Shell Paint Condition	Good
Roof Color	Tan
Roof Condition	Good

Roof Characteristics	
Type	Cone
Diameter [ft]	18
Slope [ft/ft]	0.0625

Breather Vent Settings	
Vacuum Settings [psig]	-0.030
Pressure Settings [psig]	0.030

Meteorological Data	
Location	Midland-Odessa, Texas
Atmospheric Pressure [psia]	13.28
Min Ambient Temperature [°F]	49.33
Max Ambient Temperature [°F]	77.23
Solar Insolation [BTU/ft2*day]	1689.49
Wind Speed [mph]	11.12

Tank Conditions	
Atmospheric Pressure [psia]	13.28
Flashing Temperature [°F]	110.89
Max Liquid Surface Temperature [°F]	110.89
Avg. Liquid Surface Temperature [°F]	100.78
Avg. Throughput [bbl/d] [bbl/yr]	88 31951
Turnovers Per Tank [per year]	30
Throughput [bbl/d] [bbl/yr]	44 15975
Throughput Per Tank [bbl/d] [bbl/yr]	0 0
True Vapor Pressure [psia]	11.90

Emission Summary [Total]										
Item	Flashing Losses		Working Losses		Breathing Losses		Loading Losses		Total Losses	
	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]
VOCs (C3+)	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
HAPs	0.080	0.349	0.000	0.000	0.328	1.437			0.408	1.787
BTEX	0.000	0.000	0.000	0.000	0.000	0.000			0.000	0.000
H2S	0.080	0.349	0.000	0.000	0.328	1.437			0.408	1.787

Emission Summary [Per Tank]										
Item	Flashing Losses		Working Losses		Breathing Losses		Loading Losses		Total Losses	
	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]
VOCs (C3+)	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
HAPs	0.040	0.175	0.000	0.000	0.164	0.719	0.000	0.000	0.204	0.893
BTEX	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
H2S	0.040	0.175	0.000	0.000	0.164	0.719	0.000	0.000	0.204	0.893

Stream Composition										
No.	Component	Pressurized Inlet [Mol%]	Flashing Losses [Mol%]	Working Losses [Mol%]	Breathing Losses [Mol%]	Loading Losses [Mol%]	Residual [Mol%]			
1	Nitrogen	0.000	0.000	0.000	0.000	0.000				
2	Methane	0.000	0.000	0.000	0.000	0.000				
3	Carbon Dioxide	0.041	75.687	45.448	45.448					
4	Ethane	0.000	0.000	0.000	0.000					
5	Propane	0.000	0.000	0.000	0.000					
6	Isobutane	0.000	0.000	0.000	0.000					
7	n-Butane	0.000	0.000	0.000	0.000					
8	Isopentane	0.000	0.000	0.000	0.000					
9	n-Pentane	0.000	0.000	0.000	0.000					
10	Cyclopentane	0.000	0.000	0.000	0.000					
11	2-Methylpentane	0.000	0.000	0.000	0.000					
12	3-Methylpentane	0.000	0.000	0.000	0.000					
13	n-Hexane	0.000	0.000	0.000	0.000					
14	Methylcyclopentane	0.000	0.000	0.000	0.000					
15	Benzene	0.000	0.000	0.000	0.000					
16	Cyclohexane	0.000	0.000	0.000	0.000					
17	2-Methylhexane	0.000	0.000	0.000	0.000					
18	3-Methylhexane	0.000	0.000	0.000	0.000					
19	n-Heptane	0.000	0.000	0.000	0.000					
20	Methylcyclohexane	0.000	0.000	0.000	0.000					
21	Toluene	0.000	0.000	0.000	0.000					
22	n-Octane	0.000	0.000	0.000	0.000					
23	Ethylbenzene	0.000	0.000	0.000	0.000					
24	n-Nonane	0.000	0.000	0.000	0.000					
25	n-Decane	0.000	0.000	0.000	0.000					
26	Undecane	0.000	0.000	0.000	0.000					
27	Dodecane	0.000	0.000	0.000	0.000					
28	Water	99.942	9.930	28.108	28.108					
29	Hydrogen Sulfide	0.017	14.383	26.444	26.444					
30	2,2-Dimethylpropane	0.000	0.000	0.000	0.000					
31	2,2-Dimethylbutane	0.000	0.000	0.000	0.000					
32	2,3-Dimethylbutane	0.000	0.000	0.000	0.000					
33	2,2,4-Trimethylpentane	0.000	0.000	0.000	0.000					
34	Tridecane	0.000	0.000	0.000	0.000					
35	Tetradecane	0.000	0.000	0.000	0.000					
36	Pentadecane	0.000	0.000	0.000	0.000					
37	Hexadecane	0.000	0.000	0.000	0.000					
38	Heptadecane	0.000	0.000	0.000	0.000					
39	Octadecane	0.000	0.000	0.000	0.000					
40	Nonadecane	0.000	0.000	0.000	0.000					
41	Eicosane	0.000	0.000	0.000	0.000					
42	Heneicosane	0.000	0.000	0.000	0.000					
43	Docosane	0.000	0.000	0.000	0.000					
44	Tricosane	0.000	0.000	0.000	0.000					
45	Tetracosane	0.000	0.000	0.000	0.000					
46	Pentacosane	0.000	0.000	0.000	0.000					
47	Hexacosane	0.000	0.000	0.000	0.000					
48	Heptacosane	0.000	0.000	0.000	0.000					
49	Octacosane	0.000	0.000	0.000	0.000					
50	Nonacosane	0.000	0.000	0.000	0.000					
51	triacontane	0.000	0.000	0.000	0.000					
52	2,2,4-Trimethyl-4-pentene	0.000	0.000	0.000	0.000					
53	m-Xylene	0.000	0.000	0.000	0.000					
54	o-Xylene	0.000	0.000	0.000	0.000					
55	1,1-2-Dimethylcyclopentane	0.000	0.000	0.000	0.000					
56	4,4-Dimethyl-c-pentene-2	0.000	0.000	0.000	0.000					
57	p-Xylene	0.000	0.000	0.000	0.000					
58	TEG	0.000	0.000	0.000	0.000					
59	Piperazine	0.000	0.000	0.000	0.000					
60	MDEA	0.000	0.000	0.000	0.000					
61	O2	0.000	0.000	0.000	0.000					

Stream Mass Flow [Total]										
No.	Component	MW [lb/lbmol]	Pressurized Inlet [lb/hr]	Flashing Losses [lb/hr]	Working Losses [lb/hr]	Breathing Losses [lb/hr]	Loading Losses [lb/hr]	Residual [lb/hr]	Total Emissions [lb/hr]	
1	Nitrogen	28.013	0.000	0.000	0.000	0.000			0.000	
2	Methane	16.042	0.000	0.000	0.000	0.000			0.000	
3	Carbon Dioxide	44.010	1.270	0.542	0.000	0.728			1.270	
4	Ethane	30.069	0.000	0.000	0.000	0.000			0.000	
5	Propane	44.096	0.000	0.000	0.000	0.000			0.000	
6	Isobutane	58.122	0.000	0.000	0.000	0.000			0.000	
7	n-Butane	58.122	0.000	0.000	0.000	0.000			0.000	
8	Isopentane	72.149	0.000	0.000	0.000	0.000			0.000	
9	n-Pentane	72.149	0.000	0.000	0.000	0.000			0.000	
10	Cyclopentane	70.133	0.000	0.000	0.000	0.000			0.000	
11	2-Methylpentane	86.175	0.000	0.000	0.000	0.000			0.000	
12	3-Methylpentane	86.175	0.000	0.000	0.000	0.000			0.000	
13	n-Hexane	86.175	0.000	0.000	0.000	0.000			0.000	
14	Methylcyclopentane	84.159	0.000	0.000	0.000	0.000			0.000	
15	Benzene	78.112	0.000	0.000	0.000	0.000			0.000	
16	Cyclohexane	84.159	0.000	0.000	0.000	0.000			0.000	
17	2-Methylhexane	100.202	0.000	0.000	0.000	0.000			0.000	
18	3-Methylhexane	100.202	0.000	0.000	0.000	0.000			0.000	
19	n-Heptane	100.202	0.000	0.000	0.000	0.000			0.000	
20	Methylcyclohexane	98.186	0.000	0.000	0.000	0.000			0.000	
21	Toluene	92.138	0.000	0.000	0.000	0.000			0.000	
22	n-Octane	114.229	0.000	0.000	0.000	0.000			0.000	
23	Ethylbenzene	106.165	0.000	0.000	0.000	0.000			0.000	
24	n-Nonane	128.255	0.000	0.000	0.000	0.000			0.000	
25	n-Decane	142.282	0.000	0.000	0.000	0.000			0.000	
26	Undecane	156.308	0.000	0.000	0.000	0.000			0.000	
27	Dodecane	170.335	0.000	0.000	0.000	0.000			0.000	
28	Water	18.015	1267.541	0.029	0.000	0.184			0.213	
29	Hydrogen Sulfide	34.081	0.408	0.080	0.000	0.328			0.408	
30	2,2-Dimethylpropane	72.149	0.000	0.000	0.000	0.000			0.000	
31	2,2-Dimethylbutane	86.175	0.000	0.000	0.000	0.000			0.000	
32	2,3-Dimethylbutane	86.175	0.000	0.000	0.000	0.000			0.000	
33	2,2,4-Trimethylpentane	114.229	0.000	0.000	0.000	0.000			0.000	
34	Tridecane	184.361	0.000	0.000	0.000	0.000			0.000	
35	Tetradecane	198.388	0.000	0.000	0.000	0.000			0.000	
36	Pentadecane	212.415	0.000	0.000	0.000	0.000			0.000	
37	Hexadecane	226.441	0.000	0.000	0.000	0.000			0.000	
38	Heptadecane	240.468	0.000	0.000	0.000	0.000			0.000	
39	Octadecane	254.494	0.000	0.000	0.000	0.000			0.000	
40	Nonadecane	268.521	0.000	0.000	0.000	0.000			0.000	
41	Eicosane	282.547	0.000	0.000	0.000	0.000			0.000	
42	Heneicosane	296.574	0.000	0.000	0.000	0.000			0.000	
43	Docosane	310.601	0.000	0.000	0.000	0.000			0.000	
44	Tricosane	324.627	0.000	0.000	0.000	0.000			0.000	
45	Tetracosane	338.654	0.000	0.000	0.000	0.000			0.000	
46	Pentacosane	352.680	0.000	0.000	0.000	0.000			0.000	
47	Hexacosane	366.707	0.000	0.000	0.000	0.000			0.000	
48	Heptacosane	380.734	0.000	0.000	0.000	0.000			0.000	
49	Octacosane	394.760	0.000	0.000	0.000	0.000			0.000	
50	Nonacosane	408.787	0.000	0.000	0.000	0.000			0.000	
51	Triacontane	422.813	0.000	0.000	0.000	0.000			0.000	
52	2,2,4-Trimethyl-4-Pentene	112.213	0.000	0.000	0.000	0.000			0.000	
53	m-Xylene	106.165	0.000	0.000	0.000	0.000			0.000	
54	o-Xylene	106.165	0.000	0.000	0.000	0.000			0.000	
55	1,1-2-Dimethylcyclopentane	98.186	0.000	0.000	0.000	0.000			0.000	
56	4,4-Dimethyl-c-pentene-2	98.186	0.000	0.000	0.000	0.000			0.000	
57	p-Xylene	106.165	0.000	0.000	0.000	0.000			0.000	
58	TEG	150.173	0.000	0.000	0.000	0.000			0.000	
59	Piperazine	86.136	0.000	0.000	0.000	0.000			0.000	
60	MDEA	119.162	0.000	0.000	0.000	0.000			0.000	
61	O2	31.999	0.000	0.000	0.000	0.000			0.000	

Stream Properties										
			Pressurized Inlet	Flashing Losses	Working Losses	Breathing Losses	Loading Losses	Residual		
MW [lb/lbmol]			18.03	40.00	34.08	34.08				
Heating Value [BTU/scf]			-	96.6	182.6	182.6				
Specific Gravity				-	-	-				
Reid Vapor Pressure [psi]			2.48	-	-	-				
Gas Volumetric Flow [scf/hr]			-	6.18	0.00	13.82				

Project information	
File Name	LUCID
Company	
City	
State	
Equation of State	Peng-Robinson
Description	

Separator Information	
Separator Name	4 x 400bbls Slop Tanks
Separator Inlet Stream	1
Separator Inlet Pressure [psia]	15.70
Separator Inlet Temperature [°F]	121.31
Separator Outlet Pressure [psia]	13.28
Separator Outlet Temperature [°F]	80.76

Tank Specifications	
Tank Losses Stencil Name	Tank-2
Tank Losses Stencil Reference Stream	1
Number of Tanks	4
Shell Height [ft]	20
Diameter [ft]	12
Maximum Fill Percent [%]	100
Average Fill Percent [%]	50
Total Tank Volume [bbbl]	402.9
Is Tank Heated?	

Paint Characteristics	
Shell Color	Tan
Shell Paint Condition	Good
Roof Color	Tan
Roof Condition	Good

Roof Characteristics	
Type	Cone
Diameter [ft]	14
Slope [ft/ft]	0.0625

Breather Vent Settings	
Vacuum Settings [psig]	-0.030
Pressure Settings [psig]	0.030

Meteorological Data	
Location	Midland-Odessa, Texas
Atmospheric Pressure [psia]	13.28
Min Ambient Temperature [°F]	49.33
Max Ambient Temperature [°F]	77.23
Solar Insolation [BTU/ft2*day]	1689.49
Wind Speed [mph]	11.12

Tank Conditions	
Atmospheric Pressure [psia]	13.28
Flashing Temperature [°F]	111.62
Max Liquid Surface Temperature [°F]	111.62
Avg. Liquid Surface Temperature [°F]	101.51
Avg. Throughput [bbbl/d] [bbbl/yr]	244 88944
Avg. Throughput Per Tank [bbbl/d] [bbbl/yr]	61 22236
Turnovers Per Tank (per year)	55
Throughput [bbbl/d] [bbbl/yr]	
Throughput Per Tank [bbbl/d] [bbbl/yr]	0 0
True Vapor Pressure [psia]	12.31

Emission Summary [Total]										
Item	Flashing Losses		Working Losses		Breathing Losses		Loading Losses		Total Losses	
	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]
VOCs (C3+)	0.308	1.351	0.001	0.003	0.023	0.099			0.332	1.453
HAPs	0.016	0.069	0.001	0.002	0.016	0.072			0.033	0.143
BTEX	0.013	0.057	0.001	0.002	0.016	0.072			0.030	0.131
H2S	0.000	0.000	0.000	0.000	0.000	0.000			0.000	0.000

Emission Summary [Per Tank]										
Item	Flashing Losses		Working Losses		Breathing Losses		Loading Losses		Total Losses	
	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]
VOCs (C3+)	0.077	0.338	0.000	0.001	0.006	0.025	0.000	0.000	0.083	0.363
HAPs	0.004	0.017	0.000	0.001	0.004	0.018	0.000	0.000	0.008	0.036
BTEX	0.003	0.014	0.000	0.001	0.004	0.018	0.000	0.000	0.007	0.033
H2S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Stream Composition									
No.	Component	Pressurized Inlet [Mol%]	Flashing Losses [Mol%]	Working Losses [Mol%]	Breathing Losses [Mol%]	Loading Losses [Mol%]	Residual [Mol%]		
1	Nitrogen	0.001	1.194	0.109	0.109				
2	Methane	0.051	72.626	13.540	13.540				
3	Carbon Dioxide	0.000	0.197	0.629	0.629				
4	Ethane	0.008	11.166	2.686	2.686				
5	Propane	0.002	3.452	0.576	0.576				
6	Isobutane	0.000	0.205	0.020	0.020				
7	n-Butane	0.001	0.771	0.119	0.119				
8	Isopentane	0.000	0.083	0.008	0.008				
9	n-Pentane	0.000	0.047	0.002	0.002				
10	Cyclopentane	0.000	0.000	0.000	0.000				
11	2-Methylpentane	0.000	0.000	0.000	0.000				
12	3-Methylpentane	0.000	0.000	0.000	0.000				
13	n-Hexane	0.000	0.023	0.001	0.001				
14	Methylcyclopentane	0.000	0.000	0.000	0.000				
15	Benzene	0.000	0.105	0.954	0.954				
16	Cyclohexane	0.000	0.010	0.005	0.005				
17	2-Methylhexane	0.000	0.000	0.000	0.000				
18	3-Methylhexane	0.000	0.000	0.000	0.000				
19	n-Heptane	0.000	0.000	0.000	0.000				
20	Methylcyclohexane	0.000	0.001	0.000	0.000				
21	Toluene	0.000	0.018	0.160	0.160				
22	n-Octane	0.000	0.000	0.000	0.000				
23	Ethylbenzene	0.000	0.000	0.000	0.000				
24	n-Nonane	0.000	0.000	0.000	0.000				
25	n-Decane	0.000	0.000	0.000	0.000				
26	Undecane	0.000	0.000	0.000	0.000				
27	Dodecane	0.000	0.000	0.000	0.000				
28	Water	99.936	10.102	81.191	81.191				
29	Hydrogen Sulfide	0.000	0.000	0.000	0.000				
30	2,2-Dimethylpropane	0.000	0.000	0.000	0.000				
31	2,2-Dimethylbutane	0.000	0.000	0.000	0.000				
32	2,3-Dimethylbutane	0.000	0.000	0.000	0.000				
33	2,2,4-Trimethylpentane	0.000	0.000	0.000	0.000				
34	Tridecane	0.000	0.000	0.000	0.000				
35	Tetradecane	0.000	0.000	0.000	0.000				
36	Pentadecane	0.000	0.000	0.000	0.000				
37	Hexadecane	0.000	0.000	0.000	0.000				
38	Heptadecane	0.000	0.000	0.000	0.000				
39	Octadecane	0.000	0.000	0.000	0.000				
40	Nonadecane	0.000	0.000	0.000	0.000				
41	Eicosane	0.000	0.000	0.000	0.000				
42	Heneicosane	0.000	0.000	0.000	0.000				
43	Docosane	0.000	0.000	0.000	0.000				
44	Tricosane	0.000	0.000	0.000	0.000				
45	Tetracosane	0.000	0.000	0.000	0.000				
46	Pentacosane	0.000	0.000	0.000	0.000				
47	Hexacosane	0.000	0.000	0.000	0.000				
48	Heptacosane	0.000	0.000	0.000	0.000				
49	Octacosane	0.000	0.000	0.000	0.000				
50	Nonacosane	0.000	0.000	0.000	0.000				
51	Triacontane	0.000	0.000	0.000	0.000				
52	2,2,4-Trimethyl-4-Pentene	0.000	0.000	0.000	0.000				
53	m-Xylene	0.000	0.000	0.000	0.000				
54	o-Xylene	0.000	0.000	0.000	0.000				
55	1,1-2-Dimethylcyclopentane	0.000	0.000	0.000	0.000				
56	4,4-Dimethyl-c-pentene-2	0.000	0.000	0.000	0.000				
57	p-Xylene	0.000	0.000	0.000	0.000				
58	TEG	0.001	0.000	0.000	0.000				
59	Piperazine	0.000	0.000	0.000	0.000				
60	MDDEA	0.000	0.000	0.000	0.000				
61	O2	0.000	0.000	0.000	0.000				

Stream Mass Flow [Total]										
No.	Component	MW [lb/lbmol]	Pressurized Inlet [lb/hr]	Flashing Losses [lb/hr]	Working Losses [lb/hr]	Breathing Losses [lb/hr]	Loading Losses [lb/hr]	Residual [lb/hr]	Total Emissions [lb/hr]	
1	Nitrogen	28.013	0.045	0.045	0.000	0.001			0.045	
2	Methane	16.042	1.596	1.555	0.001	0.040			1.596	
3	Carbon Dioxide	44.010	0.017	0.012	0.000	0.005			0.017	
4	Ethane	30.069	0.463	0.448	0.000	0.015			0.463	
5	Propane	44.096	0.208	0.203	0.000	0.005			0.208	
6	Isobutane	58.122	0.016	0.016	0.000	0.000			0.016	
7	n-Butane	58.122	0.061	0.060	0.000	0.001			0.061	
8	Isopentane	72.149	0.008	0.008	0.000	0.000			0.008	
9	n-Pentane	72.149	0.005	0.004	0.000	0.000			0.005	
10	Cyclopentane	70.133	0.000	0.000	0.000	0.000			0.000	
11	2-Methylpentane	86.175	0.000	0.000	0.000	0.000			0.000	
12	3-Methylpentane	86.175	0.000	0.000	0.000	0.000			0.000	
13	n-Hexane	86.175	0.003	0.003	0.000	0.000			0.003	
14	Methylcyclopentane	84.159	0.000	0.000	0.000	0.000			0.000	
15	Benzene	78.112	0.035	0.011	0.000	0.014			0.025	
16	Cyclohexane	84.159	0.001	0.001	0.000	0.000			0.001	
17	2-Methylhexane	100.202	0.000	0.000	0.000	0.000			0.000	
18	3-Methylhexane	100.202	0.000	0.000	0.000	0.000			0.000	
19	n-Heptane	100.202	0.000	0.000	0.000	0.000			0.000	
20	Methylcyclohexane	98.186	0.000	0.000	0.000	0.000			0.000	
21	Toluene	92.138	0.006	0.002	0.000	0.003			0.005	
22	n-Octane	114.229	0.000	0.000	0.000	0.000			0.000	
23	Ethylbenzene	106.165	0.000	0.000	0.000	0.000			0.000	
24	n-Nonane	128.255	0.000	0.000	0.000	0.000			0.000	
25	n-Decane	142.282	0.000	0.000	0.000	0.000			0.000	
26	Undecane	156.308	0.000	0.000	0.000	0.000			0.000	
27	Dodecane	170.335	0.000	0.000	0.000	0.000			0.000	
28	Water	18.015	3530.245	0.243	0.008	0.268			0.519	
29	Hydrogen Sulfide	34.081	0.000	0.000	0.000	0.000			0.000	
30	2,2-Dimethylpropane	72.149	0.000	0.000	0.000	0.000			0.000	
31	2,2-Dimethylbutane	86.175	0.000	0.000	0.000	0.000			0.000	
32	2,3-Dimethylbutane	86.175	0.000	0.000	0.000	0.000			0.000	
33	2,2,4-Trimethylpentane	114.229	0.000	0.000	0.000	0.000			0.000000	
34	Tridecane	184.361	0.000	0.000	0.000	0.000			0.000	
35	Tetradecane	198.388	0.000	0.000	0.000	0.000			0.000	
36	Pentadecane	212.415	0.000	0.000	0.000	0.000			0.000	
37	Hexadecane	226.441	0.000	0.000	0.000	0.000			0.000	
38	Heptadecane	240.468	0.000	0.000	0.000	0.000			0.000	
39	Octadecane	254.494	0.000	0.000	0.000	0.000			0.000	
40	Nonadecane	268.521	0.000	0.000	0.000	0.000			0.000	
41	Eicosane	282.547	0.000	0.000	0.000	0.000			0.000	
42	Heneicosane	296.574	0.000	0.000	0.000	0.000			0.000	
43	Docosane	310.601	0.000	0.000	0.000	0.000			0.000	
44	Tricosane	324.627	0.000	0.000	0.000	0.000			0.000	
45	Tetracosane	338.654	0.000	0.000	0.000	0.000			0.000	
46	Pentacosane	352.680	0.000	0.000	0.000	0.000			0.000	
47	Hexacosane	366.707	0.000	0.000	0.000	0.000			0.000	
48	Heptacosane	380.734	0.000	0.000	0.000	0.000			0.000	
49	Octacosane	394.760	0.000	0.000	0.000	0.000			0.000	
50	Nonacosane	408.787	0.000	0.000	0.000	0.000			0.000	
51	Triacontane	422.813	0.000	0.000	0.000	0.000			0.000	
52	2,2,4-Trimethyl-4-Pentene	112.213	0.000	0.000	0.000	0.000			0.000	
53	m-Xylene	106.165	0.000	0.000	0.000	0.000			0.000	
54	o-Xylene	106.165	0.000	0.000	0.000	0.000			0.000	
55	1,1,2-Dimethylcyclopentane	98.186	0.000	0.000	0.000	0.000			0.000	
56	4,4-Dimethyl-c-pentene-2	98.186	0.000	0.000	0.000	0.000			0.000	
57	p-Xylene	106.165	0.000	0.000	0.000	0.000			0.000000	
58	TEG	150.173	0.395	0.000	0.000	0.000			0.000	
59	Piperazine	86.136	0.000	0.000	0.000	0.000			0.000	
60	MDEA	119.162	0.000	0.000	0.000	0.000			0.000	
61	O2	31.999	0.000	0.000	0.000	0.000			0.000	

Stream Properties										
			Pressurized Inlet	Flashing Losses	Working Losses	Breathing Losses	Loading Losses	Residual		
MW [lb/lbmol]			18.02	19.56	19.15	19.15				
Heating Value [BTU/scf]			-	1066.4	287.7	287.7		-		
Specific Gravity			-	-	-	-	-	-		
Reid Vapor Pressure [psi]			1.05	-	-	-	-	-		
Gas Volumetric Flow [scf/hr]			-	50.64	0.22	6.95		-		

Project information	
File Name	LUCID
Company	
City	
State	
Equation of State	Peng-Robinson
Description	

Separator Information	
Separator Name	6 x 500bbls Condensate Tanks
Separator Inlet Stream	STORAGE
Separator Inlet Pressure [psia]	14.70
Separator Inlet Temperature [°F]	120.57
Separator Outlet Pressure [psia]	13.28
Separator Outlet Temperature [°F]	80.76

Tank Specifications	
Tank Losses Stencil Name	Tank-6
Tank Losses Stencil Reference Stream	STORAGE
Number of Tanks	6
Shell Height [ft]	16
Diameter [ft]	15.5
Maximum Fill Percent [%]	100
Average Fill Percent [%]	50
Total Tank Volume [bbl]	537.7
Is Tank Heated?	

Paint Characteristics	
Shell Color	Tan
Shell Paint Condition	Good
Roof Color	Tan
Roof Condition	Good

Roof Characteristics	
Type	Cone
Diameter [ft]	18
Slope [ft/ft]	0.0625

Breather Vent Settings	
Vacuum Settings [psig]	-0.030
Pressure Settings [psig]	0.030

Meteorological Data	
Location	Midland-Odessa, Texas
Atmospheric Pressure [psia]	13.28
Min Ambient Temperature [°F]	49.33
Max Ambient Temperature [°F]	77.23
Solar Insolation [BTU/ft2*day]	1689.49
Wind Speed [mph]	11.12

Tank Conditions	
Atmospheric Pressure [psia]	13.28
Flashing Temperature [°F]	111.21
Max Liquid Surface Temperature [°F]	111.21
Avg. Liquid Surface Temperature [°F]	101.10
Avg. Throughput [bbl/d] [bbl/yr]	3216 1173898
Avg. Throughput Per Tank [bbl/d] [bbl/yr]	536 195650
Turnovers Per Tank (per year)	364
Throughput [bbl/d] [bbl/yr]	
Throughput Per Tank [bbl/d] [bbl/yr]	0 0
True Vapor Pressure [psia]	9.24

Emission Summary [Total]										
Item	Flashing Losses		Working Losses		Breathing Losses		Loading Losses		Total Losses	
	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]
VOCs (C3+)			23.155	101.419	8.334	36.502			31.489	137.921
HAPs			8.519	37.315	3.066	13.430			11.586	50.745
BTEX			0.475	2.081	0.171	0.749			0.646	2.829
H2S			0.000	0.000	0.000	0.000			0.000	0.000

Emission Summary [Per Tank]										
Item	Flashing Losses		Working Losses		Breathing Losses		Loading Losses		Total Losses	
	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]	[lb/hr]	[ton/yr]
VOCs (C3+)	0.000	0.000	3.859	16.903	1.389	6.084	0.000	0.000	5.248	22.987
HAPs	0.000	0.000	1.420	6.219	0.511	2.238	0.000	0.000	1.931	8.457
BTEX	0.000	0.000	0.079	0.347	0.028	0.125	0.000	0.000	0.108	0.472
H2S	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

Stream Composition									
No.	Component	Pressurized Inlet [Mol%]	Flashing Losses [Mol%]	Working Losses [Mol%]	Breathing Losses [Mol%]	Loading Losses [Mol%]	Residual [Mol%]		
1	Nitrogen	0.000	0.000	0.000	0.000				
2	Methane	0.000	0.000	0.000	0.000				
3	Carbon Dioxide	0.000	0.000	0.000	0.000				
4	Ethane	0.000	0.003	0.003	0.003				
5	Propane	0.021	0.376	0.376	0.376				
6	Isobutane	0.198	1.486	1.486	1.486				
7	n-Butane	2.406	12.065	12.065	12.065				
8	Isopentane	9.363	22.190	22.190	22.190				
9	n-Pentane	14.945	27.190	27.190	27.190				
10	Cyclopentane	1.754	2.184	2.184	2.184				
11	2-Methylpentane	0.000	0.000	0.000	0.000				
12	3-Methylpentane	0.000	0.000	0.000	0.000				
13	n-Hexane	53.994	29.982	29.982	29.982				
14	Methylcyclopentane	0.000	0.000	0.000	0.000				
15	Benzene	2.561	1.435	1.435	1.435				
16	Cyclohexane	3.443	1.452	1.452	1.452				
17	2-Methylhexane	0.000	0.000	0.000	0.000				
18	3-Methylhexane	0.000	0.000	0.000	0.000				
19	n-Heptane	2.184	0.401	0.401	0.401				
20	Methylcyclohexane	3.029	0.523	0.523	0.523				
21	Toluene	1.980	0.360	0.360	0.360				
22	n-Octane	0.988	0.059	0.059	0.059				
23	Ethylbenzene	0.239	0.014	0.014	0.014				
24	n-Nonane	0.659	0.013	0.013	0.013				
25	n-Decane	0.000	0.000	0.000	0.000				
26	Undecane	0.000	0.000	0.000	0.000				
27	Dodecane	0.000	0.000	0.000	0.000				
28	Water	0.000	0.000	0.000	0.000				
29	Hydrogen Sulfide	0.000	0.000	0.000	0.000				
30	2,2-Dimethylpropane	0.000	0.000	0.000	0.000				
31	2,2-Dimethylbutane	0.000	0.000	0.000	0.000				
32	2,3-Dimethylbutane	0.000	0.000	0.000	0.000				
33	2,2,4-Trimethylpentane	1.053	0.200	0.200	0.200				
34	Tridecane	0.000	0.000	0.000	0.000				
35	Tetradecane	0.000	0.000	0.000	0.000				
36	Pentadecane	0.000	0.000	0.000	0.000				
37	Hexadecane	0.000	0.000	0.000	0.000				
38	Heptadecane	0.000	0.000	0.000	0.000				
39	Octadecane	0.000	0.000	0.000	0.000				
40	Nonadecane	0.000	0.000	0.000	0.000				
41	Eicosane	0.000	0.000	0.000	0.000				
42	Heneicosane	0.000	0.000	0.000	0.000				
43	Docosane	0.000	0.000	0.000	0.000				
44	Tricosane	0.000	0.000	0.000	0.000				
45	Tetracosane	0.000	0.000	0.000	0.000				
46	Pentacosane	0.000	0.000	0.000	0.000				
47	Hexacosane	0.000	0.000	0.000	0.000				
48	Heptacosane	0.000	0.000	0.000	0.000				
49	Octacosane	0.000	0.000	0.000	0.000				
50	Nonacosane	0.000	0.000	0.000	0.000				
51	Triacotane	0.000	0.000	0.000	0.000				
52	2,2,4-Trimethyl-4-Pentene	0.000	0.000	0.000	0.000				
53	m-Xylene	0.000	0.000	0.000	0.000				
54	o-Xylene	0.000	0.000	0.000	0.000				
55	1,1-2-Dimethylcyclopentane	0.000	0.000	0.000	0.000				
56	4,4-Dimethyl-c-pentene-2	0.000	0.000	0.000	0.000				
57	p-Xylene	1.184	0.068	0.068	0.068				
58	TEG	0.000	0.000	0.000	0.000				
59	Piperazine	0.000	0.000	0.000	0.000				
60	MDEA	0.000	0.000	0.000	0.000				
61	O2	0.000	0.000	0.000	0.000				

Stream Mass Flow [Total]										
No.	Component	MW [lb/lbmol]	Pressurized Inlet [lb/hr]	Flashing Losses [lb/hr]	Working Losses [lb/hr]	Breathing Losses [lb/hr]	Loading Losses [lb/hr]	Residual [lb/hr]	Total Emissions [lb/hr]	
1	Nitrogen	28.013	0.000		0.000	0.000			0.000	
2	Methane	16.042	0.000		0.000	0.000			0.000	
3	Carbon Dioxide	44.010	0.000		0.000	0.000			0.000	
4	Ethane	30.069	0.006		0.000	0.000			0.000	
5	Propane	44.096	3.376		0.051	0.018			0.070	
6	Isobutane	58.122	42.535		0.267	0.096			0.362	
7	n-Butane	58.122	516.905		2.164	0.779			2.943	
8	Isopentane	72.149	2496.777		4.941	1.778			6.719	
9	n-Pentane	72.149	3985.468		6.054	2.179			8.233	
10	Cyclopentane	70.133	454.625		0.473	0.170			0.643	
11	2-Methylpentane	86.175	0.000		0.000	0.000			0.000	
12	3-Methylpentane	86.175	0.000		0.000	0.000			0.000	
13	n-Hexane	86.175	17198.087		7.974	2.870			10.844	
14	Methylcyclopentane	84.159	0.000		0.000	0.000			0.000	
15	Benzene	78.112	739.320		0.346	0.125			0.470	
16	Cyclohexane	84.159	1071.015		0.377	0.136			0.513	
17	2-Methylhexane	100.202	0.000		0.000	0.000			0.000	
18	3-Methylhexane	100.202	0.000		0.000	0.000			0.000	
19	n-Heptane	100.202	808.984		0.124	0.045			0.169	
20	Methylcyclohexane	98.186	1099.279		0.158	0.057			0.215	
21	Toluene	92.138	674.191		0.102	0.037			0.139	
22	n-Octane	114.229	417.071		0.021	0.008			0.028	
23	Ethylbenzene	106.165	93.861		0.005	0.002			0.006	
24	n-Nonane	128.255	312.555		0.005	0.002			0.007	
25	n-Decane	142.282	0.000		0.000	0.000			0.000	
26	Undecane	156.308	0.000		0.000	0.000			0.000	
27	Dodecane	170.335	0.000		0.000	0.000			0.000	
28	Water	18.015	0.000		0.000	0.000			0.000	
29	Hydrogen Sulfide	34.081	0.000		0.000	0.000			0.000	
30	2,2-Dimethylpropane	72.149	0.000		0.000	0.000			0.000	
31	2,2-Dimethylbutane	86.175	0.000		0.000	0.000			0.000	
32	2,3-Dimethylbutane	86.175	0.000		0.000	0.000			0.000	
33	2,2,4-Trimethylpentane	114.229	444.492		0.070	0.025			0.096	
34	Tridecane	184.361	0.000		0.000	0.000			0.000	
35	Tetradecane	198.388	0.000		0.000	0.000			0.000	
36	Pentadecane	212.415	0.000		0.000	0.000			0.000	
37	Hexadecane	226.441	0.000		0.000	0.000			0.000	
38	Heptadecane	240.468	0.000		0.000	0.000			0.000	
39	Octadecane	254.494	0.000		0.000	0.000			0.000	
40	Nonadecane	268.521	0.000		0.000	0.000			0.000	
41	Eicosane	282.547	0.000		0.000	0.000			0.000	
42	Heneicosane	296.574	0.000		0.000	0.000			0.000	
43	Docosane	310.601	0.000		0.000	0.000			0.000	
44	Tricosane	324.627	0.000		0.000	0.000			0.000	
45	Tetracosane	338.654	0.000		0.000	0.000			0.000	
46	Pentacosane	352.680	0.000		0.000	0.000			0.000	
47	Hexacosane	366.707	0.000		0.000	0.000			0.000	
48	Heptacosane	380.734	0.000		0.000	0.000			0.000	
49	Octacosane	394.760	0.000		0.000	0.000			0.000	
50	Nonacosane	408.787	0.000		0.000	0.000			0.000	
51	triacontane	422.813	0.000		0.000	0.000			0.000	
52	2,2,4-Trimethyl-4-Pentene	112.213	0.000		0.000	0.000			0.000	
53	m-Xylene	106.165	0.000		0.000	0.000			0.000	
54	o-Xylene	106.165	0.000		0.000	0.000			0.000	
55	1,1-2-Dimethylcyclopentane	98.186	0.000		0.000	0.000			0.000	
56	4,4-Dimethyl-c-pentene-2	98.186	0.000		0.000	0.000			0.000	
57	p-Xylene	106.165	464.437		0.022	0.008			0.030	
58	TEG	150.173	0.000		0.000	0.000			0.000	
59	Piperazine	86.136	0.000		0.000	0.000			0.000	
60	MDEA	119.162	0.000		0.000	0.000			0.000	
61	O2	31.999	0.000		0.000	0.000			0.000	

Stream Properties										
			Pressurized Inlet	Flashing Losses	Working Losses	Breathing Losses	Loading Losses	Residual		
MW [lb/lbmol]			83.39		75.03	75.03				
Heating Value [BTU/scf]					4142.7	4142.7				
Specific Gravity			0.646	-	-	-	-	-		
Reid Vapor Pressure [psi]			8.91	-	-	-	-	-		
Gas Volumetric Flow [scf/hr]			-	0.00	117.12	42.15				

	UOM	Gas	2 x 500bbls Sour Water Tanks	4 x 400bbls Slop Tanks	6 x 500bbls Condensate Tanks	
Daily Rate	MMSCFD					
Daily Throughput	bbl/d		87	242	3130	
Annual Throughput	gal/yr		1333710	3709860	47976768	
Per Tank Throughput	gal/yr		666855	927465	7996128	
# of Tanks			2	4	6	
Turnover Per Tank	per year		30	55	364	
Total Flow	lb/hr		1.89	2.97	31.49	
VOC [C3+] total	lb/hr		0.00	0.33	31.49	
VOC [C3+] per tank	lb/hr		0.00	0.082955	5.25	
Bz total	lb/hr		0.00	0.025054	0.47	
Bz per tank	lb/hr		0.00	0.006264	0.08	
H2S total	lb/hr		0.41	0.000000	0.00	
H2S per tank	lb/hr		0.20	0.000000	0.00	
Temperature	*F		110.89	111.62	111.21	
VOC [C3+] wt %	%		0.00	11.16	100.00	
Bz wt %	%		0.00	0.84	1.49	
H2S wt %	%		21.56	0.00	0.00	
MW Vapors	lb/lbmol		40.00	19.56	75.03	
SCF/hr	SCF/hr		19.99	57.81	159.27	
HV	btu/ft^3		96.63	1066.42	4142.72	
C3 % (mass)	%		0.00	7.00	0.22	
			sourwater tanks liq	slop tanks liq	COND STORAGE	
RVP	psi		2.33	1.04	8.91	
Vapor Pressure @ 100 *F	psia		16.4870	15.3910	9.06029	
Vapor Pressure @ 65 *F	psia					

*Results for vapor streams are for flashing, working ,and breathing combined unless otherwise noted in cell comments

Stream Vapor Pressures

Stream	VP @ 100 °F [psia]	VP at 65 °F [psia]	VP @ 62.4
1	495.843	383.586	
AGI SOUR WATER	19.0200	12.6503	12.17715574
AIR			
BREATHING COND TANKS	18.3345	9.57073	
BREATHING SLOP TANKS VOCS			
BREATHING SOUR WATER	992.902	663.519	
COND STORAGE	9.06029	4.42361	4.079166381
COND TANK FLASH		13.28	
FLASHING COND TANKS VOCS			
FLASHING SLOP TANKS VC	2343.36		
FLASHING SOUR WATER T	1028.03	689.383	
LOSSES	18.3345	9.57073	
mole sieve stream 16	495.843	383.586	
slop tanks flash		2020.04	
slop tanks liq	15.3910	11.6343	11.35522193
sourwater tanks flash	1086.13	757.299	
sourwater tanks liq	16.4870	10.9207	
STORAGE	9.06029	4.42361	
to atm			
TO COMB			
WORKING COND TANKS V	18.3345	9.57073	
WORKING SLOP TANKS VOCS			
WORKING SOUR WATER T	992.902	663.519	

4.0 DESIGN BASIS

4.1 Site Conditions

Elevation, ft	3612
Seismic Zone	Zone 0, ASCE 7-10
Design Wind Velocity	100 MPH, ASCE 7-10
Barometric Pressure, psia	13.0 (assumed)
Temperature, °F (Min/Max)	0 / 105
Design Relative Humidity	90% (assumed)

4.2 Waste Stream Summary

	Amine Acid Gas	TEG Overhead
COMPONENT:	Mol%	Mol%
N2	0.000476436	0.023533817
C1	0.160343489	10.52602613
CO2	92.80947832	0.139200764
C2	0.043605007	13.12750526
H2S	0.006564341	0
C3	0.013389894	17.86443624
iC4	0.00094232	2.552395332
nC4	0.003913018	10.55245659
iC5	0.000141998	4.19340138
nC5	0.000248341	5.266306596
C6	0.000126353	8.807176215
C7	2.72456E-07	0.15051084
C8	1.06148E-07	0.059643694
C9	2.60623E-09	0.044655609
Cyclopentane	0.00016068	2.031482149
Benzene	0.012892923	7.777448444
Cyclohexane	0.000139167	1.150332198
Methylcyclohexane	9.42409E-06	0.457895628
2,2,4-Trimethylpentane	2.13572E-07	0.073574104
Toluene	0.002402702	2.682916488
Ethylbenzene	5.08093E-05	0.110829457
p-Xylene	0.000330822	0.500214123
H2O	6.944783312	11.90746968
MDEA	2.22147E-08	0.000589214
Piperazine	2.96789E-08	7.98446E-12
TEG	0	4.50342E-08

Total Flowrate for Base Case, lbmol/hr	1622.5	3.5
Total Flowrate for 2x Base Case, lbmol/hr	3245.0	7.0
Mol. Wt.	42.2	50.2
Pressure, psig	11.8	1.3
Temperature, °F	120	120

All waste streams are assumed to be in vapor state, no liquids have been considered in the design of the thermal oxidizer. If liquids are present, a knock out drum needs to be installed upstream of the thermal oxidizer as well as heat tracing and insulating the waste lines to avoid condensation. This additional scope is currently not included in Zeeco's scope.

It is assumed that the Acid Gas, Amine and TEG Flash Gases and TEG Overhead streams will be entering in two separate connections, inert streams such as Acid Gas in one connection and rich gases, such as the Amine and TEG Flash Gases and TEG Overhead streams in the other. It is assumed both inert and rich gas streams and will be running continuously and simultaneously. The Acid Gas stream will never be without TEG/ Amine Flash streams and vice versa.

4.3 Utilities

Electrical Power	460V / 3 Phase / 60 Hz
Instrument Air, SCFH	2000 to 4000
Fuel Gas Required for Base Case- all waste coming to TO simultaneously (Fuel Gas assumed as Methane)	58 MMBtu/hr
Fuel Gas Required for 2x Base Case - all waste coming to TO simultaneously (Fuel Gas assumed as Methane)	112 MMBtu/hr

4.4 Flue Gas at 1600°F

	Base Case (all waste streams with 0% margin included)	2X Base Case (all waste streams with 0% margin included)
COMPONENT:	Mol%	Mol%
CO ₂	38.51	39.04
H ₂ O	15.69	15.60
N ₂	42.74	42.32
SO ₂	0.00	0.00
O ₂	3.06	3.03
TOTAL, lbmol/hr	4390.11	8637.01

4.5 System Performance for the Base Case and 2x Waste Flow Case

Stack Emission	Expected Performance
Destruction Efficiency	> 99.9% of VOCs
NO _x , ppm _{vd} @ 3% O ₂	50
CO, ppm _{vd} @ 3% O ₂	50

These values are understood to apply only when the system is operated in accordance with the operating conditions stipulated in the design summary and for the waste stipulated in the design basis sections of this proposal. VOC is defined as non-methane and non-ethane hydrocarbons.

5.0 EQUIPMENT DESCRIPTION- BASE CASE

5.1 Thermal Oxidizer

One (1) vertical thermal oxidizer with integral stack is offered. It is designed to operate at 1600°F with excess air to ensure complete combustion of the waste gas combustible components. The thermal oxidizer has the following features:

- Nominal 10'-0" OD to 75'- 0" elevation
- Shell Material: SA-36
- All Carbon Steel External Surfaces Sandblasted to SSPC-SP6
- Painted per Zeeco Standard

5.2 Burner

One (1) Forced Draft Zeeco GB Burner is offered with the following features:

- 60 MMBtu/hr maximum fuel gas release rating
- AR/GS Pilot for intermittent use
- A-36 Carbon Steel Construction
- 60% Al₂O₃ Burner Tile Construction
- 10:1 Fuel Gas Turndown
- All Carbon Steel External Surfaces Sandblasted to SSPC-SP6
- Painted per Zeeco Standard

5.3 Combustion Air Fan

One (1) Combustion Air Fan is offered and has the following features:

- Design Rate: 79672 lb/hr
- Discharge Pressure: 6 in W.C
- Motor HP: ≤30
- Manufacturer's standard design
- Painted as per Manufacturer's Standard

5.4 Refractory

The bottom of the thermal oxidizer, near the burner, is dual lined with 4" of 3000°F castable, backed with 2" of lightweight insulating castable. The stack of the thermal oxidizer is lined with a single layer of 4", 2300°F lightweight insulating castable. Refractory will be supplied, shop installed and partially dried out in the shop by Zeeco.

5.5 Instrumentation & Controls

Zeeco Instrumentation and Controls scope includes basic burner management functions within a local control panel to comply with **NFPA 86**. A fuel rack is included in the base scope for pilot and main burner fuel supply and control/shutdown. All instruments included are sourced from Zeeco standard suppliers. See attached P&IDs. Line sizes will be adjusted as necessary.

Zeeco has not offered the waste gas piping or isolation valve/ controls. These items can be offered as an optional price.

6.0 EQUIPMENT DESCRIPTION- 2x BASE CASE

6.1 Thermal Oxidizer

One (1) vertical thermal oxidizer with integral stack is offered. It is designed to operate at 1600°F with excess air to ensure complete combustion of the waste gas combustible components. The thermal oxidizer has the following features:

- Nominal 12'-9" OD to 70'- 0" elevation
- Shell Material: SA-36
- All Carbon Steel External Surfaces Sandblasted to SSPC-SP6
- Painted per Zeeco Standard

6.2 Burner

One (1) Forced Draft Zeeco GB Burner is offered with the following features:

- 118.0 MMBtu/hr maximum fuel gas release rating
- AR/GS Pilot for intermittent use
- A-36 Carbon Steel Construction
- 60% Al₂O₃ Burner Tile Construction
- 10:1 Fuel Gas Turndown
- All Carbon Steel External Surfaces Sandblasted to SSPC-SP6
- Painted per Zeeco Standard

6.3 Combustion Air Fan

One (1) Combustion Air Fan is offered and has the following features:

- Design Rate: 155233 lb/hr
- Discharge Pressure: 7 in W.C
- Motor HP: ≤75
- Manufacturer's standard design and construction
- Painted as per Manufacturer's Standard

6.4 Refractory

The bottom of the thermal oxidizer, near the burner, is dual lined with 4" of 3000 °F castable, backed with 2" of lightweight insulating castable. The stack of the thermal

oxidizer is lined with a single layer of 4", 2300°F lightweight insulating castable. Refractory will be supplied, shop installed and partially dried out in the shop by Zeeco.

6.5 Instrumentation & Controls

Zeeco Instrumentation and Controls scope includes basic burner management functions within a local control panel to comply with **NFPA 86**. A fuel rack is included in the base scope for pilot and main burner fuel supply and control/shutdown. All instruments included are sourced from Zeeco standard suppliers. See attached P&IDs. Line sizes will be adjusted as necessary.

Zeeco has not offered the waste gas piping or isolation valve/ controls. These items can be offered as an optional price.



Process Conditions -- English Units

Client: Lucid Midstream	Zeeco Ref.: 2019-03373FL-01	Date: 21-May-19
Location: Jal, NM	Client Ref.: "Red Hills V"	Rev. 0

	Mol %					
	Cold Case 1	Cold Case 2	Warm Case 1	Warm Case 2	Case E	Case F
METHANE	75.95	1.22		69.81		
ETHANE	11.67	60.16	0.25	10.97		
PROPANE	5.82	26.07	99.00	5.78		
BUTANE	2.16	9.31	0.75	2.49		
PENTANE	0.55	2.56		0.87		
HEXANE	0.09	0.48		0.26		
HEPTANE	0.02	0.14		0.12		
OCTANE		0.02		0.03		
NONANE						
DECANE						
DODECANE						
TRIDECANE						
CYCLOPENTANE						
ETHYLENE						
PROPYLENE						
BUTYLENE						
ACETYLENE						
BENZENE						
TOLUENE						
XYLENE						
CARBON MONOXIDE						
CARBON DIOXIDE	1.01	0.03		7.00		
HYDROGEN SULFIDE				0.20		
SULFUR DIOXIDE						
AMMONIA						
AIR						
HYDROGEN						
OXYGEN						
NITROGEN	2.70			2.48		
WATER						
BUTADIENE						
METHANOL						
Total	100	100	100	100		
Mol. Wt.	21.21	37.63	44.17	23.34		
L. H. V. (BTU/SCF):	1,104	1,992	2,319	1,073		
Temperature (Deg. F):	9.0	170.0	190.0	65.0		
Avail. Static Pressure (psig):	40.00	20.00	10.00	20.00		
Flow Rate (lbs/hr):	1,052,040	535,560	221,526	352,687		
Smokeless Rate (lbs/hr):	210,408	107,112	44,305	70,537		

ATTACHMENTS

Attachment D

Specification Sheets:

- Flare Tip Specification Sheet
- Flare Pilot Specification Sheet
- Flare Stack Structure Specification Sheet
- High Energy Spark Ignition (HEI) Specification Sheet
- Utility Piping Scope of Supply Specification Sheet
- Typical High-Temp Ignition Wiring Spec Sheet



Air Assisted Flare Tip Specification Sheet


Client: Lucid Midstream	Zeeco Ref.: 2019-03373FL-01	Date: 21-May-19
Location: Jal, NM	Client Ref.: "Red Hills V"	Rev. 0

General Information:

Tag No.:	FL-5100	
Model:	AFDSMJW-20/80 - 26	Type: Air-Assisted
Length:	10'- 0 "	
Weight:	6000 lbs	
No. of Pilots	3	

Design Case:

Governing Case:	Cold Case 1
Molecular weight:	21.2
L. H. V. :	1,104 BTU/SCF
Temperature:	9 Deg. F
Available Static Pressure:	40.0 psig
Design Flow Rate:	1,052,040 lbs/hr
Governing Smokeless Case:	Case A
Design Smokeless Rate:	210,408 lbs/hr
Approximate Exit Velocity:	1194 ft/s
Mach No.:	1.00
Approx. Tip Press. Drop:	14.54 psig



(Typical drawing only)

Construction:

Upper Section:	310 SS	Flame Retention Hub:	310 SS
Warm / Air Riser Lower Section:	Carbon Steel	Lifting Lugs:	YES - C.S. Type
Cold Riser Lower Section:	304 SS	Refractory:	None
Windshield:	YES	Refractory Thk:	N/A

Surface Finish (Carbon Steel Surfaces):

Surface Preparation:	SSPC-SP6	Primer:	Inorganic Zinc
Paint (c. s. surfaces):	High Heat Aluminum		

Connections:

	Qty.	Size	Type	Material
N1 - Warm Flare Gas Inlet:	1	20 "	Beveled ; Weld	Carbon Steel
N2 - Cold Flare Gas Inlet	1	26 "	150# RFWN	304 SS
N3 - Combustion Air Inlet:	1	80 "	Fab. Plate Flange	Carbon Steel
N4 - Pilot Gas Manifold:	1	1 "	150# RFSW	Carbon Steel

Miscellaneous Notes:

1. Includes Integral Purge Reducing Velocity Seals.
 2. Warm Flare Required Fuel Gas Purge Rate = 1200 SCFH.
 3. Cold Flare Required Fuel Gas Purge Rate = 1050 SCFH.
- Note: Design case shown is for Cold flare only, please refer to process conditions for warm flare design conditions.



AIR ASSISTED FLARE

COMBUSTION AND ENVIRONMENTAL SOLUTIONS.
PURE AND SIMPLE.®

AF Series



AIR ASSISTED AF FLARE

AF SERIES DESCRIPTION

Zeeco's AF series flares use technology proven to achieve smokeless flaring when neither steam nor assist gas is available or economical.

Our AF series flares utilize a low-pressure blower to inject assist air via our proprietary design, which splits the waste gas stream into several smaller streams at the exit of the flare tip. This increases the contact surface area between the waste gas and the assist air, maximizing mixing and turbulence while minimizing the amount of blower horsepower required to achieve smokeless flaring.

BETTER DESIGN MEANS SAFER OPERATION

The waste gases from the flare header as well as the assist air from the blower are isolated from the base of the flare stack to the top of the flare tip. As a result, at no point do the two streams come in contact with each other prior to exiting the flare tip. This ensures the safe operation of your flare system. Zeeco's AF series flare systems can operate without the blower, providing safe disposal of the waste gas in the event of a power outage.

Our proprietary design and the blower's velocity virtually eliminate "flame lick" on the exterior of the flare tip and "burnback" inside the flare tip. The forced air from the blower also shortens the flame length and reduces the radiation at grade due to the highly aerated mixture of waste gases.

WHY CHOOSE ZEECO?

Zeeco is the leading designer of combustion equipment in the global market today in part because we have produced superior air assisted flare systems around the world for more than 30 years. Our philosophy of providing customers with superior quality, on-time shipments and competitive pricing is the cornerstone of our success. Let us put our experience to work for you. Call or email us today for more information on Zeeco's full line of flare products and replacement components for your new or existing flare system(s).



BURNERS



FLARES



INCINERATORS



PARTS & SERVICE

COMBUSTION AND ENVIRONMENTAL SOLUTIONS.
PURE AND SIMPLE.®

Air Assisted Flare

APPLICATIONS

- ZEECO® AF series flares are perfect for refining, LNG, production, steel industries, petrochemical, offshore platforms, pulp and paper plants, pharmaceuticals and food processing plants.
- Our AF series flares are the preferred choice for industries that require smokeless flaring when neither steam nor assist gas is desired, available or cost effective.
- AF series flares are the best option for harsh conditions such as arctic environments where steam could freeze or desert environments where water is scarce.
- ZEECO AF series flare tips make sense as a replacement for other manufacturers' flare tips.

ADVANTAGES

- Very low operating cost for smokeless operation
- High stability, low fuel consumption pilots are standard with AF flare tips
- 98.5% or higher hydrocarbon destruction efficiency
- Superior materials and construction
- Lower blower horsepower requirements than competing designs

FEATURES

- Sizes ranging from 2 inch (50 mm) to 120 inch (3050 mm)
- Longer flare tip life due to continual cooling by forced air flow
- Lower radiation level at grade due to a highly aerated flame
- Lower noise than similar size steam assisted flares
- High stability pilots (tested to 150 mph [241 Km/hr] wind speed)
- Critical parts supplied as investment castings
- 310 stainless steel in high heat areas



AIR ASSISTED AF FLARE BLOWERS



AIR ASSISTED AF FLARE



AIR ASSISTED AF FLARE

CERTIFICATIONS APPLY TO ZEECO HEADQUARTERS ONLY.



CERTIFIED
NBBI



CERTIFIED
ASME



CERTIFIED
ASME



REGISTERED
ISO 9001: 2008

Zeeco Corporate Headquarters

22151 East 91st Street

Broken Arrow, Oklahoma 74014 USA

Phone: +1.918.258.8551

Fax: +1.918.251.5519


E-mail: sales@zeeco.com

zeeco.com

ZEECO® is a registered trademark of Zeeco, Inc. in the U.S.

• ZEECO office, affiliate, sales, representative, or third party representative/licensee offices.

© COPYRIGHT 2011 - ZEECO, INC. ALL RIGHTS RESERVED





Pre-Mix Flare Pilot Assembly Specification Sheet

Client: Lucid Midstream	Zeeco Ref.: 2019-03373FL-01	Date: 21-May-19
Location: Jal, NM	Client Ref.: "Red Hills V"	Rev. 0

General Information:


Tag No.:	FP-1
Model:	HSLF
Length:	9.135 feet
Weight:	68 lbs.
Pilot Type:	Pre-Mix High Stability
Ignition Type:	High Energy Spark

Process Design Data:

Design Heat Release:	65,000 BTU/hr
Fuel Gas MW:	18.00
Fuel Gas LHV:	1,000 BTU/SCF
Fuel Gas Temperature:	100 Deg. F
Fuel Gas Inlet Pressure:	15.00 psig
Fuel Gas Flow rate:	65.0 SCFH
Design Wind Velocity:	150 mph
Design Rainfall:	50.00 inches/hr
Mounting Position:	Vertical
Thermocouple Type:	K Ungrounded

Construction:

Pilot Firing Tip:	HK
Windshield Assembly:	HK
Integral Thermowell:	HK
Mounting Brackets:	HK
Premix Fuel Line:	310 SS
Thermocouple Sheath:	310 SS
Thermocouple Head:	316 SS
Fuel Mixer / Spud Assembly:	CF-3M / 18-8
Fuel Strainer Assembly:	CF-8M
HEI Probe and Support:	310 SS
HEI Junction Head:	CF-3M



Connections:	Qty.	Size	Type	Material
C1 - Fuel Gas Inlet:	1	1/2"	FNPT	CF8M
C3 - Thermocouple:	1	1/2"	Tube	316 SS
C4 - HEI Ignition:	1	3/4"	FNPT	Cast Iron

Misc. Notes: (see ignition system datasheet for type applicable to this quote)

1. Upper mounting bracket is reinforced hook type for pilot removal from platform.
2. Pilot mounting brackets and thermocouple mounting brackets are investment cast assemblies.
3. Pilot mixer assembly is investment cast, high efficiency computer modeled venturi section.
4. Thermocouples are simplex, retractable type (replaceable from grade).




HSLF Series



The only pilot to operate continuously in hurricane force winds.

Just ask our customers in the eye of the storm. They'll tell you the ZEECO® HSLF pilot was the only flare pilot to operate continuously when their facilities were directly hit by hurricanes Ike and Rita.

You can expect the same level of reliability – in some of the harshest weather conditions on the planet – when you install a ZEECO HSLF pilot. Proven to withstand hurricane-force winds of 170 mph (274 km/h) at Zeeco's Combustion Research and Test Facility, the HSLF flare pilot offers unparalleled performance.



To view the HSLF hurricane test video, visit www.zeeco.com/pilots

Engineering experience for extreme longevity.


Flare pilots are exposed to all kinds of extremes – temperature, inert flare purge, flame impingement, environmental conditions, weather events, and more. That's why Zeeco goes to extreme lengths to engineer and manufacture our HSLF pilots to withstand the challenges and outlast the rest.

The ZEECO HSLF flare pilot utilizes investment castings instead of welded seam fabrication to maximize the pilot's operating life. To guard the orifice and prevent weather from disrupting gas flow, we fortify our flare pilots with a unique investment cast pilot mixer assembly with an integrated weathershield. No other pilot has this feature. We can also retrofit the HSLF pilot to competitor flare systems.

The ZEECO HSLF pilot operates with a variety of hydrocarbon fuel gas compositions, including butane, ethylene, hydrogen and propane, low-BTU gases, or any combination of these fuels.

Why choose Zeeco?

Zeeco leads today's global market in the design of advanced combustion and environmental solutions. For nearly 40 years, ZEECO flare systems have played vital roles in industries around the world. Our mission to provide customers with superior quality, on-time shipments, and competitive pricing is the cornerstone of our success. Let Zeeco put its experience to work for you. Call or email us today to learn more about the full line of ZEECO flare products and replacement components.




HSLF Flare Pilot

Standard Features

- Flame Front Generator (FFG) ignition
- Fixed, single element type K thermocouple with stainless steel thermocouple protection system (provides tertiary protection and ensures the thermocouple maintains the proper position in the thermo well)
- Cast heavy wall thermo wells included in pilot shields (maximizes thermal conductivity between flame and thermocouple)
- HSLF mixer is engineered to maximize the efficiency of inspiration and mixing
- Extensive utilization of stainless steel investment cast components
- All stainless steel construction, including a stainless steel strainer that prevents plugging of pilot mixer orifice
- Mixer is engineered to easily transfer and handle high utility piping loads
- Can operate using a wide variety of hydrocarbon fuel gas compositions
- Configurations available for all flare types

Options

- Stand-alone High Energy Ignition (HEI) with investment cast junction box and integral radiation shield (as an alternative to standard FFG ignition) or in combination with FFG ignition
- Dual High Energy Ignition (HEI) systems
- Flame proving using ionization rod
- Flame proving using optical monitoring from grade
- Dual element or multiple thermocouples
- Alternative metallurgies available, e.g. INCONEL® 625 or INCOLOY® 800H
- Retractable thermocouple systems
- Patented pusher/straightener installation machine



Standard HSLF Pilot

ZEECO® combustion solutions are designed and manufactured to comply with applicable local and international standards as defined by our customers.



REGISTERED
ISO 9001: 2008

CERTIFICATION APPLIES TO ZEECO HEADQUARTERS ONLY.

Zeeco Corporate Headquarters

22151 East 91st Street

Broken Arrow, Oklahoma 74014 USA

Phone: +1 918 258 8551

Fax: +1 918 251 5519


E-mail: sales@zeeco.com

Zeeco.com

ZEECO® is a registered trademark of Zeeco, Inc. in the U.S.

• ZEECO office, affiliate, sales, representative, or third party representative/licensee offices.

© COPYRIGHT 2016 - ZEECO, INC. ALL RIGHTS RESERVED





Self-supported Flare Stack Specification Sheet


Client: Lucid Midstream	Zeeco Ref.: 2019-03373FL-01	Date: 21-May-19
Location: Jal, NM	Client Ref.: "Red Hills V"	Rev.: 0

General Information:

Tag No.: FL-5100
 Overall Height: 199'- 0 "

Design Criteria:

Wind Design Code: ASCE 7-05
 Seismic Design Code: UBC
 Importance Factor: 1.00
 Structural Design Code: ASME STS-1 / AISC
 Wind Speed (Structural): 120 mph
 Seismic Zone: 1
 Warm Min./Max. Design Temp. -20 / 350 Deg. F
 Cold Min./Max. Design Temp.: -150 / 350 Deg. F
 Air Riser Design Temp.: Ambient
 Warm / Cold Design Pressure: 50 psig
 Air Riser Design Pressure: Ambient
 CS Riser Corrosion Allow.: 0.0625 in.



(Typical drawing only)

Construction:

Air Riser Diameter: 80"	Ladders & Step-offs: None
Cold Riser Diameter: 26"	Platform at Tip: None
Warm Riser Diameter: 20"	Additional Platforms: None
Air / Warm Riser Material: CS	ACWL: None
Cold Riser Material: 304 SS	

Surface Finish (Carbon Steel Surfaces):

Surface Preparation: SSPC-SP-6	Primer: Inorganic Zinc
Int. Coat: None	Finish Paint: None

Utility Piping:

Per Attached Utility Piping Scope of Supply

Miscellaneous Notes:

1. Vane Axial blower mounted at base of stack.
2. Blower Power Available: 460 V, 3 Ph, 60 Hz
3. Elevation considered for blower sizing: 850 feet. Ambient temp considered: 20 / 100 F
4. See GA attached.

PROCESS DATA

GAS STREAM	<i>Amine Cont. LV / Stabilizer Surge</i>
FLOW MAXIMUM	<i>316,355 lb/hr / 9,917 lb/hr smokeless</i>
FLOW MINIMUM	<i>PURGE</i>
MOLECULAR WEIGHT	<i>25.5 / 46.4</i>
TEMPERATURE	<i>-26 / 142.5 °F</i>
INLET PRESSURE	<i>10 psig Max</i>

UTILITIES

PILOT FUEL GAS	<i>50 SCFH of N.G (per pilot)</i>
PURGE GAS	<i>139 SCFH</i>

PILOTS (RETRACTABLE)

QUANTITY	<i>Three (3)</i>	TYPE	<i>WindPROOF Zeus</i>
THERMOCOUPLES	<i>One / Pilot</i>		
TYPE	<i>Single Element Type K</i>		

DIMENSIONS (approx.)

HEIGHT	<i>10' - 0"</i>
WEIGHT	<i>2,800 LBS</i>

MATERIALS

MAIN BODY	<i>316 SS Upper / 304 SS Lower</i>
MIXING HEAD	<i>316 SS</i>
PILOT	<i>310 SS</i>
PILOT NOZZLE	<i>Cast 310 SS</i>
LIFTING LUGS	<i>304 SS</i>

SURFACE FINISH / PAINT (stainless steel)

SANDBLAST	NONE
PRIMER	NONE
TOP COAT	NONE

NDE


RADIOGRAPHY	<i>10% radiography butt weld</i>
OTHER NDE	<i>none</i>

TERMINAL POINTS

GAS INLET	<i>20"</i>	<i>Class 150 RF Carbon Steel</i>
AIR INLET	<i>30"</i>	<i>Plate Flange A36</i>
PILOT INLET	<i>3/4"</i>	<i>Class 150 RF</i>

REMARKS

CARBON STEEL FLARE TIP INLET FLANGES SHALL BE COATED TO SSPC-SP6 SURFACE PREPARATION AND 2 COATS HIGH TEMP. ALUMINUM, 1-2 MILS DFT



This offer may not include all items show.



Office/Shop
2300 S. Adams Road
Sand Springs, OK 74063
U.S.A.

Contacts
Ph: 918-215-1900
Fax: 918-215-1908
E-mail: sales@tulsacombustion.com
Web site: www.tulsacombustion.com

October 10th, 2017

ONSTREAM OPERATIONS, LLC
2999 Ave T NE
Winter Haven, FL 33881

Attn: Brad Campbell

Ref: Lucid Sour Gas Flares
Tulsa Combustion TC-17-09-2126

Greetings:

Thank you for the opportunity to offer a proposal for the Sour Gas Flares mentioned above. The stated scope and technology requirements are a very good match for the expertise, experience and capabilities of Tulsa Combustion LLC. We understand well the physical and process implications and limitations of this application. In collaboration with Onstream, we will provide a system that is reliable and safe, with an optimal economic value over the long term.

The major design criterion was the ground level SO₂ concentrations as required by the NAAQS for a 1-hour averaging time of 75 PPB SO₂.

Following discussions with Onstream and RFS Consulting, the following approach was taken.

- Use of this flare will be limited to 500 Hours per year and based on this limitation the average SO₂ molar emissions utilized was the design numbers presented times the ratio of 500/8760.
- We were advised by RFS Consulting that this approach has been accepted by the EPA for other applications and is a reasonable approach
- With these understandings, the height of the flare system is set by thermal radiation, not by ground level concentrations of SO₂

Based on this, we are offering a self-supporting flare at 85ft OAH for the acid gas and inlet gas feed flare. An optional KO Drum at that base of the flare is also provided at an additional cost. A separate Tank and Truck loading self-supporting flare with a 20 ft overall height as the is also included in the proposal.

These are some features of our offer to which we invite your attention:

- We are comfortable in meeting the delivery requirements
- Tulsa Combustion will provide the engineering, design and fabrication for the scope of supply


- Our senior staff individually have over 45 years of experience in flare design.

We look forward with enthusiasm to developing this project. Please let us know how we can assist you in moving to the next step.


Best regards,

Mitt Chinsethagid
Tulsa Combustion LLC

Technical Specifications



Lucid Energy- 60 MMscfd, 800 psig, 0.55 mol% H2S, 3 mol% CO2, Winter



Technical Discussion:

A review of the EPA Screen runs utilizing AERSCREEN showne below indicate 1-Hr concentrations of 17.70 ug/m3.

 ***** FLARE PARAMETERS *****

SOURCE EMISSION RATE: 3.3460 g/s 26.556 lb/hr
 FLARE HEIGHT: 25.908 meters 85.00 feet
 EFF RELEASE HEIGHT: 30.027 meters 98.51 feet
 HEAT RELEASE RATE: 0.1527E+07 cal/sec
 HEAT LOSS FRACTION: 0.120
 EFF STACK DIAMETER: 1.145 meters 45.09 inches
 EFF EXIT TEMPERATURE: 1273.0 K 1831.7 Deg F
 EFF EXIT VELOCITY: 20.000 m/s 65.62 ft/s
 RURAL OR URBAN: RURAL

INITIAL PROBE DISTANCE = 5000. meters 16404. feet

***** PROBE ANALYSIS *****

25 meter receptor spacing: 1. meters - 5000. meters

Zo SECTOR	ROUGHNESS LENGTH	1-HR CONC (ug/m3)	DIST (m)	TEMPORAL PERIOD
1*	0.300	17.70	350.0	SPR

Main Gas and Acid Gas Flare Tips - Nominal 18" and 3" Size

- 10 feet overall length
- 316SS or higher grade shell upper 5 feet
- ASME Section IX welding with Fabrication in an ASME approved shop
- Mechanical details and Flanges per API standard 537
- Self-generating pilot proving system
- 3 Pilots per API Standard 537 - two per 18" and one per 3"

Purge Conservation Seal: Dry Type - Velocity Seal

Any flare stack is subject to the effects of wind, which will produce a high-pressure area on the side the wind strikes and a low-pressure area at the sides of the burner where the velocity is highest. This combination of high and low-pressure zones produces air flow into the stack. The velocity seal is a specially designed section that returns the air to the main flow where it is swept out of the stack. This purge conservation seal design greatly reduces the amount of purge gas required to keep the oxygen concentration at a safe level. In most flares, the design calls for 6% O₂ below the seal. This is a safe level for any gas that depends on oxygen for combustion.

TC HEI-800 Ignition system

Ignition Panel

Panel contains the BX igniters and temperature switches with logic that provides pilot monitoring and automatic ignition/relight. Form C contacts are provided for a common alarm. Panel IP 65 (NEMA 4X Stainless steel) with NFPA air purge for Div. 2 area.

Design

The TC-HEI-800 ignition modules were designed using the latest technology in high-performance solid state DC-to-DC converters and capacitive discharge modules for use with a state-of-the-art igniter which is currently used in aircraft turbines. The use of these high-performance units allows Tulsa Combustion to manufacture high quality and high output ignition modules while requiring a minimum input load. Many months of theoretical design and product research were expended in the development of the TC-HEI-800 ignition module which resulted in a very versatile, economical and powerful unit.

Application

The TC-HEI-800 ignition module is used exclusively with the TC-HEI-800 high performance igniter. This combination is used on flare and burner pilots alike.

Features

The TC-HEI-800 ignition module is manufactured with all solid state components to eliminate costly equipment failures. The TC-HEI-800 ignition module is encased in a high-performance epoxy to ensure long life and thermal stability of the solid state components. In the case of ignition modules supplied by our competitors, the user can only surmise that the igniter is

working by the ignition of the device on which it is installed. Because of this the TC-HEI-800 has a visual indicator that can be seen through a window mounted on the igniter module, one can be assured that the igniter is indeed working, thus eliminating the need to physically check the igniter when trouble-shooting pilot problems.

The TC-HEI-800 ignition module can be ordered in either a single-output or double-output application, and also for DIN rail mounting or panel mounting.

The TC-HEI-800 high-performance igniter is used in commercial aircraft turbines, which ensures reliability and long life as mandated by the FAA.

Specifications:

Input: 24 Vdc
Output: 800 Vdc
Power Usage: < 10 watts
Mounting: DIN rail or Panel mount
Environmental: -47°C to 40°C
Humidity 85% non-condensing

Weight: Single output 468 gm (16.5 oz)
Double output 510 gm (18.0 oz)
Dimensions: 150 mm x 70 mm x 76

Flame Front Generator for manual back up of HEI-800 Automatic Ignition System

A manual Flame Front Generator system complete with pilot ignition lines is provided. The FFG will operate with fuel gas and has provisions for a back-up propane fuel supply. Propane bottles for the back-up FFG system are not in the Tulsa Combustion Scope of Supply, as these are site-dependent.

The manual FFG is optional with the application of the Tulsa Combustion HEI-800 pilot ignition system and can be eliminated if that is preferred.

Utilities

Service	Units	
Electricity	Volts/Ph/HZ	110/1/50
Fuel Gas Pilot	SCFH	100 SCFH per pilot
Purge Gas	SCFH	18" -233 SCFH / 3" - 10 SCFH

Self-Supported Flare

85ft Overall Height

- Flange per API Standard 537 for flare tip air attachment
- Base Ring for attachment to foundation
- Utility piping
- Material – A-53 b for 18" main gas and 3" acid gas
- Structural Design - Per ASCE 7 and AISC
- Paint System - SP-6 with one primer coat of inorganic zinc on external carbon steel surfaces and one finished coat of epoxy paint.
- Ignition system
- Two pilots
- Meets 40 CFR requirements
- Enrichment fuel for acid gas 1300 scfh to reach 200 Btu/SCF (40 CFR requirement)

Optional KO Drum-

The base of the self supporting stack can easily be designed as the main flare knock out drum by adding a bottom head and a few additional nozzles. This approach may make the self supporting stack more attractive economically as the cost of a separate KO drum is eliminated.

1. Drawings and Documents

The following customer deliverables are included in pricing:

	DRAWING/DATA	For Approval A	For Record B
1	Process Flow Diagram	A	B
2	Piping & Instrumentation Diagram	A	B
3	Engineering Drawings	A	B
4	System Plans & Elevations	A	B
5	Instrument List	A	B
6	General Assembly-Major Components	A	B
7	Foundation Plan & Anchor Bolt Layout	A	B
8	All Available Vendor Data		B
9	Specification Sheets	A	B

Pricing includes one submission, one review and return of documents incorporating all customer comments for submission A. Submission B will be for record only and not subject to review or modification within the original scope. Additional comments, format changes, additional documents are not included in the quoted price and will be supplied at the current professional rates and will be charged to the customer.

DEFINITIONS

1. Process Flow Diagram: A schematic representation of the process indicating state of the fluid at the input and output of each major component.
2. Piping and Instrumentation Diagram: A schematic representation of the process, based on the process flow diagram, indicating control, scope, functions, major interconnecting line sizes, and instrument locations (panel, field, etc.).
3. Engineering Drawings: Plan and Elevation with Member sizes and connection details
4. System Plans and Elevations: An orthographic depiction of the equipment indicating overall size of major components, plot area requirements, height and location of major components with respect to each other.
5. Instrument List: A list indicating type of instrument, tag number, location, and vendor.
6. General Assembly of Major Components: An orthographic depiction of each major component. This drawing will indicate overall dimensions, weight, connection locations, Nozzle legends, materials of construction and equipment features.
7. Foundation Plan and Anchor Bolt Layout: Orthographic depiction of foundation requirements including anchor bolt location and loading.
8. All Available Vendor Data: All technical and maintenance data furnished to Tulsa Combustion by its component vendors.
9. Specification Sheets: The technical specifications that were used to purchase major components and instrumentation.

The following items are not included:

1. Calculations: Tulsa Combustion will perform calculations. They will not be subject to formal review.
2. Shop details/fabrication drawings
3. Foundation design
4. Wire and conduit schedules

The following items are to be provided by the customer unless otherwise specified in this proposal:

1. Shipment of all material from Point of Manufacture
2. Interconnecting piping, conduit and wire
3. Fuel and labor for cure of refractory (supervised by Tulsa Combustion)

CLARIFICATIONS: STANDARDS FOR PROPOSED EQUIPMENT

Unless otherwise specified in this Proposal, the following standards will apply to the proposed equipment:

1. WELDING: Per ASME SECTION IX Standards
2. Pressure vessels over 8" are constructed to ASME SECTION VIII and stamped, below 6" diameter they are considered piping and constructed to ANSI B 31.3
3. PIPING MATERIAL: A-106 or A-53B. Unless specifically called out in this proposal, piping 1.5" or smaller will be field-fabricated by others from materials supplied by Tulsa Combustion.
4. CARBON STEEL: A-572-50 or equal. A-500 for structural pipe
5. INSPECTION AND TESTING:
 - a. The following items are not provided for:
 - Hydrostatic test except as called out below
 - PMI
 - Hardness
 - Charpy tests
 - b. The following tests will be performed:
 - X ray as required by ASME code calculations only
 - Hydro Tests as required by ASME code or B31.3

2. Project Schedule

Initial Drawings for Approval: 1-2 weeks after the acceptance of a purchase order.
Shipment of Flare: 10-14 weeks after approved drawings for any options listed

3. Pricing and Commercial Terms

-85ft OAH Self-Supported Flare	\$89,489.00 USD
-Alternative – 85ft OAH Self-Supported Flare with KO drum at base of flare	\$99,156.00 USD
-20ft OAH Truck/Tank Flare	\$9,632.00 USD

Payment Schedule

Payments required by Tulsa Combustion to keep the project in a neutral cash flow will be due according the completion of milestones as follows:

- 30 % on Acceptance of a Purchase Order – Net 0
- 30% on Submittal of Initial Drawings for Approval – Net 15
- 30% on Completion of Fabrication – Net 15
- 10% on Shipment or Notification Equipment is Ready – Net 15

All progress payments are net 15 days, except the initial payment that is due with the Purchase Order.

Terms of Sale

Tulsa Combustion's standard Terms of Sale appear on the following pages.



Zeeco S.O. No. 31974

Customer Saulsbury Industries

Customer PO No. 10231-80312

FL-2850

This manual covers the component description, installation, operation and maintenance of the below description.

- (1) 40' Ft tall enclosed ground flare stack EGF-7.5-40 with Proflame Flame Scanner
- 10hp Blower
- VFD for customer control
- (2) HSLF-HEI electronic ignition pilot with status monitoring thermocouple.
- HEI ignition and pilot thermocouple wire in flex conduit to connect to the pilot ignition and monitoring rack.
- (1) HEIC pilot ignition and monitoring system mounted on a free standing rack
- (1) 6" Protego DA-SB-300/150-IIA-P1,1

Installation, Operation and Maintenance Manual

For Information, Service or Repair Please Contact:

**Zeeco, Inc.
22151 East 91st Street
Broken Arrow, OK 74014 USA**

**Phone: 918-258-8551
Fax: 918-251-5519**

**World Wide Web: www.zeeco.com
E-Mail: sales@zeeco.com**





Customer Process Data Sheet



Process Conditions -- English Units

Client: Salsbury	Zeeco Ref.: 31974	Date: 1-Jun-17
Location: Loving, NM	Client Ref.: Lucid Road Runner	Rev. AS SOLD

	Mol %					
	Scen. 1 (1101 lb/hr)	Scen. 2 (191 lb/hr)	Scen. 1 + Scen. 2 (1292 lb/hr)	Scen. 2 (191 lb/hr)	Scen. 3 (1740 lb/hr)	Scen. 2 + Scen. 3 (1931 lb/hr)
METHANE		98.20	42.85	98.20		30.34
ETHANE		0.38	0.17	0.38		0.12
PROPANE	0.03	0.01	0.02	0.01	0.47	0.33
BUTANE	27.48	0.01	15.49	0.01	53.74	37.14
PENTANE	48.22		27.18		35.39	24.45
HEXANE	13.66		7.70		8.19	5.66
HEPTANE	3.77		2.12		2.09	1
OCTANE	0.24		0.13		0.12	0
NONANE	3.33		1.88			
DECANE						
DODECANE						
TRIDECANE						
CYCLOPENTANE						
ETHYLENE						
PROPYLENE						
BUTYLENE						
ACETYLENE						
BENZENE	1.16		0.66			
TOLUENE	0.32		0.18			
XYLENE	0.06		0.03			
CARBON MONOXIDE						
CARBON DIOXIDE		0.00	0.00	0.00		0.00
HYDROGEN SULFIDE						
SULFUR DIOXIDE						
AMMONIA						
AIR						
HYDROGEN						
OXYGEN						
NITROGEN	1.74	1.40	1.59	1.40		0.43
WATER						
BUTADIENE						
METHANOL						
Total	100	100	100	100	100	100
Mol. Wt.	72.61	16.27	48.03	16.27	66.27	50.82
L. H. V. (BTU/SCF):	3,691	899	2,473	899	3,407	2,632.2
Temperature (Deg. F):	120.0	75.0	100.4	75.0	90.0	85.4
Avail. Static Pressure (psig):	0.75	0.75	0.75	0.75	0.75	0.75
Flow Rate (lbs/hr):	1,101	191	1,292	191	1,740	1,931
Smokeless Rate (lbs/hr):	1,101	191	1,292	191	1,740	1,931



UTILITIES REQUIREMENTS



Utility Requirements

Client:	Saulsbury	Zeeco Ref.: 31974	Date:	1-Jun-17
Location:	Loving, NM	Client Ref.: Lucid Road Runner	Rev.	AS SOLD

Pilot Gas

Pilots: 2
Total Fuel Gas: 130 Scfh @ 15 psig or 58 Scfh Propane @ 7 psig

Electricity

Control Panel: 120V / 60 Hz / 1 Phase
Blower Motor: 460V / 60 Hz / 3 Phase

Recommended Flare Purge Rate

Flare Tip Size: 6
Seal Type: Velocity Seal
Purge Rate: 30 Scfh of a gas that will not go to dew point at operating temperatures



Zeeco Spare Parts



Spare Parts for Start-up and Two Years Operation

Client:	Zeeco Ref.: Standard List	Date: 1-Jan-14
Location:	Client Ref.:	Rev.

Part No.	Qty	Description	Unit Price	Delivery (Weeks)
	1	Pilot Temperature Switch		4
	1	Pilot Thermocouple		4
	1	HSLF-Z-T/C Pilot Assembly		4
	1	Electric Ignitor Probe Assembly		4
	1	HEI Ignition Module		4
	1	Pilot Light Bulb		2
	1	Pressure Gauge (Pilot Fuel Gas)		2

Net Price: U. S. Dollars

Minimum Invoice:

F.O.B. Point: Shop Door - Broken Arrow, OK, USA


Terms: Net 30 Days

Notes:

1. Prices are subject to change without notice.
2. The spare part items and quantities listed above are preliminary and are subject to change upon determination of final scope of supply.




Protego



In-Line Detonation Flame Arrester

for stable detonations and deflagrations in a straight through design with shock tube, bidirectional

PROTEGO® DA-SB



● Connection to the protected side
(only for type DA-SB-T-...)

Function and Description

The in-line detonation flame arresters type PROTEGO® DA-SB are the newest generation of flame arresters. On the basis of fluid dynamic, explosion dynamics calculation and decades of experience from field tests, a product line was developed that offers minimum pressure loss and maximum safety. The flame arrester uses the *Shock Wave Guide Tube Effect (SWGTE)* to separate the flame front and shock wave. The result is an in-line detonation arrester without a classic shock absorber; in addition the use of FLAMEFILTER® discs is minimized.

The devices are symmetrical and offer bidirectional flame arresting for deflagrations and stable detonations. The arrester essentially consists of two housing parts with an integrated shock tube (1) and the PROTEGO® flame arrester unit (2) in the center. The PROTEGO® flame arrester unit is modular and consists of several FLAMEFILTER® discs (3) and spacers firmly held in a FLAMEFILTER® cage. The number of FLAMEFILTER® discs and their gap size depends on the arrester's conditions of use.

By indicating the operating parameters such as temperature, pressure and explosion group, and the composition of the fluid, the optimum detonation arrester can be selected from a series of approved devices. The PROTEGO® DA-SB flame arresters are available for all explosion groups.

The standard design can be used up to an operating temperature of +60°C / 140°F and an absolute operating pressure up to 1.1 bar / 15.9 psi. Numerous devices with special approval can be obtained for higher pressures (see table 3) and higher temperatures.

Type-approved in accordance with the current ATEX Directive and EN ISO 16852 as well as other international standards.

Special Features and Advantages

- optimized performance from the patented *Shock Wave Guide Tube Effect (SWGTE)*
- less number of FLAMEFILTER® discs from the use of the patented shock tube (*SWGTE*)
- modular flame arrester unit enables each individual FLAMEFILTER® discs to be replaced and cleaned
- different series allow increase of FLAMEFILTER® size for given flange connection resulting in lower pressure drop across the device
- service-friendly design
- expanded application range for higher operating temperatures and pressures
- bidirectional operation as well as any direction of flow and installation position
- installation of temperature sensors are possible
- minimum pressure loss and associated low operating and life-cycle cost
- cost efficient spare parts

Design Types and Specifications

There are four different designs available:

Basic in-line detonation flame arrester **DA-SB - [] - []**

In-line detonation flame arrester with integrated temperature sensor* as additional protection against short time burning from one side **DA-SB - [T] - []**

In-line detonation flame arrester with two integrated temperature sensors* for additional protection against short time burning from both sides **DA-SB - [TB] - []**

In-line detonation flame arrester with heating jacket **DA-SB - [H] - []**

Additional special flame arresters upon request

*Resistance thermometer for device group II, category (1) 2 (GII cat. (1) 2)

Table 1: Dimensions

Dimensions in mm / inches

To select nominal width/nominal size (NG/DN) - combination, please use the flow capacity charts on the following pages

Additional nominal width/nominal size (NG/DN) - combinations for improved flow capacity upon request

standard (special sizes up to NG 2000/80", DN 1000/40" available)

NG	150 6"	150 6"	200 8"	300 12"	400 16"	500 20"	600 24"	700 28"	800 32"	1000 40"	1200 48"	1600 64"
DN	≤ 50 2"	65, 80 2 ½", 3"	≤ 100 4"	≤ 150 6"	≤ 200 8"	≤ 250 10"	≤ 300 12"	≤ 350 14"	≤ 400 16"	≤ 500 20"	≤ 600 24"	800 32"
a	285 / 11.22	285 / 11.22	340 / 13.39	445 / 17.52	565 / 22.24	670 / 26.38	780 / 30.71	895 / 35.24	1015 / 39.96	1230 / 48.43	1455 / 57.28	1915 / 75.39
IIA-P1,1	388 / 15.28	388 / 15.28	476 / 18.74	626 / 24.65	700 / 27.56	800 / 31.50*	1000 / 39.37*	1200 / 47.24	1400 / 55.12	1600 / 62.99	1800 / 70.87	2200 / 86.61**
IIA-P1,4-X3	400 / 15.75	400 / 15.75	488 / 19.21	626 / 24.65	724 / 28.50	800 / 31.50	1000 / 39.37	1200 / 47.24	1400 / 55.12			
b IIB3-P1,1	400 / 15.75	412 / 16.22	500 / 19.69	650 / 25.59	724 / 28.50	824 / 32.44	1000 / 39.37	1200 / 47.24	1400 / 55.12	1600 / 62.99	1800 / 70.87	
IIB3-P1,4-X3	412 / 16.22	412 / 16.22	512 / 20.16	650 / 25.59	724 / 28.50	824 / 32.44	1000 / 39.37	1200 / 47.24	1400 / 55.12			
IIC-P1,1	400 / 15.75	400 / 15.75	500 / 19.69	638 / 25.12	700 / 27.56	788 / 31.02	1000 / 39.37***	1200 / 47.24***	1400 / 55.12***			
c	500 / 19.69	500 / 19.69	520 / 20.47	570 / 22.44	620 / 24.41	670 / 26.38	720 / 28.35	770 / 30.31	820 / 32.28	950 / 37.40	1050 / 41.34	1250 / 49.21

* dimension b only for P1.4 / 20.3

** dimension b only for P1.2 / 17.4

*** EN 12874

Table 2: Selection of the explosion group

MESG	Expl. Gr. (IEC/CEN)	Gas Group (NEC)	Special approvals upon request
> 0,90 mm	IIA	D	
≥ 0,65 mm	IIB3	C	
< 0,50 mm	IIC	B	

Table 3: Selection of max. operating pressure


NG	150 6"	150 6"	200 8"	300 12"	400 16"	500 20"	600 24"	700 28"	800 32"	1000 40"	1200 48"	1600 64"	
DN	≤ 50 2"	65, 80 2 ½", 3"	≤ 100 4"	≤ 150 6"	≤ 200 8"	≤ 250 10"	≤ 300 12"	≤ 350 14"	≤ 400 16"	≤ 500 20"	≤ 600 24"	800 32"	
Expl. Gr.	IIA	P _{max}	2.1 / 30.5	2.1 / 30.5	2.1 / 30.5	2.1 / 30.5	2.1 / 30.5	1.4 / 20.3	1.4 / 20.3	1.4 / 20.3	1.1 / 15.9	1.1 / 15.9	1.2 / 17.4
	IIB3	P _{max}	1.4 / 20.3	1.4 / 20.3	1.4 / 20.3	1.8 / 26.1	1.8 / 26.1	1.8 / 26.1	1.8 / 26.1	1.4 / 20.3	1.4 / 20.3	1.1 / 15.9	1.1 / 15.9
	IIC	P _{max}	2.2 / 31.9	2.2 / 31.9	1.1 / 15.9	1.1 / 15.9	1.1 / 15.9	1.1 / 15.9	1.1 / * 15.9	1.1 / * 15.9	1.1 / * 15.9		

P_{max} = maximum allowable operating pressure in bar / psi absolut, higher operating pressure upon request

in-between size up to P_{max} upon request

* capacity charts upon request





In-Line Detonation Flame Arrester

for stable detonations and deflagrations in a straight through design with shock tube, bidirectional

PROTEGO® DA-SB

Table 4: Specification of max. operating temperature

≤ 60°C / 140°F	≤ 200°C / 392°F	T _{maximum allowable operating temperature in °C}	higher operating temperatures upon request
-	X3	Designation	

Table 5: Material selection for housing

Design	A	B	C	The housing is also available in Steel with ECTFE coating.
Housing	Steel	Stainless Steel	Hastelloy	
Heating jacket (DA-SB-(T)-H-...)	Steel	Stainless Steel	Stainless Steel	
Gasket	PTFE	PTFE	PTFE	
Flame arrester unit	A, B	B, C, D	D	

Special materials upon request

Table 6: Material combinations of the flame arrester unit

Design	A	B	C	D	*the FLAMEFILTER® are also available in the materials Tantalum, Inconel, Copper, etc. when the listed housing and cage materials are used.
FLAMEFILTER® cage	Steel	Stainless Steel	Stainless Steel	Hastelloy	
FLAMEFILTER® *	Stainless Steel	Stainless Steel	Hastelloy	Hastelloy	
Spacer	Stainless Steel	Stainless Steel	Hastelloy	Hastelloy	

Special materials upon request

Table 7: Flange connection type


EN 1092-1; Form B1	other types upon request
ASME B16.5; 150 lbs RFSF	

In-Line Detonation Flame Arrester


Flow Capacity Charts

PROTEGO® DA-SB

* P1.4
** P1.2




X3 maximum allowable operating temperature 200 °C



The flow capacity charts have been determined with a calibrated and TÜV certified flow capacity test rig. Volume flow \dot{V} in (m³/h) and CFH refer to the standard reference conditions of air ISO 6358 (20°C, 1bar). Conversion to other densities and temperatures refer to Vol. 1: "Technical Fundamentals".








In-Line Detonation Flame Arrester

Flow Capacity Charts

PROTEGO® DA-SB



The flow capacity charts have been determined with a calibrated and TÜV certified flow capacity test rig.
 Volume flow \dot{V} in (m³/h) and CFH refer to the standard reference conditions of air ISO 6358 (20°C, 1bar).
 Conversion to other densities and temperatures refer to Vol. 1: "Technical Fundamentals".




Section 8


Map(s)

A map such as a 7.5 minute topographic quadrangle showing the exact location of the source. The map shall also include the following:

The UTM or Longitudinal coordinate system on both axes	An indicator showing which direction is north
A minimum radius around the plant of 0.8km (0.5 miles)	Access and haul roads
Topographic features of the area	Facility property boundaries
The name of the map	The area which will be restricted to public access
A graphical scale	

An area map is attached.



			Area Map		Lucid Energy Delaware, LLC		
Scale: 1:20,000	Drawn by: MDF	Date: 10/29/2021	Red Hills Gas Processing Plant N 32° 12' 38" Latitude W 103° 31' 26" Longitude		Project No.:	File Name:	Figure:
	Chk'd by:	Date:			097-013	Red Hills Area Map	Section 8

Section 9

Proof of Public Notice

(for NSR applications submitting under 20.2.72 or 20.2.74 NMAC)

(This proof is required by: 20.2.72.203.A.14 NMAC “Documentary Proof of applicant’s public notice”)

Public notice is not required for this application as it is a being submitted under 20.2.70 NMAC, for Title V permits. Public notice was last completed for the NSR permit revision application in July 2019.

Section 10

Written Description of the Routine Operations of the Facility

A written description of the routine operations of the facility. Include a description of how each piece of equipment will be operated, how controls will be used, and the fate of both the products and waste generated. For modifications and/or revisions, explain how the changes will affect the existing process. In a separate paragraph describe the major process bottlenecks that limit production. The purpose of this description is to provide sufficient information about plant operations for the permit writer to determine appropriate emission sources.

The Red Hills Gas Processing Plant is an existing natural gas processing plant located in Lea County, NM. The primary function of the plant is to remove CO₂ and water from sweet field gas so that the gas can meet pipeline specifications. The plant has been designated a primary Standard Industrial Classification (SIC) Code of 1311.

The operation of the Red Hills Gas Processing Plant is intended to process 75 MMSCFD of gas in Train 1, 40 MMSCFD in Train 1.5, 200 MMSCFD in Train 2, 200 MMSCFD in Train 3, 200 MMSCFD in Train 4 and 247.5 MMSCFD in Train 5 and 6 each. The facility total will be 1210 MMSCFD. Plant 2.5 will not increase total capacity of the site. The gas will be treated to remove acid gases (H₂S and SO₂) dehydrated to remove water and processed to remove C₂+ hydrocarbons from the gas stream. Several plant systems will be involved to perform these functions.

Slug Catcher / Separator

A slug catcher has been installed at the front of Train 1 to catch and separate any free hydrocarbon liquids and water present in the inlet pipeline gas stream. It is capable of handling large slugs of liquid brought into the plant from pipeline pigging operations. This equipment acts as a three-phase separator to separate the free hydrocarbons, gas to be processed, and any water that may condensed in the pipeline after field dehydration. A separate inlet system consisting of a series of separators and slug catchers will be associated with Train 2, and Train 3, 4, 5, and 6.

Propane Refrigeration

The propane refrigeration system works in tandem with the overhead stabilization system to remove heavier hydrocarbons in the gas stream in order to increase cryogenic efficiencies later in the process. Typically, the gas stream is refrigerated to just above -200°F and C₄+ components are dropped out of the process gas in varying efficiencies so the cryogenic equipment can concentrate on the lighter C₂ and C₃ components.

Stabilizer Overhead / Compressor

The overhead stabilization system is in place to assist in increasing plant efficiencies of Natural Gas Liquid (NGL) production and to lower the Reid Vapor Pressure (RVP) of the pipeline liquids and condensate after they are dropped out of the gas stream. Through a process that chills and compresses the gas from the inlet system, remaining vapors are separated off the refrigeration stream and are processed so the RVP is lowered to 9. Both the condensate from the refrigeration section of the plant and the hydrocarbon liquids out of the slug catcher are combined, stabilized and sent to the tank farm for truck or pipeline sales. Any remaining vapors are recycled back to the front of the stabilization process. The liquid in the tank farm is then stable and thus does not give off significant vapors. The tank farm is equipped with a fuel gas blanket for further protection.

Amine Treating

The amine units are designed to remove CO₂ and H₂S from the natural gas stream to meet pipeline specifications. In addition, carbon dioxide can freeze in the cryogenic unit, forming dry ice and forcing the shutdown of the facility. Amine treating is an exothermic chemical reaction process. The treating solution is a mixture of RO water and approximately 28-35% DEA (diethanolamine). This aqueous mixture is regenerated and reused. Lean DEA solution is pumped to the top of the contactor and allowed to flow downward. Wet gas is fed into the bottom of the contactor and flows upward. As the lean DEA solution flows down through the contactor, it comes into contact with the wet gas. The CO₂ reacts with the amine to form an amine carbonate. The reacted amine, known as "sour" or "rich" amine, and the processed ("sweet") gas continues to the dehydration system. Emissions from amine units 1-EP-4 and 2-EP-4 are controlled by the thermal oxidizer unit EP-5. Emissions from amine units 2.5-EP-4 and 5.5-EP-1d are controlled by Acid Gas Injection Wells (AGI) #1 and #2, respectively. During AGI compressor downtime, the controlled emissions are handled by Emergency AGI Flares, units 2.5-EP-5 and 5.5-EP-1b. Emissions from amine unit, 3-EP-4, are routed to the thermal oxidizer unit, EP-6. Emissions from amine unit, 4-EP-4, are routed to the thermal oxidizer unit, EP-8. Emissions from amine units, 5-EP-1f and 6-EP-1f, are routed to the thermal oxidizer unit, EP-10.

Hot Oil System

The hot oil system at the plant is used to provide heat to certain processes within the facility. The system will circulate hot oil and deliver 50.0 MMBTU/hr to other processes. It consists of the following components:

- Natural Gas-Fired Heater – This provides heat input into the system by burning natural gas and circulating the oil through the heater. The heater also has a convection section that assists in heating the regeneration gas for the molecular sieves.
- Hot Oil Pumps – These pumps circulate the required amount of hot oil through the system.
- Hot Oil Surge Tank – This tank provides expansion volume for the system. As the system heats up, the liquid will expand. This tank allows for the liquid to expand without spilling out of the system.
- Heat Exchangers – A series of exchangers, mainly the amine reboilers, glycol reboilers and regeneration gas heat exchangers that remove heat from the hot oil system and transfer it to the respective process.

Glycol Dehydration

Triethylene glycol (TEG) dehydration is used to remove water from the natural gas stream and is accomplished by reducing the inlet water dew point (temperature at which vapor begins to condense into a liquid) to the outlet dew point temperature which will contain a specified amount of water. Water vapor is absorbed by the TEG solution. The wet gas is brought into contact with dry “lean” glycol in a countercurrent contactor tower. Water vapor is absorbed in the glycol and consequently, its dew point reduces. Wet gas passing through the contactor tower is dehydrated, then passed to the mol sieves. The wet (or “rich”) glycol then flows from the absorber to a regeneration system in which it is partially decompressed, then heated to remove water vapor, resulting in “lean” glycol that is reintroduced to the contactor tower. Emissions from glycol dehydrator units, 1-EP-3 and 2a-EP-3, are controlled by thermal oxidizer unit, EP-5. Emissions from the other glycol dehydrator units, 3-EP-3 and 4-EP-3, are controlled by thermal oxidizer units, EP-6 and EP-8, respectively. Emissions from glycol dehydrator units, 5-EP-1e and 6-EP-1e, are controlled by thermal oxidizer, EP-10.

Molecular Sieve Dehydration

Molecular sieve dehydration is used upstream of the cryogenic units to achieve a gas stream dew point of -150°F. The process uses two molecular sieve vessels with one vessel in service absorbing moisture from the gas stream and the other vessel in the regeneration mode. During the regeneration mode, hot, dry gas (regen gas) is passed up through the vessel to drive off the absorbed moisture from the molecular sieve. The gas comes from the discharge of the residue compressors and it is passed through a heat exchanger (heated by hot oil) and a heater to achieve a temperature of approximately 500°F. After the gas passes through the bed it is cooled in an air-cooled exchanger. The water in the gas condenses and is separated from the gas stream in a separator. The regen gas can be routed to the sales gas stream, depending on the water content of the gas.

Cryogenic Unit

The cryogenic unit is designed to liquefy natural gas components from the sweet, dehydrated inlet gas by removing work (heat) from the gas by means of the turbo expander. The cryogenic unit recovers natural gas liquids (NGL) by cooling the gas stream to extremely cold temperatures (-150°F and lower) and condensing components such as ethane, propane, butanes and heavier. The gas is cooled by a series of heat exchangers and by rapidly lowering the pressure of the gas from around 760 PSIG to approximately 190 PSIG. Once the gas has passed through the system of heat exchangers and expansion, it is re-compressed using the energy obtained from expanding the gas. The gas is sent to residue compressors and pipelined out of the facility. In case the compressors are shut in, the gas is temporarily sent to the emergency flares.

Storage and Loading Operations

The natural gas liquids will be stored in up to five pressurized 90,000-gallon tanks, also called bullets. These tanks are not a source of regulated pollutants. The tank loading will take place via a pressurized, closed loop system. Unloading is done directly into a pipeline. The controls for tanks are listed below:

- Condensate tanks 1-T-1 through 1-T-6 are controlled by the enclosed combustion devices, EP-7
- Sour slop tanks, 2-T-1 and 2-T-2, are controlled by the sour slop tank control flare, EP-9
- Condensate tanks 3-T-1 through 3-T-6, are controlled by the enclosed combustion devices, EP-10
- Sour Water tanks 4-T-1 and 4-T-2, are controlled by the sour slop tank control flare, EP-13.

Flares

The plant flares are used during startup, shutdown, maintenance and upset conditions. The only steady state operations associated with these flares are from the pilot and purge gas streams. SSM emissions from the plant flare result from maintenance activities per manufacturer-recommended or other preventative maintenance schedules. These maintenance activities include, but are not limited to compressor catalyst changes, blowdowns for associated maintenance throughout the facility, instrument calibrations, and process safety device maintenance.

Emergency AGI Flare

When the AGI well is inoperable due to maintenance or upset conditions, acid gas will be flared for limited periods at the acid gas flare. Under startup, shutdown, maintenance, and upset conditions the AGI well could be offline. During times when the AGI well is down, the sour gas will be sent to the acid gas flare. The AGI Flare units, 2.5-EP-5 and 5.5-EP-5, will also control in-condensable and flash tank emissions from the amine vent units, 2.5-EP-4 and 5.5-EP-5.

Section 11

Source Determination

Source submitting under 20.2.70, 20.2.72, 20.2.73, and 20.2.74 NMAC

Sources applying for a construction permit, PSD permit, or operating permit shall evaluate surrounding and/or associated sources (including those sources directly connected to this source for business reasons) and complete this section. Responses to the following questions shall be consistent with the Air Quality Bureau’s permitting guidance, Single Source Determination Guidance, which may be found on the Applications Page in the Permitting Section of the Air Quality Bureau website.

Typically, buildings, structures, installations, or facilities that have the same SIC code, that are under common ownership or control, and that are contiguous or adjacent constitute a single stationary source for 20.2.70, 20.2.72, 20.2.73, and 20.2.74 NMAC applicability purposes. Submission of your analysis of these factors in support of the responses below is optional, unless requested by NMED.

A. Identify the emission sources evaluated in this section (list and describe):
See the Section 2 Tables for a list of all equipment included in this application.

B. Apply the 3 criteria for determining a single source:

SIC Code: Surrounding or associated sources belong to the same 2-digit industrial grouping (2-digit SIC code) as this facility, OR surrounding or associated sources that belong to different 2-digit SIC codes are support facilities for this source.

Yes **No**

Common Ownership or Control: Surrounding or associated sources are under common ownership or control as this source.

Yes **No**

Contiguous or Adjacent: Surrounding or associated sources are contiguous or adjacent with this source.

Yes **No**

C. Make a determination:

The source, as described in this application, constitutes the entire source for 20.2.70, 20.2.72, 20.2.73, or 20.2.74 NMAC applicability purposes. If in “A” above you evaluated only the source that is the subject of this application, all “YES” boxes should be checked. If in “A” above you evaluated other sources as well, you must check **AT LEAST ONE** of the boxes “NO” to conclude that the source, as described in the application, is the entire source for 20.2.70, 20.2.72, 20.2.73, and 20.2.74 NMAC applicability purposes.

The source, as described in this application, **does not** constitute the entire source for 20.2.70, 20.2.72, 20.2.73, or 20.2.74 NMAC applicability purposes (A permit may be issued for a portion of a source). The entire source consists of the following facilities or emissions sources (list and describe):

Section 12

Section 12.A

PSD Applicability Determination for All Sources

(Submitting under 20.2.72, 20.2.74 NMAC)

This section is not applicable as this is a Title V permit application be submitted under 20.2.70 NMAC. A PSD applicability determination was completed in the July 2019 NSR application.

Section 13

Determination of State & Federal Air Quality Regulations

This section lists each state and federal air quality regulation that may apply to your facility and/or equipment that are stationary sources of regulated air pollutants.

Not all state and federal air quality regulations are included in this list. Go to the Code of Federal Regulations (CFR) or to the Air Quality Bureau's regulation page to see the full set of air quality regulations.

Required Information for Specific Equipment:

For regulations that apply to specific source types, in the 'Justification' column **provide any information needed to determine if the regulation does or does not apply. For example**, to determine if emissions standards at 40 CFR 60, Subpart IIII apply to your three identical stationary engines, we need to know the construction date as defined in that regulation; the manufacturer date; the date of reconstruction or modification, if any; if they are or are not fire pump engines; if they are or are not emergency engines as defined in that regulation; their site ratings; and the cylinder displacement.

Required Information for Regulations that Apply to the Entire Facility:

See instructions in the 'Justification' column for the information that is needed to determine if an 'Entire Facility' type of regulation applies (e.g. 20.2.70 or 20.2.73 NMAC).

Regulatory Citations for Regulations That Do Not, but Could Apply:

If there is a state or federal air quality regulation that does not apply, but you have a piece of equipment in a source category for which a regulation has been promulgated, you must **provide the low level regulatory citation showing why your piece of equipment is not subject to or exempt from the regulation. For example** if you have a stationary internal combustion engine that is not subject to 40 CFR 63, Subpart ZZZZ because it is an existing 2 stroke lean burn stationary RICE with a site rating of more than 500 brake HP located at a major source of HAP emissions, your citation would be 40 CFR 63.6590(b)(3)(i). **We don't want a discussion of every non-applicable regulation, but if it is possible a regulation could apply, explain why it does not. For example**, if your facility is a power plant, you do not need to include a citation to show that 40 CFR 60, Subpart OOO does not apply to your non-existent rock crusher.

Regulatory Citations for Emission Standards:

For each unit that is subject to an emission standard in a source specific regulation, such as 40 CFR 60, Subpart OOO or 40 CFR 63, Subpart HH, include the low level regulatory citation of that emission standard. Emission standards can be numerical emission limits, work practice standards, or other requirements such as maintenance. **Here are examples:** a glycol dehydrator is subject to the general standards at 63.764C(1)(i) through (iii); an engine is subject to 63.6601, Tables 2a and 2b; a crusher is subject to 60.672(b), Table 3 and all transfer points are subject to 60.672(e)(1)

Federally Enforceable Conditions:

All federal regulations are federally enforceable. All Air Quality Bureau State regulations are federally enforceable except for the following: affirmative defense portions at 20.2.7.6.B, 20.2.7.110(B)(15), 20.2.7.11 through 20.2.7.113, 20.2.7.115, and 20.2.7.116; 20.2.37; 20.2.42; 20.2.43; 20.2.62; 20.2.63; 20.2.86; 20.2.89; and 20.2.90 NMAC. Federally enforceable means that EPA can enforce the regulation as well as the Air Quality Bureau and federally enforceable regulations can count toward determining a facility's potential to emit (PTE) for the Title V, PSD, and nonattainment permit regulations.

INCLUDE ANY OTHER INFORMATION NEEDED TO COMPLETE AN APPLICABILITY DETERMINATION OR THAT IS RELEVANT TO YOUR FACILITY'S NOTICE OF INTENT OR PERMIT.

EPA Applicability Determination Index for 40 CFR 60, 61, 63, etc: <http://cfpub.epa.gov/adi/>

Table for STATE REGULATIONS:

STATE REGULATIONS CITATION	Title	Applies? Enter Yes or No	Unit(s) or Facility	JUSTIFICATION: (You may delete instructions or statements that do not apply in the justification column to shorten the document.)
20.2.1 NMAC	General Provisions	Yes	Facility	General Provisions apply to Notice of Intent, Construction, and Title V permit applications.
20.2.3 NMAC	Ambient Air Quality Standards NMAAQS	Yes	Facility	This site is in compliance with the Federal and New Mexico ambient air quality standards. Air dispersion modeling was completed for the July 2019 NSR permit application.
20.2.7 NMAC	Excess Emissions	Yes	Facility	This regulation establishes requirements for the facility if operations at the facility result in any excess emissions. The owner or operator will operate the source at the facility having an excess emission, to the extent practicable, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions. The facility will notify the NMED of any excess emission per 20.2.7.110 NMAC.
20.2.23 NMAC	Fugitive Dust Control	No	N/A	This regulation may apply if, this is an application for a notice of intent (NOI) per 20.2.73 NMAC, if the activity or facility is a fugitive dust source listed at 20.2.23.108.A NMAC, and if the activity or facility is located in an area subject to a mitigation plan pursuant to 40 CFR 51.930. As of January 2019, the only areas of the State subject to a mitigation plan per 40 CFR 51.930 are in Doña Ana and Luna Counties. As this site is a permitted facility located in Lea County, NM, this regulation does not apply.
20.2.33 NMAC	Gas Burning Equipment - Nitrogen Dioxide	No	N/A	This facility does not have gas burning equipment with a heat input greater than 1,000,000 MMBtu.
20.2.34 NMAC	Oil Burning Equipment: NO ₂	No	N/A	This facility does not have oil burning equipment (external combustion emission sources, such as oil-fired boilers and heaters) having a heat input of greater than 1,000,000 million British Thermal Units per year per unit.
20.2.35 NMAC	Natural Gas Processing Plant – Sulfur	Yes	Facility	This regulation establishes sulfur emission standards for natural gas processing plants. The proposed facility meets the definition of a new natural gas processing plant under this regulation and is subject to the requirements of this regulation [20.2.35.7 (B) NMAC]. The facility will comply with all requirements under 20.2.35 NMAC as applicable.
20.2.37 and 20.2.36 NMAC	Petroleum Processing Facilities and Petroleum Refineries	N/A	N/A	These regulations were repealed by the Environmental Improvement Board. If you had equipment subject to 20.2.37 NMAC before the repeal, your combustion emission sources are now subject to 20.2.61 NMAC.
20.2.38 NMAC	Hydrocarbon Storage Facility	No	N/A	This regulation could apply to storage tanks at petroleum production facilities, processing facilities, tanks batteries, or hydrocarbon storage facilities. This facility does not meet any of the applicability determinations under 20.2.38 NMAC; therefore, this regulation does not apply.
20.2.39 NMAC	Sulfur Recovery Plant - Sulfur	No	N/A	This regulation could apply to sulfur recovery plants that are not part of petroleum or natural gas processing facilities. As this site is a natural gas processing facility, this regulation does not apply.
20.2.61.109 NMAC	Smoke & Visible Emissions	Yes	Stationary Combustion Equipment	This regulation that limits opacity to 20% applies to Stationary Combustion Equipment, such as engines, boilers, heaters, and flares unless your equipment is subject to another state regulation that limits particulate matter such as 20.2.19 NMAC (see 20.2.61.109 NMAC). The listed equipment must comply with this regulation.
20.2.70 NMAC	Operating Permits	Yes	Facility	This facility is a Title V major source and operates under Title V permit number P-278.

<u>STATE REGULATIONS</u> CITATION	Title	Applies? Enter Yes or No	Unit(s) or Facility	JUSTIFICATION: (You may delete instructions or statements that do not apply in the justification column to shorten the document.)
20.2.71 NMAC	Operating Permit Fees	Yes	Facility	If 20.2.70 NMAC applies then 20.2.71 NMAC applies. All operating permit fees will be paid, as required.
20.2.72 NMAC	Construction Permits	Yes	Facility	This facility is subject to 20.2.72 NMAC and currently operates under NSR permit number 4310-M5.
20.2.73 NMAC	NOI & Emissions Inventory Requirements	Yes	Facility	All facilities that are a Title V Major Source as defined at 20.2.70.7.R NMAC, are subject to Emissions Inventory Reporting.
20.2.74 NMAC	Permits – Prevention of Significant Deterioration (PSD)	Yes	Facility	This facility is a PSD major source and currently operates under NSR permit number 4310-M5.
20.2.75 NMAC	Construction Permit Fees	No	N/A	As this is a Title V permit application, construction permit fees do not apply.
20.2.77 NMAC	New Source Performance	Yes	Units subject to 40 CFR 60	This is a stationary source which is subject to the requirements of 40 CFR Part 60.
20.2.78 NMAC	Emission Standards for HAPS	No	N/A	This facility emits hazardous air pollutants but none of which are subject to the requirements of 40 CFR Part 61.
20.2.79 NMAC	Permits – Nonattainment Areas	No	N/A	This facility is not located in a non-attainment area and therefore it is not subject to this regulation.
20.2.80 NMAC	Stack Heights	No	N/A	This regulation establishes requirements for the evaluation of stack heights and other dispersion techniques. This regulation does not apply as all stacks at the facility follow good engineering practice.
20.2.82 NMAC	MACT Standards for source categories of HAPS	Yes	Units Subject to 40 CFR 63	This regulation applies to all sources emitting hazardous air pollutants, which are subject to the requirements of 40 CFR Part 63.

Table for FEDERAL REGULATIONS:

<u>FEDERAL REGULATIONS</u> CITATION	Title	Applies? Enter Yes or No	Unit(s) or Facility	JUSTIFICATION:
40 CFR 50	NAAQS	Yes	Facility	This regulation defines national ambient air quality standards. The facility meets all applicable national ambient air quality standards for NOx, CO, SO2, PM10, and PM2.5 under this regulation.
NPS 40 CFR 60, Subpart A	General Provisions	Yes	Units subject to 40 CFR 60	Applies if any other Subpart in 40 CFR 60 applies.

<u>FEDERAL REGU- LATIONS CITATION</u>	Title	Applies? Enter Yes or No	Unit(s) or Facility	JUSTIFICATION:
NSPS 40 CFR60.40a, Subpart Da	Subpart Da, Performance Standards for Electric Utility Steam Generating Units	No	N/A	This regulation establishes standards of performance for electric utility steam generating units. This regulation does not apply because the facility does not operate any electric utility steam generating units.
NSPS 40 CFR60.40b Subpart Db	Electric Utility Steam Generating Units	No	N/A	This regulation does not apply because the facility does not operate any electric utility steam generating units.
40 CFR 60.40c, Subpart Dc	Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units	Yes	1-EP-1, 1.5-EP-1g, 4-EP-1g, 2-EP-1b, 2-EP-1h, 2a-EP-1d, 2.5-EP-1d, EP-5, EP-6, EP-8, 3-EP-1b, 3-EP-1d, 3-EP-1h, 4-EP-1a, 4-EP-1b, 4-EP-1d, 4-EP-1e, 4-EP-1h, 5-EP-1a, 5-EP-1b, 5-EP-1d, 6-EP-1a, 6-EP-1b, 6-EP-1d, 7-EP-1d, 5.5-EP-1a, EP-11	The listed units are steam generating units for which construction, modification or reconstruction is commenced after June 9, 1989 and that have a maximum design heat input capacity of 29 MW (100 MMBtu/hr) or less, but greater than or equal to 2.9 MW (10 MMBtu/hr).
NSPS 40 CFR 60, Subpart Ka	Standards of Performance for Storage Vessels for Petroleum Liquids for which Construction, Reconstruction, or Modification Commenced After May 18, 1978, and Prior to July 23, 1984	No	N/A	Except as provided in paragraph (b) of this section, the affected facility to which this subpart applies is each storage vessel with a storage capacity greater than 151,416 liters (40,000 gallons) that is used to store petroleum liquids for which construction is commenced after May 18, 1978 and prior to July 23, 1984. The condensate tanks at this facility were constructed after July 23, 1984, therefore, this subpart does not apply.
NSPS 40 CFR 60, Subpart Kb	Standards of Performance for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels) for Which Construction, Reconstruction, or Modification Commenced After July 23, 1984	No	N/A	Except as provided in paragraph (b) of this section, the affected facility to which this subpart applies is each storage vessel with a capacity greater than or equal to 75 cubic meters (m3) that is used to store volatile organic liquids (VOL) for which construction, reconstruction, or modification is commenced after July 23, 1984. The tanks at this facility have a design capacity less than or equal to 1,589.874 m3 used for petroleum or condensate stored, processed, or treated prior to custody transfer. The tanks are not subject.
NSPS 40 CFR 60.330 Subpart GG	Stationary Gas Turbines	No	N/A	There are no turbines onsite; therefore, this regulation does not apply.

<u>FEDERAL REGU- LATIONS CITATION</u>	Title	Applies? Enter Yes or No	Unit(s) or Facility	JUSTIFICATION:
NSPS 40 CFR 60, Subpart KKK	Leaks of VOC from Onshore Gas Plants	No	N/A	Affected Facility with Leaks of VOC from Onshore Gas Plants. Any affected facility under paragraph (a) of this section that commences construction, reconstruction, or modification after January 20, 1984 and on or before August 23, 2011, is subject to the requirements of this subpart. As this site was constructed after August 23, 2011, Subpart KKK is not applicable.
NSPS 40 CFR Part 60 Subpart LLL	Standards of Performance for Onshore Natural Gas Processing: SO₂ Emissions	No	N/A	This regulation applies to onshore natural gas processing facilities which commence construction, reconstruction, or modification after January 20, 1984 and on or before August 23, 2011. As this site was constructed after August 23, 2011, Subpart LLL does not apply.
NSPS 40 CFR Part 60 Subpart OOOO	Standards of Performance for Crude Oil and Natural Gas Production, Transmission, and Distribution for which construction, modification or reconstruction commenced after August 23, 2011 and before September 18, 2015	Yes	1-T-1, 1-T-2, 1-T-3, 1-T-4, 1-T-5, 1-T-6, 1-EP-4, FUG (Train 1), reciprocating compressors	<p>This regulation establishes emission standards and compliance schedule for the control of volatile organic compounds (VOC) emissions from affected facilities that commence construction, modification or reconstruction after August 23, 2011 and before September 18, 2015. Since the facility has equipment that was constructed or modified after August 23, 2011 and before September 18, 2015, pneumatic devices and equipment leaks are subject to this regulation. Amine Units, reciprocating compressors, and fugitive equipment leaks constructed between August 24, 2011 and September 18, 2015 are subject to this regulation. Lucid will comply with any applicable requirements under this subpart. Some of the condensate tanks at the facility are pressurized and do not meet the definition of a storage vessel in this regulation. All atmospheric condensate storage tanks are exempt from this regulation as they have less than 6 tpy VOC per affected unit. [40 CFR 60.5395]. As the control device for some of the tanks is included in the site's monitoring plan, the tanks listed here must to comply with OOOO requirements, per NSR permit 4310-M5.</p> <p>Sweetening units located at onshore natural gas processing plants are an affected unit. [40 CFR 60.5365(g)(1)].</p> <p>Leak standards will apply to new and modified units at this facility as per [40 CFR 60.5400].</p> <p>The pneumatic devices located at the facility will not be continuous gas bleed and therefore will not have applicable requirements under this regulation [40 CFR 60.5365(d)(3)]. This facility uses pneumatic air devices.</p>
NSPS 40 CFR Part 60 Subpart OOOOa	Standards of Performance for Crude Oil and Natural Gas Facilities for which Construction, Modification or Reconstruction Commenced After September 18, 2015	Yes	2-EP-4, 2.5-EP-4, 3-EP-4, 4-EP-4, 5-EP-1f, 6-EP-1f, FUG (Train 2-4), FUG-1, 2-T-1, 2-T-2, 3-T-1, 3-T-2, 3-T-3, 3-T-4, 3-T-5, 3-T-6, 4-T-1, 4-T-2, 5-T-1, 5-T-2, 5-T-3, 5-T-4	<p>This regulation applies to amine units and fugitive equipment leaks which commenced construction after September 18, 2015.</p> <p>Some of the condensate tanks at the facility are pressurized and do not meet the definition of a storage vessel in this regulation. All atmospheric condensate storage tanks are exempt from this regulation as they have less than 6 tpy VOC per affected unit. [40 CFR 60.5365a]. As the control device for some of the tanks is included in the site's monitoring plan, the tanks listed here must to comply with OOOOa requirements, per NSR permit 4310-M5.</p>

<u>FEDERAL REGU- LATIONS CITATION</u>	Title	Applies? Enter Yes or No	Unit(s) or Facility	JUSTIFICATION:
NSPS 40 CFR 60 Subpart IIII	Standards of performance for Stationary Compression Ignition Internal Combustion Engines	No	N/A	Not applicable as there are no compression ignition engines included in this permit.
NSPS 40 CFR Part 60 Subpart JJJJ	Standards of Performance for Stationary Spark Ignition Internal Combustion Engines	Yes	1-Gen-1	This regulation establishes standards of performance for stationary spark ignition internal combustion engines. The Caterpillar CG137 engine, unit 1- GEN-1, at this facility is subject to NSPS JJJJ as it commenced construction after June 12, 2006 and was manufactured on or after July 1, 2007 [§60.4230(a)(4)(i)].
NSPS 40 CFR 60 Subpart TTTT	Standards of Performance for Greenhouse Gas Emissions for Electric Generating Units	No	N/A	The facility does not operate an affected source under this subpart.
NSPS 40 CFR 60 Subpart UUUU	Emissions Guidelines for Greenhouse Gas Emissions and Compliance Times for Electric Utility Generating Units	No	N/A	The facility does not operate an affected source under this subpart.
NSPS 40 CFR 60, Subparts WWW, XXX, Cc, and Cf	Standards of performance for Municipal Solid Waste (MSW) Landfills	No	N/A	This facility is not a MSW landfill.
NESHAP 40 CFR 61 Subpart A	General Provisions	No	N/A	NSPS 40 CFR 61 does not apply to the facility because the facility does not emit or have the triggering substances on site and/or the facility is not involved in the triggering activity. The facility is not subject to this regulation. None of the subparts of Part 61 apply to the facility.
NESHAP 40 CFR 61 Subpart E	National Emission Standards for Mercury	No	N/A	The provisions of this subpart are applicable to those stationary sources which process mercury ore to recover mercury, use mercury chlor-alkali cells to produce chlorine gas and alkali metal hydroxide, and incinerate or dry wastewater treatment plant sludge. This facility is not involved in these activities. This regulation does not apply.
NESHAP 40 CFR 61 Subpart V	National Emission Standards for Equipment Leaks (Fugitive Emission Sources)	No	N/A	This regulation establishes national emission standards for equipment leaks (fugitive emission sources). The facility does not have equipment that operates in volatile hazardous air pollutant (VHAP) service [40 CFR Part 61.240]. The regulated activities subject to this regulation do not take place at this facility. The facility is not subject to this regulation.
MACT 40 CFR 63, Subpart A	General Provisions	Yes	Units Subject to 40 CFR 63	Applies if any other Subpart in 40 CFR 63 applies.

<u>FEDERAL REGU- LATIONS CITATION</u>	Title	Applies? Enter Yes or No	Unit(s) or Facility	JUSTIFICATION:
MACT 40 CFR 63.760 Subpart HH	Oil and Natural Gas Production Facilities	Yes	1-EP-3, 2a-EP-3, 3-EP-3, 4-EP-3, 5-EP-1e, 6-EP-1e, FUG, FUG-1	<p>This regulation establishes national emission standards for hazardous air pollutants from oil and natural gas production facilities. The facility is a major source of HAPs and meets the definition of a natural gas processing plant. The dehydrators will have a natural gas flow rate equal to or greater than 85 thousand standard cubic feet. The dehydrators that vent less than 0.90 megagrams per year to the atmosphere are exempt from the emissions control requirements of MACT HH per 63.764(e)(1)(ii). The dehydrators that comply with the 1 tpy control option under 63.765(b)(1)(ii) are considered large dehydrators under MACT HH.</p> <p>Fugitive components must comply with requirements under NSPS Subpart OOOO or OOOOa but there are still some reporting requirements that may apply under MACT Subpart HH. Lucid will comply with any applicable requirements under Subpart HH for this site.</p>
MACT 40 CFR 63 Subpart HHH	National Emissions Standards for Hazardous Air Pollutants from Natural Gas Transmission and Storage facilities	No	N/A	<p>This subpart applies to owners and operators of natural gas transmission and storage facilities that transport or store natural gas prior to entering the pipeline to a local distribution company or to a final end user (if there is no local distribution company), and that are major sources of hazardous air pollutants (HAP) emissions as defined in §63.1271. This regulation does not apply because this facility is not a natural gas transmission or storage facility as defined in this regulation [40 CFR Part 63.1270(a)].</p>
MACT 40 CFR 63 Subpart DDDDD	National Emission Standards for Hazardous Air Pollutants for Major Industrial, Commercial, and Institutional Boilers & Process Heaters	Yes	1-EP-1, 1.5-EP-1g, 4-EP-1g, 2-EP-1a, 2-EP-1b, 2-EP-1e, 2-EP-1h, 2a-EP-1d, 2.5-EP-1d, 3-EP-1a, 3-EP-1b, 3-EP-1d, 3-EP-1e, 3-EP-1h, 4-EP-1a, 4-EP-1b, 4-EP-1d, 4-EP-1e, 4-EP-1h, 5-EP-1a, 5-EP-1b, 5-EP-1c, 5-EP-1d, 5.5-EP-1a, 6-EP-1a, 6-EP-1b, 6-EP-1c, 6-EP-1d, 7-EP-1c, 7-EP-1d	<p>The facility is a major source of HAPS. The units listed will be subject to MACT 40 CFR 63 Subpart DDDDD as they will be constructed after the June 4, 2010 applicability date. The boilers and process heaters will be combusting natural gas. Lucid will comply with all applicable MACT DDDDD requirements.</p>
MACT 40 CFR 63 Subpart UUUUU	National Emission Standards for Hazardous Air Pollutants Coal & Oil Fire Electric Utility Steam Generating Unit	No	N/A	<p>See 63.9980 (known as the MATs rule) EPA Guidance Page: https://www.epa.gov/boilers</p>
MACT 40 CFR 63 Subpart ZZZZ	National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE MACT)	Yes	1-Gen-1	<p>The generator engine (1-Gen-1) at this facility is subject to ZZZZ as new stationary RICE located at a major source. The engine must meet the requirements of MACT ZZZZ by meeting the requirements of NSPS JJJJ. No other requirements under this part apply.</p>

<u>FEDERAL REGU- LATIONS CITATION</u>	Title	Applies? Enter Yes or No	Unit(s) or Facility	JUSTIFICATION:
40 CFR 64	Compliance Assurance Monitoring	Yes	2-EP-4, 3-EP-4, 4-EP-4, 5-EP-1f, 6-EP-1f, 1-EP-3, 2a-EP-3, 3-EP-3, 4-EP-3, 5-EP-1e, 6-EP-1e	This regulation defines compliance assurance monitoring (CAM). This regulation applies to the listed amine units and glycol dehydration units because the units have potential pre-control device emissions that are equal to or greater than 100 percent of the amount, in tons per year, required for a source to be classified as a major source. The units currently in operation are included in the site's CAM plan, which is being updated with this application, and can be found in Section 19. Lucid will comply with all applicable requirements under 40 CFR Part 64.
40 CFR 68	Chemical Accident Prevention	Yes	Facility	The facility is an affected facility, as it will use flammable process chemicals such as propane at quantities greater than the thresholds. The facility will develop and maintain an RMP for these chemicals.
Title IV – Acid Rain 40 CFR 72	Acid Rain	No	N/A	This regulation does not apply as this facility does not generate commercial electric power or electric power for sale.
Title IV – Acid Rain 40 CFR 73	Sulfur Dioxide Allowance Emissions	No	N/A	This regulation does not apply as this facility does not generate commercial electric power or electric power for sale.
Title IV-Acid Rain 40 CFR 75	Continuous Emissions Monitoring	No	N/A	This regulation does not apply as this facility does not generate commercial electric power or electric power for sale.
Title IV – Acid Rain 40 CFR 76	Acid Rain Nitrogen Oxides Emission Reduction Program	No	N/A	This regulation does not apply as this facility does not generate commercial electric power or electric power for sale.
Title VI – 40 CFR 82	Protection of Stratospheric Ozone	No	N/A	Not applicable as this facility does not meet any of the following: (40 CFR 82.1 and 82.100) produce, transform, destroy, import or export a controlled substance or import or export a controlled product; (40 CFR 82.30) if you perform service on a motor vehicle for consideration when this service involves the refrigerant in the motor vehicle air conditioner; (40 CFR 82.80) if you are a department, agency, and instrumentality of the United States subject to Federal procurement requirements; (82.150) if you service, maintain, or repair appliances, dispose of appliances, refrigerant reclaimers, if you are an owner or operator of an appliance , if you are a manufacturer of appliances or of recycling and recovery equipment, if you are an approved recycling and recovery equipment testing organization, and/or if you sell or offer for sell or purchase class I or class I refrigerants.

Section 14

Operational Plan to Mitigate Emissions

(Submitting under 20.2.70, 20.2.72, 20.2.74 NMAC)

- Title V Sources** (20.2.70 NMAC): By checking this box and certifying this application the permittee certifies that it has developed an **Operational Plan to Mitigate Emissions During Startups, Shutdowns, and Emergencies** defining the measures to be taken to mitigate source emissions during startups, shutdowns, and emergencies as required by 20.2.70.300.D.5(f) and (g) NMAC. This plan shall be kept on site to be made available to the Department upon request. This plan should not be submitted with this application.
- NSR** (20.2.72 NMAC), **PSD** (20.2.74 NMAC) & **Nonattainment** (20.2.79 NMAC) **Sources**: By checking this box and certifying this application the permittee certifies that it has developed an **Operational Plan to Mitigate Source Emissions During Malfunction, Startup, or Shutdown** defining the measures to be taken to mitigate source emissions during malfunction, startup, or shutdown as required by 20.2.72.203.A.5 NMAC. This plan shall be kept on site to be made available to the Department upon request. This plan should not be submitted with this application.
- Title V** (20.2.70 NMAC), **NSR** (20.2.72 NMAC), **PSD** (20.2.74 NMAC) & **Nonattainment** (20.2.79 NMAC) **Sources**: By checking this box and certifying this application the permittee certifies that it has established and implemented a Plan to Minimize Emissions During Routine or Predictable Startup, Shutdown, and Scheduled Maintenance through work practice standards and good air pollution control practices as required by 20.2.7.14.A and B NMAC. This plan shall be kept on site or at the nearest field office to be made available to the Department upon request. This plan should not be submitted with this application.
-

Lucid has developed the above-mentioned plans and they will be made available to the Department upon request.

Section 15

Alternative Operating Scenarios

(Submitting under 20.2.70, 20.2.72, 20.2.74 NMAC)

Alternative Operating Scenarios: Provide all information required by the department to define alternative operating scenarios. This includes process, material and product changes; facility emissions information; air pollution control equipment requirements; any applicable requirements; monitoring, recordkeeping, and reporting requirements; and compliance certification requirements. Please ensure applicable Tables in this application are clearly marked to show alternative operating scenario.

Construction Scenarios: When a permit is modified authorizing new construction to an existing facility, NMED includes a condition to clearly address which permit condition(s) (from the previous permit and the new permit) govern during the interval between the date of issuance of the modification permit and the completion of construction of the modification(s). There are many possible variables that need to be addressed such as: Is simultaneous operation of the old and new units permitted and, if so for example, for how long and under what restraints? In general, these types of requirements will be addressed in Section A100 of the permit, but additional requirements may be added elsewhere. Look in A100 of our NSR and/or TV permit template for sample language dealing with these requirements. Find these permit templates at: https://www.env.nm.gov/aqb/permit/aqb_pol.html. Compliance with standards must be maintained during construction, which should not usually be a problem unless simultaneous operation of old and new equipment is requested.

In this section, under the bolded title “Construction Scenarios”, specify any information necessary to write these conditions, such as: conservative-realistic estimated time for completion of construction of the various units, whether simultaneous operation of old and new units is being requested (and, if so, modeled), whether the old units will be removed or decommissioned, any PSD ramifications, any temporary limits requested during phased construction, whether any increase in emissions is being requested as SSM emissions or will instead be handled as a separate Construction Scenario (with corresponding emission limits and conditions, etc).

There are no alternative operating scenarios being proposed with this application.

Section 16

Air Dispersion Modeling

- 1) Minor Source Construction (20.2.72 NMAC) and Prevention of Significant Deterioration (PSD) (20.2.74 NMAC) ambient impact analysis (modeling): Provide an ambient impact analysis as required at 20.2.72.203.A(4) and/or 20.2.74.303 NMAC and as outlined in the Air Quality Bureau’s Dispersion Modeling Guidelines found on the Planning Section’s modeling website. If air dispersion modeling has been waived for one or more pollutants, attach the AQB Modeling Section modeling waiver approval documentation.
- 2) SSM Modeling: Applicants must conduct dispersion modeling for the total short term emissions during routine or predictable startup, shutdown, or maintenance (SSM) using realistic worst case scenarios following guidance from the Air Quality Bureau’s dispersion modeling section. Refer to "Guidance for Submittal of Startup, Shutdown, Maintenance Emissions in Permit Applications (http://www.env.nm.gov/aqb/permit/app_form.html) for more detailed instructions on SSM emissions modeling requirements.
- 3) Title V (20.2.70 NMAC) ambient impact analysis: Title V applications must specify the construction permit and/or Title V Permit number(s) for which air quality dispersion modeling was last approved. Facilities that have only a Title V permit, such as landfills and air curtain incinerators, are subject to the same modeling required for preconstruction permits required by 20.2.72 and 20.2.74 NMAC.

What is the purpose of this application?	Enter an X for each purpose that applies
New PSD major source or PSD major modification (20.2.74 NMAC). See #1 above.	
New Minor Source or significant permit revision under 20.2.72 NMAC (20.2.72.219.D NMAC). See #1 above. Note: Neither modeling nor a modeling waiver is required for VOC emissions.	
Reporting existing pollutants that were not previously reported.	
Reporting existing pollutants where the ambient impact is being addressed for the first time.	
Title V application (new, renewal, significant, or minor modification. 20.2.70 NMAC). See #3 above.	X
Relocation (20.2.72.202.B.4 or 72.202.D.3.c NMAC)	
Minor Source Technical Permit Revision 20.2.72.219.B.1.d.vi NMAC for like-kind unit replacements.	
Other: i.e. SSM modeling. See #2 above.	
This application does not require modeling since this is a No Permit Required (NPR) application.	
This application does not require modeling since this is a Notice of Intent (NOI) application (20.2.73 NMAC).	
This application does not require modeling according to 20.2.70.7.E(11), 20.2.72.203.A(4), 20.2.74.303, 20.2.79.109.D NMAC and in accordance with the Air Quality Bureau’s Modeling Guidelines.	

Check each box that applies:

- See attached, approved modeling **waiver for all** pollutants from the facility.
- See attached, approved modeling **waiver for some** pollutants from the facility.
- Attached in Universal Application Form 4 (UA4) is a **modeling report for all** pollutants from the facility.
- Attached in UA4 is a **modeling report for some** pollutants from the facility.
- No modeling is required.

This application is for a Title V revision submitted under 20.2.70 NMAC; therefore, air dispersion modeling is not required with this submittal. Air dispersion modeling was last performed for the July 2019 NSR revision application.

Section 17

Compliance Test History

(Submitting under 20.2.70, 20.2.72, 20.2.74 NMAC)

To show compliance with existing NSR permits conditions, you must submit a compliance test history. The table below provides an example.

The generator engine (1-Gen-1) has not yet operated onsite; therefore, no compliance testing has been performed. Per 40 CFR Part 60, Subpart JJJJ, §60.4244(b): “You may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified in § 60.8(c). If your stationary SI internal combustion engine is non-operational, you do not need to startup the engine solely to conduct a performance test; however, you must conduct the performance test immediately upon startup of the engine.” Lucid will perform any required compliance testing once the engine is operating.

Any other compliance testing information will be made available upon request by NMED.

Section 18

Addendum for Streamline Applications

Do not print this section unless this is a streamline application.

This Section is not applicable as this application is for a Title V permit under 20.2.70 NMAC.

Section 19

Requirements for Title V Program

Do not print this section unless this is a Title V application.

Who Must Use this Attachment:

- * Any major source as defined in 20.2.70 NMAC.
 - * Any source, including an area source, subject to a standard or other requirement promulgated under Section 111 - Standards of Performance for New Stationary Sources, or Section 112 Hazardous Air Pollutants, of the 1990 federal Clean Air Act ("federal Act"). Non-major sources subject to Sections 111 or 112 of the federal Act are exempt from the obligation to obtain an 20.2.70 NMAC operating permit until such time that the EPA Administrator completes rulemakings that require such sources to obtain operating permits. In addition, sources that would be required to obtain an operating permit solely because they are subject to regulations or requirements under Section 112(r) of the federal Act are exempt from the requirement to obtain an Operating Permit.
 - * Any Acid Rain source as defined under title IV of the federal Act. The Acid Rain program has additional forms. See <http://www.env.nm.gov/aqb/index.html>. Sources that are subject to both the Title V and Acid Rain regulations are encouraged to submit both applications simultaneously.
 - * Any source in a source category designated by the EPA Administrator ("Administrator"), in whole or in part, by regulation, after notice and comment.
-

19.1 - 40 CFR 64, Compliance Assurance Monitoring (CAM) (20.2.70.300.D.10.e NMAC)

Any source subject to 40CFR, Part 64 (Compliance Assurance Monitoring) must submit all the information required by section 64.7 with the operating permit application. The applicant must prepare a separate section of the application package for this purpose; if the information is already listed elsewhere in the application package, make reference to that location. Facilities not subject to Part 64 are invited to submit periodic monitoring protocols with the application to help the AQB to comply with 20.2.70 NMAC. Sources subject to 40 CFR Part 64, must submit a statement indicating your source's compliance status with any enhanced monitoring and compliance certification requirements of the federal Act.

The glycol dehydrators, amine vents, sour slop tanks and fugitive emissions (Units 1-EP-3, 2-EP-4, 2a-EP-3, 3-EP-3, 3-EP-4, 4-EP-3, 4-EP-4, 5-EP-1e, 5-EP-1f, 6-EP-1e, 6-EP-1f, 2-T, FUG) have pre-control emissions of VOC greater than 100 tpy. Glycol dehydrator Units 1-EP-3, 2a-EP-3, 3-EP-3, 4-EP-3, 5-EP-1e, 6-EP-1e, and FUG, however, are subject to MACT HH and are therefore exempt from CAM requirements per 40 CFR 64.2(b)(1)(i). Storage tanks subject to NSPS OOOO/OOOOa are also exempt from CAM requirements. See Section 13 for a list of equipment subject to HH and OOOO/OOOOa.

Amine Unit 2.5-EP-4 has pre-controlled H₂S emissions greater than 100 tpy and will therefore be subject to CAM requirements.

The CAM plans for the following units that are currently operating are attached following this section: Units EP-5, EP-6, and EP-8 which control the Facility's amine vents (Units 2-EP-4, 3-EP-4, and 4-EP-4), and EP-8 and EP-10, which control the Facility's amine vents (Units 4-EP-4, 5-EP-1f, and 6-EP-1f) and the acid gas flare (2.5-EP-5) which control Unit 2.5-EP-4.

19.2 - Compliance Status (20.2.70.300.D.10.a & 10.b NMAC)

Describe the facility's compliance status with each applicable requirement at the time this permit application is submitted. This statement should include descriptions of or references to all methods used for determining compliance. This statement should include descriptions of monitoring, recordkeeping and reporting requirements and test methods used to determine compliance with all applicable requirements. Refer to Section 2, Tables 2-N and 2-O of the Application Form as necessary. (20.2.70.300.D.11 NMAC) For facilities with existing Title V permits, refer to most recent Compliance Certification for existing requirements. Address new requirements such as CAM, here, including steps being taken to achieve compliance.

Based on the information and belief formed after reasonable inquiry, Lucid believes that the Red Hills Gas Plant is in compliance with each requirement applicable to the facility.

19.3 - Continued Compliance (20.2.70.300.D.10.c NMAC)

Provide a statement that your facility will continue to be in compliance with requirements for which it is in compliance at the time of permit application. This statement must also include a commitment to comply with other applicable requirements as they come into effect during the permit term. This compliance must occur in a timely manner or be consistent with such schedule expressly required by the applicable requirement.

As described in Section 19.2 and based on information and belief formed after reasonable inquiry, Lucid states that Red Hills Gas Plant will continue to be operated in compliance with applicable requirements for which it is in compliance as of the submittal date of this application.

In addition, Lucid will meet additional applicable requirements that become effective during the permit term in a timely manner or on such a time schedule as expressly required by the applicable requirement. In the event that Lucid should discover new information affecting the compliance status of Red Hills Gas Plant, Lucid will make appropriate notifications and/or take corrective actions as appropriate.

19.4 - Schedule for Submission of Compliance (20.2.70.300.D.10.d NMAC)

You must provide a proposed schedule for submission to the department of compliance certifications during the permit term. This certification must be submitted annually unless the applicable requirement or the department specifies a more frequent period. A sample form for these certifications will be attached to the permit.

The Red Hills current Title V permit, number P278, currently states that an annual compliance certification report is due within 30 days of the end of every 12-month reporting permit. The 12-month reporting period starts on June 1st of each year.

19.5 - Stratospheric Ozone and Climate Protection

In addition to completing the four (4) questions below, you must submit a statement indicating your source's compliance status with requirements of Title VI, Section 608 (National Recycling and Emissions Reduction Program) and Section 609 (Servicing of Motor Vehicle Air Conditioners).

-
1. Does your facility have any air conditioners or refrigeration equipment that uses CFCs, HCFCs or other ozone-depleting substances? Yes No
 2. Does any air conditioner(s) or any piece(s) of refrigeration equipment contain a refrigeration charge greater than 50 lbs? Yes No
(If the answer is yes, describe the type of equipment and how many units are at the facility.)
 3. Do your facility personnel maintain, service, repair, or dispose of any motor vehicle air conditioners (MVACs) or appliances ("appliance" and "MVAC" as defined at 82. 152)? Yes No
 4. Cite and describe which Title VI requirements are applicable to your facility (i.e. 40 CFR Part 82, Subpart A through G.)
-

Lucid states that Red Hills does not service, maintain, repair, or dispose of appliances that use Class I or Class II chemicals (chlorofluorocarbons, halon, carbon tetrachloride, methyl chloroform or hydrochlorofluorocarbon). Additionally, motor vehicle air conditioners are not serviced at Red Hills. Therefore, the requirements of Title VI, Sections 608 and 609 of the Clean Air Act are not applicable to this facility.

19.6 - Compliance Plan and Schedule

Applications for sources, which are not in compliance with all applicable requirements at the time the permit application is submitted to the department, must include a proposed compliance plan as part of the permit application package. This plan shall include the information requested below:

A. Description of Compliance Status: (20.2.70.300.D.11.a NMAC)

A narrative description of your facility's compliance status with respect to all applicable requirements (as defined in 20.2.70 NMAC) at the time this permit application is submitted to the department.

B. Compliance plan: (20.2.70.300.D.11.B NMAC)

A narrative description of the means by which your facility will achieve compliance with applicable requirements with which it is not in compliance at the time you submit your permit application package.

C. Compliance schedule: (20.2.70.300D.11.c NMAC)

A schedule of remedial measures that you plan to take, including an enforceable sequence of actions with milestones, which will lead to compliance with all applicable requirements for your source. This schedule of compliance must be at least as stringent as that contained in any consent decree or administrative order to which your source is subject. The obligations of any consent decree or administrative order are not in any way diminished by the schedule of compliance.

D. Schedule of Certified Progress Reports: (20.2.70.300.D.11.d NMAC)

A proposed schedule for submission to the department of certified progress reports must also be included in the compliance schedule. The proposed schedule must call for these reports to be submitted at least every six (6) months.

E. Acid Rain Sources: (20.2.70.300.D.11.e NMAC)

If your source is an acid rain source as defined by EPA, the following applies to you. For the portion of your acid rain source subject to the acid rain provisions of title IV of the federal Act, the compliance plan must also include any additional requirements under the acid rain provisions of title IV of the federal Act. Some requirements of title IV regarding the schedule and methods the source will use to

achieve compliance with the acid rain emissions limitations may supersede the requirements of title V and 20.2.70 NMAC. You will need to consult with the Air Quality Bureau permitting staff concerning how to properly meet this requirement.

NOTE: The Acid Rain program has additional forms. See <http://www.env.nm.gov/aqb/index.html>. Sources that are subject to both the Title V and Acid Rain regulations are **encouraged** to submit both applications **simultaneously**.

Based on information and belief formed after reasonable inquiry as described in Section 19.2, and with this filing, Lucid states that Red Hills is in compliance with applicable requirements. No compliance plan, compliance schedule, or compliance reports are required at this time.

In addition, based on information and belief formed after reasonable inquiry Lucid states that Red Hills is not an acid rain source as defined at 40 CFR 72.6.

19.7 - 112(r) Risk Management Plan (RMP)

Any major sources subject to section 112(r) of the Clean Air Act must list all substances that cause the source to be subject to section 112(r) in the application. The permittee must state when the RMP was submitted to and approved by EPA.

Based on information and belief formed after reasonable inquiry, Lucid states that Red Hills Gas Plant is subject to 40 CFR 68, Chemical Accident Prevention Provisions. The facility is an affected facility, as it will use flammable process chemicals such as propane at quantities greater than the thresholds. The facility has developed and maintains an RMP for these chemicals. The RMP was submitted to EPA on February 6, 2020 and was approved by EPA on February 6, 2020.

19.8 - Distance to Other States, Bernalillo, Indian Tribes and Pueblos

Will the property on which the facility is proposed to be constructed or operated be closer than 80 km (50 miles) from other states, local pollution control programs, and Indian tribes and pueblos (20.2.70.402.A.2 and 20.2.70.7.B NMAC)?

(If the answer is yes, state which apply and provide the distances.)

Yes. 43 km from Texas; No Indian tribes, pueblos, or local pollution control programs are within 80 km.

19.9 - Responsible Official

Provide the Responsible Official as defined in 20.2.70.7.AD NMAC:

Responsible Official: Matt Eales – Vice President of ESH&R

Address: P.O. Box 158, Artesia, NM 88211-0158

Email: MEales@lucid-energy.com

Lucid Energy Delaware, LLC / Red Hills Gas Processing Plant CAM Plan for Amine Vent Controlled by Acid Gas Injection and Flare

I. Background

A. Emissions Unit

Description: Amine Vent
 Identification: 2.5-EP-4
 Facility: Red Hills Gas Plant

B. Applicable Regulation, Emission Limit, and Pre-CAM Monitoring Requirements

Regulation: Operation and reporting requirements created in NSR Permit 4310-M5 et seq. to establish federally enforceable recognition of the Amine Vent.
 Emission limits: In accordance with Table 106.A, a zero emissions limit is established for the Amine Vent.

Uncontrolled Emissions:

VOC pph	VOC tpy	H2S pph	H2S tpy
10.65	46.66	612.94	2,684.68

Pre-CAM Monitoring Requirements: There are no pre-CAM monitoring requirements.

C. Control Technology, Capture System, Bypass, PER

Controls: Acid Gas Injection System (Compressor, Injection Well) and Acid Gas Flare (unit 2.5-EP-5)
 Capture System: N/A
 Bypass: The AGI well is the primary control mechanism for the Amine Unit. Alternate scenario emissions are routed to the flare. No other bypass on still vent stream.

Potential pre-control device emissions: Under 40 CFR 64.2 this is a CAM affected unit.

Potential post-control device emissions: 100% controlled, emission rate = 0 tpy for all pollutants from acid gas injection; 98% controlled for acid gas flare.

II. Monitoring Approach

The key elements of the monitoring approach are presented in the attached table.

III. Response to Excursion

Excursions of the AGI compressor injection pressure or flare system will trigger an inspection, corrective action, and reporting. Maintenance personnel will inspect the compressor, injection well, or acid gas flare within 24 hours and make needed repairs as soon as practicable.

Monitoring Approach: Red Hills Gas Plant AGI

	Indicator No. 1	Indicator No. 2.
I. AGI Performance Indicator	Injection pressure (psig)	Monitoring flow of acid gas to flare and AGI.
II. Indicator Range	900 – 2250 psig	Lucid will investigate any excursion outside the specified range of 0 to 11.7 MMscfd and perform corrective action as required. All information will be recorded and included in the required semi-annual Monitoring Report.
III. Performance Criteria	N/A	N/A
a. Data Representativeness	Pressure will be monitored by a pressure transducer	Flow rate will be monitored with a flow rate monitor.
b. QA/QC Practices/Criteria	Pressure transducer will be verified at least annually.	Acid gas flow meters will be calibrated as specified by the manufacturer or equivalent and as necessary to ensure correct and accurate readings.
c. Monitoring Frequency	Injection pressure will be monitored continuously.	Acid gas flow rates will be monitored continuously.
d. Data Collection Procedures	Injection pressure monitoring data will be reduced to daily averages.	Flow monitor data will be reduced to daily totals. Records of AGI system outages for maintenance or upset will be maintained. Lucid Energy Delaware will report acid gas compressor downtime, as required.
e. Averaging Time	24 hour average.	24 hour total.

Monitoring Approach: Red Hills Gas Plant Acid Gas Flare (unit 2.5-EP-5)

	Indicator No. 1	Indicator No. 2	Indicator No. 3
I. Indicator	Presence of combustion in the flare.	Presence of Visible Emissions.	Totalized flow volume.
Measurement Approach	The presence of combustion in the flare shall be monitored by a well-maintained thermocouple with alarm that signals non-combustion of gas.	The flare should be monitored for visible emissions once during each week that the flare is operational.	Flow rate shall be measured continuously with a flow meter, and the volume shall be totalized once every 24hr period.
II. Indicator Range	Flame present (sensed) or no flame present (sensed).	Visible emissions present or not present, in accordance with 40 CFR 60, Appendix A, Reference Method 22.	Flow rate should be within the operating velocities specified in NSPS Subpart A.
III. Performance Criteria	Destruction depends upon the presence of a flame. If the flame is not present, VOCs and H ₂ S are not being destroyed.	Efficient combustion is assumed if no visible emissions are observed.	Efficient combustion is assumed if flow rates are within the operating velocities and minimum btu specified in NSPS Subpart A.
A. Data Representativeness			
B. QA/QC Practices and Criteria	Proper operation of the flare achieved by maintaining the non-combustion thermocouple with alarm system. Operators will record the date and result of each such maintenance activity, as well as repairs or replacements made.	Visible emissions to be determined in accordance with Method 22 of Appendix A of 40 CFR 60 subpart A.	Verification will be in accordance with Appendix A Test method used to measure flow.
C. Monitoring Frequency	The thermocouple and alarm system will be tested twice a year by turning off the thermocouples and recording the time required for the alarm to respond.	Visible emissions monitoring to occur once each week that the flare is operational.	Continuous monitoring with totalized flow rate measured once per 24hr period.
D. Data Collection Procedures	Records will be maintained of flare shutdown for any reason, including failure to deliver fuel, and of inspection and maintenance to the flare and flare pilot.	Records shall be maintained of all visible emissions observations.	Totalized flow recorded once per each 24 hr period that the flare is in operation.
E. Averaging Period	Not applicable.	A six-minute Method 22 observation will be performed weekly.	24 hour.

Justification

I. Background

The monitoring approach outlined here applies to the AGI and the acid gas flare that are control devices for the amine vent. The amine system is the CAM affected unit.

II. Rationale for Selection of Performance Indicators

The destruction and removal of VOC and H₂S is dependent upon combustion and on proper operation of the AGI. Thus, the monitoring approach is based on three primary indicators: correct operation of the flare, integrity of the ducting from the process equipment to the flare and integrity of the ducting from the amine unit to the AGI.

Measuring AGI injection pressure will indicate proper operation of the injection well. Proper operation of the AGI system results in zero emissions to the atmosphere. AGI injection pressure indicates that the acid gas from the Amine Sweetening System is being injected into the subterranean formation. Monitoring of this pressure can also indicate any problems with the injection well or injecting gas into the formation. A high injection pressure could result in over-pressuring of the receiving formation.

III. Rationale for Selection of Indicator Ranges

Maintaining the AGI injection pressure in the ranges specified will indicate proper operation of the injection well for acid gas injection. Based on Lucid's experience with this AGI System, the AGI injection pressure range represented in the Monitoring Plan is representative and is based on geologist surveying of the injection formation.

In the case of ensuring proper operation of the flare, the presence of a flame to initiate or maintain combustion has only two states: a flame is present or a flame is not present. By design, a well-maintained thermocouple-based alarm system will indicate the state of combustion. The Measurement of totalized flow volume will determine if the volumetric flow is in line with the design specifications, and the max velocity determined from earlier testing of the flare.

The permit issued by the NMED requires the incinerator to achieve 98 percent or greater destruction efficiency.

**Lucid Energy Delaware, LLC / Red Hills Gas Processing Plant
CAM Plan for the Amine Vents Controlled by the Thermal Oxidizers**

I. Background

A. Emissions Unit

Description: Amine Vents
 Identification: 2-EP-4, 3-EP-4, 4-EP-4
 Facility: Red Hills Gas Plant

B. Applicable Regulation, Emission Limit, and Pre-CAM Monitoring Requirements

Regulation: Operation and reporting requirements created in NSR Permit 4310-M5 et seq. to establish federally enforceable recognition of the amine vents.

Emission limits: In accordance with Table 106.A, a zero emissions limit are established for the Amine Vents 2-EP-4, 3-EP-4, and 4-EP-4.

Uncontrolled Emissions:

Unit	VOC pph	VOC tpy	H2S pph	H2S tpy
2-EP-4	66.22	290.07	5.26	23.03
3-EP-4	72.35	316.90	5.03	22.04
4-EP-4	68.61	300.5	5.29	23.17

Controlled Emissions (based on the control equipment unit emissions):

Unit	Control Unit	VOC pph	VOC tpy	H2S pph	H2S tpy
2-EP-4	EP-5	5.92	25.92	0.14	0.62
3-EP-4	EP-6	3.64	15.92	0.10	0.44
4-EP-4	EP-8	3.56	15.57	0.11	0.46

C. Control Technology, Capture System, Bypass, PER

Controls¹: Thermal Oxidizer (units EP-5, EP-6 and EP-8)

Capture System: N/A

Potential pre-control device emissions: Under 40 CFR 64.2 this is a CAM affected unit.

Potential post-control device emissions: 98% controlled by Thermal Oxidizer.

Note: ¹ Unit EP-5 controls unit 2-EP-4, unit EP-6 controls 3-EP-4, and EP-8 controls 4-EP-4.

II. Monitoring Approach

The key elements of the monitoring approach are presented in the attached table.

III. Response to Excursion

Excursions of the thermal oxidizer systems that monitors the presence of combustion or visual emissions will trigger an inspection, corrective action, and reporting. Maintenance personnel will inspect the thermal oxidizer within 24 hours and make needed repairs as soon as practicable.

Monitoring Approach: Red Hills Gas Plant Thermal Oxidizers (units EP-5, EP-6, and EP-8)

	Indicator No. 1	Indicator No. 2	Indicator No. 3
I. Indicator	Presence of combustion in the THERMAL OXIDIZER .	Combustion Temperature	Equipment Inspection
Measurement Approach	The presence of combustion in the thermal oxidizer shall be monitored by a well-maintained thermocouple with alarm that signals non-combustion of gas.	Temperature of TO shall be measured with a thermocouple.	The thermal oxidizer is inspected on a semi-annual basis to ensure that the process is properly controlled. The unit is inspected according to an NMED-approved inspection protocol which includes at minimum the methods for inspecting and adjusting proper minimum combustion temperature and proper air distribution.
II. Indicator Range	Flame present (sensed) or no flame present (sensed).	>1600 deg F	An excursion is defined as equipment malfunctions which result in a release of uncontrolled emissions from the amine vent operations.
III. Performance Criteria	Destruction depends upon the presence of a flame. If the flame is not present, VOC is not being destroyed.	Destruction depends upon achieving a temperature of 1600 deg F or greater.	Inspections and maintenance are being conducted on the thermal oxidizer.
A. Data Representativeness			
B. QA/QC Practices and Criteria	Proper operation of the thermal oxidizer achieved by maintaining the non-combustion thermocouple with alarm system. Operators will record the date and result of each such maintenance activity, as well as repairs or replacements made.	Proper operation of the thermal oxidizer shall be achieved by maintaining the non-combustion thermocouple with alarm system. Operators will record the date a result of each maintenance activity, as well as repairs or replacements made.	The thermal oxidizer is inspected on a semi-annual basis to ensure that the process is properly controlled. The unit is inspected according to an NMED-approved inspection protocol which includes at minimum the methods for inspecting and adjusting proper minimum combustion temperature, and proper air distribution.
C. Monitoring Frequency	The thermocouple and alarm system will be tested twice a year by turning off the thermocouples and recording the time required for the alarm to respond.	One measurement will be recorded per 24-hours.	Semi-annually.
D. Data Collection Procedures	Records will be maintained of thermal oxidizer shutdown for any reason, including failure to deliver fuel, and of inspection and maintenance to the thermal oxidizer.	Temperature will be recorded automatically once per day with a data logger. Records will be available for review at the site.	Semi-annually inspections are performed and documented by the observer. Any repairs or adjustments are documented.
E. Averaging Period	Not applicable.	Not applicable.	Not applicable.

Justification

I. Background

The monitoring approach outlined here applies to the thermal oxidizer that is a control device for the amine vent emissions. The amine vent (units 2-EP-4, 3-EP-4 and 4-EP-4) are the CAM affected units.

II. Rationale for Selection of Performance Indicators

The destruction and removal of VOC is dependent upon combustion. Thus, the monitoring approach is based on two primary indicators: correct operation of the thermal oxidizer and integrity of the ducting from the process equipment to the thermal oxidizer.

III. Rationale for Selection of Indicator Ranges

In the case of ensuring proper operation of the thermal oxidizer, the presence of a flame to initiate or maintain combustion has only two states: a flame is present or a flame is not present. By design, a well-maintained thermocouple-based alarm system will indicate the state of combustion. The Measurement of totalized flow volume will determine if the volumetric flow is in line with the design specifications, and the max velocity determined from earlier testing of the thermal oxidizer.

The permit issued by the NMED requires the thermal oxidizer to achieve 98 percent DRE or greater destruction efficiency.

Lucid Energy Delaware, LLC / Red Hills Gas Processing Plant CAM Plan for the Loading Operations Controlled by the ECDs

I. Background

A. Emissions Unit

Description: Condensate Loading Emissions
 Identification: 1-Load, 3-LOAD
 Facility: Red Hills Gas Plant

B. Applicable Regulation, Emission Limit, and Pre-CAM Monitoring Requirements

Regulation: Operation and reporting requirements created in NSR Permit 4310-M5 et seq. to establish federally enforceable recognition of the loading emissions.

Emission limits:

Uncontrolled:

Unit	VOC pph	VOC tpy
1-Load	*	129.20
3-LOAD	71.22	105.14

* Indicates that hourly emission limits are not appropriate.

Controlled:

Unit	VOC pph	VOC tpy
1-Load	*	0.0
3-LOAD	*	31.54

C. Control Technology, Capture System, Bypass, PER

Controls¹: Enclosed Combustion Device (units EP-7 and EP-12)
 Capture System: N/A
 Potential pre-control device emissions: Under 40 CFR 64.2 this is a CAM affected unit.
 Potential post-control device emissions: 98% controlled by ECD.

Note: ¹ Unit EP-7 controls unit 1-Load and EP-12 controls unit 3-LOAD.

II. Monitoring Approach

The key elements of the monitoring approach are presented in the attached table.

III. Response to Excursion

X Excursions of the enclosed combustion device (ECD) that monitors the presence of combustion or visual emissions will trigger an inspection, corrective action, and reporting. Maintenance personnel will inspect the ECD within 24 hours and make needed repairs as soon as practicable.

Monitoring Approach: Red Hills Gas Plant ECDs (units EP-7 and EP-12)

	Indicator No. 1	Indicator No. 2	Indicator No. 3
I. Indicator	Presence of combustion in the ECD	Combustion Temperature	Equipment Inspection
Measurement Approach	The presence of combustion in the ECD shall be monitored by a well-maintained thermocouple with alarm that signals non-combustion of gas.	Temperature of ECD shall be measured with a thermocouple.	The ECD is inspected on a semi-annual basis to ensure that the process is properly controlled. The unit is inspected according to an NMED-approved inspection protocol which includes at minimum the methods for inspecting and adjusting proper residence time within the combustion chamber, minimum combustion temperature, and proper air distribution.
II. Indicator Range	Flame present (sensed) or no flame present (sensed).	1000 – 2700 deg F	An excursion is defined as equipment malfunctions which result in a release of uncontrolled emissions from the condensate loading operations.
III. Performance Criteria	Destruction depends upon the presence of a flame. If the flame is not present, VOC is not being destroyed.	Destruction depends upon achieving a temperature in the proper range.	Inspections and maintenance are being conducted on the ECD.
A. Data Representativeness			
B. QA/QC Practices and Criteria	Proper operation of the ECD is achieved by maintaining the non-combustion thermocouple with alarm system. Operators will record the date and result of each such maintenance activity, as well as repairs or replacements made.	Proper operation of the ECD shall be achieved by maintaining the non-combustion thermocouple with alarm system. Operators will records the date and result of each such maintenance activity, as well as repairs r replacements made.	The ECD is inspected on a semi-annual basis to ensure that the process is properly controlled. The unit is inspected according to an NMED-approved inspection protocol which includes at minimum the methods for inspecting and adjusting proper residence time within the combustion chamber, minimum combustion temperature, and proper air distribution.
C. Monitoring Frequency	The thermocouple and alarm system will be tested twice a year by turning off the thermocouples and recording the time required for the alarm to respond.	One measurement will be recorded per 24 hours.	Semi-annually.
D. Data Collection Procedures	Records will be maintained of ECD shutdown for any reason, including failure to deliver fuel, and of inspection and maintenance to the ECD.	Temperature will be recorded automatically once per day with a data logger. Records will be available for review at the site.	Semi-annually inspections are performed and documented by the observer. Any repairs or adjustments are documented.
E. Averaging Period	Not applicable.	Not applicable.	Not applicable.

Justification

I. Background

The monitoring approach outlined here applies to the ECD that is a control device for the emissions lost during condensate loading operations. The condensate loading operation (Units 1-Load and 3-LOAD) are the CAM affected units.

II. Rationale for Selection of Performance Indicators

The destruction and removal of VOC is dependent upon combustion. Thus, the monitoring approach is based on two primary indicators: correct operation of the ECD and integrity of the ducting from the process equipment to the ECD.

III. Rationale for Selection of Indicator Ranges

In the case of ensuring proper operation of the ECD, the presence of a flame to initiate or maintain combustion has only two states: a flame is present or a flame is not present. By design, a well-maintained thermocouple-based alarm system will indicate the state of combustion. The Measurement of totalized flow volume will determine if the volumetric flow is in line with the design specifications, and the max velocity determined from earlier testing of the ECD.

The permit issued by the NMED requires the ECD to achieve 98 percent DRE or greater destruction efficiency.

Section 20

Other Relevant Information

Other relevant information. Use this attachment to clarify any part in the application that you think needs explaining. Reference the section, table, column, and/or field. Include any additional text, tables, calculations or clarifying information.

Additionally, the applicant may propose specific permit language for AQB consideration. In the case of a revision to an existing permit, the applicant should provide the old language and the new language in track changes format to highlight the proposed changes. If proposing language for a new facility or language for a new unit, submit the proposed operating condition(s), along with the associated monitoring, recordkeeping, and reporting conditions. In either case, please limit the proposed language to the affected portion of the permit.

No other relevant information is being included in this application.

Section 21

Addendum for Landfill Applications

Do not print this section unless this is a landfill application.

This Section is not applicable as this is not a landfill application.

Section 22: Certification

Company Name: Lucid Energy Delaware, LLC

I, Matt Eales, hereby certify that the information and data submitted in this application are true and as accurate as possible, to the best of my knowledge and professional expertise and experience.

Signed this 11 day of November, 2021, upon my oath or affirmation, before a notary of the State of

New Mexico.

Matt Eales
*Signature

Nov 11, 2021
Date

Matt Eales
Printed Name

VP of EHS&R
Title

Scribed and sworn before me on this 11th day of November, 2021.


My authorization as a notary of the State of New Mexico expires on the

9th day of October, 2025.

[Signature]
Notary's Signature

11/11/2021
Date

Liz Saiz
Notary's Printed Name



*For Title V applications, the signature must be of the Responsible Official as defined in 20.2.70.7.AE NMAC.