



SUSANA MARTINEZ  
Governor  
JOHN A. SANCHEZ  
Lieutenant Governor

**NEW MEXICO  
ENVIRONMENT DEPARTMENT**

Po Box 5469  
Santa Fe, NM 87502  
Tel. 505-476-8635 • Fax 505-476-8656  
Toll Free 1-877-654-8720  
www.env.nm.gov



RYAN FLYNN  
Cabinet Secretary  
BUTCH TONGATE  
Deputy Secretary

July 22, 2016

Fred Whistle  
Morningstar Water Supply System, NM3510524  
Po Box 5520  
Farmington, NM 87499

**RE: Emergency Powers Order 2016-2 Status Update**

Mr. Whistle:

In response to the ongoing boil water advisory and extended water outages at the Morningstar Water Supply System (System No. NM3510524), the New Mexico Environment Department (NMED) issued Emergency Order 2016-2 on June 24, 2016. This Emergency Order requires the Morningstar Water Supply to take specific actions to address the ongoing water emergencies at the water system.

The New Mexico Environment Department's Drinking Water Bureau (NMED DWB) has evaluated Morningstar Water Supply's compliance with the requirements of the Emergency Order as of July 22, 2016 and is providing you with the attached status update.

As of July 22, 2016 the Morningstar Water Supply has accumulated the following fines:


Requirement Number	Deadline	Days Non-Compliant	Accumulated Fines
1	July 1, 2016	21	\$21,000
2	No later than 24 hours after repair has been completed	Pending	Pending
3	July 15, 2016	7	\$7,000
5	Noon Each Friday beginning July 1, 2016	3	\$3,000
7	July 15, 2016	7	\$7,000
<b>Totals</b>		<b>38</b>	<b>\$38,000</b>

Please be aware that all of the requirements outlined in Emergency Order 2016-2 must be completed. Fines may continue to accumulate until those requirements have been fully completed and verified as required.

Additionally in an email submitted by Animas Valley Land & Water's legal representative Ms. Germaine Chappelle on July 15, 2016, a formal request was made to allow Souder Miller and MolzinCorbin to be authorized as the independent third parties to conduct and verify work required in Emergency Order 2016-2. NMED DWB approves the request to allow Souder Miller and MolzinCorbin to act as independent third parties.

If you have any questions or need additional clarification concerning this status update please call 505-476-8635 or e-mail [joe.martinez@state.nm.us](mailto:joe.martinez@state.nm.us).

Respectfully,

*for*   
Stephanie Stringer, Chief  
Drinking Water Bureau  
Water Protection Division

Cc: Joe Martinez, PWSS Group Manager  
Chris Cudia, Area Supervisor (electronic)  
Momingstar Water Supply System Area Office file  
Electronic Central File

**NEW MEXICO ENVIRONMENT DEPARTMENT**  
**Emergency Powers Order No. 2016-2**

<b>Requirement Number</b>	<b>Action Required By Morningstar Water Supply</b>	<b>Deadline</b>	<b>Current Status</b>	<b>Comments On Current Status</b>
1	<p>Optimize distribution system operation by identifying any deficiencies including, but not limited to, line leaks and valve operations to ensure maximum delivery of potable water to all storage tanks and customers; submit a distribution system status report to DWB no later than close of business Friday July 1, 2016 including all discovered distribution deficiencies identified along with a prioritized corrective action plan. This work must be completed and verified by an independent third party approved by DWB.</p>	July 1, 2016	Non-Compliant	<ul style="list-style-type: none"> <li>• On Friday July 1, 2016 Mr. Whistle submitted a distribution system deficiency report via email. In the email, Mr. Whistle states that the report was compiled by Mr. Thomas Barrow, operator.</li> <li>• The submitted report includes ten various sections which include fire hydrants, valves, dead end lines, storage tanks/facilities, dedicated sample sites, commercial meter cans, safety equipment, and other various system issues.</li> <li>• Emergency Order 2016-01 requires that the work that is done in order to comply with Requirement #1 be "completed and verified by an independent third party approved by DWB."</li> <li>• Due to the fact that this evaluation and report was not compiled by an independent third party that was approved by DWB, the Morningstar Water Supply is currently not in compliance with this order.</li> <li>• On Friday July 8, 2016 the NMED provided Morningstar with a status update that indicated that they were not in compliance with Requirement #1.</li> <li>• On July 12, 2016, Germaine Chappelle, attorney for Animas Valley Land &amp; Water (Animas Valley) submitted several documents indicating that distribution analysis work had been proposed by Animas Valley and the Molzen Corbin Engineering firm over the past several years. The documents included a system map as well as various other proposals and executed contract documents. During a conference call with Animas Valley representatives, NMED stated that Morningstar Water Supply would still be required to submit an updated distribution system evaluation report and updated distribution system map. If previous distribution analysis and work had been completed Animas Valley could include aspects of that previous work within the report that is currently required to be completed, but NMED would not solely accept the previous Molzen Corbin report as compliance documentation for the requirements of Emergency Order 2016-2.</li> <li>• On July 15, 2016 Ms. Chappelle, legal representative for Animas Valley submitted an extension request on behalf of</li> </ul>

Requirement Number	Action Required By Morningstar Water Supply	Deadline	Current Status	Comments On Current Status
2	<p>Any distribution deficiencies that are identified in Section 1 of this Order shall be repaired in a timeframe acceptable to DWB. Completion of any required distribution repairs shall be verified by an independent third party. All repair activities shall be performed in accordance with all regulatory requirements and best management practices for repairs of this nature, including but not limited to appropriate disinfection and special sampling. The System shall provide a report of each repair to DWB along with disinfection and sampling results no later than 24 hours after the repair has been completed.</p>	<p>No later than 24 hours after repair has been completed</p>	<p>Non-Compliant</p>	<p>Animas Valley. The extension request included a request for extension of Requirement #1.</p> <ul style="list-style-type: none"> <li>As of the date of this update, the requirements of Requirement #1 still have not been completed.</li> </ul> <ul style="list-style-type: none"> <li>Requirement #2 is dependent on the results of the distribution system deficiency report required in Requirement #1</li> <li>On July 15, 2016 Ms. Chappelle, legal representative for Animas Valley submitted an extension request on behalf of Animas Valley. The extension request included a request for extension of Requirement #2.</li> <li>Due to the fact that Requirement #1 is currently non-compliant, and the fact that an acceptable timeframe for completion of work has not been accepted by DWB, Requirement #2 is currently in non-compliant.</li> </ul>
3	<p>In conjunction with identification and repair of distribution system deficiencies, the System shall either develop or update a comprehensive distribution system map which includes identification and location of distribution system features including but not limited to, size and type of all distribution lines, distribution valves and their operational status, hydrants, storage tanks, interconnections, and operating pressure zones. This comprehensive map shall be submitted to DWB no later than July 15, 2016.</p>	<p>July 15, 2016</p>	<p>Non-Compliant</p>	<ul style="list-style-type: none"> <li>Requirement #3 is dependent on the results of the distribution system deficiency report required in Requirement #1</li> <li>On July 12, 2016, Ms. Chappelle, attorney for Animas Valley submitted several documents indicating that distribution analysis work had been proposed by Animas Valley and the Molzen Corbin Engineering firm over the past several years. The documents included a system map as well as various other proposals and executed contract documents. During a conference call with Animas Valley representatives, NMED stated that Morningstar Water Supply would still be required to submit an updated distribution system evaluation report and updated distribution system map. If previous distribution analysis and work had been completed Animas Valley could include aspects of that previous work within the report that is currently required to be completed, but NMED would not solely accept the previous Molzen Corbin report as compliance documentation for the requirements of Emergency Order 2016-2.</li> <li>On July 15, 2016 Ms. Chappelle, legal representative for Animas Valley submitted an extension request on behalf of Animas Valley. The extension request included a request for extension of Requirement #3.</li> <li>Due to the fact that Requirement #1 is currently non-</li> </ul>

				<p>compliant, and the fact that an acceptable timeframe for completion of work has not been accepted by DWB, Requirement #3 is currently in non-compliant.</p>
Requirement Number	Action Required By Morningsstar Water Supply	Deadline	Current Status	Comments On Current Status
4	<p>Develop water conservation measures and provide a copy of these measures to System customers and DWB within 24 hours of this Emergency Order. These water conservation measures shall remain in effect until the System provides verification that all distribution system deficiencies have been corrected and the final interconnection with the Farmington Water System has been fully constructed and verified as operational. Water conservation notification to customers shall be distributed in a form and manner reasonably calculated to reach all persons served by the System including but not limited to all local broadcast media, San Juan County Emergency Management, and posting in public places throughout the System. Copies of this notice and verification of all distribution methods must be provided to DWB no later than 24 hours after the notifications have been distributed.</p>	June 25, 2016	Compliant	<ul style="list-style-type: none"> <li>On June 25, 2016, Mr. Whistle submitted a press release via email which included water conservation measures for Morningsstar Water Supply customers.</li> <li>The submitted email confirms that the press release was submitted to San Juan County Emergency Management as well as various media outlets and other County Officials.</li> </ul>
5	<p>In addition to the water conservation public notifications, the System shall send out at minimum, weekly public notifications to System customers regarding the current status of the Boil Water Advisory and Water Outage(s) no later than noon on Friday of each week until these water emergencies have been fully resolved. These public notifications shall be distributed in a form and manner reasonably calculated to reach all persons served by the System including but not limited to all local broadcast media, San Juan County Emergency Management, and phone calls or mail outs to all customers of the System. Copies this notice and verification of the proper distribution of these public notifications must be provided to DWB no later than 24 hours after the notifications have been distributed. The contents shall include but are not limited to, current status of the Boil Water Advisory, current status of distribution system deficiencies and corrective actions being taken to repair these deficiencies, current status of the proposed interconnection to the Farmington Water System, current status of the construction of the pumping station which will permanently provide Farmington water to System customers, information regarding water conservation</p>	Noon Each Friday beginning July 1, 2016	Partial Non-Compliance for the weeks ending July 1, 2016, July 8, 2016, and July 15, 2016	<ul style="list-style-type: none"> <li>On Friday July 1, 2016 at 4:31 PM, Mr. Whistle submitted a press release via email indicating that the weekly customer update had been delivered to San Juan County Emergency Management as well as various media outlets and County Officials.</li> <li>On Friday July 8, 2016 at 2:26 PM, Mr. Whistle submitted a press release via email indicating that the weekly customer update had been delivered to San Juan County Emergency Management as well as various media outlets and County Officials.</li> <li>On Friday July 15, 2016 at 3:51 PM, Mr. Whistle submitted a press release via email indicating that the weekly customer update had been delivered to San Juan County Emergency Management as well as various media outlets and County Officials. Within the press release, Mr. Whistle incorrectly states that the deficiency report was concluded on July 1. However, in the status update letter that was provided to Mr. Whistle, NMED DWB indicated that the distribution deficiency status report was not accepted.</li> <li>Additionally, the Emergency Order specifically requires that these notifications be sent to system customers no later than noon on Friday of each week.</li> <li>The Emergency Order also specifically requires that the</li> </ul>

	measures that are currently in place, and information regarding any applicable timeframes for completion of the final interconnection with the Farmington Water System. Verification of the proper contents and distribution of these public notifications must be provided to DWB no later than 24 hours after the notifications have been sent out.			notification be distributed in a manner, including but not limited to all local broadcast media, San Juan County Emergency Management, and phoné calls or mail outs to all customers of the System.  <ul style="list-style-type: none"> <li>Due to the fact that not all of the notifications, specifically the phone and/or mail outs were not completed by Noon on each Friday, Morningstar Water Supply has not complied with this portion of Requirement #5 for the weeks of Friday July 1, 2016, Friday July 8, 2016, and Friday July 15, 2016.</li> <li>Additionally, verification of the proper contents and distribution of these public notifications must be provided to DWB no later than 24 hours after the notifications have been sent out. As of the date of this status update, DWB has not received full verification of required distribution.</li> </ul>
<b>Requirement Number</b>	<b>Action Required By Morningstar Water Supply</b>	<b>Deadline</b>	<b>Current Status</b>	<b>Comments On Current Status</b>
6	The System shall provide daily written updates to DWB regarding the current status of the Boil Water Advisory and Water Outage(s) no later than close of business on each day until all water emergencies have been fully resolved. The contents of these updates shall include but are not limited to, current status of the Boil Water Advisory, current status of distribution system deficiencies and corrective actions being taken to repair these deficiencies, current status of the proposed interconnection to the Farmington Water System, current status of the construction of the pumping station which will permanently provide Farmington water to System customers, information regarding the effectiveness of water conservation measures that are currently in place, and information regarding any applicable timeframes for completion of the final interconnection with the Farmington Water System.	Close of Business each day	Compliant	<ul style="list-style-type: none"> <li>Mr. Whistle has consistently provided the required daily updates to DWB</li> </ul>
7	All permanent interconnection construction activities and pump station shall be completed no later than July 15, 2016. Immediately upon completion of the permanent interconnection and pump station the system shall notify DWB in writing.	July 15, 2016	Non-Compliant	<ul style="list-style-type: none"> <li>The permanent interconnection construction activities and pump station was not completed by the July 15, 2016 deadline</li> <li>On July 15, 2016 Ms. Chappelle, legal representative for Animas Valley submitted an extension request on behalf of Animas Valley. The extension request included a request for extension of Requirement #7.</li> </ul>
8	Hauling of potable water from adjacent public water systems shall continue until continuous water service	Until continuous	Compliant	<ul style="list-style-type: none"> <li>According to the June 27, 2016 daily update from Mr. Whistle, all customers' water service has been restored as</li> </ul>

	has been restored to all customers. Water hauling activities shall be conducted using a water hauler that is acceptable to the DWB.	water service has been restored		<p>of June 24, 2016.</p> <ul style="list-style-type: none"> <li>This was confirmed by San Juan County Office of Emergency Management</li> <li>Water hauling continued through the weekend and was finally halted on June 27, 2016</li> </ul>
9	Continuous water service shall be provided to all System customers no later than Friday July 1, 2016 through the correction of distribution system deficiencies or an alternative solution such as construction of a temporary pumping facility.	July 1, 2016	Compliant	<ul style="list-style-type: none"> <li>According to the June 27, 2016 daily update from Mr. Whistle, all customers' water service has been restored as of June 24, 2016.</li> <li>This was confirmed by San Juan County Office of Emergency Management</li> </ul>
10	All regulatory requirements and best management practices shall be followed during any construction or related activities identified in this Order.	Ongoing	Ongoing	<ul style="list-style-type: none"> <li>DWB will continue to evaluate this requirement</li> <li>Mr. Whistle indicates within each update that all regulatory requirements and Best management practices have been followed on all construction.</li> </ul>