



SUSANA MARTINEZ
Governor
JOHN A. SANCHEZ
Lieutenant Governor

**NEW MEXICO
ENVIRONMENT DEPARTMENT**

Po Box 5469
Santa Fe, NM 87502
Tel. 505-476-8635 • Fax 505-476-8656
Toll Free 1-877-654-8720
www.env.nm.gov



RYAN FLYNN
Cabinet Secretary
BUTCH TONGATE
Deputy Secretary

July 8, 2016

Fred Whistle
Morningstar Water Supply System, NM3510524
Po Box 5520
Farmington, NM 87499

RE: Emergency Powers 2016-2 Status Update

Mr. Whistle:

In response to the ongoing boil water advisory and extended water outages at the Morningstar Water Supply System (System No. NM3510524), the New Mexico Environment Department (NMED) issued Emergency Order 2016-2 on June 24, 2016. This Emergency Order requires the Morningstar Water Supply to take specific actions to address the ongoing water emergencies at the water system.

The New Mexico Environment Department's Drinking Water Bureau (NMED DWB) has evaluated Morningstar Water Supply's compliance with the requirements of the Emergency Order as of July 7, 2016 and is providing you with the attached status update.

Please be aware that NMED reserves the right to impose a fine of up to one thousand dollars (\$1,000) per day for each order with which the System does not comply.

If you have any questions or need additional clarification concerning this status update please call 505-476-8635 or e-mail joe.martinez@state.nm.us.

Respectfully,

A handwritten signature in blue ink that reads "Stephanie Stringer".

Stephanie Stringer, Chief
Drinking Water Bureau
Water Protection Division

Cc: Joe Martinez, PWSS Group Manager
Chris Cudia, Area Supervisor (electronic)
Morningstar Water Supply System Area Office file
Electronic Central File

**NEW MEXICO ENVIRONMENT DEPARTMENT
Emergency Powers Order No. 2016-2**

Order Number	Action Required By Morningstar Water Supply	Deadline	Current Status	Comments On Current Status
1	<p>Optimize distribution system operation by identifying any deficiencies including, but not limited to, line leaks and valve operations to ensure maximum delivery of potable water to all storage tanks and customers; submit a distribution system status report to DWB no later than close of business Friday July 1, 2016 including all discovered distribution deficiencies identified along with a prioritized corrective action plan. This work must be completed and verified by an independent third party approved by DWB.</p>	July 1, 2016	Non-Compliant	<ul style="list-style-type: none"> On Friday July 1, 2016 Mr. Fred Whistle submitted a distribution system deficiency report via email. In the email, Mr. Whistle states that the report was compiled by Mr. Thomas Barrow, operator. The submitted report includes ten various sections which include fire hydrants, valves, dead end lines, storage tanks/facilities, dedicated sample sites, commercial meter cans, safety equipment, and other various system issues. Emergency Order 2016-01 requires that the work that is done in order to comply with Order #1 be "completed and verified by an independent third party approved by DWB." Due to the fact that this evaluation and report was not compiled by an independent third party that was approved by DWB, the Morningstar Water Supply is currently not in compliance with this order.
2	<p>Any distribution deficiencies that are identified in Section 1 of this Order shall be repaired in a timeframe acceptable to DWB. Completion of any required distribution repairs shall be verified by an independent third party. All repair activities shall be performed in accordance with all regulatory requirements and best management practices for repairs of this nature, including but not limited to appropriate disinfection and special sampling. The System shall provide a report of each repair to DWB along with disinfection and sampling results no later than 24 hours after the repair has been completed.</p>	No later than 24 hours after repair has been completed	Non-Compliant	<ul style="list-style-type: none"> Order #2 is dependent on the results of the distribution system deficiency report required in Order #1 Due to the fact that Order #1 is currently non-compliant, and the fact that an acceptable timeframe for completion of work has not been accepted by DWB, Order #2 is currently in non-compliant.
3	<p>In conjunction with identification and repair of distribution system deficiencies, the System shall either develop or update a comprehensive distribution system map which includes identification and location of distribution system features including but not limited to, size and type of all distribution lines, distribution valves and their operational status, hydrants, storage tanks, interconnections, and operating pressure zones. This comprehensive map shall be submitted to DWB no later than July 15, 2016.</p>	July 15, 2016	On going	<ul style="list-style-type: none"> Deadline for Order #3 is July 15, 2016

Order Number	Action Required By Morningstar Water Supply	Deadline	Current Status	Comments On Current Status
4	<p>Develop water conservation measures and provide a copy of these measures to System customers and DWB within 24 hours of this Emergency Order. These water conservation measures shall remain in effect until the System provides verification that all distribution system deficiencies have been corrected and the final interconnection with the Farmington Water System has been fully constructed and verified as operational. Water conservation notification to customers shall be distributed in a form and manner reasonably calculated to reach all persons served by the System including but not limited to all local broadcast media, San Juan County Emergency Management, and posting in public places throughout the System. Copies of this notice and verification of all distribution methods must be provided to DWB no later than 24 hours after the notifications have been distributed.</p>	June 25, 2016	Compliant	<ul style="list-style-type: none"> On June 25, 2016, Mr. Fred Whistle submitted a press release via email which included water conservation measures for Morningstar Water Supply customers. The submitted email confirms that the press release was submitted to San Juan County Emergency Management as well as various media outlets and other County Officials.
5	<p>In addition to the water conservation public notifications, the System shall send out at minimum, weekly public notifications to System customers regarding the current status of the Boil Water Advisory and Water Outage(s) no later than noon on Friday of each week until these water emergencies have been fully resolved. These public notifications shall be distributed in a form and manner reasonably calculated to reach all persons served by the System including but not limited to all local broadcast media, San Juan County Emergency Management, and phone calls or mail outs to all customers of the System. Copies of this notice and verification of the proper distribution of these public notifications must be provided to DWB no later than 24 hours after the notifications have been distributed. The contents shall include but are not limited to, current status of the Boil Water Advisory, current status of distribution system deficiencies and corrective actions being taken to repair these deficiencies, current status of the proposed interconnection to the Farmington Water System, current status of the construction of the pumping station which will permanently provide Farmington water to System customers, information regarding water conservation measures that are currently in place, and information regarding any applicable timeframes for completion of the final interconnection with the Farmington Water System. Verification of the proper contents and distribution of these public notifications must be provided to DWB no later than</p>	Noon Each Friday beginning July 1, 2016	Partial Non-Compliance for the week ending July 1, 2016	<ul style="list-style-type: none"> On Friday July 1, 2016 at 4:31 PM, Mr. Fred Whistle submitted a press release via email indicating that the weekly customer update had been delivered to San Juan County Emergency Management as well as various media outlets and County Officials. The email also indicated that all customers were being contacted by mail or phone or hand delivery and confirmation of those notifications would be sent within 24 hours of the last hand delivery. The Emergency Order specifically requires that these notifications be sent to system customers no later than noon on Friday of each week. The Emergency Order also specifically requires that the notification be distributed in a manner, including but not limited to all local broadcast media, San Juan County Emergency Management, and phone calls or mail outs to all customers of the System. Due to the fact that not all of the notifications, specifically the phone and/or mail outs were not completed by Noon on Friday July 1, 2016, Morningstar Water Supply has not complied with this portion of Order #5. Additionally, verification of the proper contents and distribution of these public notifications must be provided to DWB no later than 24 hours after the notifications have been sent out. As of the date of this status update, DWB has not received full verification of required distribution.

	24 hours after the notifications have been sent out.			
Order Number	Action Required By Morningstar Water Supply	Deadline	Current Status	Comments On Current Status
6	<p>The System shall provide daily written updates to DWB regarding the current status of the Boil Water Advisory and Water Outage(s) no later than close of business on each day until all water emergencies have been fully resolved. The contents of these updates shall include but are not limited to, current status of the Boil Water Advisory, current status of distribution system deficiencies and corrective actions being taken to repair these deficiencies, current status of the proposed interconnection to the Farmington Water System, current status of the construction of the pumping station which will permanently provide Farmington water to System customers, information regarding the effectiveness of water conservation measures that are currently in place, and information regarding any applicable timeframes for completion of the final interconnection with the Farmington Water System.</p>	Close of Business each day	Compliant	<ul style="list-style-type: none"> Mr. Fred Whistle has consistently provided the required daily updates to DWB
7	<p>All permanent interconnection construction activities and pump station shall be completed no later than July 15, 2016. Immediately upon completion of the permanent interconnection and pump station the system shall notify DWB in writing.</p>	July 15, 2016	On Going	<ul style="list-style-type: none"> Due date for interconnection is July 15, 2016
8	<p>Hauling of potable water from adjacent public water systems shall continue until continuous water service has been restored to all customers. Water hauling activities shall be conducted using a water hauler that is acceptable to the DWB.</p>	Until continuous water service has been restored	Compliant	<ul style="list-style-type: none"> According to the June 27, 2016 daily update from Mr. Fred Whistle, all customers' water service has been restored as of June 24, 2016. This was confirmed by San Juan County Office of Emergency Management Water hauling continued through the weekend and was finally halted on June 27, 2016
9	<p>Continuous water service shall be provided to all System customers no later than Friday July 1, 2016 through the correction of distribution system deficiencies or an alternative solution such as construction of a temporary</p>	July 1, 2016	Compliant	<ul style="list-style-type: none"> According to the June 27, 2016 daily update from Mr. Fred Whistle, all customers' water service has been restored as of June 24, 2016. This was confirmed by San Juan County Office of

10	pumping facility. All regulatory requirements and best management practices shall be followed during any construction or related activities identified in this Order.	Ongoing	Ongoing	Emergency Management
			Ongoing	<ul style="list-style-type: none"> • DWB will continue to evaluate this requirement